



STATE OF CONNECTICUT
CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: siting.council@ct.gov

Web Site: portal.ct.gov/csc

VIA ELECTRONIC MAIL

July 28, 2023

Kenneth C. Baldwin, Esq.
Robinson & Cole LLP
280 Trumbull Street
Hartford, CT 06103-3597
kbaldwin@rc.com

RE: **DOCKET NO. 505** – Haddam Quarter Solar, LLC Certificate of Environmental Compatibility and Public Need for the construction, maintenance, and operation of a 2.8-megawatt-AC solar photovoltaic electric generating facility located south of Haddam Quarter Road and north of Johnson Lane, Durham, Connecticut and associated electrical interconnection.

Dear Attorney Baldwin:

The Connecticut Siting Council (Council) requests your responses to the enclosed questions no later than August 11, 2023.

Please submit an original and 15 copies to the Council's office and an electronic copy to siting.council@ct.gov. In accordance with the State Solid Waste Management Plan and in accordance with Section 16-50j-12 of the Regulations of Connecticut State Agencies, the Council requests all filings be submitted on recyclable paper, primarily regular weight white office paper. Please avoid using heavy stock paper, colored paper, and metal or plastic binders and separators. Fewer copies of bulk material may be provided as appropriate.

Please be advised that the original and 15 copies are required to be submitted to the Council's office on or before the August 11, 2023 deadline.

Copies of your responses are required to be provided to all parties and intervenors listed in the service list, which can be found on the Council's website under the "Pending Matters" link.

Any request for an extension of time to submit responses to interrogatories shall be submitted to the Council in writing pursuant to §16-50j-22a of the Regulations of Connecticut State Agencies.

Sincerely,

Melanie Bachman
Executive Director

c: Service List, dated August 19, 2021

Docket No. 505
Development & Management (D&M) Plan
Interrogatories – Set 2

11. Referencing the response to Interrogatory 7c, the Toxicity Characteristic Leaching Procedure (TCLP) test results indicate the selected solar panels will be considered hazardous waste at the time of disposal, under current testing criteria. Specifically, the result for lead (10.3 mg/L) exceeds the State and Federal Regulatory Level of 5.0 mg/L. Submit TCLP results for solar panels to be used for the project that meet TCLP regulatory criteria, in accordance with the Council's Findings of Fact No. 128.
12. Referencing D&M Plan Sheet T-02, construction hours are listed as 6:30 a.m. to 3:30 p.m. Monday-Friday. The Council's Findings of Fact No. 116 listed construction hours as 7:00 a.m. to 5:00 pm. Monday through Saturday. Clarify.
13. Referencing the Spill Response and Control Plan in D&M Plan Attachment 7 -Health and Safety Plan, and Site Plan GN-2, provide contact information for the spill response contractor and the DEEP Spill Emergency Response Unit.