

Burlington Solar One, LLC Exhibit E, Project Capacity Factors

Year of Operation	Megawatt Hour Production	Solar Capacity (Megawatts AC)	Capacity Factor
1	6,714.00	3.5	21.9%
2	6,683.00	3.5	21.8%
3	6,652.00	3.5	21.7%
4	6,620.90	3.5	21.6%
5	6,589.90	3.5	21.5%
6	6,558.90	3.5	21.4%
7	6,515.40	3.5	21.3%
8	6,471.90	3.5	21.1%
9	6,428.40	3.5	21.0%
10	6,384.90	3.5	20.8%
11	6,341.40	3.5	20.7%
12	6,310.10	3.5	20.6%
13	6,278.80	3.5	20.5%
14	6,247.50	3.5	20.4%
15	6,216.20	3.5	20.3%
16	6,184.90	3.5	20.2%
17	6,115.40	3.5	19.9%
18	6,045.90	3.5	19.7%
19	5,976.50	3.5	19.5%
20	5,907.00	3.5	19.3%
21	5,837.50	3.5	19.0%
22	5,776.30	3.5	18.8%
23	5,715.20	3.5	18.6%
24	5,654.10	3.5	18.4%
25	5,592.90	3.5	18.2%
26	5,531.80	3.5	18.0%
27	5,483.90	3.5	17.9%
28	5,436.10	3.5	17.7%
29	5,388.20	3.5	17.6%
30	5,340.40	3.5	17.4%
31	5,292.50	3.5	17.3%
32	5,244.30	3.5	17.1%
33	5,196.00	3.5	16.9%
34	5,147.80	3.5	16.8%
35	5,099.60	3.5	16.6%