


December 23, 2015

**DOCKET NO. 466**

Robert Stein, Chairman  
Connecticut Siting Council  
10 Franklin Square  
New Britain, CT 06051



Re: Frost Bridge to Campville 115-kV Project

**ORIGINAL**

Dear Chairman Stein:

Pursuant to Connecticut General Statutes § 16-50/(a), The Connecticut Light and Power Company doing business as Eversource Energy ("Eversource") herewith submits an Application for a Certificate of Environmental Compatibility and Public Need ("Application") for the Frost Bridge to Campville 115-kV Project (the "Project").

With this letter, Eversource submits (a) an original and 15 copies of the Application, and (b) a Compact Disc containing an electronic copy of the Application.

The Project includes construction of a new 10.4-mile 115-kilovolt (kV) overhead electric transmission line between Eversource's Frost Bridge Substation in Watertown and its Campville Substation in Harwinton, to make related improvements to both substations and to reconfigure a short (0.4-mile) segment of two existing 115-kV transmission lines that are supported on common structures. The Project would be located in portions of four towns: Watertown, Thomaston, Litchfield and Harwinton. The transmission line would be located within Eversource's existing right-of-way.

In accordance with Connecticut General Statutes § 16-50/(b) and the Application Guides for Electric and Fuel Transmission Line Facility, we enclose the following:

- Copies of the cover letters sent with a copy of this Application to federal, state, and local governmental officials and agencies;
- An affidavit regarding proof of service of the Application;
- An affidavit regarding publication of the legal notices of Eversource's intent to file the Application;
- An affidavit regarding the notice that Eversource provided to customers in Watertown, Thomaston, Litchfield and Harwinton with a bill insert;
- An affidavit regarding the notice provided to substation abutters and the abutters list; and

- An affidavit regarding the notice provided to community organizations and water companies (pursuant to Section VIII of the Application Guide).

We also enclose the following:


- Bulk Filing #1, which consists of four copies and 1 Compact Discs containing the inland wetlands and planning and zoning regulations and Plan of Conservation and Development and zoning maps of the towns of Watertown, Thomaston, Litchfield and Harwinton and the Municipal Consultation Filing;
- A check for the Application filing fee in the amount of \$25,250; and
- A check for the municipal participation fee in the amount of \$25,000.

By January 7, 2016, Eversource will submit the following:

- Bulk Filing #2, which will consist of four copies of materials that Eversource provided at the open houses and materials provided to municipal leaders and agencies during the municipal consultation process; and
- Copies of written public comments received as part of the municipal consultation process (including from the public open house), and Eversource's responses.

Please advise us if any additional material is necessary for the Council's review of this Application.

Respectfully submitted,

A handwritten signature in blue ink, appearing to read "John M. [unclear]".

Attachment

AFFIDAVIT REGARDING PUBLICATION OF LEGAL NOTICE


STATE OF CONNECTICUT)

) ss.

COUNTY OF HARTFORD )


Pursuant to Section 16-50l(b) of the Connecticut General Statutes, I hereby certify that I caused legal notices in not less than ten-point, boldface type, to be published in the newspapers set forth below of the intent of The Connecticut Light and Power Company doing business as Eversource Energy (Eversource) to file an Application with the Connecticut Siting Council for a Certificate of Environmental Compatibility and Public Need for the Frostbridge to Campville 115-kV Project, which includes the construction of a new 115-kV electric transmission line between Eversource's existing Frost Bridge Substation in the Town of Watertown and its existing Campville Substation in the Town of Harwinton, related modifications to Frost Bridge Substation and Campville Substation, and the reconfiguration of a short segment of two existing 115-kV transmission lines in the Towns of Litchfield and Harwinton. These legal notices included a summary of the Application and the date on or about which it would be filed.

| Daily Publications            | Dates                   |
|-------------------------------|-------------------------|
| Litchfield County Times       | 12/11/2015 & 12/18/2015 |
| Waterbury Republican-American | 12/15/2015 & 12/17/2015 |
| Torrington Register Citizen   | 12/15/2015 & 12/19/2015 |


  
Tyler Aubrey, Boathouse Group Inc.

On this the 22 day of DECEMBER, 2015, before me, the undersigned officer, personally appeared TYLER AUBREY, known to be (or satisfactorily proven) to be the person whose name is subscribed to the within instrument and acknowledged that he/she executed the same for the purposes therein contained.

In Witness Whereof, I hereunto set my hand and official seal.

  
Notary Public

My Commission Expires: 09/23/2022



**TO PLACE A CLASSIFIED AD CALL 800.922.7066 • Dir. 860.294.0080**

**ADVERTISE YOUR TAG SALE FOR THE BEST RESULTS Deadline: Tuesday at noon • Call 800.922.7066**

**ATTENTION ADVERTISERS:** Our sales associates make every effort to avoid misprints in advertisements. It is necessary that you check your advertisement the **FIRST TIME** it runs. If an error is found, call us by deadline for the next edition. We will credit errors for one publication only.

**LEGAL NOTICES**

**Legal Notice**  
**Borough of Litchfield Historic District Commission**  
 Public Hearings will be held on December 17, 2015, beginning at 7:00 p.m. at 28 Russell Street, to consider the following applications for Certificate of Appropriateness:  
 1. Application #1785, Wendy and Richard Story, 184 Meadow Street, to remove outbuilding.  
 2. Application #1786, Nathan Keller, 37 Sedgewick Lane, for windows.  
 3. Application #1787, Litchfield United Methodist Church, 69 West Street, for signs.  
**A public hearing will also be held at the end of the regular meeting to review possible changes to the HDC application instructions.** At these hearings interested persons may appear and be heard and written communications will be received.  
 Dated in Litchfield this 11th day of December, 2015.  
 Judith Acerbi, Clerk

**LOST AND FOUND**

**LOST** Friday Dec. 4th, in New Milford, very small gold pendant with diamonds and emeralds on gold chain, high sentimental value.  
**REWARD call 860-354-9773**

**APARTMENTS FOR RENT (UNFURNISHED)**

**The Mill at Still River**  
 101 Whiting St.  
 WINSTED, CT 06098  
 Has elegant brick & beam. 1 & 2 bedrooms. Every Apartment has River views, dishwasher, garbage disposal, gas heat, cathedral ceilings. Laundry & elevator on premises.  
**"SMOKE FREE ENVIRONMENT"**  
**"Move-In Special"**  
 Call Paula  
 978-821-6880.

**HOUSES FOR RENT (UNFURNISHED)**

**ROXBURY** rental - Charming, private 1BR cottage. Updated bath & appl. W/D \$1,000/mo. + util. (203) 770-7177.  
**WINTER RENTAL SHARON.** Brick house, Living Room w/ Fireplace insert, Dining Room, kitchen w/appliances, 4 Bedrooms, 2 Bathrooms, utility rm. w/washer & dryer & garage. Terms: \$1,200/mo. w/ security deposit. Avail. Nov. - April w/optional renewal. Call 860-364-5019.

**THE CLASSIFIEDS** ... they go where you can't ... into thousands of homes. And they do all in one day!  
**1-800-922-7066**

**EDUCATION/TRAINING**

**Early Learning Center - Teacher's Aide**  
 The Kent School ELC seeks a kind, and responsible PT Teacher Aide to help implementing its child-centered curriculum. The ideal candidate will be upbeat, flexible and passionate about caring for and educating young children, ensure the daily care of children following all licensing guidelines, be able to communicate effectively with parents, and be willing to work with existing staff to achieve program goals. The Center follows an Academic Schedule. A CDA or 12 credits in early childhood and afternoon hours are required. Interested candidates should submit a resume to Director, Rachel O'Hazo at oha20@kent-school.edu  
**Food Services**  
 Kent School's Dining Services seek two motivated and responsible individuals to support its operation. A Weekend Dishwasher, Part-Time Academic Year position, and a CT Kitchen Help who will be responsible for the stir fry stations. Successful candidates will have demonstrated a reliable work history. Experience preferred but will train. To apply, please call Food Services at 860-927-6128.  
**Safety/Driver**  
 Kent School seeks a PT safety/driver to support its operation. This is a PT, Academic Year position, 4pm to 9pm. Must hold a Public Service License and a clean driving record. Interested candidates should submit resume to benjamin@kent-school.edu.

**HANDYMAN**

**Pro Green Paradise**  
 Professional grounds Management corporation  
 Snow Removal, Commercial and residential, gutters clean, all types mason work, natural stone walls, fireplace, chimney, fall clean up, tree removal, tree trimming. 20% discount on any job.  
 License 28777 CT, NY 203-442-2342  
 nazzaro2015@hotmail.com

**LOOK!**

Attention Getters draw **ATTENTION** to your Classified Ad. Add one for just a few dollars extra. There are many to choose from.  
**1-800-922-7066**

*Do you have a car for sale?*



How about a boat? Or maybe some furniture? Call to place a classified ad with one of our helpful representatives & sell your no-longer-wanted items **FAST!**

**Notice of Application by The Connecticut Light and Power Company doing business as Eversource Energy for Approval of a New 115-kV Electric Transmission Line in the Towns of Watertown, Thomaston, Litchfield, and Harwinton, Connecticut**

Pursuant to the provisions of Section 16-50(b) of the General Statutes of Connecticut, Section 16-50-1(e) of the regulations of the Connecticut Siting Council, and the Application Guide for an Electric and Fuel Transmission Line Facility of the Connecticut Siting Council (adopted April 2010), notice is hereby given that The Connecticut Light and Power Company doing business as Eversource Energy (Eversource) will on or about December 22, 2015, submit an Application to the Connecticut Siting Council seeking a Certificate of Environmental Compatibility and Public Need (Application) for the Frost Bridge to Campville 115-kV Project (Project). The Project includes construction of a new 115-kV electric transmission line between Eversource's existing Frost Bridge Substation in the Town of Watertown and its existing Campville Substation in the Town of Harwinton, related modifications to Frost Bridge Substation and Campville Substation, and the reconfiguration of a short (0.4-mile) segment of two existing 115-kV transmission lines in the Towns of Litchfield and Harwinton. The Project is needed to improve the regional supply system in northwest Connecticut into compliance with national and regional reliability standards and criteria by eliminating potential thermal overloads and voltage violations identified in studies conducted by Independent System Operator- New England, the regional system planning authority.  
 The Proposed Route is approximately 10.4 miles long. The new transmission line will be constructed overhead on an existing Eversource right-of-way (ROW) for approximately 10.3 miles in the Towns of Watertown, Thomaston, Litchfield, and Harwinton, and constructed underground for approximately 0.1 mile where the new line exits Frost Bridge Substation in Watertown. The new overhead transmission line will be built on unused portions of the existing Eversource ROW and aligned adjacent to existing overhead transmission lines. The 0.1-mile underground segment will be constructed within Frost Bridge Substation and on Eversource-owned property just outside the fence line of the substation.  
 The Application will describe the proposed new transmission line, including descriptions of both the 10.3-mile overhead segment and the 0.1-mile underground segment. The Application will include a description of the Proposed Route and alternate routes considered for the transmission line, along with an evaluation of the environmental, engineering, reliability, operability, and cost considerations associated with those routes. The Application will also describe the required modifications to the existing Frost Bridge Substation (located adjacent to Frost Bridge Road and State Route 8 in Watertown) and to the existing Campville Substation (located adjacent to Wildcat Hill Road in Harwinton). Modifications are needed at these substations, each of which is located within larger parcels of Eversource-owned property, to connect the new 115-kV line to the existing transmission system. The modifications at Frost Bridge Substation will not require any expansion to the existing fence line, while the modifications at Campville Substation will increase the fenced area by approximately 0.4 acre on Eversource-owned property. The Application will also include a description of the reconfiguration of a short segment (0.4-mile) of two existing 115-kV transmission lines that are currently supported on common structures at the crossing of the Naugatuck River in the Towns of Litchfield and Harwinton.  
 In addition, the Application will describe two route variations - one overhead and one underground - developed by Eversource for the portion of the Proposed Route in the Town of Watertown where the new 115-kV transmission line exits from Frost Bridge Substation and connects to the existing ROW. The overhead variation would be located on Eversource property and would exit the southeastern side of the substation, extending around the substation to the east before turning northwest, while the underground variation would involve a short (0.1 mile) underground transmission line cable that exits out of the southeastern side of the substation, also extending around the substation to the east before turning northwest and transitioning to overhead prior to the crossing of Frost Bridge Road.  
 If approved by the Connecticut Siting Council, Project construction is expected to begin in the second quarter of 2017. The new transmission line is proposed to be completed and in service by the end of 2018.

No proposed Project facilities are located in either the Town of Plymouth or the City of Waterbury, but each have a town boundary within 2,500 feet of the Proposed Route of the new 115-kV transmission line. Copies of the Application will be available at the municipal offices of Watertown, Thomaston, Litchfield, Harwinton, Plymouth, and Waterbury.

For further information about this Project, please visit [www.Eversource.com](http://www.Eversource.com), call 1-800-793-2202, or email [TransmissionInfo@eversource.com](mailto:TransmissionInfo@eversource.com).


Every 8 seconds...a cat or dog is euthanized in the U.S.



You have the right to remain silent...

...but if you do, they pay the price.

**REPORT ANIMAL CRUELTY TO THE POLICE**



**No matter what you're looking for:**

- local events
- local sports
- news briefs
- financial analysis
- entertainment features
- travel insights
- real estate
- employment and so much more you can find in.....

**THE REGISTER CITIZEN**

RegisterCitizen.com

Call 860-489-1450 to subscribe today

**TO PLACE A CLASSIFIED AD CALL 800.922.7066 • Dir. 860.294.0080**

**ADVERTISE YOUR TAG SALE FOR THE BEST RESULTS Deadline: Tuesday at noon • Call 800.922.7066**

**ATTENTION ADVERTISERS:** Our sales associates make every effort to avoid misprints in advertisements. It is necessary that you check your advertisement the **FIRST TIME** it runs. If an error is found, call us by deadline for the next edition. We will credit errors for one publication only.

**LEGAL NOTICES**

**NOTICE TO CREDITORS**  
ESTATE OF Jacqueline M. Miller (15-00487)

The Hon. Martin F. Landgrebe, Judge of the Court of Probate, District of Housatonic Probate District, by decree dated December 4, 2015, ordered that all claims must be presented to the fiduciary at the address below. Failure to promptly present any such claim may result in the loss of rights to recover on such claim.

Jessie Grecke, Assistant Clerk

The fiduciary is:

Elizabeth J. Riley  
c/o Paula Boa Sousa, Esq.  
Collins Hamatin, P.C.  
148 Deer Hill Avenue  
Danbury, CT 06810  
852030 12/18/2015

**LEGAL NOTICES**

**NOTICE TO CREDITORS**  
ESTATE OF Jacqueline M. Miller (15-00488)

The Hon. Martin F. Landgrebe, Judge of the Court of Probate, District of Housatonic Probate District, by decree dated December 4, 2015, ordered that all claims must be presented to the fiduciary at the address below. Failure to promptly present any such claim may result in the loss of rights to recover on such claim.

Jessie Grecke, Assistant Clerk

The fiduciary is:

Bonnie L. Miller  
14 Aunt Park Lane  
Newtown, CT 06470  
852039 12/18/2015

**LOST AND FOUND**

**LOST** Friday Dec. 4th, in New Milford, very small gold pendant with diamonds and emeralds on gold chain, high sentimental value.

**REWARD** Call 860-354-9773

**CAN'T FIND** what you're looking for? Find it the fast & easy, effective way by using the classified Ad and place a low cost classified ad under "Wanted To Buy" in next week's paper.

**APARTMENTS FOR RENT (UNFURNISHED)**

**The Mill at Still River**  
101 Whiting St.  
WINSTED, CT 06098

Has elegant brick & beam, 1 & 2 bedrooms. Every Apartment has River views, dishwasher, garbage disposal, gas heat, cathedral ceilings. Laundry & elevator on premises.

**"SMOKE FREE ENVIRONMENT"**  
**"Move-In Special"**  
Call Paula  
978-821-6880.

**HOUSES FOR RENT (UNFURNISHED)**

**ROXBURY rental** - Charming, private 1BR cottage. Updated bath & appl. W/D \$1,000/mo. + util. (213) 770-7177.

**WINTER RENTAL SHARON**, Brick house, Living Room, Fireplace insert, Dining Room, kitchen w/appliances, 4 Bedrooms, 2 Bathrooms, utility rm, w/washer & dryer & garage. Terms: \$1,200/mo. w/ security deposit. Avail. Nov. - April w/optional renewal. Call 860-364-5019.

**TO ADVERTISE**  
Call today!  
1-800-922-7066

**HANDYMAN**

**Pro Green Paradise Professional grounds Management corporation**  
Snow Removal, Commercial and residential, gutters clean, all types mason work, natural stone walls, fireplace, chimney, fall clean up, tree removal, tree trimming, 20% discount on any job.  
Licence 28777 CT, NY 203-442-7341  
nazzaro2015@hotmail.com

**Want fast cash?**  
Our Classified advertisers get great results. If you have merchandise to sell, place a classified ad.

**TAX COLLECTOR'S NOTICE**

Pursuant to Sec. 12-145 of the Connecticut statutes, the undersigned Tax Collector of the Town of Goshen gives notice that she will be ready to receive Supplemental Motor Vehicle taxes and the second installment of Real Estate & Personal Property taxes due January 1, 2016 at the Tax Collector's office in the Goshen Town Hall, 42A North St., Goshen, CT on Tuesday 9-12 NOON and Wednesday 1PM - 4PM. Extra hours will be on Monday February 1, 2016 from 1PM - 4PM. Payments must be received or postmarked by February 1, 2016 to avoid interest.

All taxes remaining unpaid after February 1, 2016 will be charged interest from January 1, 2016 at the rate of 1.5% for each month elapsing from the due date of the delinquent tax to the date of payment, with a minimum interest charge of \$2.00. Sec. 12-146

Failure to receive a tax bill does not relieve the taxpayer of his/her responsibility for the payment of taxes or delinquent charges. Sec. 12-130

Dated at Goshen, Connecticut this 2nd day of December 2015.  
Rebecca M. Juchert-Derungs, CCMC  
Tax Collector

**Notice of Application by The Connecticut Light and Power Company doing business as Eversource Energy for Approval of a New 115-kV Electric Transmission Line in the Towns of Watertown, Thomaston, Litchfield, and Harwinton, Connecticut**

Pursuant to the provisions of Section 16-50(b) of the General Statutes of Connecticut, Section 16-50(c) of the Connecticut Siting Council, and the Application Guide for an Electric and Fuel Transmission Line Facility of the Connecticut Siting Council (adopted April 2010), notice is hereby given that The Connecticut Light and Power Company doing business as Eversource Energy (Eversource) will on or about December 22, 2015, submit an Application to the Connecticut Siting Council seeking a Certificate of Environmental Compatibility and Public Need (Application) for the Frost Bridge to Campville 115-kV Project (Project). The Project includes construction of a new 115-kV electric transmission line between Eversource's existing Frost Bridge Substation in the Town of Watertown and its existing Campville Substation in the Town of Harwinton, related modifications to Frost Bridge Substation and Campville Substation, and the reconfiguration of a short (0.4-mile) segment of two existing 115-kV transmission lines in the Towns of Litchfield and Harwinton. The Project is needed to bring the electric supply system in northwest Connecticut into compliance with national and regional reliability standards and criteria by eliminating potential thermal overloads and voltage violations identified in studies conducted by independent system operator New England, and regional system planning authority.

The Proposed Route for the new 115-kV transmission line is approximately 10.4 miles long. The new transmission line will be constructed overhead on an existing Eversource right-of-way (ROW) for approximately 10.3 miles in the Towns of Watertown, Thomaston, Litchfield, and Harwinton, and constructed underground for approximately 0.1 mile where the new line exits Frost Bridge Substation in Watertown. The new overhead transmission line will be built on unused portions of the existing Eversource ROW and aligned adjacent to existing overhead transmission lines. The 0.1-mile underground segment will be constructed within Frost Bridge Substation and on Eversource-owned property just outside the fence line of the substation.

The Application will describe the proposed new transmission line, including descriptions of both the 10.3-mile overhead segment and the 0.1-mile underground segment. The Application will include a description of the Proposed Route and alternate routes considered for the transmission line, along with an evaluation of the environmental, engineering, reliability, operability, and cost considerations associated with those routes. The Application will also describe the required modifications to the existing Frost Bridge Substation (located adjacent to Frost Bridge Road and State Route 8 in Watertown) and to the existing Campville Substation (located adjacent to Wildcat Hill Road in Harwinton). Modifications are needed at these substations, each of which is located within larger parcels of Eversource-owned property, to connect the new 115-kV line to the existing transmission system. The modifications at Frost Bridge Substation will not require any expansion to the existing fence line, while the modifications at Campville Substation will increase the fenced area by approximately 0.4 acre on Eversource-owned property. The Application will also include a description of the reconfiguration of a short segment (0.4-mile) of two existing 115-kV transmission lines that are currently supported on common structures at the crossing of the Naugatuck River in the Towns of Litchfield and Harwinton.

In addition, the Application will describe two route variations - one overhead and one underground - developed by Eversource for the portion of the Proposed Route in the Town of Watertown where the new 115-kV transmission line exits from Frost Bridge Substation and connects to the existing ROW. The overhead variation would be located on Eversource property and would exit the southeast side of the substation, extending around the substation to the east before turning northwest, while the underground variation would involve a short (0.1 mile) underground transmission line cable that exits out of the southeastern side of the substation, also extending around the substation to the east before turning northwest and transitioning to overhead prior to the crossing of Frost Bridge Road.

If approved by the Connecticut Siting Council, Project construction is expected to begin in the second quarter of 2017. The new transmission line is proposed to be completed and in-service by the end of 2018.

No proposed Project facilities are located in either the Town of Plymouth or the City of Waterbury, but each have a town boundary within 2,500 feet of the Proposed Route of the new 115-kV transmission line. Copies of the Application will be available at the municipal offices of Watertown, Thomaston, Litchfield, Harwinton, Plymouth, and Waterbury.

For further information about this Project, please visit [www.Eversource.com](http://www.Eversource.com), call 1-800-793-2202, or email [TransmissionInfo@eversource.com](mailto:TransmissionInfo@eversource.com).




**What's In It For You?**

- local events • local sports
- news briefs
- financial analysis
- entertainment features
- travel insights • real estate and so much more ...

**THE REGISTER CITIZEN**

Call 860-489-1450 to subscribe today!

RegisterCitizen.com



**No matter what you're looking for:**

- local events
- local sports
- news briefs
- financial analysis
- entertainment features
- travel insights
- real estate
- employment and so much more you can find in.....

**THE REGISTER CITIZEN**

RegisterCitizen.com

Call 860-489-1450 to subscribe today







**▶ HOW TO PLACE A CLASSIFIED AD:**

**CALL ▶ 1.800.922.7066** (Toll Free)

**EMAIL ▶ [classified@registercitizen.com](mailto:classified@registercitizen.com)**  
**WEBSITE ▶ [registercitizen.com/classifieds](http://registercitizen.com/classifieds)**

Classified is open Monday through Friday from 8am to 5pm.  
 The ad deadline is 4pm for publication the following day (Friday @ 4pm for publication Sunday or Monday).

Please check your ad on the first day it is published to make sure it is correct. If you find an error, please report it IMMEDIATELY. Call 1.800.922.7066. The Register Citizen will be responsible for only ONE incorrect insertion.

**HOLIDAY**

**FREE Gift-wrapping Service.**  
 Sat. Dec. 19th 1pm-5pm  
 at the  
**Advent Christian Church**  
 217 New Harwinton Road  
 Torrington  
 Just bring your gifts and  
 any necessary boxes and  
 we will do the rest.

**APARTMENTS FOR RENT (UNFURNISHED)**

**NORTHSIDE TERRACES**  
 TORRINGTON  
 2 BR \$1050/mo.  
 Heat & Hot Water  
 Included. Hardwood  
 Floors, Appl. Assisted  
 Parking, Playground,  
 Laundry Facilities.  
 24 hr Emergency  
 Services, Sec. 8 Voucher  
 Accepted.  
 Apply at  
 4 Terrace Dr.  
 Torrington.  
 (860)482-4707

**The Mill at Still River**

101 Whiting St.  
 WINSTED, CT 06098  
 Has elegant brick & beam.  
 1 & 2 bedrooms.  
 Every Apartment has River  
 views, dishwasher,  
 garbage disposal, gas  
 heat, cathedral ceilings.  
 Laundry & elevator on  
 premises.  
**"SMOKE FREE ENVIRONMENT"**  
**"Move-In Special"**  
 Call Paula  
 978-821-6880.

WINSTED. 1 BR, 1st floor,  
 available immediately. Walking  
 distance for shopping,  
 entertainment, & parks. \$615  
 + utils. & sec. Background  
 check. Call 860-738-1776

Winsted - Litchfield Heights  
 Apartments. 2 bedroom town-  
 house. Full basement. Washer/  
 dryer hookups available.  
 (860) 379-7881.

**HELP WANTED GENERAL**

**Bookkeeper/Payroll**  
 If you are good with numbers  
 and are hardworking, honest,  
 and loyal we will train you.  
 Computer experience helpful.  
 Some flexibility in hours.  
 call 860-489-5154  
 and ask for Janet.

**LOOK!**

Attention Getters  
 draw ATTENTION  
 to your Classified Ad.  
 Add one for just  
 a few dollars extra.  
 There are many  
 to choose from.  
**1-800-922-7066**

**SAV HELLO** to the most  
 mobile marketplace in the  
 area - the Insider Classifieds.

**CERICAL/ADMINISTRATIVE**

**Acura of Avon**  
 Entry Level Office - F/T  
 Acura of Avon seeks Of-  
 fice Clerk responsible for  
 A/R, vehicle swaps, stock-  
 ing in new cars, whole-  
 sales, light filing, making  
 service appointments, an-  
 swering multi-line phone  
 system, cashing out cus-  
 tomers. Hours are Mon-  
 Thurs 8-4:30, Fri 8-6. Our  
 full time positions come  
 with all the benefits you'd  
 expect from the best deal-  
 er group in the state in-  
 cluding competitive pay,  
 Medical and Dental cov-  
 erage, paid holidays and  
 vacation, and matching  
 401K plan. Email resume  
 to: [imcalkins@acuraford.com](mailto:imcalkins@acuraford.com)  
 or call Janice  
 Calkins at 860-693-6981 to  
 schedule an interview.

**BARGAINS!**

COINS-WHEAT CENTS \$1.50  
 A ROLL, 20th CENTURY  
 NICKEL SET \$5.00, 5 COIN  
 S-MINT QUARTERS, SETS.  
 A.T.B. 2012,13,14,15, \$3. PER  
 SET. 860-489-7685  
 RECORDS(LP)-JAZZ,POP,  
 ROCK,COUNTRY -MOST AT  
 \$1.00 EACH. 45c & 78c. Audio  
 cassettes at .50c Also avail-  
 able. 860-489-7685

Attention Getters  
 draw ATTENTION  
 to your Classified Ad.  
 Add one for just  
 a few dollars extra.  
 There are many  
 to choose from.

**TO SUBSCRIBE**  
 Call  
**888-533-6133.**

**FIREWOOD**

**FIREWOOD:**  
 Cut, Split and Delivered.  
 (860)485-9693  
**TREE SERVICE:**  
 Brush Chipping,  
 Storm Damage,  
 Building Lot  
 (860)485-9693  
 Fully Insured.  
 Free Estimate.

**DEADLINE for the REGISTER CITIZEN is 4 p.m.**  
 Tuesday through Friday.  
 To advertise weekends and  
 Mondays the deadline is  
 Friday at 3 p.m.  
 Call 1-800-922-7066

**Notice of Application by The Connecticut Light and Power Company doing business as Eversource Energy for Approval of a New 115-kV Electric Transmission Line in the Towns of Watertown, Thomaston, Litchfield, and Harwinton, Connecticut**

Pursuant to the provisions of Section 16-50(b) of the General Statutes of Connecticut, Section 16-50-1(e) of the regulations of the Connecticut Siting Council, and the Application Guide for an Electric and Fuel Transmission Line Facility of the Connecticut Siting Council (adopted April 2010), notice is hereby given that The Connecticut Light and Power Company doing business as Eversource Energy (Eversource) will on or about December 22, 2015, submit an Application to the Connecticut Siting Council seeking a Certificate of Environmental Compatibility and Public Need (Application) for the Frost Bridge to Campville 115-kV Project (Project). The Project includes construction of a new 115-kV electric transmission line between Eversource's existing Frost Bridge Substation in the Town of Watertown and its existing Campville Substation in the Town of Harwinton, related modifications to Frost Bridge Substation and Campville Substation, and the reconfiguration of a short (0.4-mile) segment of two existing 115-kV transmission lines in the Towns of Litchfield and Harwinton. The Project is needed to bring the electric supply system in northwest Connecticut into compliance with national and regional reliability standards and criteria by eliminating potential thermal overloads and voltage violations identified in studies conducted by Independent System Operator- New England, the regional system planning authority. The Proposed Route for the new 115-kV transmission line is approximately 10.4 miles long. The new transmission line will be constructed on an existing Eversource right-of-way (ROW) for approximately 10.3 miles in the Towns of Watertown, Thomaston, Litchfield, and Harwinton, and constructed underground for approximately 0.1 mile where the new line exits Frost Bridge Substation in Watertown. The new overhead transmission line will be built on unused portions of the existing Eversource ROW and aligned adjacent to existing overhead transmission lines. The 0.1-mile underground segment will be constructed within Frost Bridge Substation and on Eversource-owned property just outside the fence line of the substation. The Application will describe the proposed new transmission line, including descriptions of both the 10.3-mile overhead segment and the 0.1-mile underground segment. The Application will include a description of the Proposed Route and alternate routes considered for the transmission line, along with an evaluation of the environmental, engineering, reliability, operability, and cost considerations associated with those routes. The Application will also describe the required modifications to the existing Frost Bridge Substation (located adjacent to Frost Bridge Road and State Road 8 in Watertown) and to the existing Campville Substation (located adjacent to Wildcat Hill Road in Harwinton). Modifications are needed at these substations, each of which is located within larger parcels of Eversource-owned property, to connect the new 115-kV line to the existing transmission system. The modifications at Frost Bridge Substation will not require any expansion to the existing fence line, while the modifications at Campville Substation will increase the fenced area by approximately 0.4 acre on Eversource-owned property. The Application will also include a description of the reconfiguration of a short segment (0.4-mile) of two existing 115-kV transmission lines that are currently supported on common structures at the crossing of the Naugatuck River in the Towns of Litchfield and Harwinton. In addition, the Application will describe two route variations - one overhead and one underground - developed by Eversource for the portion of the Proposed Route in the Town of Watertown where the new 115-kV transmission line exits from Frost Bridge Substation and connects to the existing ROW. The overhead variation would be located on Eversource property and would exit the southeastern side of the substation, extending around the substation to the east before turning northwest, while the underground variation would involve a short (0.1 mile) underground transmission line cable that exits out of the southeastern side of the substation, also extending around the substation to the east before turning northwest and transitioning to overhead prior to the crossing of Frost Bridge Road. If approved by the Connecticut Siting Council, Project construction is expected to begin in the second quarter of 2017. The new transmission line is proposed to be completed and in-service by the end of 2018. No proposed Project facilities are located in either the Town of Plymouth or the City of Waterbury, but each have a town boundary within 2,500 feet of the Proposed Route of the new 115-kV transmission line. Copies of the Application will be available at the municipal offices of Watertown, Thomaston, Litchfield, Harwinton, Plymouth, and Waterbury. For further information about this Project, please visit [www.Eversource.com](http://www.Eversource.com), call 1-800-793-2202, or email [TransmissionInfo@Eversource.com](mailto:TransmissionInfo@Eversource.com).

**RECYCLE THIS NEWSPAPER**

**Sharon Health Care Center**  
 Sharon Health Care Center, an 88 bed skilled nursing & rehabilitation facility. It is a newly renovated facility offering a friendly customer environment.  
**CERTIFIED NURSING ASSISTANTS**  
 7-3, 3-11, 11-7 shifts available  
**\$1000.00 SIGN ON BONUS for C.N.A.s!**  
**\$500.00 AFTER 6 MONTHS OF EMPLOYMENT;**  
**\$500.00 AFTER 1 YEAR OF EMPLOYMENT**  
 Patience, enthusiasm, positive attitude a must!  
 Great benefit!  
 Stop in to complete an application  
 or send/ fax resume to the address & fax number listed below.  
 Sharon Health Care Center  
 Attn: Lisa Beldock  
 27 Hospital Hill Rd, Sharon CT 06093  
 860-364-1002 (Phone); 860-364-0237 (fax)  
[Athenahealthcare.com/sharon](http://Athenahealthcare.com/sharon)

**At Your SERVICE DIRECTORY**


**HAULING**  
 Attics - Basements  
 Garages Cleared  
 Trash Removed  
 Dump Runs  
 860-496-7853 or  
 860-309-7496  
 Howard Nodine

**HAULING**  
**DUMP RUNS!**  
 Lumber, Furniture,  
 Construction Debris,  
 Appliances Clothes,  
 Paper, Glass, Pools,  
 Sheds, Decks, Fences,  
 Brush, leaves, & More.  
 Call 860-394-6740.

**TO ADVERTISE**  
 Call 1-800-922-7066

**DO YOU PROVIDE A SERVICE?**

Advertise it here in The Register Citizen  
 "At Your Service" Directory.  
 We'll help you put together an ad to reach  
 over 30,000 readers every day!  
**Call 1-800-922-7066 Today!**



**No matter what you're looking for:**

- local events
- local sports
- news briefs
- financial analysis
- entertainment features
- travel insights
- real estate
- employment and so much more you can find in.....

**THE REGISTER CITIZEN**  
 RegisterCitizen.com  
 Call 860-489-1450  
 to subscribe today





56 Prospect Street  
Hartford, CT 06103

**John Morissette**  
Project Manager - Transmission Siting  
Tel: 860-728-4532

December 22, 2015

Robert M. Scannell, Town Manager  
Town Hall Annex  
424 Main Street  
Watertown CT 06795

The Honorable Edmond V. Mone  
First Selectman  
Thomaston Town Hall  
158 Main Street  
Thomaston, CT 06787

The Honorable Leo Paul, Jr.  
First Selectman  
Litchfield Town Hall  
4 West Street  
Litchfield, CT 06759

The Honorable Michael R. Criss  
First Selectman  
Harwinton Town Hall  
PO Box 66  
100 Bentley Drive  
Harwinton, CT 06791

The Honorable Neil O'Leary  
c/o Joe Geary  
Waterbury City Hall  
235 Grand Avenue  
Waterbury, CT 06702

The Honorable David V. Merchant  
Plymouth Town Hall  
80 Main Street  
Terryville, CT 06786

Re: Application of The Connecticut Light and Power Company doing business as Eversource Energy the Connecticut Siting Council for a Certificate of Environmental Compatibility and Public Need for the Construction of the Frost Bridge to Campville 115-kV Project

Dear Municipal Leaders:

Enclosed are paper copies of an Application submitted by The Connecticut Light and Power Company doing business as Eversource Energy ("Eversource") to the Connecticut Siting Council ("Council") for a Certificate of Environmental Compatibility and Public Need for the construction of a new 10.4-mile 115-kilovolt (kV) primarily overhead electric transmission line between Eversource's Frost Bridge Substation in Watertown and its Campville Substation in Harwinton, referred to as the Frost Bridge to Campville 115-kV Project ("Project").

The Project is proposed to make related improvements to both substations and to reconfigure a short (0.4-mile) segment of two existing 115-kV transmission lines that are supported on common structures. The Project would be located in portions of four towns: Watertown, Thomaston, Litchfield and Harwinton. The transmission line would be located within Eversource's existing right-of-way.

Eversource is filing this Application on or about December 23, 2015.

Section 16-50n(a) of the Connecticut General Statutes provides that each person entitled to receive a copy of an application under § 16-50/ may become a party to the proceeding before the Siting Council by giving the Council a notice of intent to be a party.

Respectfully submitted,

THE CONNECTICUT LIGHT AND  
POWER COMPANY DOING BUSINESS  
AS EVERSOURCE ENERGY

*Kenneth Roberts*

Kenneth Roberts  
Project Manager  
Frost Bridge to Campville 115-kV Project

Enclosures

December 22, 2015

TO THE FEDERAL, STATE, AND LOCAL GOVERNMENT AGENCIES AND OFFICIALS REFERRED TO IN § 16-50(b) OF THE CONNECTICUT GENERAL STATUTES:

Re: Application of The Connecticut Light and Power Company doing business as Eversource Energy to the Connecticut Siting Council for a Certificate of Environmental Compatibility and Public Need for the Frost Bridge to Campville 115-kV Project in the four towns: Watertown, Thomaston, Litchfield and Harwinton, Connecticut

Enclosed are paper copies of an Application submitted by The Connecticut Light and Power Company doing business as Eversource Energy ("Eversource") to the Connecticut Siting Council ("Council") for a Certificate of Environmental Compatibility and Public Need for the construction of a new 10.4-mile 115-kilovolt (kV) primarily overhead electric transmission line between Eversource's Frost Bridge Substation in Watertown and its Campville Substation in Harwinton, referred to as the Frost Bridge to Campville 115-kV Project ("Project").

The Project is proposed to make related improvements to both substations and to reconfigure a short (0.4-mile) segment of two existing 115-kV transmission lines that are supported on common structures. The Project would be located in portions of four towns: Watertown, Thomaston, Litchfield and Harwinton. The transmission line would be located within Eversource's existing right-of-way.

Eversource is filing this Application on or about December 23, 2015.

Section 16-50n(a) of the Connecticut General Statutes provides that each person entitled to receive a copy of an application under § 16-50/ may become a party to the proceeding by giving the Council a notice of intent to be a party. The Council's address is: Connecticut Siting Council, 10 Franklin Square, New Britain, CT 06051.

Respectfully submitted,

THE CONNECTICUT LIGHT AND  
POWER COMPANY DOING BUSINESS  
AS EVERSOURCE ENERGY

*Kenneth Roberts*

Kenneth Roberts  
Project Manager  
Frost Bridge to Campville 115-kV Project Enclosure

Enclosure

# Frost Bridge to Campville 115-kV Project

## Application Service List

### 1. Municipal Chief Elected Officials:

Robert M. Scannell, Town Manager  
Town Hall Annex  
424 Main Street  
Watertown CT 06795

The Honorable Edmond V. Mone  
First Selectman  
Thomaston Town Hall  
158 Main Street  
Thomaston, CT 06787

The Honorable Leo Paul, Jr.  
First Selectman  
Litchfield Town Hall  
4 West Street  
Litchfield, CT 06759

The Honorable Michael R. Criss  
First Selectman  
Harwinton Town Hall  
PO Box 66  
100 Bentley Drive  
Harwinton, CT 06791

The Honorable Neil O'Leary  
C/O Joe Geary  
Waterbury City Hall  
235 Grand Avenue  
Waterbury, CT 06702

The Honorable David V. Merchant  
Plymouth Town Hall  
80 Main Street  
Terryville, CT 06786

# Frost Bridge to Campville 115-kV Project

## 2. Attorney General:

Attorney General George C. Jepsen  
Office of the Attorney General  
55 Elm Street  
Hartford, CT 06106

Assistant Attorney General Michael Wertheimer  
Public Utilities Regulatory Authority  
10 Franklin Square  
New Britain, CT 06051

## 3. State Senatorial (Districts 8, 30, 31 and 32)

The Honorable Kevin Witkos (Senate District 8)  
Legislative Office Building  
Room 3400  
Hartford, CT 06106-1591

The Honorable Clark Chapin (Senate District 30)  
Legislative Office Building  
Room 3400  
Hartford, CT 06106-1591

The Honorable Henri Martin (Senate District 31)  
Legislative Office Building  
Room 3400  
Hartford, CT 06106-1591

The Honorable Rob Kane (Senate District 32)  
Legislative Office Building  
Room 3400  
Hartford, CT 06106-1591

## 4. State House (Districts 66, 68, and 76)

The Honorable Craig Miner (House District 66)  
Connecticut House Republican Office  
L.O.B. Room 4200  
Hartford, CT 06106

# Frost Bridge to Campville 115-kV Project

The Honorable Eric Berthel (House District 68)  
Connecticut House Republican Office  
L.O.B. Room 4200  
Hartford, CT 06106

The Honorable John Piscopo (House District 76)  
Connecticut House Republican Office  
L.O.B. Room 4200  
Hartford, CT 06106

5. U.S. Army Corps of Engineers, New England District, Regulatory Division

Attention: Susan Lee, Permit Project Manager  
696 Virginia Avenue  
Concord, MA 01742-2751

6. Bureau of Land Management

Dr. John Lyon  
Acting State Director  
7450 Boston Road  
Springfield, VA 22153

7. Department of Energy and Environmental Protection:

Commissioner Rob Klee  
Office of the Commissioner  
Connecticut Department of Energy and Environmental Protection  
79 Elm Street  
Hartford, CT 06106-5127

8. Department of Public Health:

Dr. Raul Pino, Acting Commissioner Office of the Commissioner  
Connecticut Dept. of Public Health  
410 Capitol Avenue  
Hartford, CT

# Frost Bridge to Campville 115-kV Project

9. Council on Environmental Quality:

Chairman Susan D. Merrow  
Council on Environmental Quality  
79 Elm St.  
Hartford, CT 06106

10. Public Utilities Regulatory Authority:

Chairman Arthur House  
Public Utilities Regulatory Authority  
Ten Franklin Square  
New Britain, CT 06051

11. Office of Consumer Counsel:

Consumer Counsel Elin Swanson Katz  
Office of Consumer Counsel  
Ten Franklin Square  
New Britain, CT 06051-2605

12. Office of Policy and Management:

Secretary Benjamin Barnes  
Office of the Secretary  
Office of Policy and Management  
450 Capitol Avenue  
Hartford, CT 06106

13. Department of Economic and Community Development:

Commissioner Catherine Smith  
Office of the Commissioner  
Department of Economic and Community Development  
505 Hudson Street  
Hartford, CT 06106-7106

## Frost Bridge to Campville 115-kV Project

14. Department of Agriculture:

Commissioner Steven K. Reviczky  
Office of the Commissioner  
Department of Agriculture  
165 Capitol Avenue  
Hartford, CT 06106

15. Department of Transportation:

Commissioner James P. Redeker  
Office of the Commissioner  
Department of Transportation  
P.O. Box 317546  
2800 Berlin Turnpike  
Newington, CT 06131-7546

16. State Historic Preservation Officer of the Connecticut Department of Economic and Community Development, Commission on Culture and Tourism:

Daniel Forrest  
State Historic Preservation Officer  
One Constitution Plaza, 2<sup>nd</sup> Floor  
Hartford, CT 06103

17. Department of Emergency Services and Public Protection:

Commissioner Dora Schriro  
Office of the Commissioner  
Department of Emergency Services and Public Protection  
1111 Country Club Road  
Middletown, CT 06457

18. Bureau of Land Management

Director Neil Kornze  
BLM Washington Office  
1849 C Street NW, Rm. 5665  
Washington DC 20240

# Frost Bridge to Campville 115-kV Project

## 19. U.S. Fish and Wildlife Service:

Supervisor Tom Chapman  
U.S. Fish & Wildlife Service  
New England Office  
70 Commercial Street  
Concord, NH 03301-5087

## 20. Naugatuck Valley Council of Governments

Rick Dunne, Executive Director Naugatuck Valley Council of Governments  
9 Leavenworth Street, 3rd Floor  
Waterbury, Connecticut 06702

## 21. Harwinton Planning and Zoning

Polly Redmond, Land Use Coordinator  
Harwinton Planning & Zoning Commission  
Town of Harwinton  
100 Bentley Drive  
Harwinton, CT 06791

## 22. Harwinton Inland Wetlands and Watercourses Commission

Bruce R. Burnett, Chairman  
Harwinton Inland Wetlands & Watercourses Commission  
Town of Harwinton  
100 Bentley Drive  
Harwinton, CT 06791

## 23. Harwinton Conservation Commission

John D. Goodno, Chairman  
Harwinton Conservation Commission  
Town of Harwinton  
100 Bentley Drive  
Harwinton, CT 06791

# Frost Bridge to Campville 115-kV Project

## 24. Litchfield Planning and Zoning Commission

Dennis Paul Tobin, PhD, Land Use Administrator  
Litchfield Planning & Zoning Commission  
P.O. Box 12  
80 Doyle Road  
Bantam, CT 06750

## 25. Litchfield Inlands Wetlands Commission

Dennis Paul Tobin, PhD, Land Use Administrator  
Litchfield Inlands Wetlands Commission  
P.O. Box 12  
80 Doyle Road  
Bantam, CT 06750

## 26. Litchfield Conservation Commission

Dennis Paul Tobin, PhD, Land Use Administrator  
Litchfield Conservation Commission  
P.O. Box 12  
80 Doyle Road  
Bantam, CT 06750

## 27. Thomaston Planning and Zoning Commission

Jeremy Leifert , Zoning Enforcement Offcier  
Thomaston Planning & Zoning Commission  
Thomaston Town Hall  
158 Main Street  
Thomaston, CT 06787

## 28. Thomaston Inlands Wetlands Commission

Jeremy Leifert, Wetland Enforcement Officer  
Thomaston Inland Wetlands Commission  
Thomaston Town Hall  
158 Main Street  
Thomaston, CT 06787

# Frost Bridge to Campville 115-kV Project

## 29. Thomaston Conservation Commission

Joseph Fainer, Chairman

Thomaston Conservation Commission Thomaston Town Hall  
158 Main Street  
Thomaston, CT 06787

## 30. Watertown Planning and Zoning Commission

Ruth Mulcahy, Land Use Administrator  
Watertown Planning & Zoning Commission  
Town of Watertown  
61 Echo Lake Road  
Watertown, CT 06795

## 31. Watertown Inlands Wetlands Commission

Ruth Mulcahy, Land Use Administrator  
Watertown Inland Wetlands Commission  
Town of Watertown  
61 Echo Lake Road  
Watertown, CT 06795

## 32. Watertown Conservation Commission

Edwin Undercuffler, Chairman  
Watertown Conservation Commission  
Watertown Town Hall Annex  
424 Main Street  
Watertown, CT 06795



# NOTICE OF PROPOSED CONSTRUCTION OF A HIGH-VOLTAGE ELECTRIC TRANSMISSION LINE

## Eversource Plans Improvements to Electric System to Maintain System Reliability

So that customers will have reliable electric power to meet their energy needs, we are continuing our efforts to improve Connecticut's electric system in four Litchfield County towns—Watertown, Thomaston, Litchfield and Harwinton.

These proposed transmission system improvements, known as the Frost Bridge to Campville 115-kV Transmission Line Project, are required to bring the electric supply system in northwest Connecticut into compliance with national and regional reliability standards. This notice provides a summary of our plan, as currently proposed.

### Project Summary

To provide reliable, cost-effective, and environmentally sound improvements to the regional electric transmission system, Eversource proposes to construct a new 10.4-mile, 115-kilovolt (kV) overhead transmission line between its Frost Bridge Substation in Watertown and its Campville Substation in Harwinton, and to make related improvements in both substations.

We also plan to reconfigure two 115-kV circuits where they cross the Naugatuck River. These circuits are currently supported by common transmission structures. The reconfiguration will allow each circuit to be supported by its own set of structures.

The new overhead line would be located entirely within Eversource's existing transmission line rights-of-way. In addition, new equipment will be installed at both the Frost Bridge and Campville substations. At the Campville Substation, the project requires the expansion of the existing fence line to the east, while remaining on Eversource property. No fence line expansion is needed at Frost Bridge Substation. The proposed modifications to the substations, as required to connect the new 115-kV line to the existing transmission system, would be on Eversource property.

Eversource plans to submit an application to the Connecticut Siting Council (Siting Council) within the next 60 days, seeking a "Certificate of Environmental Compatibility and Public Need" for this project. If approved by the Siting Council, construction is projected to begin in the third quarter of 2017. The new transmission line and related substation improvements are proposed to be completed and in service by the end of 2018.

### Technical Description

The structure types under consideration for the overhead 115-kV transmission line are steel monopoles with typical heights of 85 to 95 feet tall. In a 2.5-mile segment between Frost Bridge Substation and Thomaston Road in Watertown, the structure height will typically be between 95 to 105 feet tall.

In addition to the new line structures, two existing structures at the Naugatuck River crossing will be

replaced. The new structures will be taller than the typical new monopoles, standing at approximately 155 feet tall. This height is necessary to safely span the Naugatuck River.

Eversource's application will provide additional siting and technical details, including information as to how the specific design of the line impacts magnetic field levels and measures to minimize magnetic fields. The proposed new lines will meet the requirements of the Siting Council's "Best Management Practices for Electric and Magnetic Fields," as amended.


Project siting and magnetic field information, including calculated magnetic field levels, will be included in the application. A link to the application will be available on the project's website at [www.eversource.com](http://www.eversource.com), and on the Siting Council's website at [www.ct.gov/csc](http://www.ct.gov/csc). Paper copies will be available at libraries in the towns along the project route. Additional information about the project can be obtained by calling 1-800-793-2202 or by emailing [TransmissionInfo@eversource.com](mailto:TransmissionInfo@eversource.com). Additional information on electric and magnetic fields may be obtained by calling 1-800-793-2202 or contacting the Connecticut Department of Public Health at 860-509-7740.

### Proposed Route Under Consideration

The proposed line route for the new 115-kV transmission line will extend 10.4 miles on existing rights-of-way between Frost Bridge Substation and Campville Substation, crossing through the towns of Watertown, Thomaston, Litchfield and Harwinton.

The proposed line route exits the Frost Bridge Substation and extends for 2.6 miles along existing rights-of-way crossing James H. Darcey Memorial Highway/Route 8, Echo Lake Road, Park Road, Nova Scotia Hill Road, and Thomaston Road/Route 6, before moving north for 2.1 miles into Thomaston. In Thomaston, the proposed 2.6-mile route crosses Branch Road/Route 109, Walnut Hill Road, and Northfield Road/Route 254, before entering Litchfield. In Litchfield, the 1.8-mile proposed route crosses Mason Hill Road, Hopkins Road, Campville Road and James H. Darcey Memorial Highway/Route 8, before entering Harwinton. In Harwinton, the 1.3-mile proposed route crosses Valley Road and Wildcat Hill Road before entering the Campville Substation.

## Project Location Map Frost Bridge to Campville 115-kV Transmission Project



The map above depicts the proposed route of the overhead transmission line between Watertown and Harwinton.

### Additional Information

For more information regarding the project, please contact:

Frost Bridge to Campville 115-kV Transmission Line Project  
Project Outreach  
Eversource Energy  
P.O. Box 270, Hartford, CT 06141

1-800-793-2202

[TransmissionInfo@eversource.com](mailto:TransmissionInfo@eversource.com)

**EVERSOURCE**

# NOTIFICACIÓN DE PROPUESTA DE CONSTRUCCIÓN DE LÍNEA DE TRANSMISIÓN ELÉCTRICA DE ALTO VOLTAJE

## Eversource Planifica Mejoras al Sistema de Transmisión Para Aumentar la Confiabilidad

Para que los clientes tengan energía eléctrica confiable y puedan satisfacer sus necesidades de energía, continuamos nuestros esfuerzos para mejorar el sistema eléctrico de Connecticut en cuatro ciudades del Condado de Litchfield -- Watertown, Thomaston, Litchfield y Harwinton.

Estas propuestas de mejoras del sistema de transmisión, conocidas como el proyecto de la línea de transmisión "Frost Bridge to Campville 115-kV Transmission Line Project" está requerido para que el sistema que suplente la electricidad en el noroeste de Connecticut cumpla con las reglas nacionales y regionales de confiabilidad. Este aviso proporciona un resumen de nuestro plan, según la propuesta actual.

### Resumen del Proyecto

Para proveer mejoras al sistema de transmisión regional que sean confiables, económicas y ecológicas, Eversource propone construir una línea de transmisión área de 10.4 millas, 115-kilovoltios (kV) entre la Subestación de Frost Bridge en Watertown y la Subestación Campville en Harwinton, y de hacer todas las mejoras relacionadas a las dos subestaciones.

También planeamos reconfigurar dos circuitos de 115-kV adonde estos cruzan con el Río de Naugatuck. Estos circuitos al presente son apoyados por sus estructuras de transmisión comunes. La reconfiguración permitirá que cada circuito sea apoyado por sus propias estructuras.

Las nuevas líneas eléctricas aéreas estarán localizadas completamente dentro de las líneas existentes de transmisión y sus derechos de paso. En adición, nuevo equipo será instalado en las dos subestaciones de Frost Bridge y Campville. En la Subestación Campville, el proyecto requiere la expansión más allá de la línea de la cerca existente hacia al este, mientras que se mantengan en la propiedad de Eversource. No se necesita ninguna expansión en la Subestación de Frost Bridge. Las modificaciones que han sido propuestas a las subestaciones, que se requieren para conectar la nueva línea de 115-kV al sistema existente de transmisión, estarán dentro de la propiedad de Eversource.

En los próximos 60 días, Eversource solicitará un Certificado de Compatibilidad Ambiental y Necesidad Pública al Consejo de Emplazamiento de Connecticut (Siting Council) para este proyecto. Si es aprobado por el Consejo de Emplazamiento, la construcción está pautada para comenzar el tercer trimestre del 2017. La nueva línea de transmisión subterránea y las mejoras relacionadas están planeadas para finalizarse y entrar en funcionamiento a fines del 2018.

### Descripción Técnica

Los tipos de estructura bajo consideración para la línea de transmisión aérea de 115-kV son monopolos de acero con alturas típicas de 85 a 95 pies de altura. En un segmento de 2.5 millas entre la subestación llamada Frost Bridge y Thomaston Road en Watertown, lo alto de la estructura será típicamente entre 95 a 105 pies de altura.

Además de las nuevas estructuras de la línea, se reemplazarán dos estructuras existentes en el cruce

del Río Naugatuck. Las nuevas estructuras serán más altas que los monopolos típicos, en aproximadamente 155 pies de altura. Esta altura es necesaria para cruzar con seguridad el Río de Naugatuck.

La solicitud de Eversource incluirá detalles técnicos y de emplazamiento, como información sobre cómo el diseño específico de la línea afectará los niveles y medidas de campos magnéticos para minimizar los campos magnéticos. Las propuestas nuevas de líneas cumplirán con los requisitos del Consejo de Emplazamiento respecto de las "Buenas Prácticas de Manejo de Campos Magnéticos y Eléctricos," según lo enmendado.

Se incluirá detalles técnicos y de emplazamiento, incluyendo información sobre niveles y medidas de campos magnéticos. Un "link" o enlace para ver la aplicación estará en la página web del proyecto [www.eversource.com](http://www.eversource.com), y en la página web del Consejo de Emplazamiento, [www.ct.gov/csc](http://www.ct.gov/csc). Las copias en papel estarán disponibles en las bibliotecas de las ciudades a lo largo de la ruta del proyecto. Información adicional sobre el proyecto puede obtenerse llamando al 1-800-793-2202 o enviando un correo electrónico al [TransmissionInfo@eversource.com](mailto:TransmissionInfo@eversource.com). Información adicional sobre campos eléctricos y magnéticos puede obtenerse llamando al 1-800-793-2202 o ponerse en contacto con el Departamento de Salud Pública de Connecticut al 860-509-7740.


### Propuesta de Ruta Bajo Construcción

La propuesta de ruta bajo consideración para la nueva línea de transmisión de 115-kV se extenderá 10.4 millas dentro de los derechos de paso existentes entre las Subestaciones de Frost Bridge y Campville, cruzando los municipios de Watertown, Thomaston, Litchfield y Harwinton.

La ruta propuesta sale de la Subestación de Frost Bridge y se extiende por 2.6 millas dentro de sus derechos de paso y cruza el James H. Darcy Memorial Highway/Route 8, Echo Lake Road, Park Road, Nova Scotia Hill Road, y Thomaston Road/Route 6, antes de llegar al norte por 2.1 millas en Thomaston. En Thomaston, la ruta propuesta de 2.6 millas cruza Branch Road/Route 109, Walnut Hill Road, y Northfield Road/Route 254, antes de entrar en Litchfield. En Litchfield, la ruta propuesta de 1.8 millas cruza Mason Hill Road, Hopkins Road, Campville Road y James H. Darcy Memorial Highway/Route 8, antes de entrar a Harwinton. En Harwinton, la ruta propuesta de 1.3 millas cruza Valley Road y Wildcat Hill Road antes de entrar en la Subestación de Campville.

## Mapa de Ubicación del Proyecto

Proyecto de Transmisión 115-kV de Frost Bridge a Campville



El mapa arriba enseña la ruta propuesta de la línea de transmisión aérea entre Watertown y Harwinton.

**EVSOURCE**

### Información Adicional

Para más información acerca de este proyecto, por favor llame a:

Frost Bridge to Campville 115-kV Transmission Line Project  
Project Outreach  
Eversource Energy  
P.O. Box 270, Hartford, CT 06141

1-800-793-2202

[TransmissionInfo@eversource.com](mailto:TransmissionInfo@eversource.com)

Esta notificación se proporciona conforme a §16-50(b) de los Estatutos Generales de Connecticut. Este folleto es pagado por los clientes.





## Frost Bridge to Campville 115-kV Project Substation Direct Abutters

| Frost Bridge Substation Direct Abutters                            |                         |           |       |          |  |
|--|-------------------------|-----------|-------|----------|--|
| Name   | Address                 | Town      | State | Zip Code |  |
| Connecticut Department of Transportation, Office of Rails          | c/o Richard Jankovich   | Newington | CT    | 06111    |  |
| City of Waterbury  | c/o Office of the Mayor | Waterbury | CT    | 06702    |  |
| Connecticut Department of Transportation, Division of Right of Way | c/o Terrence J. Obey    | Newington | CT    | 06111    |  |

| Campville Substation Direct Abutters |                       |           |       |          |  |
|--------------------------------------|-----------------------|-----------|-------|----------|--|
| Name                                 | Address               | Town      | State | Zip Code |  |
| John C. & Joyce L. McNabney          | 370 Wildcat Hill Road | Harwinton | CT    | 06791    |  |
| Jan M. Prenoveau                     | 421 Hill Road         | Harwinton | CT    | 06791    |  |
| Brian C. & Sharon L. Viets           | 66 Hayden Road        | Harwinton | CT    | 06791    |  |

December 18, 2015

CERTIFIED MAIL RETURN RECEIPT REQUESTED

[PROPERTY OWNER]

Re: Notice to Owners of Property Abutting Eversource's Frostbridge Substation in Watertown

Dear Neighbor:

This letter is to inform you that The Connecticut Light and Power Company, doing business as Eversource Energy ("Eversource"), is continuing its efforts to improve the electric power delivery system in the towns of Watertown, Thomaston, Litchfield and Harwinton. Eversource will be seeking approval from the Connecticut Siting Council (Council) to construct a new 10.4-mile 115-kilovolt (kV) primarily overhead electric transmission line between Eversource's Frost Bridge Substation in Watertown and its Campville Substation in Harwinton, to make related improvements to both substations and to reconfigure a short (0.4-mile) segment of two existing 115-kV transmission lines that are supported on common structures where the line crosses the Naugatuck River. The name of the proposed Project is the Frost Bridge to Campville 115-kV Project.

Eversource is proposing to make related modifications to Frost Bridge Substation located at Frost Bridge Road in Watertown, which abuts or is near your property. The proposed modifications at Frost Bridge Substation would include new equipment and a new terminal structure, approximately 60 feet high. The modifications are within the existing developed (fenced) area of the station and on Eversource property.

This letter is to provide notice of Eversource's intent to apply to the Council on or about December 23, 2015 for a Certificate of Environmental Compatibility and Public Need for this Project. After reviewing the application for completeness the Council will conduct a local public hearing. If the Project is approved by the Council we anticipate starting construction in the third quarter of 2017, with completion in 2018. Please note this work will not interrupt electric service to homes or businesses.

If you would like more information concerning the Frost Bridge to Campville 115-kV Project please visit the Project website at [www.Eversource.com](http://www.Eversource.com) and scroll down for the Transmission link. Or you may email us at [TranmissionInfo@eversource.com](mailto:TranmissionInfo@eversource.com) or call the Transmission Information line at 1.800.793.2202.

Sincerely,

*Kenneth Roberts*

Kenneth Roberts  
Project Manager  
Frost Bridge to Campville 115-kV Project

December 18, 2015

CERTIFIED MAIL RETURN RECEIPT REQUESTED

[PROPERTY OWNER]

Re: Notice to Owners of Property Abutting Eversource's Campville Substation in Harwinton

Dear Neighbor:

This letter is to inform you that The Connecticut Light and Power Company, doing business as Eversource Energy ("Eversource"), is continuing its efforts to improve the electric power delivery system in the towns of Watertown, Thomaston, Litchfield and Harwinton. Eversource will be seeking approval from the Connecticut Siting Council (Council) to construct a new 10.4-mile 115-kilovolt (kV) primarily overhead electric transmission line between Eversource's Frost Bridge Substation in Watertown and its Campville Substation in Harwinton, to make related improvements to both substations and to reconfigure a short (0.4-mile) segment of two existing 115-kV transmission lines that are supported on common structures where the line crosses the Naugatuck River. The name of the proposed Project is the Frost Bridge to Campville 115-kV Project.

Eversource is proposing to make related modifications to Campville Substation located at 366 Litchfield Road in Harwinton, which abuts or is near your property. The modifications at Campville Substation will require the expansion of the developed portion of the substation by approximately 0.4 acre, involving an extension of the existing station fence to the east by approximately 90 feet on Eversource property.

This letter is to provide notice of Eversource's intent to apply to the Council on or about December 23, 2015 for a Certificate of Environmental Compatibility and Public Need for this Project. After reviewing the application for completeness the Council will conduct a local public hearing. If the Project is approved by the Council we anticipate starting construction in the third quarter of 2017, with completion in 2018. Please note this work will not interrupt electric service to homes or businesses.

If you would like more information concerning the Frost Bridge to Campville 115-kV Project please visit the Project website at [www.Eversource.com](http://www.Eversource.com) and scroll down for the Transmission link. Or you may email us at [TranmissionInfo@eversource.com](mailto:TranmissionInfo@eversource.com) or call the Transmission Information line at 1.800.793.2202.

Sincerely,

*Kenneth Roberts*

Kenneth Roberts  
Project Manager  
Frost Bridge to Campville 115-kV Project





December 18, 2015

**NOTICE TO COMMUNITY GROUPS REGARDING  
THE FROST BRIDGE to CAMPVILLE 115-kV PROJECT**

The Connecticut Light and Power Company doing business as Eversource Energy ("Eversource") is providing notice to community groups, including Chambers of Commerce, land trusts, environmental groups, trail organizations, historic preservation groups, advocacy groups for the protection of Long Island Sound and river protection organizations within the watershed affected by the proposed facility or that have been identified by a municipality where the facility is proposed to be located or those community groups that have registered with the Connecticut Siting Council to be provided notice, of its intent to apply to the Connecticut Siting Council on or about December 23, 2015 for a Certificate of Environmental Compatibility and Public Need for the Frost Bridge to Campville Project ("Project").

Eversource is proposing to construct a new 10.4-mile 115-kilovolt (kV) predominately overhead electric transmission line between Eversource's Frost Bridge Substation in Watertown and its Campville Substation in Harwinton, to make related improvements to both substations and to reconfigure a short (0.4-mile) segment of two existing 115-kV transmission lines that are supported on common structures. The Project would be located in portions of four towns: Watertown, Thomaston, Litchfield and Harwinton. The transmission line would be located within Eversource's existing right-of-way.

This notice is provided pursuant to Section VIII of the Connecticut Siting Council's Application Guides for an Electric and Fuel Transmission Line Facility (adopted April 2010).

Details regarding the Project are set forth in the enclosed notice.

THE CONNECTICUT LIGHT AND  
POWER COMPANY DOING BUSINESS  
AS EVERSOURCE ENERGY

*Kenneth Roberts*

Kenneth Roberts  
Project Manager  
Frost Bridge to Campville 115-kV Project

Frost Bridge to Campville 115-kV Project  
Community Organizations

| Organization                                 | Addressee  | Address                                 | City             | State       | Zip        |
|--|--|---|------------------|-------------|------------|
| <b>Economic Development Commission</b>       |  |   |                  |             |            |
| Harwinton Economic Development Commission    | P. Thomas Schoenemann, Chair                             | 100 Bentley Drive                       | Harwinton,       | CT          | 06791      |
| Waterbury Regional Chamber (Watertown)       | Timothy Bergstrom, Chairman                              | 83 Bank Street, 4th Floor               | Waterbury,       | CT          | 06721      |
| Litchfield Economic Development Commission   | Heather Boesch-Wages, Chair.                             | Litchfield Town Offices, 74 West Street | Litchfield,      | CT          | 06759      |
| Economic Development Commission              | Richard Sileo, Chairman                                  | Thomaston Town Hall, 158 Main Street    | Thomaston,       | CT          | 06787      |
| <b>Land Trusts</b>                           |  |   |                  |             |            |
| Litchfield Land Trust, Inc.                  | Richard Heys, President                                  | P.O. Box 712                            | Litchfield,      | CT          | 06759      |
| Harwinton Land Trust                         | Bob Orciari, President                                   | P.O. Box 113                            | Harwinton,       | CT          | 06791      |
| The Watertown Land Trust                     | Gail Sangree, Chairman                                   | P.O. Box 382                            | Watertown,       | CT          | 06795      |
| <b>Environmental Groups</b>                  |  |   |                  |             |            |
| Housatonic Valley Association                | Michael Jastremski, Connecticut Water Protection Manager | P.O. Box 28, 150 Kent Road              | Cornwall Bridge, | CT          | 06754      |
| Connecticut League of Conservation Voters    | David Bingham, Co-Chair                                  | 553 Farmington Avenue, Suite 201        | Hartford,        | CT          | 06105      |
| The Nature Conservancy Connecticut Chapter   | Frogyard Ryan, State Director                            | 55 Church Street                        | New Haven,       | CT          |            |
| Citizens Campaign for the Environment        | Hali Greene, Connecticut Outreach Director               | 2404 Whitney Avenue, 2nd Floor          | Hamden,          | CT          | 06518      |
|  | Trail Organizations*                                     |   |                  |             |            |
| Connecticut Forest & Park Association (CFPA) | Eric Hammerling, Executive Director                      | 16 Meriden Road                         | Rockfall,        | CT          | 06481-2372 |
| Naugatuck River Greenway                     | Rick Dunne, Executive Director                           | 49 Leavenworth Street, 3rd Floor,       | Waterbury,       | Connecticut | 06702      |

\*Several trails are also traversed lands within jurisdictions of the ACOE and CT DEEP, these government agencies are being provided separate notice.

Frost Bridge to Campville 115-kV Project  
Community Organizations

| <b>River Protection Organizations</b>                          |                                      |  |                           |
|--|--------------------------------------|--|---------------------------|
| Rivers Alliance of Connecticut                                 | Margaret Minor, Executive Director   | 7 West Street, 3rd Floor                                 | Litchfield, CT 06759      |
| Farmington River Watershed Association                         | Eileen Fielding, Executive Director  | 749 Hopmeadow Street                                     | Simsbury, CT 06070        |
| Farmington River Coordinating Committee                        | Attn: Liz Lacy                       | P.O. Box 395   | Pleasant Valley, CT 06063 |
| <b>Historic Preservation Groups</b>                            |                                      |  |                           |
| The Harwinton Historical Society                               | Bonnie Andrews, President            | 120 South Road   | Harwinton, CT06791        |
| The Historic District Commission                               | Carole Romano Chairperson            | 100 Bentley Drive, PO Box 66                             | Harwinton, CT 06791       |
| Litchfield Historical Society                                  | Catherine Fields, Executive Director | 7 South Street, P.O. Box 385                             | Litchfield, CT 06759      |
| Litchfield Hills Audubon Society                               | Harry Ainsworth, President           | P.O. Box 861   | Litchfield, CT 06759      |
| White Memorial Conservation Center                             | Keith Cudworth, Executive Director   | 71 Whitehall Road, PO Box 368                            | Litchfield, CT 06759      |
| Thomaston Historical Commission                                | Joseph Wassong, Chairman             | 342 Hickory Hill Road                                    | Thomaston, CT 0687        |
| The Watertown Historical Society                               | Brigitte Crispino, President         | 22 Deforest Street                                       | Watertown, CT 06795       |
| Railroad Museum of New England                                 | Celeste Echlin, President            | PO Box 400   | Thomaston, CT 06787-0400  |
| Connecticut Trust for Historic Preservation                    | Charles Janson, Chairman             | 940 Whitney Avenue                                       | Hamden, CT 06517          |
| <b>Advocacy Groups for the Protection of Long Island Sound</b> |                                      |  |                           |
| Connecticut Fund for the Environment Save The Sound            | Don Strait, President                | 142 Temple Street, Suite 305                             | New Haven, CT 06510       |
| Long Island Sound Foundation                                   | Susan McNamara, Executive Director   | 1084 Shennecosset Road, Community & Professional Bldg 19 | Groton, CT 06340          |





December 21, 2015

NOTICE TO  
AQUARION WATER COMPANY  
THE FROST BRIDGE TO CAMPVILLE 115-kV PROJECT

The Connecticut Light and Power Company doing business as Eversource Energy ("Eversource") is providing notice to the affected water company that would provide water to, or be within the watershed affected by, the proposed facilities of its intent to apply to the Connecticut Siting Council on or about December 23, 2015 for a Certificate of Environmental Compatibility and Public Need for the Frost Bridge to Campville 115-kV Project ("Project").

Eversource is proposing to construct a new 10.4-mile 115-kilovolt (kV) predominately overhead electric transmission line between Eversource's Frost Bridge Substation in Watertown and its Campville Substation in Harwinton, to make related improvements to both substations and to reconfigure a short (0.4-mile) segment of two existing 115-kV transmission lines that are supported on common structures. The Project would be located in portions of four towns: Watertown, Thomaston, Litchfield and Harwinton. The transmission line would be located within Eversource's existing right-of-way.

This notice is provided pursuant to Section VIII of the Connecticut Siting Council's Application Guides for an Electric and Fuel Transmission Line Facility (adopted April 2010).

Details regarding the proposed project are set forth in the enclosed notice.

THE CONNECTICUT LIGHT AND  
POWER COMPANY DOING BUSINESS  
AS EVERSOURCE ENERGY

Sincerely,

*Kenneth Roberts*

Kenneth Roberts  
Project Manager  
Frost Bridge to Campville 115-kV Project



December 21, 2015

NOTICE TO  
BRISTOL WATER COMPANY  
THE FROST BRIDGE TO CAMPVILLE 115-kV PROJECT

The Connecticut Light and Power Company doing business as Eversource Energy ("Eversource") is providing notice to the affected water company that would provide water to, or be within the watershed affected by, the proposed facilities of its intent to apply to the Connecticut Siting Council on or about December 23, 2015 for a Certificate of Environmental Compatibility and Public Need for the Frost Bridge to Campville 115-kV Project ("Project").

Eversource is proposing to construct a new 10.4-mile 115-kilovolt (kV) predominately overhead electric transmission line between Eversource's Frost Bridge Substation in Watertown and its Campville Substation in Harwinton, to make related improvements to both substations and to reconfigure a short (0.4-mile) segment of two existing 115-kV transmission lines that are supported on common structures. The Project would be located in portions of four towns: Watertown, Thomaston, Litchfield and Harwinton. The transmission line would be located within Eversource's existing right-of-way.

This notice is provided pursuant to Section VIII of the Connecticut Siting Council's Application Guides for an Electric and Fuel Transmission Line Facility (adopted April 2010).

Details regarding the proposed project are set forth in the enclosed notice.

THE CONNECTICUT LIGHT AND  
POWER COMPANY DOING BUSINESS  
AS EVERSOURCE ENERGY

Sincerely,

*Kenneth Roberts*

Kenneth Roberts  
Project Manager  
Frost Bridge to Campville 115-kV Project



December 21, 2015

NOTICE TO  
The CONNECTICUT WATER COMPANY  
THE FROST BRIDGE TO CAMPVILLE 115-kV PROJECT

The Connecticut Light and Power Company doing business as Eversource Energy ("Eversource") is providing notice to the affected water company that would provide water to, or be within the watershed affected by, the proposed facilities of its intent to apply to the Connecticut Siting Council on or about December 23, 2015 for a Certificate of Environmental Compatibility and Public Need for the Frost Bridge to Campville 115-kV Project ("Project").

Eversource is proposing to construct a new 10.4-mile 115-kilovolt (kV) predominately overhead electric transmission line between Eversource's Frost Bridge Substation in Watertown and its Campville Substation in Harwinton, to make related improvements to both substations and to reconfigure a short (0.4-mile) segment of two existing 115-kV transmission lines that are supported on common structures. The Project would be located in portions of four towns: Watertown, Thomaston, Litchfield and Harwinton. The transmission line would be located within Eversource's existing right-of-way.

This notice is provided pursuant to Section VIII of the Connecticut Siting Council's Application Guides for an Electric and Fuel Transmission Line Facility (adopted April 2010).

Details regarding the proposed project are set forth in the enclosed notice.

THE CONNECTICUT LIGHT AND  
POWER COMPANY DOING BUSINESS  
AS EVERSOURCE ENERGY

Sincerely,

*Kenneth Roberts*

Kenneth Roberts  
Project Manager  
Frost Bridge to Campville 115-kV Project



December 21, 2015

NOTICE TO  
THE TORRINGTON WATER COMPANY  
THE FROST BRIDGE TO CAMPVILLE 115-kV PROJECT

The Connecticut Light and Power Company doing business as Eversource Energy ("Eversource") is providing notice to the affected water company that would provide water to, or be within the watershed affected by, the proposed facilities of its intent to apply to the Connecticut Siting Council on or about December 23, 2015 for a Certificate of Environmental Compatibility and Public Need for the Frost Bridge to Campville 115-kV Project ("Project").

Eversource is proposing to construct a new 10.4-mile 115-kilovolt (kV) predominately overhead electric transmission line between Eversource's Frost Bridge Substation in Watertown and its Campville Substation in Harwinton, to make related improvements to both substations and to reconfigure a short (0.4-mile) segment of two existing 115-kV transmission lines that are supported on common structures. The Project would be located in portions of four towns: Watertown, Thomaston, Litchfield and Harwinton. The transmission line would be located within Eversource's existing right-of-way.

This notice is provided pursuant to Section VIII of the Connecticut Siting Council's Application Guides for an Electric and Fuel Transmission Line Facility (adopted April 2010).

Details regarding the proposed project are set forth in the enclosed notice.

THE CONNECTICUT LIGHT AND  
POWER COMPANY DOING BUSINESS  
AS EVERSOURCE ENERGY

Sincerely,

*Kenneth Roberts*

Kenneth Roberts  
Project Manager  
Frost Bridge to Campville 115-kV Project



December 21, 2015

NOTICE TO  
WATERBURY WATER DEPARTMENT  
THE FROST BRIDGE TO CAMPVILLE 115-kV PROJECT

The Connecticut Light and Power Company doing business as Eversource Energy ("Eversource") is providing notice to the affected water company that would provide water to, or be within the watershed affected by, the proposed facilities of its intent to apply to the Connecticut Siting Council on or about December 23, 2015 for a Certificate of Environmental Compatibility and Public Need for the Frost Bridge to Campville 115-kV Project ("Project").

Eversource is proposing to construct a new 10.4-mile 115-kilovolt (kV) predominately overhead electric transmission line between Eversource's Frost Bridge Substation in Watertown and its Campville Substation in Harwinton, to make related improvements to both substations and to reconfigure a short (0.4-mile) segment of two existing 115-kV transmission lines that are supported on common structures. The Project would be located in portions of four towns: Watertown, Thomaston, Litchfield and Harwinton. The transmission line would be located within Eversource's existing right-of-way.

This notice is provided pursuant to Section VIII of the Connecticut Siting Council's Application Guides for an Electric and Fuel Transmission Line Facility (adopted April 2010).

Details regarding the proposed project are set forth in the enclosed notice.

THE CONNECTICUT LIGHT AND  
POWER COMPANY DOING BUSINESS  
AS EVERSOURCE ENERGY

Sincerely,

*Kenneth Roberts*

Kenneth Roberts  
Project Manager  
Frost Bridge to Campville 115-kV Project



December 21, 2015

NOTICE TO  
WATERTOWN WATER AND SEWER DEPARTMENT  
THE FROST BRIDGE TO CAMPVILLE 115-kV PROJECT

The Connecticut Light and Power Company doing business as Eversource Energy ("Eversource") is providing notice to the affected water company that would provide water to, or be within the watershed affected by, the proposed facilities of its intent to apply to the Connecticut Siting Council on or about December 23, 2015 for a Certificate of Environmental Compatibility and Public Need for the Frost Bridge to Campville 115-kV Project ("Project").

Eversource is proposing to construct a new 10.4-mile 115-kilovolt (kV) predominately overhead electric transmission line between Eversource's Frost Bridge Substation in Watertown and its Campville Substation in Harwinton, to make related improvements to both substations and to reconfigure a short (0.4-mile) segment of two existing 115-kV transmission lines that are supported on common structures. The Project would be located in portions of four towns: Watertown, Thomaston, Litchfield and Harwinton. The transmission line would be located within Eversource's existing right-of-way.

This notice is provided pursuant to Section VIII of the Connecticut Siting Council's Application Guides for an Electric and Fuel Transmission Line Facility (adopted April 2010).

Details regarding the proposed project are set forth in the enclosed notice.

THE CONNECTICUT LIGHT AND  
POWER COMPANY DOING BUSINESS  
AS EVERSOURCE ENERGY

Sincerely,

*Kenneth Roberts*

Kenneth Roberts  
Project Manager  
Frost Bridge to Campville 115-kV Project



December 21, 2015

NOTICE TO  
WATER POLLUTION CONTROL AUTHORITY  
THE FROST BRIDGE TO CAMPVILLE 115-kV PROJECT

The Connecticut Light and Power Company doing business as Eversource Energy ("Eversource") is providing notice to the affected water company that would provide water to, or be within the watershed affected by, the proposed facilities of its intent to apply to the Connecticut Siting Council on or about December 23, 2015 for a Certificate of Environmental Compatibility and Public Need for the Frost Bridge to Campville 115-kV Project ("Project").

Eversource is proposing to construct a new 10.4-mile 115-kilovolt (kV) predominately overhead electric transmission line between Eversource's Frost Bridge Substation in Watertown and its Campville Substation in Harwinton, to make related improvements to both substations and to reconfigure a short (0.4-mile) segment of two existing 115-kV transmission lines that are supported on common structures. The Project would be located in portions of four towns: Watertown, Thomaston, Litchfield and Harwinton. The transmission line would be located within Eversource's existing right-of-way.

This notice is provided pursuant to Section VIII of the Connecticut Siting Council's Application Guides for an Electric and Fuel Transmission Line Facility (adopted April 2010).

Details regarding the proposed project are set forth in the enclosed notice.

THE CONNECTICUT LIGHT AND  
POWER COMPANY DOING BUSINESS  
AS EVERSOURCE ENERGY

Sincerely,

*Kenneth Roberts*

Kenneth Roberts  
Project Manager  
Frost Bridge to Campville 115-kV Project

Frost Bridge to Campville 115-kV Project  
Water Companies

|  |                                   |                                     |                      |
|--|-----------------------------------|-------------------------------------|----------------------|
| Bristol Water Department                 | Robert Longo, Superintendent      | 119 Riverside Ave                   | Bristol, CT 06010    |
| Aquarion Water Company                   | Charles Firlotte, President       | 200 Monroe Turnpike                 | Monroe, CT 06468     |
| The Connecticut Water Company            | Eric W. Thornburg, President      | 93 West Main Street                 | Clinton, CT 06413    |
| Waterbury Water Department               | Chris Bogucki, Superintendent     | 21 East Aurora                      | Waterbury, CT 06708  |
| Watertown Water and Sewer Department     | Vincent Caterino, Superintendent  | 747 French Street                   | Watertown, CT 06795  |
| The Torrington Water Company             | Susan M. Suhanovsky, President    | 277 Norfolk Road, P.O. Box 867      | Torrington, CT 06790 |
| Water Pollution Control Authority (WPCA) | Richard W. Tingle, Superintendent | Town Hall, Level 3, 158 Main Street | Thomaston, CT 06787  |