




WASTE MANAGEMENT
 4 Liberty Lane West
 Hampton, NH 03842

March 11, 2013



Ms. Linda Roberts
 Executive Director
 Connecticut Siting Council
 10 Franklin Square
 New Britain, CT 06051

Re: Waste Management of Connecticut, Inc., New Milford Landfill
 Connecticut Siting Council Annual Report
 Docket No. F-2012/2013

Dear Ms. Roberts,

Pursuant to and to the extent required by the Connecticut General Statute §16-50r, Waste Management of Connecticut, Inc. (WMI) hereby submits the following information requested for the New Milford Landfill:

1. **A tabulation of estimated peak loads, resources and margins for each year.** WMI operates a Class I renewable energy source through the collection of landfill gas and combustion in three (3) reciprocating engines each with a generator rated at 820 kilowatts. The combined output of 2.5 MW was maintained at a relatively high operating efficiency during the past calendar year.

2. **Data on energy use and peak loads for the five preceding calendar years.**

<u>Year</u>	<u>Peak Load (MW)</u>	<u>Energy Produced (kW-hrs)</u>	<u>Energy Used (kW-hrs)</u>	<u>Energy Sold (kW-hrs)</u>
2008	2.5	11,439,711	564,789	10,874,922
2009	2.5	16,739,804	814,868	15,924,936
2010	2.5	15,082,868	672,386	14,410,482
2011	2.5	13,512,221	637,387	12,874,834
2012	2.5	13,017,670	688,779	12,328,891

3. **A list of existing generating facilities in service.** New Milford is the only generating facility in Connecticut.

4. A list of scheduled generating facilities for which a property has been acquired, for which certificates have been issued and for which certificate applications have been filed. None
5. A list of planned generating units at plant locations for which property has been acquired, or at plant locations not yet acquired, that will be needed to provide estimated additional electrical requirements, and the location of such facilities. None
6. A list of planned transmission lines on which proposed route reviews are being undertaken of for which certificate applications have already been filed. None
7. A description of the steps taken to upgrade existing facilities and to eliminate overhead transmission and distribution lines in accordance with the regulation and standards described in section 16-50t. No upgrades are planned for the three LFG engines.
8. For each private power producer having a facility generating more than one megawatt and from whom the person furnishing the report has purchased electricity during the preceding calendar year, a statement including the name, location, size and type of generating facility, the fuel consumed by the facility and the by-product of the consumption. Not applicable.

If you have any questions or need additional information, please contact me at (603) 929-5436.

Sincerely,

WASTE MANAGEMENT OF CONNECTICUT, INC.



Mark P. DeVine
District Manager

Enclosures

cc: Michael Sullivan, WMCT
Albert Wilder, TRC