



September 17, 2015

Melanie Bachman
Acting Executive Director
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051

RE: Docket No. F-2014/2015

Dear Melanie Bachman:

I am writing in response to the 2012 Connecticut General Statutes Title 16 – Public Service Companies Chapter 277a – Public Utility Environmental Standards Act Section 16-50r – Report of forecast of loads and resources for the Town of Wallingford CT Department of Public Utilities.

The attached document includes:

- A tabulation of estimated peak loads
- Data on energy use and peak loads for the five preceding calendar years

Enclosed is one signed original and 15 hard copies of the report.

Sincerely,

Michelle Coscia

ENCLOSURE



9/17/2015

•••

Michelle Coscia
Energy New England
100 Foxborough Blvd. #110
Foxborough, MA 02035

Melanie Bachman
Acting Executive Director
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051

Melanie Bachman,

(1) A tabulation of estimated peak loads for each year 2015-2024

YEAR	2015	2016	2017	2018	2019
Peak MW	133.431	133.498	133.565	133.632	133.698

YEAR	2020	2021	2022	2023	2024
Peak MW	133.765	133.832	133.899	133.966	134.033

(2) Data on energy use and peak loads for the five preceding calendar years 2010-2014

YEAR	2014	2013	2012	2011	2010
Peak MW	123.241	136.954	137.385	134.339	135.238

YEAR	2014	2013	2012	2011	2010
MWH Load	613,600	617,110	617,523	623,777	619,864

Sincerely

Michelle Coscia
Senior Energy Analyst
Energy New England