



WASTE MANAGEMENT

4 Liberty Lane West
Hampton, NH 03842

February 19, 2016

Melanie Bachman
Acting Executive Director
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051

Re: New Milford Landfill, LLC, Waste Management of Connecticut, Inc.
Connecticut Siting Council Annual Report
Docket No. F-2016/2017

Dear Ms. Bachman,

Pursuant to and to the extent required by the Connecticut General Statute §16-50r, Waste Management of Connecticut, Inc. (WMI) hereby submits the following information requested for the New Milford Landfill:

- 1. A tabulation of estimated peak loads, resources and margins for each year.** WMI operates a Class I renewable energy source through the collection of landfill gas and combustion in three (3) reciprocating engines each with a generator rated at 820 kilowatts. The combined output was primarily maintained by two of the three engines due to reduced fuel availability. Engine #3 was off line effective March 1, 2015 and removed from site on February 9, 2016.
- 2. Data on energy use and peak loads for the five preceding calendar years.**

<u>Year</u>	<u>Peak Load (MW)</u>	<u>Energy Produced (kW-hrs)</u>	<u>Energy Used (kW-hrs)</u>	<u>Energy Sold (kW-hrs)</u>
2011	2.5	13,512,221	637,387	12,874,834
2012	2.5	13,017,670	688,779	12,328,891
2013	2.5	12,197,542	731,307	11,466,235
2014	2.5	11,304,580	767,793	10,536,787
2015	2.5	9,846,468	745,596	9,100,872

- 3. A list of existing generating facilities in service.** New Milford is the only generating facility in Connecticut.

Ms. Melanie Bachman

February 19, 2016

Page 2

4. **A list of scheduled generating facilities for which a property has been acquired, for which certificates have been issued and for which certificate applications have been filed.** None
5. **A list of planned generating units at plant locations for which property has been acquired, or at plant locations not yet acquired, that will be needed to provide estimated additional electrical requirements, and the location of such facilities.** None
6. **A list of planned transmission lines on which proposed route reviews are being undertaken of for which certificate applications have already been filed.** None
7. **A description of the steps taken to upgrade existing facilities and to eliminate overhead transmission and distribution lines in accordance with the regulation and standards described in section 16-50t.** No upgrades are planned for the three LFG engines.
8. **For each private power producer having a facility generating more than one megawatt and from whom the person furnishing the report has purchased electricity during the preceding calendar year, a statement including the name, location, size and type of generating facility, the fuel consumed by the facility and the by-product of the consumption.** Not applicable.

If you have any questions or need additional information, please contact me at (603) 929-5436.

Sincerely,

WASTE MANAGEMENT OF CONNECTICUT, INC.



Mark P. DeVine
District Manager

Enclosures (15 Copies of Annual Report Letter)

cc: Albert Wilder, TRC
Robert Fisher, WMCT