



February 18, 2020

Melanie Bachman
Acting Executive Director
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051

RE: Docket No. F-2014/2015

Dear Melanie Bachman:

I am writing in response to the 2012 Connecticut General Statutes Title 16 – Public Service Companies Chapter 277a – Public Utility Environmental Standards Act Section 16-50r – Report of forecast of loads and resources for the Town of Wallingford CT Department of Public Utilities.

The attached document includes:

- A tabulation of estimated peak loads
- Data on energy use and peak loads for the five preceding calendar years

Enclosed is one signed original and 15 hard copies of the report.

Sincerely,

Michelle Coscia

ENCLOSURE



2/18/2020



Michelle Coscia
Energy New England
5 Hampshire Street. #100
Mansfield MA 02048

Melanie Bachman
Acting Executive Director
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051

Melanie Bachman,

(1) A tabulation of estimated peak loads for each year 2020-2029

YEAR	2020	2021	2022	2023	2024
Peak MW	127.885	128.780	129.682	130.590	131.504

YEAR	2025	2026	2027	2028	2029
Peak MW	132.424	133.351	134.285	135.225	136.171

(2) Data on energy use and peak loads for the five preceding calendar years 2015-2019

YEAR	2019	2018	2017	2016	2015
Peak MW	126.335	129.912	126.632	130.687	125.860

YEAR	2019	2018	2017	2016	2015
MWH Load	583,621	615,485	596,391	611,919	617,641

Sincerely

Michelle Coscia

Michelle Coscia
Senior Energy Analyst
Energy New England