



56 Prospect Street,  
P.O. Box 270  
Hartford, CT 06103

Kathleen M. Shanley  
Manager – Transmission Siting  
Tel: (860) 728-4527

September 9, 2020

Melanie A. Bachman  
Executive Director  
Connecticut Siting Council  
10 Franklin Square  
New Britain, CT 06051

**RE: Notice of Exempt Modification  
Eversource Site # 943  
22 East High Street, East Hampton, CT 06424  
Latitude: 41-34-54.3 N / Longitude: 72-30-10.3 W**

Dear Ms. Bachman:

The Connecticut Light and Power Company doing business as Eversource Energy (“Eversource”) currently maintains three (3) antennas and one (1) microwave dish at various mounting heights on an existing 120-foot self-support tower located at 22 East High Street in East Hampton. See [Attachment A](#), Parcel Map and Property Card. The tower and property are owned by Eversource. Eversource plans to install one 18-foot 7-inch tall omni-directional antenna, to be mounted at approximately 117 feet above ground level (“AGL”), and two 7/8-inch diameter coaxial cables. There will be no changes to the area of the fenced compound, the tower or the antennas and equipment currently mounted on the tower. The tower and existing and proposed equipment on the tower are depicted on [Attachment B](#), Construction Drawings, dated June 17, 2020 and [Attachment C](#), Structural Analysis, dated June 15, 2020. The Connecticut Siting Council approved the tower at this location in Petition No. 1252 in November 2016.

The proposed installation is part of Eversource’s program to update the current obsolete analog voice radio communications system to a modern digital voice communications system. The new system will enable the highest level of voice communications under all operating conditions, including during critical emergency and storm restoration activities. The new radio system will also provide for remote control of distribution safety equipment.


Please accept this letter as notification pursuant to Regulations of Connecticut State Agencies (“R.C.S.A.”) §16-50j-73, for construction that constitutes an exempt modification pursuant to R.C.S.A § 16-50j-72(b)(2). In accordance with R.C.S.A. § 16-50j-73, a copy of this notice is being delivered to Pete Brown, Town Council Chairman for the Town of East Hampton, David Cox, Town Manager for the Town of East Hampton and Jeremy DeCarli, AICP, Planning and Zoning Official for the Town of East Hampton via private carrier. Proof of delivery is attached. See [Attachment D](#), Proof of Delivery of Notice.

The planned modifications to the facility fall squarely within those activities explicitly provided for in R.C.S.A. § 16-50j-72(b)(2):

1. There will be no change to the height of the existing tower.
2. The proposed modifications will not require the extension of the site boundary.
3. The proposed modification will not increase noise levels at the facility by six decibels or more, or to levels that exceed state and local criteria.
4. The operation of the new antennas will not increase radio frequency emissions at the facility to a level at or above the Federal Communications Commission safety standard as shown in the attached Radio Frequency Emissions Report, dated June 22, 2020 (Attachment E – Power Density Report)<sup>1</sup>.
5. The proposed modifications will not cause a change or alteration in the physical or environmental characteristics of the site.
6. The existing structure and its foundation can support the proposed loading.

For the foregoing reasons, Eversource respectfully submits that the proposed modifications to the above referenced telecommunications facility constitute an exempt modification under R.C.S.A. § 16-50j-72(b)(2). One original copy of this notice has been provided via courier to the Council.

Communications regarding this Notice of Exempt Modification should be directed to Kathleen Shanley at (860) 728-4527.

By:   
Kathleen M. Shanley  
Manager – Transmission Siting

cc: Pete Brown, Town Council Chairman, Town of East Hampton  
David Cox, Town Manager, Town of East Hampton  
Jeremy DeCarli, AICP, Planning and Zoning Official, Town of East Hampton

#### Attachments

- A. Parcel Map and Property Card
- B. Construction Drawings
- C. Structural Analysis
- D. Proof of Delivery of Notice
- E. Power Density Report


---

<sup>1</sup> Any inactive or receive-only antennas are not included in the MPE calculations as they are irrelevant in terms of the total MPE percentage.

ATTACHMENT A – PARCEL MAP AND PROPERTY CARD

# Legend

○ Approximate Tower Location



## 22 EAST HIGH ST

**Location** 22 EAST HIGH ST

**Mblu** 05A/ 62/ 5/ /

**Acct#** R00994

**Owner** CONNECTICUT LIGHT AND  
POWER CO

**Assessment** \$2,376,620

**Appraisal** \$3,395,180

**PID** 943

**Building Count** 2

### Current Value

Appraisal			
Valuation Year	Improvements	Land	Total
2019	\$2,223,290	\$1,171,890	\$3,395,180

Assessment			
Valuation Year	Improvements	Land	Total
2019	\$1,556,300	\$820,320	\$2,376,620

### Owner of Record

**Owner** CONNECTICUT LIGHT AND POWER CO

**Sale Price** \$0

**Co-Owner**

**Certificate**

**Address** 22 EAST HIGH ST

**Book & Page** 110/ 444

EAST HAMPTON, CT 06424

**Sale Date** 01/01/1900

**Instrument** 29

### Ownership History

Ownership History					
Owner	Sale Price	Certificate	Book & Page	Instrument	Sale Date
CONNECTICUT LIGHT AND POWER CO	\$0		110/ 444	29	01/01/1900

### Building Information

#### Building 1 : Section 1

**Year Built:** 1973  
**Living Area:** 15,664  
**Replacement Cost:** \$2,067,787  
**Building Percent Good:** 86  
**Replacement Cost  
Less Depreciation:** \$1,778,300

### Building Attributes


No Data for Building Attributes

### Building Photo



(<http://images.vgsi.com/photos/EastHamptonCTPhotos//00\00\08\39.JPG>)

### Building Layout



([http://images.vgsi.com/photos/EastHamptonCTPhotos//Sketches/943\\_943](http://images.vgsi.com/photos/EastHamptonCTPhotos//Sketches/943_943))

Building Sub-Areas (sq ft)			Legend
Code	Description	Gross Area	Living Area
AOF	Office Area	15,664	15,664
CAN	Canopy	11,596	0
		27,260	15,664

### Building 2 : Section 1

**Year Built:** 1974  
**Living Area:** 4,550  
**Replacement Cost:** \$366,036  
**Building Percent Good:** 86  
**Replacement Cost Less Depreciation:** \$314,790

### Building Attributes : Bldg 2 of 2


No Data for Building Attributes

## Building Photo



(<http://images.vgsi.com/photos/EastHamptonCTPhotos//00\00\69\02.jpg>)

## Building Layout



([http://images.vgsi.com/photos/EastHamptonCTPhotos//Sketches/943\\_20C](http://images.vgsi.com/photos/EastHamptonCTPhotos//Sketches/943_20C))

Building Sub-Areas (sq ft)			<u>Legend</u>
Code	Description	Gross Area	Living Area
BAS	First Floor	4,550	4,550
		4,550	4,550

## Extra Features

Extra Features	<u>Legend</u>
No Data for Extra Features	

## Land

### Land Use

Use Code	201
Description	Commercial Improv
Zone	R-2S

### Land Line Valuation

Size (Acres)	10.53
Frontage	
Depth	

Neighborhood CTR  
 Alt Land Appr No  
 Category

Assessed Value \$820,320  
 Appraised Value \$1,171,890

**Outbuildings**

Outbuildings						Legend
Code	Description	Sub Code	Sub Description	Size	Value	Bldg #
PAV1	Paving Asph.			123000 S.F.	\$98,400	1
SHD1	Shed	FR	Frame	1280 S.F.	\$19,200	1
FN6	6' Fence chain link			1400 L.F.	\$12,600	1

**Valuation History**

Appraisal			
Valuation Year	Improvements	Land	Total
2019	\$2,223,290	\$1,171,890	\$3,395,180
2018	\$2,223,290	\$1,171,890	\$3,395,180
2016	\$2,223,290	\$1,171,890	\$3,395,180

Assessment			
Valuation Year	Improvements	Land	Total
2019	\$1,556,300	\$820,320	\$2,376,620
2018	\$1,556,300	\$820,320	\$2,376,620
2016	\$1,556,300	\$820,320	\$2,376,620

ATTACHMENT B – CONSTRUCTION DRAWINGS



# EAST HAMPTON AWC 22 EAST HIGH STREET EAST HAMPTON, CT 06424

**EVERSOURCE**  
ENERGY

107 SELDEN STREET  
BERLIN, CT 06037  
PHONE: (800) 286-2000



**BLACK & VEATCH**

6800 W 115TH ST, SUITE 2292  
OVERLAND PARK, KS 66211  
PHONE: (913) 458-3595

### PROJECT SUMMARY

THE GENERAL SCOPE OF WORK CONSISTS OF THE FOLLOWING:

1. INSTALL (1) NEW OMNI/WHIP ANTENNA AT ELEVATION 135'-8 3/16"± AGL
2. INSTALL (1) NEW RACK WITH DMR EQUIPMENT IN EXISTING BUILDING

### GOVERNING CODES

2018 CONNECTICUT STATE BUILDING CODE (2015 IBC BASIS)  
2017 NATIONAL ELECTRIC CODE  
TIA-222-H

### GENERAL NOTES

THE FACILITY IS UNMANNED AND NOT FOR HUMAN HABITATION. A TECHNICIAN WILL VISIT THE SITE AS REQUIRED FOR ROUTINE MAINTENANCE. THE PROJECT WILL NOT RESULT IN ANY SIGNIFICANT DISTURBANCE OR EFFECT ON DRAINAGE; NO SANITARY SEWER SERVICE, POTABLE WATER, OR TRASH DISPOSAL IS REQUIRED AND NO COMMERCIAL SIGNAGE IS PROPOSED.


### SITE INFORMATION

SITE NAME: EAST HAMPTON AWC  
SITE ID NUMBER: 943  
SITE ADDRESS: 22 EAST HIGH STREET  
EAST HAMPTON, CT 06424  
MAP: 05A  
BLOCK: 62  
LOT: 5  
ZONE: R-2S  
LATITUDE: 41° 34' 54.3" N  
LONGITUDE: 72° 30' 10.3" W  
ELEVATION: 486'± AMSL  
FEMA/FIRM DESIGNATION: X  
ACREAGE: 10.53± AC (BOOK: 110, PAGE: 444)

### CONTACT INFORMATION

**APPLICANTS:**  
EVERSOURCE ENERGY  
107 SELDEN STREET  
BERLIN, CT 06037  
**POWER PROVIDER:**  
EVERSOURCE ENERGY  
(800) 286-2000  
**PROPERTY OWNER:**  
EVERSOURCE ENERGY  
107 SELDEN STREET  
BERLIN, CT 06037  
**TELCO PROVIDER:**  
FRONTIER  
(800) 921-8102  
**EVERSOURCE ENERGY**  
**PROJECT MANAGER:**  
NIKOLL PRECI  
(860) 655-3079  
**CALL BEFORE YOU DIG:**  
(800) 922-4455

### LOCATION MAP



### DESIGN TYPE

SITE UPGRADE  
SELF-SUPPORT TOWER

### DRAWING INDEX

SHEET NO:	SHEET TITLE
T-1	TITLE SHEET
C-1	SITE PLAN
C-2	TOWER ELEVATION
G-1	GROUNDING DETAILS
N-1	NOTES & SPECIFICATIONS
N-2	NOTES & SPECIFICATIONS
N-3	NOTES & SPECIFICATIONS

### DO NOT SCALE DRAWINGS

SUBCONTRACTOR SHALL VERIFY ALL PLANS & EXISTING DIMENSIONS & CONDITIONS ON THE JOB SITE & SHALL IMMEDIATELY NOTIFY THE ENGINEER IN WRITING OF ANY DISCREPANCIES BEFORE PROCEEDING WITH THE WORK OR BE RESPONSIBLE FOR SAME




**UNDERGROUND  
SERVICE ALERT**  
**UTILITIES PROTECTION CENTER, INC.**  
811

48 HOURS BEFORE YOU DIG

PROJECT NO: 405025  
DRAWN BY: TYW  
CHECKED BY: TH

REV	DATE	DESCRIPTION
0	06/17/20	ISSUED FOR FILING



EAST HAMPTON AWC  
22 EAST HIGH STREET  
EAST HAMPTON, CT 06424

SHEET TITLE  
TITLE SHEET

SHEET NUMBER  
**T-1**

**EVERSOURCE**  
ENERGY

107 SELDEN STREET  
BERLIN, CT 06037  
PHONE: (800) 286-2000



**BLACK & VEATCH**

6800 W 115TH ST, SUITE 2292  
OVERLAND PARK, KS 66211  
PHONE: (913) 458-3595

PROJECT NO: 405025  
DRAWN BY: TYW  
CHECKED BY: TH

REV	DATE	DESCRIPTION
0	06/17/20	ISSUED FOR FILING




IT IS A VIOLATION OF LAW FOR ANY PERSON,  
UNLESS THEY ARE ACTING UNDER THE DIRECTION  
OF A LICENSED PROFESSIONAL ENGINEER,  
TO ALTER THIS DOCUMENT.

EAST HAMPTON AWC  
22 EAST HIGH STREET  
EAST HAMPTON, CT 06424

SHEET TITLE  
SITE PLAN

SHEET NUMBER  
**C-1**



**SITE PLAN**  
NO SCALE







PROJECT NO:	405025
DRAWN BY:	TYW
CHECKED BY:	TH

REV	DATE	DESCRIPTION
0	06/17/20	ISSUED FOR FILING




IT IS A VIOLATION OF LAW FOR ANY PERSON, UNLESS THEY ARE ACTING UNDER THE DIRECTION OF A LICENSED PROFESSIONAL ENGINEER, TO ALTER THIS DOCUMENT.

EAST HAMPTON AWC  
22 EAST HIGH STREET  
EAST HAMPTON, CT 06424

SHEET TITLE  
**GROUNDING  
DETAILS**

SHEET NUMBER

**G-1**




**NOTE**

1. NUMBER OF GROUND BARS MAY VARY DEPENDING ON THE TYPE OF TOWER, ANTENNA LOCATION AND CONNECTION ORIENTATION. PROVIDE AS REQUIRED.

**ANTENNA CABLE GROUNDING**

NO SCALE




**NOTES**

1. DO NOT INSTALL CABLE GROUND KIT AT A BEND AND ALWAYS DIRECT GROUND WIRE DOWN TO GROUND BAR.
2. GROUNDING KIT SHALL BE TYPE AND PART NUMBER AS SUPPLIED OR RECOMMENDED BY CABLE MANUFACTURER.
3. WEATHER PROOFING SHALL BE TYPE AND PART NUMBER AS SUPPLIED OR RECOMMENDED BY CABLE MANUFACTURER.


**CONNECTION OF CABLE GROUND KIT TO ANTENNA CABLE**

NO SCALE



**CABLE INSTALLATION WITH WALL FEED THRU ASSEMBLY**

NO SCALE



**NOTE**

1. PROVIDE GROUND KIT 6" BEFORE TURN

**ICE BRIDGE AND ANTENNA CABLE DETAIL**

NO SCALE





**SYMBOLS**

●	EXOTHERMIC CONNECTION
■	COMPRESSION CONNECTION
⊕	5/8"Øx10'-0" COPPER CLAD STEEL GROUND ROD.
⊕	TEST GROUND ROD WITH INSPECTION SLEEVE
---	GROUNDING CONDUCTOR
(A)	KEY NOTES
— X — X — X — X — X — X —	CHAINLINK FENCE
— □ — □ — □ — □ — □ — □ —	WOOD FENCE
---	LEASE AREA
▒	ICE BRIDGE
▒	CABLE TRAY
— G — G — G — G — G —	GAS LINE
— E/T — E/T — E/T — E/T —	UNDERGROUND ELECTRICAL/TELCO
— E/C — E/C — E/C — E/C —	UNDERGROUND ELECTRICAL/CONTROL
— E — E — E — E — E —	UNDERGROUND ELECTRICAL
— T — T — T — T — T —	UNDERGROUND TELCO
---	PROPERTY LINE (PL)

**ABBREVIATIONS**

AC	ALTERNATING CURRENT	MGB	MASTER GROUNDING BAR
AIC	AMPERAGE INTERRUPTION CAPACITY	MIN	MINIMUM
ANI	AUXILIARY NETWORK INTERFACE	MW	MICROWAVE
ATM	ASYNCHRONOUS TRANSFER MODE	MTS	MANUAL TRANSFER SWITCH
ATS	AUTOMATIC TRANSFER SWITCH	NEC	NATIONAL ELECTRICAL CODE
AWG	AMERICAN WIRE GAUGE	OC	ON CENTER
AWS	ADVANCED WIRELESS SERVICES	PP	POLARIZING PRESERVING
BATT	BATTERY	PCU	PRIMARY CONTROL UNIT
BBU	BASEBAND UNIT	PDU	PROTOCOL DATA UNIT
BTC	BARE TINNED COPPER CONDUCTOR	PWR	POWER
BTS	BASE TRANSCEIVER STATION	RECT	RECTIFIER
CCU	CLIMATE CONTROL UNIT	RET	REMOTE ELECTRICAL TILT
CDMA	CODE DIVISION MULTIPLE ACCESS	RMC	RIGID METALLIC CONDUIT
CHG	CHARGING	RF	RADIO FREQUENCY
CLU	CLIMATE UNIT	RUC	RACK USER COMMISSIONING
COMM	COMMON	RRH	REMOTE RADIO HEAD
DC	DIRECT CURRENT	RRU	REMOTE RADIO UNIT
DIA	DIAMETER	RWY	RACEWAY
DWG	DRAWING	SFP	SMALL FORM-FACTOR PLUGGABLE
EC	ELECTRICAL CONDUCTOR	SIAD	SMART INTEGRATED ACCESS DEVICE
EMT	ELECTRICAL METALLIC TUBING	SSC	SITE SOLUTIONS CABINET
FIF	FACILITY INTERFACE FRAME	T1	1544KBPS DIGITAL LINE
GEN	GENERATOR	TDMA	TIME-DIVISION MULTIPLE ACCESS
GPS	GLOBAL POSITIONING SYSTEM	TMA	TOWER MOUNT AMPLIFIER
GSM	GLOBAL SYSTEM FOR MOBILE	TVSS	TRANSIENT VOLTAGE SUPPRESSION SYSTEM
HVAC	HEAT/VENTILATION/AIR CONDITIONING	TYP	TYPICAL
ICF	INTERCONNECTION FRAME	UMTS	UNIVERSAL MOBILE TELECOMMUNICATION SYSTEM
IGR	INTERIOR GROUNDING RING (HALO)	UPS	UNINTERRUPTIBLE POWER SUPPLY (DC POWER PLANT)
LTE	LONG TERM EVOLUTION		

**EVERSOURCE ENERGY**

107 SELDEN STREET  
BERLIN, CT 06037  
PHONE: (800) 286-2000



**BLACK & VEATCH**

6800 W 115TH ST, SUITE 2292  
OVERLAND PARK, KS 66211  
PHONE: (913) 458-3595

PROJECT NO:	405025
DRAWN BY:	TYW
CHECKED BY:	TH

REV	DATE	DESCRIPTION
0	06/17/20	ISSUED FOR FILING



IT IS A VIOLATION OF LAW FOR ANY PERSON, UNLESS THEY ARE ACTING UNDER THE DIRECTION OF A LICENSED PROFESSIONAL ENGINEER, TO ALTER THIS DOCUMENT.

EAST HAMPTON AWC  
22 EAST HIGH STREET  
EAST HAMPTON, CT 06424

SHEET TITLE  
**NOTES & SPECIFICATIONS**

SHEET NUMBER  
**N-3**

ATTACHMENT C – STRUCTURAL ANALYSIS REPORT

Date: **June 15, 2020**



Black & Veatch Corp.  
6800 W. 115th St., Suite 2292  
Overland Park, KS 66211  
(913) 458-2522

**Subject:** **Structural Analysis Report**

**Eversource Designation:** **Site Number:** ES-154  
**Site Name:** EHamptonAWC

**Engineering Firm Designation:** **Black & Veatch Corp. Project Number:** 405025

**Site Data:** **22 East High Street, East Hampton, Middlesex County, CT**  
**Latitude 41° 34' 54.3", Longitude -72° 30' 10.3"**  
**120 Foot - Self Support Tower**

Black & Veatch Corp. is pleased to submit this “**Structural Analysis Report**” to determine the structural integrity of the above mentioned tower.

The purpose of the analysis is to determine acceptability of the tower stress level. Based on our analysis we have determined the tower stress level for the structure and foundation, under the following load case, to be:


LC1: Proposed Equipment Configuration **Sufficient Capacity – 43.0%**

This analysis utilizes an ultimate 3-second gust wind speed of 140 mph as required by the 2018 Connecticut State Building Code. Applicable Standard references and design criteria are listed in Section 2 - Analysis Criteria.

Structural analysis prepared by: Changzhi Zang / Christopher Giannotti

Respectfully submitted by:

Joshua J. Riley, P.E.  
Professional Engineer



## TABLE OF CONTENTS

### 1) INTRODUCTION

### 2) ANALYSIS CRITERIA

Table 1 - Proposed Equipment Configuration

Table 2 - Other Considered Equipment

### 3) ANALYSIS PROCEDURE

Table 3 - Documents Provided

3.1) Analysis Method

3.2) Assumptions

### 4) ANALYSIS RESULTS

Table 4 - Section Capacity (Summary)

Table 5 – Tower Component Stresses vs. Capacity

4.1) Recommendations

### 5) APPENDIX A

tnxTower Output

### 6) APPENDIX B

Base Level Drawing

### 7) APPENDIX C

Additional Calculations

### 1) INTRODUCTION

This tower is a 120 ft Self Support tower designed by Sabre in June of 2016.

### 2) ANALYSIS CRITERIA

<b>TIA-222 Revision:</b>	TIA-222-H
<b>Risk Category:</b>	III
<b>Wind Speed:</b>	140 mph
<b>Exposure Category:</b>	C
<b>Topographic Factor:</b>	1
<b>Ice Thickness:</b>	1.5 in
<b>Wind Speed with Ice:</b>	50 mph
<b>Seismic S<sub>s</sub>:</b>	0.178
<b>Seismic S<sub>1</sub>:</b>	0.062
<b>Service Wind Speed:</b>	60 mph

**Table 1 - Proposed Equipment Configuration**

Mounting Level (ft)	Center Line Elevation (ft)	Number of Antennas	Antenna Manufacturer	Antenna Model	Number of Feed Lines	Feed Line Size (in)	Note
117.5	127.0	1	db spectra	DS2C03F36D-D	2	7/8	-
	117.5	1	site pro 1	R5-LL [PM 602-1]			

**Table 2 - Other Considered Equipment**

Mounting Level (ft)	Center Line Elevation (ft)	Number of Antennas	Antenna Manufacturer	Antenna Model	Number of Feed Lines	Feed Line Size (in)	Note
120.0	127.0	1	kreco	CO-36AN	1	7/8	1
	120.0	1	tower mounts	Side Arm Mount [SO 602-1]			
117.0	117.0	1	rfs	PADX6-59A	1	EW63	1
		1	tower mounts	Pipe Mount [PM 601-1]			
96.0	103.0	1	kreco	CO-41AN	1	7/8	1
	96.0	1	tower mounts	Side Arm Mount [SO 602-1]			
80.0	87.0	1	kreco	CO-41AN	1	7/8	1
	80.0	1	tower mounts	Side Arm Mount [SO 602-1]			

Notes:

- 1) Existing Equipment

### 3) ANALYSIS PROCEDURE

**Table 3 - Documents Provided**

Document	Remarks	Reference	Source
GEOTECHNICAL REPORTS	Dr. Clarence Welti, P.E., P.C., dated 12/31/2015	-	Eversource
TOWER FOUNDATION DRAWINGS/DESIGN/SPECS	Sabre, dated 06/22/2016	-	Eversource
TOWER MANUFACTURER DRAWINGS	Sabre, dated 06/22/2016	-	Eversource

### 3.1) Analysis Method

tnxTower (version 8.0.5.0), a commercially available analysis software package, was used to create a three-dimensional model of the tower and calculate member stresses for various loading cases. Selected output from the analysis is included in Appendix A.

### 3.2) Assumptions

- 1) Tower and structures were built and maintained in accordance with the manufacturer's specifications.
- 2) The configuration of antennas, transmission cables, mounts and other appurtenances are as specified in Tables 1 and 2 and the referenced drawings.
- 3) This analysis was performed under the assumption that all information provided to Black & Veatch is current and correct. This is to include site data, appurtenance loading, tower/foundation details, and geotechnical data.
- 4) Tower loading is based on 2018 drone mapping photos and previous tower analyses.
- 5) The existing base plate grout was considered in this analysis. Grout must be maintained and inspected periodically and must be replaced if damaged or cracked.

This analysis may be affected if any assumptions are not valid or have been made in error. Black & Veatch Corp. should be notified to determine the effect on the structural integrity of the tower.

## 4) ANALYSIS RESULTS

**Table 4 - Section Capacity (Summary)**

Section No.	Elevation (ft)	Component Type	Size	Critical Element	P (K)	SF*P_allow (K)	% Capacity	Pass / Fail	
T1	120 - 100	Leg	SABRE 3.5000"x0.2160"	3	-11.48	86.78	13.2	Pass	
T2	100 - 80	Leg	SABRE 3.5000"x0.2160"	33	-27.62	86.63	31.9	Pass	
T3	80 - 60	Leg	Sabre 4"x0.318"	60	-45.54	132.02	34.5	Pass	
T4	60 - 40	Leg	SABRE 5.5625"x0.2580"	81	-65.30	177.82	36.7	Pass	
T5	40 - 20	Leg	SABRE 5.5625"x0.3750"	102	-86.15	251.33	34.3	Pass	
T6	20 - 0	Leg	SABRE 5.5625"x0.5000"	123	-105.47	271.06	38.9	Pass	
T1	120 - 100	Diagonal	L2x2x1/8	11	-1.57	9.85	16.0 25.5 (b)	Pass	
T2	100 - 80	Diagonal	L2x2x1/8	38	-2.50	6.80	36.9 40.9 (b)	Pass	
T3	80 - 60	Diagonal	L2 1/2x2 1/2x3/16	65	-3.63	12.30	29.5 31.9 (b)	Pass	
T4	60 - 40	Diagonal	L3x3x3/16	86	-4.25	16.89	25.2 34.5 (b)	Pass	
T5	40 - 20	Diagonal	L3x3x3/16	107	-4.84	13.22	36.6 40.9 (b)	Pass	
T6	20 - 0	Diagonal	L3 1/2x3x1/4 (SLV)	129	-5.75	14.41	39.9	Pass	
T1	120 - 100	Top Girt	L2x2x1/8	5	-0.10	8.32	1.2 1.7 (b)	Pass	
							Summary		
							Leg (T6)	38.9	Pass
							Diagonal (T5)	40.9	Pass
							Top Girt (T1)	1.7	Pass
							Bolt Checks	40.9	Pass
							RATING =	40.9	Pass

**Table 5 - Tower Component Stresses vs. Capacity - LC1**

Notes	Component	Elevation (ft)	% Capacity	Pass / Fail
1	Anchor Rods	0	29.1	Pass
1	Base Foundation	0	30.0	Pass
	Base Foundation Soil Interaction		43.0	Pass

<b>Structure Rating (max from all components) =</b>	<b>43.0%</b>
---	--------------

Notes:

- 1) See additional documentation in "Appendix C - Additional Calculations" for calculations supporting the % capacity consumed. Ratings per TIA-222-H Section 15.5

**4.1) Recommendations**

The tower and its foundation have sufficient capacity to carry the proposed load configuration. No modifications are required at this time.

**APPENDIX A**  
**TNXTOWER OUTPUT**

### Maximum Tower Deflections - Service Wind

<i>Section No.</i>	<i>Elevation ft</i>	<i>Horz. Deflection in</i>	<i>Gov. Load Comb.</i>	<i>Tilt °</i>	<i>Twist °</i>	<i>Check*</i>
T1	120 - 100	0.931	39	0.0653	0.0131	OK
T2	100 - 80	0.655	39	0.0607	0.016	OK
T3	80 - 60	0.414	39	0.0464	0.0104	OK
T4	60 - 40	0.234	39	0.0338	0.007	OK
T5	40 - 20	0.108	39	0.0202	0.0043	OK
T6	20 - 0	0.031	39	0.0093	0.0016	OK

\*Limit State Deformation (TIA-222-H Section 2.8.2)

1) Maximum Rotation = 4 Degrees

2) Maximum Deflection = 0.03 \* Tower Height = 43 in.

### Critical Deflections of Tower at the MW Dish Elevations - Service Wind

<i>Elevation (ft)</i>	<i>MW Dish</i>	<i>Tilt (°)</i>	<i>Twist (°)</i>	<i>Diameter, D (ft)</i>	<i>Frequency, <math>\alpha</math> (GHz)</i>	<i>Decibel Points</i>	<i>Deformation Limit (<math>\theta</math>)*</i>	<i>Deformation Limit Exceeded?</i>
117	PADX6-59A	0.065	0.0139	6	6	10 dB	1.475	Not Exceeded

\*Limit per TIA-222-H Annex D

### Maximum Tower Deflections - Design Wind

<i>Section No.</i>	<i>Elevation ft</i>	<i>Horz. Deflection in</i>	<i>Gov. Load Comb.</i>	<i>Tilt °</i>	<i>Twist °</i>	<i>Combined Max</i>	<i>Check*</i>
T1	120 - 100	2.94	39	0.2051	0.0425	0.209	OK
T2	100 - 80	2.074	39	0.1902	0.0519	0.197	OK
T3	80 - 60	1.315	39	0.1464	0.0336	0.150	OK
T4	60 - 40	0.744	39	0.1066	0.0227	0.109	OK
T5	40 - 20	0.345	39	0.0639	0.0139	0.065	OK
T6	20 - 0	0.098	39	0.0295	0.0052	0.030	OK

\*Up to 0.5 degree is considered acceptable per SUB090 Section 7

### Critical Deflections of Tower at the MW Dish Elevations - Design Wind

<i>Elevation ft</i>	<i>Appurtenance</i>	<i>Gov. Load Comb.</i>	<i>Deflection in</i>	<i>Tilt °</i>	<i>Twist °</i>	<i>Radius of Curvature ft</i>
117	PADX6-59A	39	2.808	0.2041	0.045	175302.000

**DESIGNED APPURTENANCE LOADING**

TYPE	ELEVATION	TYPE	ELEVATION
CO-36AN	120	14' x 2" horizontal mount pipe	96
6' x 3" Mount Pipe	120	6' x 3" Mount Pipe	96
Side Arm Mount [SO 602-1]	120	CO-41AN	96
14' x 2" horizontal mount pipe	120	Side Arm Mount [SO 602-1]	96
DS2C03F36D-D	117.5	14' x 2" horizontal mount pipe	80
R5-LL [PM 602-1]	117.5	CO-41AN	80
Pipe Mount [PM 601-1]	117	6' x 3" Mount Pipe	80
PADX6-59A	117	Side Arm Mount [SO 602-1]	80


**MATERIAL STRENGTH**

GRADE	Fy	Fu	GRADE	Fy	Fu
A572-50	50 ksi	65 ksi	A36	36 ksi	58 ksi

**TOWER DESIGN NOTES**

1. Tower is located in Middlesex County, Connecticut.
2. Tower designed for Exposure C to the TIA-222 Standard.
3. Tower designed for a 140 mph basic wind in accordance with the TIA-222-H Standard.
4. Tower is also designed for a 50 mph basic wind with 1.50 in ice. Ice is considered to increase in thickness with height.
5. Deflections are based upon a 60 mph wind.
6. Tower Risk Category III.
7. Topographic Category 1 with Crest Height of 0.00 ft
8. TOWER RATING: 40.9%

Section	T1	T2	T3	T4	T5	T6	T7	T8	T9	T10	T11	T12	T13	T14	T15	T16	T17
Legs	SABRE 3.5000"x0.2160"																
Leg Grade	A572-50																
Diagonals	L2x2x1/8																
Diagonal Grade	A36																
Top Girts	L2x2x1/8																
Face Width (ft)	5	7	9	11	13	15	17	19	21	23	25	27	29	31	33	35	37
# Panels @ (ft)	4 @ 4.97917																
Weight (K)	0.8	0.9	1.5	1.9	2.4	3.0	3.6	4.2	4.8	5.4	6.0	6.6	7.2	7.8	8.4	9.0	9.6





ALL REACTIONS  
ARE FACTORED

MAX. CORNER REACTIONS AT BASE:

DOWN: 111 K  
SHEAR: 14 K

UPLIFT: -92 K  
SHEAR: 12 K



<b>BLACK &amp; VEATCH</b> Building a world of difference.	<b>Black &amp; Veatch Corp.</b> 6800 W. 115th St., Suite 2292 Overland Park, KS 66211 Phone: FAX:		Job: <b>ES-154 EHamptonAWC</b> Project: <b>405025 (EHamptonAWC)</b>
	Client: Eversource Code: TIA-222-H Path:	Drawn by: TH Date: 06/15/20 Scale: NTS Dwg No. E-1	

## Tower Input Data


The main tower is a 3x free standing tower with an overall height of 120.00 ft above the ground line.  
 The base of the tower is set at an elevation of 0.00 ft above the ground line.  
 The face width of the tower is 5.00 ft at the top and 17.00 ft at the base.  
 This tower is designed using the TIA-222-H standard.

The following design criteria apply:

- 1) Tower is located in Middlesex County, Connecticut.
- 2) Tower base elevation above sea level: 488.00 ft.
- 3) Basic wind speed of 140 mph.
- 4) Risk Category III.
- 5) Exposure Category C.
- 6) Simplified Topographic Factor Procedure for wind speed-up calculations is used.
- 7) Topographic Category: 1.
- 8) Crest Height: 0.00 ft.
- 9) Nominal ice thickness of 1.5000 in.
- 10) Ice thickness is considered to increase with height.
- 11) Ice density of 56 pcf.
- 12) A wind speed of 50 mph is used in combination with ice.
- 13) Temperature drop of 50 °F.
- 14) Deflections calculated using a wind speed of 60 mph.
- 15) Pressures are calculated at each section.
- 16) Stress ratio used in tower member design is 1.05.
- 17) Local bending stresses due to climbing loads, feed line supports, and appurtenance mounts are not considered.

## Options

- |  |   |  |
|--|---|--|
| <ul style="list-style-type: none"> <li>Consider Moments - Legs</li> <li>Consider Moments - Horizontals</li> <li>Consider Moments - Diagonals</li> <li>Use Moment Magnification</li> <li>Use Code Stress Ratios</li> <li>√ Use Code Safety Factors - Guys</li> <li>Escalate Ice</li> <li>Always Use Max Kz</li> <li>Use Special Wind Profile</li> <br/> <li>√ Include Bolts In Member Capacity</li> <br/> <li>Leg Bolts Are At Top Of Section</li> <li>√ Secondary Horizontal Braces Leg</li> <li>Use Diamond Inner Bracing (4 Sided)</li> <li>SR Members Have Cut Ends</li> <li>SR Members Are Concentric</li> </ul> | <ul style="list-style-type: none"> <li>Distribute Leg Loads As Uniform</li> <li>Assume Legs Pinned</li> <li>√ Assume Rigid Index Plate</li> <li>√ Use Clear Spans For Wind Area</li> <li>√ Use Clear Spans For KL/r</li> <li>Retension Guys To Initial Tension</li> <li>√ Bypass Mast Stability Checks</li> <li>√ Use Azimuth Dish Coefficients</li> <li>√ Project Wind Area of Appurt.</li> <br/> <li>Autocalc Torque Arm Areas</li> <br/> <li>Add IBC .6D+W Combination</li> <li>√ Sort Capacity Reports By Component</li> <li>Triangulate Diamond Inner Bracing</li> <li>Treat Feed Line Bundles As Cylinder</li> <li>Ignore KL/ry For 60 Deg. Angle Legs</li> </ul> | <ul style="list-style-type: none"> <li>Use ASCE 10 X-Brace Ly Rules</li> <li>√ Calculate Redundant Bracing Forces</li> <li>Ignore Redundant Members in FEA</li> <li>√ SR Leg Bolts Resist Compression</li> <li>All Leg Panels Have Same Allowable</li> <li>Offset Girt At Foundation</li> <li>√ Consider Feed Line Torque</li> <li>√ Include Angle Block Shear Check</li> <li>Use TIA-222-H Bracing Resist.</li> <li>Exemption</li> <li>Use TIA-222-H Tension Splice</li> <li>Exemption</li> <br/> <li style="text-align: center;"><b>Poles</b></li> <li>Include Shear-Torsion Interaction</li> <li>Always Use Sub-Critical Flow</li> <li>Use Top Mounted Sockets</li> <li>Pole Without Linear Attachments</li> <li>Pole With Shroud Or No</li> <li>Appurtenances</li> <li>Outside and Inside Corner Radii Are</li> <li>Known</li> </ul> |
|--|---|--|



**Triangular Tower**

**Tower Section Geometry**

Tower Section	Tower Elevation	Assembly Database	Description	Section Width	Number of Sections	Section Length
	ft			ft		ft
T1	120.00-100.00			5.00	1	20.00
T2	100.00-80.00			7.00	1	20.00
T3	80.00-60.00			9.00	1	20.00
T4	60.00-40.00			11.00	1	20.00
T5	40.00-20.00			13.00	1	20.00
T6	20.00-0.00			15.00	1	20.00

**Tower Section Geometry (cont'd)**

Tower Section	Tower Elevation	Diagonal Spacing	Bracing Type	Has K Brace End Panels	Has Horizontals	Top Girt Offset	Bottom Girt Offset
	ft	ft				in	in
T1	120.00-100.00	4.98	X Brace	No	No	1.0000	0.0000
T2	100.00-80.00	5.00	X Brace	No	No	0.0000	0.0000
T3	80.00-60.00	6.67	X Brace	No	No	0.0000	0.0000
T4	60.00-40.00	6.67	X Brace	No	No	0.0000	0.0000
T5	40.00-20.00	6.67	X Brace	No	No	0.0000	0.0000
T6	20.00-0.00	10.00	X Brace	No	No	0.0000	0.0000

**Tower Section Geometry (cont'd)**

Tower Elevation	Leg Type	Leg Size	Leg Grade	Diagonal Type	Diagonal Size	Diagonal Grade
ft						
T1 120.00-100.00	Pipe	SABRE 3.5000"x0.2160"	A572-50 (50 ksi)	Equal Angle	L2x2x1/8	A36 (36 ksi)

Tower Elevation ft	Leg Type	Leg Size	Leg Grade	Diagonal Type	Diagonal Size	Diagonal Grade
T2 100.00-80.00	Pipe	SABRE 3.5000"x0.2160"	A572-50 (50 ksi)	Equal Angle	L2x2x1/8	A36 (36 ksi)
T3 80.00-60.00	Pipe	Sabre 4"x0.318"	A572-50 (50 ksi)	Equal Angle	L2 1/2x2 1/2x3/16	A36 (36 ksi)
T4 60.00-40.00	Pipe	SABRE 5.5625"x0.2580"	A572-50 (50 ksi)	Equal Angle	L3x3x3/16	A36 (36 ksi)
T5 40.00-20.00	Pipe	SABRE 5.5625"x0.3750"	A572-50 (50 ksi)	Equal Angle	L3x3x3/16	A36 (36 ksi)
T6 20.00-0.00	Pipe	SABRE 5.5625"x0.5000"	A572-50 (50 ksi)	Single Angle	L3 1/2x3x1/4 (SLV)	A36 (36 ksi)

### Tower Section Geometry (cont'd)

Tower Elevation ft	Top Girt Type	Top Girt Size	Top Girt Grade	Bottom Girt Type	Bottom Girt Size	Bottom Girt Grade
T1 120.00-100.00	Equal Angle	L2x2x1/8	A36 (36 ksi)	Equal Angle		A36 (36 ksi)

### Tower Section Geometry (cont'd)

Tower Elevation ft	Gusset Area (per face) ft <sup>2</sup>	Gusset Thickness in	Gusset Grade	Grade Adjust. Factor A <sub>r</sub>	Adjust. Factor A <sub>r</sub>	Weight Mult.	Double Angle Stitch Bolt Spacing Diagonals in	Double Angle Stitch Bolt Spacing Horizontals in	Double Angle Stitch Bolt Spacing Redundants in
T1 120.00-100.00	0.00	0.0000	A36 (36 ksi)	1.05	1	1.05	Mid-Pt	Mid-Pt	Mid-Pt
T2 100.00-80.00	0.00	0.0000	A36 (36 ksi)	1.05	1	1.05	Mid-Pt	Mid-Pt	Mid-Pt
T3 80.00-60.00	0.00	0.0000	A36 (36 ksi)	1.05	1	1.05	Mid-Pt	Mid-Pt	Mid-Pt
T4 60.00-40.00	0.00	0.0000	A36 (36 ksi)	1.05	1	1.05	Mid-Pt	Mid-Pt	Mid-Pt
T5 40.00-20.00	0.00	0.0000	A36 (36 ksi)	1.05	1	1.05	Mid-Pt	Mid-Pt	Mid-Pt
T6 20.00-0.00	0.00	0.0000	A36 (36 ksi)	1.05	1	1.05	Mid-Pt	Mid-Pt	Mid-Pt

### Tower Section Geometry (cont'd)

Tower Elevation ft	Calc K Single Angles	Calc K Solid Rounds	Legs	K Factors <sup>1</sup>							
				X Brace Diags X Y	K Brace Diags X Y	Single Diags X Y	Girts X Y	Horiz. X Y	Sec. Horiz. X Y	Inner Brace X Y	
T1 120.00-100.00	Yes	Yes	1	1	1	1	1	1	1	1	1
T2 100.00-80.00	Yes	Yes	1	1	1	1	1	1	1	1	1
T3 80.00-60.00	Yes	Yes	1	1	1	1	1	1	1	1	1
T4 60.00-40.00	Yes	Yes	1	1	1	1	1	1	1	1	1
T5 40.00-	Yes	Yes	1	1	1	1	1	1	1	1	1

Tower Elevation ft	Calc K Single Angles	Calc K Solid Rounds	K Factors <sup>1</sup>									
			Legs	X Brace Diags	K Brace Diags	Single Diags	Girts	Horiz.	Sec. Horiz.	Inner Brace		
				X Y	X Y	X Y	X Y	X Y	X Y	X Y		
20.00				1	1	1	1	1	1	1	1	1
T6 20.00-0.00	Yes	Yes	1	1	1	1	1	1	1	1	1	1

<sup>1</sup>Note: K factors are applied to member segment lengths. K-braces without inner supporting members will have the K factor in the out-of-plane direction applied to the overall length.

### Tower Section Geometry (cont'd)

Tower Elevation ft	Leg		Diagonal		Top Girt		Bottom Girt		Mid Girt		Long Horizontal		Short Horizontal	
	Net Width Deduct in	U	Net Width Deduct in	U	Net Width Deduct in	U	Net Width Deduct in	U	Net Width Deduct in	U	Net Width Deduct in	U	Net Width Deduct in	U
T1 120.00-100.00	0.0000	1	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75
T2 100.00-80.00	0.0000	1	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75
T3 80.00-60.00	0.0000	1	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75
T4 60.00-40.00	0.0000	1	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75
T5 40.00-20.00	0.0000	1	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75
T6 20.00-0.00	0.0000	1	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75	0.0000	0.75

### Tower Section Geometry (cont'd)

Tower Elevation ft	Leg Connection Type	Leg		Diagonal		Top Girt		Bottom Girt		Mid Girt		Long Horizontal		Short Horizontal	
		Bolt Size in	No.	Bolt Size in	No.										
T1 120.00-100.00	Flange	0.7500	6	0.6250	1	0.6250	1	0.6250	0	0.6250	0	0.6250	0	0.6250	0
		A325N		A325N		A325N		A325N		A325N		A325N		A325N	
T2 100.00-80.00	Flange	1.0000	6	0.6250	1	0.6250	0	0.6250	0	0.6250	0	0.6250	0	0.6250	0
		A325N		A325N		A325X		A325N		A325N		A325N		A325N	
T3 80.00-60.00	Flange	1.0000	6	0.6250	1	0.6250	0	0.6250	0	0.6250	0	0.6250	0	0.6250	0
		A325N		A325N		A325X		A325N		A325N		A325N		A325N	
T4 60.00-40.00	Flange	1.0000	6	0.6250	1	0.6250	0	0.6250	0	0.6250	0	0.6250	0	0.6250	0
		A325N		A325N		A325X		A325N		A325N		A325N		A325N	
T5 40.00-20.00	Flange	1.0000	6	0.7500	1	0.6250	0	0.6250	0	0.6250	0	0.6250	0	0.6250	0
		A325N		A325N		A325X		A325N		A325N		A325N		A325N	
T6 20.00-0.00	Flange	1.5000	0	0.7500	1	0.6250	0	0.6250	0	0.6250	0	0.6250	0	0.6250	0
		F1554-105		A325N		A325X		A325N		A325N		A325N		A325N	

### Feed Line/Linear Appurtenances - Entered As Round Or Flat

Description	Face or Leg	Allow Shield	Exclude From Torque Calculation	Component Type	Placement ft	Face Offset in	Lateral Offset (Frac FW)	#	# Per Row	Clear Spacing in	Width or Diameter in	Perimeter in	Weight plf
-------------	-------------	--------------	---------------------------------	----------------	--------------	----------------	--------------------------	---	-----------	------------------	----------------------	--------------	------------

Description	Face or Leg	Allow Shield	Exclude From Torque Calculation	Component Type	Placement ft	Face Offset in	Lateral Offset (Frac FW)	#	# Per Row	Clear Spacing in	Width or Diameter in	Perimeter in	Weight plf
***120*** AVA5-50(7/8)	B	No	No	Ar (CaAa)	120.00 - 10.00	0.0000	-0.3	1	1	0.5000	1.1020		0.30
***117*** EW63(ELLIPTICAL)	B	No	No	Ar (CaAa)	117.00 - 10.00	0.0000	-0.32	1	1	0.5000	2.0100		0.51
***96 & 80*** AVA5-50(7/8)	B	No	No	Ar (CaAa)	80.00 - 10.00	0.0000	-0.35	2	2	0.5000	1.1020		0.30
AVA5-50(7/8)	B	No	No	Ar (CaAa)	96.00 - 80.00	0.0000	-0.35	1	1	0.5000	1.1020		0.30
***misc1*** Feedline Ladder (Af)	B	No	No	Af (CaAa)	120.00 - 0.00	0.0000	-0.4	1	1	3.0000	3.0000		8.40
Climbing Ladder (Af)	A	No	No	Af (CaAa)	120.00 - 0.00	0.0000	0	1	1	3.0000	3.0000		8.40
Safety Line 3/8	A	No	No	Ar (CaAa)	120.00 - 0.00	0.0000	0	1	1	0.3750	0.3750		0.22
***Proposed** LCF78-50J(7/8)	B	No	No	Ar (CaAa)	117.50 - 0.00	0.0000	-0.47	2	2	0.5000	1.1000		0.53

### Feed Line/Linear Appurtenances Section Areas

Tower Section	Tower Elevation ft	Face	A <sub>R</sub> ft <sup>2</sup>	A <sub>F</sub> ft <sup>2</sup>	C <sub>A</sub> A <sub>A</sub> In Face ft <sup>2</sup>	C <sub>A</sub> A <sub>A</sub> Out Face ft <sup>2</sup>	Weight K
T1	120.00-100.00	A	0.000	0.000	10.750	0.000	0.17
		B	0.000	0.000	19.471	0.000	0.20
		C	0.000	0.000	0.000	0.000	0.00
T2	100.00-80.00	A	0.000	0.000	10.750	0.000	0.17
		B	0.000	0.000	22.387	0.000	0.21
		C	0.000	0.000	0.000	0.000	0.00
T3	80.00-60.00	A	0.000	0.000	10.750	0.000	0.17
		B	0.000	0.000	25.032	0.000	0.22
		C	0.000	0.000	0.000	0.000	0.00
T4	60.00-40.00	A	0.000	0.000	10.750	0.000	0.17
		B	0.000	0.000	25.032	0.000	0.22
		C	0.000	0.000	0.000	0.000	0.00
T5	40.00-20.00	A	0.000	0.000	10.750	0.000	0.17
		B	0.000	0.000	25.032	0.000	0.22
		C	0.000	0.000	0.000	0.000	0.00
T6	20.00-0.00	A	0.000	0.000	10.750	0.000	0.17
		B	0.000	0.000	19.716	0.000	0.20
		C	0.000	0.000	0.000	0.000	0.00

### Feed Line/Linear Appurtenances Section Areas - With Ice

Tower Section	Tower Elevation ft	Face or Leg	Ice Thickness in	A <sub>R</sub> ft <sup>2</sup>	A <sub>F</sub> ft <sup>2</sup>	C <sub>A</sub> A <sub>A</sub> In Face ft <sup>2</sup>	C <sub>A</sub> A <sub>A</sub> Out Face ft <sup>2</sup>	Weight K
T1	120.00-100.00	A	1.946	0.000	0.000	26.316	0.000	0.58
		B		0.000	0.000	55.888	0.000	0.97
		C		0.000	0.000	0.000	0.000	0.00
T2	100.00-80.00	A	1.907	0.000	0.000	26.006	0.000	0.56
		B		0.000	0.000	67.374	0.000	1.12
		C		0.000	0.000	0.000	0.000	0.00
T3	80.00-60.00	A	1.860	0.000	0.000	25.628	0.000	0.55
		B		0.000	0.000	78.688	0.000	1.18
		C		0.000	0.000	0.000	0.000	0.00

Tower Section	Tower Elevation ft	Face or Leg	Ice Thickness in	A <sub>R</sub> ft <sup>2</sup>	A <sub>F</sub> ft <sup>2</sup>	C <sub>A</sub> A <sub>A</sub> In Face ft <sup>2</sup>	C <sub>A</sub> A <sub>A</sub> Out Face ft <sup>2</sup>	Weight K
T4	60.00-40.00	A	1.798	0.000	0.000	25.135	0.000	0.53
		B		0.000	0.000	77.088	0.000	1.13
		C		0.000	0.000	0.000	0.000	0.00
T5	40.00-20.00	A	1.709	0.000	0.000	24.419	0.000	0.50
		B		0.000	0.000	74.761	0.000	1.07
		C		0.000	0.000	0.000	0.000	0.00
T6	20.00-0.00	A	1.531	0.000	0.000	22.997	0.000	0.46
		B		0.000	0.000	52.018	0.000	0.74
		C		0.000	0.000	0.000	0.000	0.00

### Feed Line Center of Pressure

Section	Elevation ft	CP <sub>x</sub> in	CP <sub>z</sub> in	CP <sub>x</sub> Ice in	CP <sub>z</sub> Ice in
T1	120.00-100.00	-0.7192	-7.2226	-1.0655	-9.6568
T2	100.00-80.00	-0.6952	-9.6667	-0.9799	-13.7954
T3	80.00-60.00	-0.6282	-11.5679	-0.9449	-17.1262
T4	60.00-40.00	-0.6251	-11.4145	-0.9921	-17.8126
T5	40.00-20.00	-0.6722	-12.1911	-1.0753	-19.1775
T6	20.00-0.00	-1.4179	-12.4440	-2.3539	-18.6296

### Shielding Factor Ka

Tower Section	Feed Line Record No.	Description	Feed Line Segment Elev.	K <sub>a</sub> No Ice	K <sub>a</sub> Ice
T1	2	AVA5-50(7/8)	100.00 - 120.00	0.6000	0.5715
T1	4	EW63(ELLIPTICAL)	100.00 - 117.00	0.6000	0.5715
T1	9	Feedline Ladder (Af)	100.00 - 120.00	0.6000	0.5715
T1	10	Climbing Ladder (Af)	100.00 - 120.00	0.6000	0.5715
T1	11	Safety Line 3/8	100.00 - 120.00	0.6000	0.5715
T1	13	LCF78-50J(7/8)	100.00 - 117.50	0.6000	0.5715
T2	2	AVA5-50(7/8)	80.00 - 100.00	0.6000	0.6000
T2	4	EW63(ELLIPTICAL)	80.00 - 100.00	0.6000	0.6000
T2	7	AVA5-50(7/8)	80.00 - 96.00	0.6000	0.6000
T2	9	Feedline Ladder (Af)	80.00 - 100.00	0.6000	0.6000
T2	10	Climbing Ladder (Af)	80.00 - 100.00	0.6000	0.6000
T2	11	Safety Line 3/8	80.00 - 100.00	0.6000	0.6000
T2	13	LCF78-50J(7/8)	80.00 - 100.00	0.6000	0.6000
T3	2	AVA5-50(7/8)	60.00 - 80.00	0.6000	0.6000
T3	4	EW63(ELLIPTICAL)	60.00 - 80.00	0.6000	0.6000
T3	6	AVA5-50(7/8)	60.00 - 80.00	0.6000	0.6000

Tower Section	Feed Line Record No.	Description	Feed Line Segment Elev.	K <sub>a</sub> No Ice	K <sub>a</sub> Ice
T3	9	Feedline Ladder (Af)	60.00 - 80.00	0.6000	0.6000
T3	10	Climbing Ladder (Af)	60.00 - 80.00	0.6000	0.6000
T3	11	Safety Line 3/8	60.00 - 80.00	0.6000	0.6000
T3	13	LCF78-50J(7/8)	60.00 - 80.00	0.6000	0.6000
T4	2	AVA5-50(7/8)	40.00 - 60.00	0.6000	0.6000
T4	4	EW63(ELLIPTICAL)	40.00 - 60.00	0.6000	0.6000
T4	6	AVA5-50(7/8)	40.00 - 60.00	0.6000	0.6000
T4	9	Feedline Ladder (Af)	40.00 - 60.00	0.6000	0.6000
T4	10	Climbing Ladder (Af)	40.00 - 60.00	0.6000	0.6000
T4	11	Safety Line 3/8	40.00 - 60.00	0.6000	0.6000
T4	13	LCF78-50J(7/8)	40.00 - 60.00	0.6000	0.6000
T5	2	AVA5-50(7/8)	20.00 - 40.00	0.6000	0.6000
T5	4	EW63(ELLIPTICAL)	20.00 - 40.00	0.6000	0.6000
T5	6	AVA5-50(7/8)	20.00 - 40.00	0.6000	0.6000
T5	9	Feedline Ladder (Af)	20.00 - 40.00	0.6000	0.6000
T5	10	Climbing Ladder (Af)	20.00 - 40.00	0.6000	0.6000
T5	11	Safety Line 3/8	20.00 - 40.00	0.6000	0.6000
T5	13	LCF78-50J(7/8)	20.00 - 40.00	0.6000	0.6000
T6	2	AVA5-50(7/8)	10.00 - 20.00	0.6000	0.6000
T6	4	EW63(ELLIPTICAL)	10.00 - 20.00	0.6000	0.6000
T6	6	AVA5-50(7/8)	10.00 - 20.00	0.6000	0.6000
T6	9	Feedline Ladder (Af)	0.00 - 20.00	0.6000	0.6000
T6	10	Climbing Ladder (Af)	0.00 - 20.00	0.6000	0.6000
T6	11	Safety Line 3/8	0.00 - 20.00	0.6000	0.6000
T6	13	LCF78-50J(7/8)	0.00 - 20.00	0.6000	0.6000

### Discrete Tower Loads

Description	Face or Leg	Offset Type	Offsets: Horz Lateral Vert ft ft ft	Azimuth Adjustmen t °	Placement ft	C <sub>A</sub> A <sub>A</sub> Front ft <sup>2</sup>	C <sub>A</sub> A <sub>A</sub> Side ft <sup>2</sup>	Weight K	
***120*** CO-36AN	B	From Leg	6.00 0.00 7.00	0.0000	120.00	No Ice 1/2" Ice 1" Ice 2" Ice	2.70 3.93 5.17 7.52	2.70 3.93 5.17 7.52	0.01 0.03 0.06 0.14

Description	Face or Leg	Offset Type	Offsets: Horz Lateral Vert ft ft ft	Azimuth Adjustment t °	Placement ft		C <sub>AA</sub> Front ft <sup>2</sup>	C <sub>AA</sub> Side ft <sup>2</sup>	Weight K
6' x 3" Mount Pipe	B	From Leg	0.00 0.00 0.00	0.0000	120.00	No Ice	1.73	1.73	0.03
						1/2" Ice	2.13	2.13	0.04
						Ice	2.50	2.50	0.06
						1" Ice	3.27	3.27	0.11
						2" Ice			
Side Arm Mount [SO 602-1]	B	From Leg	3.00 0.00 0.00	0.0000	120.00	No Ice	2.58	10.83	0.15
						1/2" Ice	3.39	13.16	0.22
						Ice	4.18	15.84	0.31
						1" Ice	5.70	22.98	0.55
						2" Ice			
14' x 2" horizontal mount pipe	B	From Face	0.00 0.00 0.00	0.0000	120.00	No Ice	3.33	0.01	0.05
						1/2" Ice	4.75	0.05	0.08
						Ice	6.20	0.08	0.11
						1" Ice	9.14	0.16	0.20
						2" Ice			
***117*** Pipe Mount [PM 601-1]	C	From Leg	0.00 0.00 0.00	0.0000	117.00	No Ice	1.32	1.32	0.07
						1/2" Ice	1.58	1.58	0.08
						Ice	1.84	1.84	0.09
						1" Ice	2.40	2.40	0.13
						2" Ice			
***96*** CO-41AN	A	From Leg	6.00 0.00 7.00	0.0000	96.00	No Ice	3.15	3.15	0.01
						1/2" Ice	4.38	4.38	0.04
						Ice	5.63	5.63	0.07
						1" Ice	7.77	7.77	0.15
						2" Ice			
6' x 3" Mount Pipe	A	From Leg	0.00 0.00 0.00	0.0000	96.00	No Ice	1.77	1.77	0.03
						1/2" Ice	2.13	2.13	0.04
						Ice	2.50	2.50	0.06
						1" Ice	3.27	3.27	0.11
						2" Ice			
Side Arm Mount [SO 602-1]	A	From Leg	3.00 0.00 0.00	0.0000	96.00	No Ice	2.58	10.83	0.15
						1/2" Ice	3.39	13.16	0.22
						Ice	4.18	15.84	0.31
						1" Ice	5.70	22.98	0.55
						2" Ice			
14' x 2" horizontal mount pipe	A	From Face	0.00 0.00 0.00	0.0000	96.00	No Ice	3.33	0.01	0.05
						1/2" Ice	4.75	0.05	0.08
						Ice	6.20	0.08	0.11
						1" Ice	9.14	0.16	0.20
						2" Ice			
***80*** CO-41AN	C	From Leg	6.00 0.00 7.00	0.0000	80.00	No Ice	3.15	3.15	0.01
						1/2" Ice	4.38	4.38	0.04
						Ice	5.63	5.63	0.07
						1" Ice	7.77	7.77	0.15
						2" Ice			
6' x 3" Mount Pipe	C	From Leg	0.00 0.00 0.00	0.0000	80.00	No Ice	1.77	1.77	0.03
						1/2" Ice	2.13	2.13	0.04
						Ice	2.50	2.50	0.06
						1" Ice	3.27	3.27	0.11
						2" Ice			
Side Arm Mount [SO 602-1]	C	From Leg	3.00 0.00 0.00	0.0000	80.00	No Ice	2.58	10.83	0.15
						1/2" Ice	3.39	13.16	0.22
						Ice	4.18	15.84	0.31
						1" Ice	5.70	22.98	0.55
						2" Ice			
14' x 2" horizontal mount pipe	C	From Face	0.00 0.00 0.00	0.0000	80.00	No Ice	3.33	0.01	0.05
						1/2" Ice	4.75	0.05	0.08
						Ice	6.20	0.08	0.11
						1" Ice	9.14	0.16	0.20
						2" Ice			
***Proposed*** DS2C03F36D-D	A	From Leg	1.00	0.0000	117.50	No Ice	7.16	7.16	0.07

Description	Face or Leg	Offset Type	Offsets: Horz Lateral Vert ft ft ft	Azimuth Adjustment t °	Placement ft	C <sub>AA</sub> Front ft <sup>2</sup>	C <sub>AA</sub> Side ft <sup>2</sup>	Weight K	
R5-LL [PM 602-1]	A	From Leg	0.00	0.0000	117.50	1/2"	9.75	9.75	0.12
			9.50			Ice	12.23	12.23	0.19
						1" Ice	17.24	17.24	0.37
						2" Ice			
			0.50			No Ice	5.25	1.58	0.09
			0.00			1/2"	6.50	1.95	0.12
			0.00			Ice	7.75	2.32	0.14
						1" Ice	10.25	3.06	0.19
						2" Ice			

### Dishes

Description	Face or Leg	Dish Type	Offset Type	Offsets: Horz Lateral Vert ft	Azimuth Adjustment °	3 dB Beam Width °	Elevation ft	Outside Diameter ft	Aperture Area ft <sup>2</sup>	Weight K	
***117***	C	Paraboloid w/Radome	From Leg	0.50	-30.0000		117.00	6.00	No Ice	28.30	0.19
PADX6-59A				0.00					1/2" Ice	29.05	0.34
				0.00					1" Ice	29.80	0.48
									2" Ice	31.30	0.78
***											

### Load Combinations

Comb. No.	Description
1	Dead Only
2	1.2 Dead+1.0 Wind 0 deg - No Ice
3	0.9 Dead+1.0 Wind 0 deg - No Ice
4	1.2 Dead+1.0 Wind 30 deg - No Ice
5	0.9 Dead+1.0 Wind 30 deg - No Ice
6	1.2 Dead+1.0 Wind 60 deg - No Ice
7	0.9 Dead+1.0 Wind 60 deg - No Ice
8	1.2 Dead+1.0 Wind 90 deg - No Ice
9	0.9 Dead+1.0 Wind 90 deg - No Ice
10	1.2 Dead+1.0 Wind 120 deg - No Ice
11	0.9 Dead+1.0 Wind 120 deg - No Ice
12	1.2 Dead+1.0 Wind 150 deg - No Ice
13	0.9 Dead+1.0 Wind 150 deg - No Ice
14	1.2 Dead+1.0 Wind 180 deg - No Ice
15	0.9 Dead+1.0 Wind 180 deg - No Ice
16	1.2 Dead+1.0 Wind 210 deg - No Ice
17	0.9 Dead+1.0 Wind 210 deg - No Ice
18	1.2 Dead+1.0 Wind 240 deg - No Ice
19	0.9 Dead+1.0 Wind 240 deg - No Ice
20	1.2 Dead+1.0 Wind 270 deg - No Ice
21	0.9 Dead+1.0 Wind 270 deg - No Ice
22	1.2 Dead+1.0 Wind 300 deg - No Ice
23	0.9 Dead+1.0 Wind 300 deg - No Ice
24	1.2 Dead+1.0 Wind 330 deg - No Ice
25	0.9 Dead+1.0 Wind 330 deg - No Ice
26	1.2 Dead+1.0 Ice+1.0 Temp
27	1.2 Dead+1.0 Wind 0 deg+1.0 Ice+1.0 Temp
28	1.2 Dead+1.0 Wind 30 deg+1.0 Ice+1.0 Temp

Comb. No.	Description
29	1.2 Dead+1.0 Wind 60 deg+1.0 Ice+1.0 Temp
30	1.2 Dead+1.0 Wind 90 deg+1.0 Ice+1.0 Temp
31	1.2 Dead+1.0 Wind 120 deg+1.0 Ice+1.0 Temp
32	1.2 Dead+1.0 Wind 150 deg+1.0 Ice+1.0 Temp
33	1.2 Dead+1.0 Wind 180 deg+1.0 Ice+1.0 Temp
34	1.2 Dead+1.0 Wind 210 deg+1.0 Ice+1.0 Temp
35	1.2 Dead+1.0 Wind 240 deg+1.0 Ice+1.0 Temp
36	1.2 Dead+1.0 Wind 270 deg+1.0 Ice+1.0 Temp
37	1.2 Dead+1.0 Wind 300 deg+1.0 Ice+1.0 Temp
38	1.2 Dead+1.0 Wind 330 deg+1.0 Ice+1.0 Temp
39	Dead+Wind 0 deg - Service
40	Dead+Wind 30 deg - Service
41	Dead+Wind 60 deg - Service
42	Dead+Wind 90 deg - Service
43	Dead+Wind 120 deg - Service
44	Dead+Wind 150 deg - Service
45	Dead+Wind 180 deg - Service
46	Dead+Wind 210 deg - Service
47	Dead+Wind 240 deg - Service
48	Dead+Wind 270 deg - Service
49	Dead+Wind 300 deg - Service
50	Dead+Wind 330 deg - Service

### Maximum Member Forces

Section No.	Elevation ft	Component Type	Condition	Gov. Load Comb.	Axial K	Major Axis Moment kip-ft	Minor Axis Moment kip-ft
T1	120 - 100	Leg	Max Tension	7	9.90	-0.08	0.01
			Max. Compression	2	-11.48	0.06	-0.00
			Max. Mx	3	-1.76	-0.49	0.15
			Max. My	2	0.55	-0.18	-0.78
			Max. Vy	3	-0.41	0.32	0.15
			Max. Vx	16	-0.76	-0.00	0.06
		Diagonal	Max Tension	4	1.54	0.00	0.00
			Max. Compression	4	-1.57	0.00	0.00
			Max. Mx	29	0.29	0.03	0.00
			Max. My	27	-0.37	0.02	-0.00
			Max. Vy	29	0.03	0.03	0.00
			Max. Vx	27	0.00	0.00	0.00
		Top Girt	Max Tension	19	0.10	0.00	0.00
			Max. Compression	4	-0.10	0.00	0.00
			Max. Mx	26	-0.04	-0.04	0.00
			Max. My	26	-0.03	0.00	0.00
			Max. Vy	26	0.03	0.00	0.00
			Max. Vx	26	0.00	0.00	0.00
		T2	100 - 80	Leg	Max Tension	7	24.31
Max. Compression	2				-27.62	0.15	-0.00
Max. Mx	3				-27.18	0.15	-0.00
Max. My	20				-0.59	-0.00	0.36
Max. Vy	10				-0.25	0.14	0.10
Max. Vx	21				0.60	-0.00	-0.23
Diagonal	Max Tension			5	2.47	0.00	0.00
	Max. Compression			4	-2.50	0.00	0.00
	Max. Mx			29	0.29	0.04	0.01
	Max. My			30	-0.50	0.04	0.01
	Max. Vy			29	0.04	0.04	0.01
	Max. Vx			30	-0.00	0.00	0.00
T3	80 - 60	Leg	Max Tension	7	39.38	-0.13	0.03
			Max. Compression	2	-45.54	0.19	0.00
			Max. Mx	3	-44.91	0.19	0.00
			Max. My	9	-3.69	0.00	0.24
			Max. Vy	3	0.30	0.15	-0.00
			Max. Vx	24	0.65	-0.01	0.06
		Diagonal	Max Tension	4	3.58	0.00	0.00
			Max. Compression	4	-3.63	0.00	0.00
			Max. Mx	37	0.67	0.07	0.01

Section No.	Elevation ft	Component Type	Condition	Gov. Load Comb.	Axial K	Major Axis Moment kip-ft	Minor Axis Moment kip-ft
T4	60 - 40	Leg	Max. My	35	-0.86	0.06	-0.01
			Max. Vy	37	0.06	0.07	0.01
			Max. Vx	35	0.00	0.00	0.00
			Max Tension	7	55.77	-0.24	0.03
			Max. Compression	2	-65.30	0.26	0.00
			Max. Mx	35	-24.58	0.37	-0.00
			Max. My	9	-4.32	0.00	0.32
		Diagonal	Max. Vy	33	-0.10	-0.25	-0.01
			Max. Vx	9	-0.12	0.00	0.32
			Max Tension	4	4.23	0.00	0.00
			Max. Compression	4	-4.25	0.00	0.00
			Max. Mx	29	0.67	0.11	-0.01
			Max. My	29	0.32	0.11	0.01
			Max. Vy	29	0.07	0.11	-0.01
T5	40 - 20	Leg	Max. Vx	29	-0.00	0.00	0.00
			Max Tension	7	72.75	-0.19	0.01
			Max. Compression	2	-86.15	0.55	0.01
			Max. Mx	33	2.63	-1.15	-0.00
			Max. My	4	-3.15	-0.02	-0.34
			Max. Vy	33	0.32	-1.15	-0.00
			Max. Vx	9	-0.11	-0.01	0.34
		Diagonal	Max Tension	4	4.80	0.00	0.00
			Max. Compression	4	-4.84	0.00	0.00
			Max. Mx	29	0.00	0.13	0.02
			Max. My	30	1.47	0.11	0.02
			Max. Vy	29	0.08	0.13	0.02
			Max. Vx	30	-0.00	0.00	0.00
			Max Tension	7	88.11	-0.35	0.05
T6	20 - 0	Leg	Max. Compression	2	-105.47	0.00	0.00
			Max. Mx	33	5.68	-1.15	-0.00
			Max. My	9	-6.07	-0.03	0.74
			Max. Vy	33	-0.23	-1.15	-0.00
			Max. Vx	9	0.19	-0.03	0.74
			Max Tension	4	5.64	0.00	0.00
			Max. Compression	18	-5.75	0.00	0.00
		Diagonal	Max. Mx	29	-0.49	0.20	0.02
			Max. My	36	2.30	0.14	-0.03
			Max. Vy	29	0.09	0.20	0.02
			Max. Vx	36	0.01	0.00	0.00

### Maximum Reactions

Location	Condition	Gov. Load Comb.	Vertical K	Horizontal, X K	Horizontal, Z K
Leg C	Max. Vert	18	107.14	11.53	-7.33
	Max. H <sub>x</sub>	18	107.14	11.53	-7.33
	Max. H <sub>z</sub>	5	-81.52	-8.36	6.47
	Min. Vert	7	-92.21	-9.93	6.43
	Min. H <sub>x</sub>	7	-92.21	-9.93	6.43
Leg B	Min. H <sub>z</sub>	18	107.14	11.53	-7.33
	Max. Vert	10	103.09	-11.39	-7.03
	Max. H <sub>x</sub>	23	-86.07	9.62	5.98
	Max. H <sub>z</sub>	23	-86.07	9.62	5.98
	Min. Vert	23	-86.07	9.62	5.98
Leg A	Min. H <sub>x</sub>	10	103.09	-11.39	-7.03
	Min. H <sub>z</sub>	10	103.09	-11.39	-7.03
	Max. Vert	2	110.64	-0.17	13.88
	Max. H <sub>x</sub>	21	4.37	2.47	0.37
	Max. H <sub>z</sub>	2	110.64	-0.17	13.88
	Min. Vert	15	-88.42	0.17	-11.55
	Min. H <sub>x</sub>	8	8.10	-2.53	0.60
	Min. H <sub>z</sub>	15	-88.42	0.17	-11.55

### Tower Mast Reaction Summary

Load Combination	Vertical K	Shear <sub>x</sub> K	Shear <sub>z</sub> K	Overturning Moment, M <sub>x</sub> kip-ft	Overturning Moment, M <sub>z</sub> kip-ft	Torque kip-ft
Dead Only	13.87	0.00	0.00	-8.79	3.29	0.00
1.2 Dead+1.0 Wind 0 deg - No Ice	16.64	0.05	-23.25	-1547.25	-9.71	-5.20
0.9 Dead+1.0 Wind 0 deg - No Ice	12.48	0.05	-23.25	-1544.61	-10.70	-5.20
1.2 Dead+1.0 Wind 30 deg - No Ice	16.64	10.81	-18.84	-1273.20	-722.11	-13.39
0.9 Dead+1.0 Wind 30 deg - No Ice	12.48	10.81	-18.84	-1270.56	-723.10	-13.39
1.2 Dead+1.0 Wind 60 deg - No Ice	16.64	18.21	-10.64	-733.32	-1215.53	-18.13
0.9 Dead+1.0 Wind 60 deg - No Ice	12.48	18.21	-10.64	-730.68	-1216.52	-18.13
1.2 Dead+1.0 Wind 90 deg - No Ice	16.64	21.29	-0.16	-37.53	-1397.23	-17.30
0.9 Dead+1.0 Wind 90 deg - No Ice	12.48	21.29	-0.16	-34.89	-1398.21	-17.30
1.2 Dead+1.0 Wind 120 deg - No Ice	16.64	19.55	11.16	696.28	-1256.22	-11.34
0.9 Dead+1.0 Wind 120 deg - No Ice	12.48	19.55	11.16	698.92	-1257.21	-11.34
1.2 Dead+1.0 Wind 150 deg - No Ice	16.64	10.32	17.94	1158.04	-662.26	-2.75
0.9 Dead+1.0 Wind 150 deg - No Ice	12.48	10.32	17.94	1160.68	-663.25	-2.75
1.2 Dead+1.0 Wind 180 deg - No Ice	16.64	-0.05	20.69	1360.35	17.19	5.34
0.9 Dead+1.0 Wind 180 deg - No Ice	12.48	-0.05	20.69	1362.99	16.20	5.34
1.2 Dead+1.0 Wind 210 deg - No Ice	16.64	-10.69	18.64	1229.13	716.74	12.99
0.9 Dead+1.0 Wind 210 deg - No Ice	12.48	-10.69	18.64	1231.77	715.76	12.99
1.2 Dead+1.0 Wind 240 deg - No Ice	16.64	-19.79	11.55	751.85	1292.90	16.85
0.9 Dead+1.0 Wind 240 deg - No Ice	12.48	-19.79	11.55	754.49	1291.91	16.85
1.2 Dead+1.0 Wind 270 deg - No Ice	16.64	-20.95	-0.03	-5.75	1365.18	16.07
0.9 Dead+1.0 Wind 270 deg - No Ice	12.48	-20.95	-0.03	-3.11	1364.19	16.07
1.2 Dead+1.0 Wind 300 deg - No Ice	16.64	-17.48	-10.36	-691.43	1137.20	10.71
0.9 Dead+1.0 Wind 300 deg - No Ice	12.48	-17.48	-10.36	-688.79	1136.21	10.71
1.2 Dead+1.0 Wind 330 deg - No Ice	16.64	-10.32	-18.33	-1224.82	670.92	2.79
0.9 Dead+1.0 Wind 330 deg - No Ice	12.48	-10.32	-18.33	-1222.18	669.93	2.79
1.2 Dead+1.0 Ice+1.0 Temp	48.75	0.00	0.00	-39.86	9.21	0.00
1.2 Dead+1.0 Wind 0 deg+1.0 Ice+1.0 Temp	48.75	0.01	-5.48	-412.92	5.84	-1.11
1.2 Dead+1.0 Wind 30 deg+1.0 Ice+1.0 Temp	48.75	2.67	-4.65	-358.84	-174.70	-4.21
1.2 Dead+1.0 Wind 60 deg+1.0 Ice+1.0 Temp	48.75	4.58	-2.68	-225.35	-304.89	-6.34
1.2 Dead+1.0 Wind 90 deg+1.0 Ice+1.0 Temp	48.75	5.28	-0.03	-45.08	-348.98	-6.45
1.2 Dead+1.0 Wind 120 deg+1.0 Ice+1.0 Temp	48.75	4.65	2.67	136.84	-302.12	-4.70
1.2 Dead+1.0 Wind 150 deg+1.0 Ice+1.0 Temp	48.75	2.58	4.49	262.96	-162.91	-1.97
1.2 Dead+1.0 Wind 180 deg+1.0 Ice+1.0 Temp	48.75	-0.01	5.20	314.60	12.52	1.13
1.2 Dead+1.0 Wind 210	48.75	-2.65	4.62	275.92	191.28	4.15

Load Combination	Vertical	Shear <sub>x</sub>	Shear <sub>z</sub>	Overturning Moment, M <sub>x</sub>	Overturning Moment, M <sub>z</sub>	Torque
	K	K	K	kip-ft	kip-ft	kip-ft
deg+1.0 Ice+1.0 Temp						
1.2 Dead+1.0 Wind 240	48.75	-4.74	2.77	148.91	329.11	6.16
deg+1.0 Ice+1.0 Temp						
1.2 Dead+1.0 Wind 270	48.75	-5.23	0.00	-37.72	361.84	6.28
deg+1.0 Ice+1.0 Temp						
1.2 Dead+1.0 Wind 300	48.75	-4.42	-2.60	-215.19	306.74	4.62
deg+1.0 Ice+1.0 Temp						
1.2 Dead+1.0 Wind 330	48.75	-2.58	-4.54	-349.03	181.43	1.98
deg+1.0 Ice+1.0 Temp						
Dead+Wind 0 deg - Service	13.87	0.01	-4.27	-291.04	0.78	-0.95
Dead+Wind 30 deg - Service	13.87	1.98	-3.46	-240.71	-130.07	-2.46
Dead+Wind 60 deg - Service	13.87	3.34	-1.95	-141.55	-220.70	-3.33
Dead+Wind 90 deg - Service	13.87	3.91	-0.03	-13.75	-254.07	-3.18
Dead+Wind 120 deg - Service	13.87	3.59	2.05	121.03	-228.17	-2.08
Dead+Wind 150 deg - Service	13.87	1.89	3.30	205.85	-119.08	-0.51
Dead+Wind 180 deg - Service	13.87	-0.01	3.80	243.00	5.72	0.98
Dead+Wind 210 deg - Service	13.87	-1.96	3.42	218.90	134.21	2.39
Dead+Wind 240 deg - Service	13.87	-3.63	2.12	131.24	240.03	3.10
Dead+Wind 270 deg - Service	13.87	-3.85	-0.00	-7.91	253.31	2.95
Dead+Wind 300 deg - Service	13.87	-3.21	-1.90	-133.85	211.44	1.97
Dead+Wind 330 deg - Service	13.87	-1.90	-3.37	-231.82	125.79	0.51

## Solution Summary

Load Comb.	Sum of Applied Forces			Sum of Reactions			% Error
	PX K	PY K	PZ K	PX K	PY K	PZ K	
1	0.00	-13.87	0.00	0.00	13.87	0.00	0.000%
2	0.05	-16.64	-23.25	-0.05	16.64	23.25	0.000%
3	0.05	-12.48	-23.25	-0.05	12.48	23.25	0.000%
4	10.81	-16.64	-18.84	-10.81	16.64	18.84	0.000%
5	10.81	-12.48	-18.84	-10.81	12.48	18.84	0.000%
6	18.21	-16.64	-10.64	-18.21	16.64	10.64	0.000%
7	18.21	-12.48	-10.64	-18.21	12.48	10.64	0.000%
8	21.29	-16.64	-0.16	-21.29	16.64	0.16	0.000%
9	21.29	-12.48	-0.16	-21.29	12.48	0.16	0.000%
10	19.55	-16.64	11.16	-19.55	16.64	-11.16	0.000%
11	19.55	-12.48	11.16	-19.55	12.48	-11.16	0.000%
12	10.32	-16.64	17.94	-10.32	16.64	-17.94	0.000%
13	10.32	-12.48	17.94	-10.32	12.48	-17.94	0.000%
14	-0.05	-16.64	20.69	0.05	16.64	-20.69	0.000%
15	-0.05	-12.48	20.69	0.05	12.48	-20.69	0.000%
16	-10.69	-16.64	18.64	10.69	16.64	-18.64	0.000%
17	-10.69	-12.48	18.64	10.69	12.48	-18.64	0.000%
18	-19.79	-16.64	11.55	19.79	16.64	-11.55	0.000%
19	-19.79	-12.48	11.55	19.79	12.48	-11.55	0.000%
20	-20.95	-16.64	-0.03	20.95	16.64	0.03	0.000%
21	-20.95	-12.48	-0.03	20.95	12.48	0.03	0.000%
22	-17.48	-16.64	-10.36	17.48	16.64	10.36	0.000%
23	-17.48	-12.48	-10.36	17.48	12.48	10.36	0.000%
24	-10.32	-16.64	-18.33	10.32	16.64	18.33	0.000%
25	-10.32	-12.48	-18.33	10.32	12.48	18.33	0.000%
26	0.00	-48.75	0.00	-0.00	48.75	-0.00	0.000%
27	0.01	-48.75	-5.48	-0.01	48.75	5.48	0.000%
28	2.67	-48.75	-4.65	-2.67	48.75	4.65	0.000%
29	4.58	-48.75	-2.68	-4.58	48.75	2.68	0.000%
30	5.28	-48.75	-0.03	-5.28	48.75	0.03	0.000%
31	4.65	-48.75	2.67	-4.65	48.75	-2.67	0.000%

Load Comb.	Sum of Applied Forces			Sum of Reactions			% Error
	PX K	PY K	PZ K	PX K	PY K	PZ K	
32	2.58	-48.75	4.49	-2.58	48.75	-4.49	0.000%
33	-0.01	-48.75	5.20	0.01	48.75	-5.20	0.000%
34	-2.65	-48.75	4.62	2.65	48.75	-4.62	0.000%
35	-4.74	-48.75	2.77	4.74	48.75	-2.77	0.000%
36	-5.23	-48.75	0.00	5.23	48.75	-0.00	0.000%
37	-4.42	-48.75	-2.60	4.42	48.75	2.60	0.000%
38	-2.58	-48.75	-4.54	2.58	48.75	4.54	0.000%
39	0.01	-13.87	-4.27	-0.01	13.87	4.27	0.000%
40	1.98	-13.87	-3.46	-1.98	13.87	3.46	0.000%
41	3.34	-13.87	-1.95	-3.34	13.87	1.95	0.000%
42	3.91	-13.87	-0.03	-3.91	13.87	0.03	0.000%
43	3.59	-13.87	2.05	-3.59	13.87	-2.05	0.000%
44	1.89	-13.87	3.30	-1.89	13.87	-3.30	0.000%
45	-0.01	-13.87	3.80	0.01	13.87	-3.80	0.000%
46	-1.96	-13.87	3.42	1.96	13.87	-3.42	0.000%
47	-3.63	-13.87	2.12	3.63	13.87	-2.12	0.000%
48	-3.85	-13.87	-0.00	3.85	13.87	0.00	0.000%
49	-3.21	-13.87	-1.90	3.21	13.87	1.90	0.000%
50	-1.90	-13.87	-3.37	1.90	13.87	3.37	0.000%

**Maximum Tower Deflections - Service Wind**

Section No.	Elevation ft	Horz. Deflection in	Gov. Load Comb.	Tilt °	Twist °
T1	120 - 100	0.931	39	0.0653	0.0131
T2	100 - 80	0.655	39	0.0607	0.0160
T3	80 - 60	0.414	39	0.0464	0.0104
T4	60 - 40	0.234	39	0.0338	0.0070
T5	40 - 20	0.108	39	0.0202	0.0043
T6	20 - 0	0.031	39	0.0093	0.0016

**Critical Deflections and Radius of Curvature - Service Wind**

Elevation ft	Appurtenance	Gov. Load Comb.	Deflection in	Tilt °	Twist °	Radius of Curvature ft
120.00	CO-36AN	39	0.931	0.0653	0.0131	537252
117.50	DS2C03F36D-D	39	0.896	0.0651	0.0138	537252
117.00	PADX6-59A	39	0.889	0.0650	0.0139	537252
96.00	CO-41AN	39	0.603	0.0584	0.0154	113836
80.00	CO-41AN	39	0.414	0.0464	0.0104	71758

**Maximum Tower Deflections - Design Wind**

Section No.	Elevation ft	Horz. Deflection in	Gov. Load Comb.	Tilt °	Twist °
T1	120 - 100	4.924	2	0.3433	0.0713
T2	100 - 80	3.475	2	0.3182	0.0873
T3	80 - 60	2.203	2	0.2452	0.0565
T4	60 - 40	1.247	2	0.1786	0.0382
T5	40 - 20	0.579	2	0.1070	0.0234
T6	20 - 0	0.165	2	0.0495	0.0088

### Critical Deflections and Radius of Curvature - Design Wind

Elevation ft	Appurtenance	Gov. Load Comb.	Deflection in	Tilt °	Twist °	Radius of Curvature ft
120.00	CO-36AN	2	4.924	0.3433	0.0713	105087
117.50	DS2C03F36D-D	2	4.740	0.3418	0.0750	105087
117.00	PADX6-59A	2	4.703	0.3415	0.0757	105087
96.00	CO-41AN	2	3.201	0.3063	0.0837	22066
80.00	CO-41AN	2	2.203	0.2452	0.0565	13840

### Bolt Design Data

Section No.	Elevation ft	Component Type	Bolt Grade	Bolt Size in	Number Of Bolts	Maximum Load per Bolt K	Allowable Load per Bolt K	Ratio Load Allowable	Allowable Ratio	Criteria
T1	120	Leg	A325N	0.7500	6	1.65	30.10	0.055	1.05	Bolt Tension
		Diagonal	A325N	0.6250	1	1.54	5.76	0.268	1.05	Member Block Shear
		Top Girt	A325N	0.6250	1	0.10	5.76	0.018	1.05	Member Block Shear
T2	100	Leg	A325N	1.0000	6	4.05	54.52	0.074	1.05	Bolt Tension
		Diagonal	A325N	0.6250	1	2.47	5.76	0.429	1.05	Member Block Shear
T3	80	Leg	A325N	1.0000	6	6.56	54.52	0.120	1.05	Bolt Tension
		Diagonal	A325N	0.6250	1	3.58	10.67	0.335	1.05	Member Block Shear
T4	60	Leg	A325N	1.0000	6	9.30	54.52	0.171	1.05	Bolt Tension
		Diagonal	A325N	0.6250	1	4.23	11.69	0.362	1.05	Member Block Shear
T5	40	Leg	A325N	1.0000	6	12.13	54.52	0.222	1.05	Bolt Tension
		Diagonal	A325N	0.7500	1	4.80	11.18	0.429	1.05	Member Block Shear
T6	20	Diagonal	A325N	0.7500	1	5.64	15.42	0.366	1.05	Member Block Shear

### Compression Checks

### Leg Design Data (Compression)

Section No.	Elevation ft	Size	L ft	L <sub>u</sub> ft	KI/r	A in <sup>2</sup>	P <sub>u</sub> K	φP <sub>n</sub> K	Ratio P <sub>u</sub> φP <sub>n</sub>
T1	120 - 100	SABRE 3.5000"x0.2160"	20.03	4.99	51.4 K=1.00	2.2285	-11.48	82.64	0.139 <sup>1</sup>
T2	100 - 80	SABRE 3.5000"x0.2160"	20.03	5.01	51.7 K=1.00	2.2285	-27.62	82.51	0.335 <sup>1</sup>
T3	80 - 60	Sabre 4"x0.318"	20.03	6.68	61.3 K=1.00	3.6784	-45.54	125.73	0.362 <sup>1</sup>
T4	60 - 40	SABRE 5.5625"x0.2580"	20.03	6.68	42.7 K=1.00	4.2995	-65.30	169.35	0.386 <sup>1</sup>
T5	40 - 20	SABRE 5.5625"x0.3750"	20.03	6.68	43.6 K=1.00	6.1114	-86.15	239.36	0.360 <sup>1</sup>
T6	20 - 0	SABRE 5.5625"x0.5000"	20.03	10.02	66.8 K=1.00	7.9522	-105.47	258.15	0.409 <sup>1</sup>

<sup>1</sup>  $P_u / \phi P_n$  controls

### Diagonal Design Data (Compression)

Section No.	Elevation ft	Size	L ft	L <sub>u</sub> ft	KI/r	A in <sup>2</sup>	P <sub>u</sub> K	φP <sub>n</sub> K	Ratio $\frac{P_u}{\phi P_n}$
T1	120 - 100	L2x2x1/8	8.39	4.00	120.8 K=1.00	0.4844	-1.57	9.38	0.168 <sup>1</sup>
T2	100 - 80	L2x2x1/8	10.08	4.85	146.4 K=1.00	0.4844	-2.50	6.47	0.387 <sup>1</sup>
T3	80 - 60	L2 1/2x2 1/2x3/16	12.58	6.12	148.4 K=1.00	0.9020	-3.63	11.72	0.310 <sup>1</sup>
T4	60 - 40	L3x3x3/16	14.32	6.92	139.3 K=1.00	1.0900	-4.25	16.08	0.264 <sup>1</sup>
T5	40 - 20	L3x3x3/16	16.11	7.82	157.4 K=1.00	1.0900	-4.84	12.59	0.384 <sup>1</sup>
T6	20 - 0	L3 1/2x3x1/4 (SLV)	19.30	9.49	180.5 K=1.00	1.5625	-5.75	13.72	0.419 <sup>1</sup>

<sup>1</sup>  $P_u / \phi P_n$  controls

### Top Girt Design Data (Compression)

Section No.	Elevation ft	Size	L ft	L <sub>u</sub> ft	KI/r	A in <sup>2</sup>	P <sub>u</sub> K	φP <sub>n</sub> K	Ratio $\frac{P_u}{\phi P_n}$
T1	120 - 100	L2x2x1/8	5.01	4.38	132.3 K=1.00	0.4844	-0.10	7.92	0.013 <sup>1</sup>

<sup>1</sup>  $P_u / \phi P_n$  controls

### Tension Checks

### Leg Design Data (Tension)

Section No.	Elevation ft	Size	L ft	L <sub>u</sub> ft	KI/r	A in <sup>2</sup>	P <sub>u</sub> K	φP <sub>n</sub> K	Ratio $\frac{P_u}{\phi P_n}$
T1	120 - 100	SABRE 3.5000"x0.2160"	20.03	4.99	51.4	2.2285	9.90	100.28	0.099 <sup>1</sup>
T2	100 - 80	SABRE 3.5000"x0.2160"	20.03	5.01	51.7	2.2285	24.31	100.28	0.242 <sup>1</sup>
T3	80 - 60	Sabre 4"x0.318"	20.03	6.68	61.3	3.6784	39.38	165.53	0.238 <sup>1</sup>
T4	60 - 40	SABRE 5.5625"x0.2580"	20.03	6.68	42.7	4.2995	55.77	193.48	0.288 <sup>1</sup>
T5	40 - 20	SABRE 5.5625"x0.3750"	20.03	6.68	43.6	6.1114	72.75	275.01	0.265 <sup>1</sup>
T6	20 - 0	SABRE 5.5625"x0.5000"	20.03	10.02	66.8	7.9522	88.11	357.85	0.246 <sup>1</sup>

<sup>1</sup>  $P_u / \phi P_n$  controls

### Diagonal Design Data (Tension)

Section No.	Elevation ft	Size	L ft	L <sub>u</sub> ft	Kl/r	A in <sup>2</sup>	P <sub>u</sub> K	φP <sub>n</sub> K	Ratio P <sub>u</sub> / φP <sub>n</sub>
T1	120 - 100	L2x2x1/8	8.39	4.00	79.9	0.2930	1.54	12.74	0.121 <sup>1</sup>
T2	100 - 80	L2x2x1/8	10.08	4.85	96.1	0.2930	2.47	12.74	0.194 <sup>1</sup>
T3	80 - 60	L2 1/2x2 1/2x3/16	12.58	6.12	97.0	0.5710	3.58	24.84	0.144 <sup>1</sup>
T4	60 - 40	L3x3x3/16	14.32	6.92	90.5	0.7120	4.23	30.97	0.137 <sup>1</sup>
T5	40 - 20	L3x3x3/16	16.11	7.82	102.0	0.6945	4.80	30.21	0.159 <sup>1</sup>
T6	20 - 0	L3 1/2x3x1/4 (SLV)	19.30	9.49	127.0	1.0078	5.64	43.84	0.129 <sup>1</sup>

<sup>1</sup> P<sub>u</sub> / φP<sub>n</sub> controls

### Top Girt Design Data (Tension)

Section No.	Elevation ft	Size	L ft	L <sub>u</sub> ft	Kl/r	A in <sup>2</sup>	P <sub>u</sub> K	φP <sub>n</sub> K	Ratio P <sub>u</sub> / φP <sub>n</sub>
T1	120 - 100	L2x2x1/8	5.01	4.38	90.4	0.2930	0.10	12.74	0.008 <sup>1</sup>

<sup>1</sup> P<sub>u</sub> / φP<sub>n</sub> controls

### Section Capacity Table


Section No.	Elevation ft	Component Type	Size	Critical Element	P K	φP <sub>allow</sub> K	% Capacity	Pass Fail	
T1	120 - 100	Leg	SABRE 3.5000"x0.2160"	3	-11.48	86.78	13.2	Pass	
T2	100 - 80	Leg	SABRE 3.5000"x0.2160"	33	-27.62	86.63	31.9	Pass	
T3	80 - 60	Leg	Sabre 4"x0.318"	60	-45.54	132.02	34.5	Pass	
T4	60 - 40	Leg	SABRE 5.5625"x0.2580"	81	-65.30	177.82	36.7	Pass	
T5	40 - 20	Leg	SABRE 5.5625"x0.3750"	102	-86.15	251.33	34.3	Pass	
T6	20 - 0	Leg	SABRE 5.5625"x0.5000"	123	-105.47	271.06	38.9	Pass	
T1	120 - 100	Diagonal	L2x2x1/8	11	-1.57	9.85	16.0	Pass	
							25.5 (b)		
T2	100 - 80	Diagonal	L2x2x1/8	38	-2.50	6.80	36.9	Pass	
							40.9 (b)		
T3	80 - 60	Diagonal	L2 1/2x2 1/2x3/16	65	-3.63	12.30	29.5	Pass	
							31.9 (b)		
T4	60 - 40	Diagonal	L3x3x3/16	86	-4.25	16.89	25.2	Pass	
							34.5 (b)		
T5	40 - 20	Diagonal	L3x3x3/16	107	-4.84	13.22	36.6	Pass	
							40.9 (b)		
T6	20 - 0	Diagonal	L3 1/2x3x1/4 (SLV)	129	-5.75	14.41	39.9	Pass	
T1	120 - 100	Top Girt	L2x2x1/8	5	-0.10	8.32	1.2	Pass	
							1.7 (b)		
							Summary		
							Leg (T6)	38.9	Pass
							Diagonal (T5)	40.9	Pass
							Top Girt (T1)	1.7	Pass
							Bolt	40.9	Pass
							Checks		
							<b>RATING =</b>	<b>40.9</b>	<b>Pass</b>

**APPENDIX B**  
**BASE LEVEL DRAWING**

# Feed Line Plan 20'

— Round   
 — Flat   
 — App In Face   
 — App Out Face

## Section @ 20'



	<b>BLACK &amp; VEATCH</b>	<b>Black &amp; Veatch Corp.</b>		<b>Job: ES-154 EHamptonAWC</b>
	Building a world of difference.®	6800 W. 115th St., Suite 2292 Overland Park, KS 66211		Project: <b>405025 (EHamptonAWC)</b>
		Phone:	Date: 06/15/20	App'd:
		FAX:	Scale: NTS	Dwg No. E-7

**APPENDIX C**  
**ADDITIONAL CALCULATION**

References

# ANCHOR ROD ANALYSIS

**Project Information**

Site Name: ES-154 EHamptonAWC

TIA Revision:

Rev-G  
 Rev-H

TIA-222-G 105% Allowable?

No  
 Yes

**Max Leg Reactions**

Compression

Axial\_C := 111·kip

Shear\_C := 14·kip

Uplift

Axial\_U := 92·kip

Shear\_U := 12·kip

Apply TIA-222-H Section 15.5?

No  
 Yes

**Anchor Rod Data**

Diameter of Anchor Rod:

D := 1.0·in

Anchor Rod Grade:

Number of Anchor Rods:

N := 6

Length from top of concrete to bottom of anchor rod leveling nut:

lar := 1·in

Threads in Shear Plane?:

Yes  
 No

Thread Series:

Coarse  
 Fine  
 8-Thread

Consider Base Plate Grout?

Yes  
 No

Grout Factor η:

0.90  
 0.70  
 0.55  
 0.50

Threads per Inch: n = 8

(Thread selection invalid if n = 0)

Rod Ultimate Strength: Fu = 125·ksi

Rod Yield Strength: Fy = 105·ksi

Anchor Rod Plastic Section Modulus: (based on tension root diameter)

$$Z := \frac{1}{6} \cdot \left( D - \frac{0.9743 \text{ in}}{n} \right)^3 = 0.113 \cdot \text{in}^3$$

Radius of Gyration:

$$r := \left( \frac{1}{4} \right) \cdot \left( D - \frac{0.9743 \text{ in}}{n} \right) = 0.22 \cdot \text{in}$$

Net Area of Anchor Rod:

$$A_n := \frac{\pi}{4} \cdot \left( D - \frac{0.9743 \text{ in}}{n} \right)^2 = 0.606 \cdot \text{in}^2$$

Nominal Unthreaded Area of Anchor Rod:

$$A_b := \frac{\pi}{4} \cdot (D)^2 = 0.785 \cdot \text{in}^2$$

- F1554-105
- A687
- A354-BC
- A354-BD
- A449
- A572-42
- A572-50
- A572-55
- A572-60
- A572-65
- A588-42
- A588-46
- A588-50
- A36M-42
- A36M-45
- A36M-50
- A36M-55
- A500-50
- A514-GR100
- A53-B-35
- A53-B-42
- A607-60
- A607-65
- S-128
- S-22

TIA-222-G/H Section 4.9.6.1

### Anchor Rod Design Capacities

#### Design Tension Strength:

TIA-222-G/H Section 4.9.6.1

$$R_{nt} := F_u \cdot A_n = 75.718 \cdot \text{kip}$$

$$\phi_t = 0.75$$

$$\phi R_{nt} := \phi_t \cdot R_{nt} = 56.788 \cdot \text{kip}$$

#### Design Compression Strength:

$$R_{nc} := F_y \cdot A_n = 63.603 \cdot \text{kip}$$

$$\phi_c = 1$$

$$\phi R_{nc} := \phi_c \cdot R_{nc} = 63.603 \cdot \text{kip}$$

#### Design Buckling Strength:

TIA-222-H Section 4.5.4.2

$$K_0 := 1.2$$

$$F_{cr} = 104.519 \cdot \text{ksi}$$

$$F_e = 9.581 \times 10^3 \cdot \text{ksi}$$

$$R_{nb} := F_{cr} \cdot A_n = 63.312 \cdot \text{kip}$$

$$\phi_c = 1$$

$$\phi R_{nb} := \phi_c \cdot R_{nb} = 63.312 \cdot \text{kip}$$

#### Design Shear Strength:

TIA-222-G/H Section 4.9.6.3

$$R_{nv} := \begin{cases} 0.55 \cdot F_u \cdot A_b & \text{if Thread\_Type} = \text{"No"} \wedge \text{TIA} = \text{"Rev-G"} \\ 0.45 \cdot F_u \cdot A_b & \text{if Thread\_Type} = \text{"Yes"} \wedge \text{TIA} = \text{"Rev-G"} \\ 0.625 \cdot F_u \cdot A_b & \text{if Thread\_Type} = \text{"No"} \wedge \text{TIA} = \text{"Rev-H"} \\ 0.5 \cdot F_u \cdot A_b & \text{if Thread\_Type} = \text{"Yes"} \wedge \text{TIA} = \text{"Rev-H"} \end{cases}$$

$$R_{nv} = 49.087 \cdot \text{kip}$$

$$R_{nvc} := 0.6 \cdot F_y \cdot 0.5 \cdot A_n = 19.081 \cdot \text{kip}$$

TIA-222-H Section 4.9.9

$$\phi_v = 0.75 \quad \phi_c = 1$$

$$\phi R_{nv} := \phi_v \cdot R_{nv} = 36.816 \cdot \text{kip}$$

$$\phi R_{nvc} := \phi_c \cdot R_{nvc} = 19.081 \cdot \text{kip}$$

#### Design Flexural Strength:

TIA-222-G/H Section 4.7.1

$$R_{mn} := F_y \cdot Z = 11.853 \cdot \text{kip} \cdot \text{in}$$

$$\phi_f = 0.9$$

$$\phi R_{mn} := \phi_f \cdot R_{mn} = 10.668 \cdot \text{kip} \cdot \text{in}$$

### Anchor Rod Loading Demands

Tension Demand:

$$P_{ut} := \frac{\text{Axial\_U}}{N} = 15.333 \cdot \text{kip}$$

Compression Demand:

$$P_{uc} := \frac{\text{Axial\_C}}{N} = 18.5 \cdot \text{kip}$$

Shear Demand:

$$V_{ut} := \frac{\text{Shear\_U}}{N} = 2 \cdot \text{kip}$$

$$V_{uc} := \frac{\text{Shear\_C}}{N} = 2.333 \cdot \text{kip}$$

Moment Demand:

$$M_{ut} := 0.65 \cdot l_{ar} \cdot V_{ut} = 1.3 \cdot \text{kip} \cdot \text{in}$$

$$M_{uc} := 0.65 \cdot l_{ar} \cdot V_{uc} = 1.517 \cdot \text{kip} \cdot \text{in}$$

### Anchor Rod Interaction Check

TIA-222-G Section 4.9.9

$$SR_g := \begin{cases} \frac{P_{ut} + \frac{V_{ut}}{\eta}}{\phi R_{nt}} & \text{if } \eta > 0.50 \\ \frac{P_{ut} + \frac{V_{ut}}{\eta}}{\phi R_{nt}} & \text{if } \eta = 0.50 \wedge l_{ar} \leq D \wedge P_{ut} > P_{uc} \\ \frac{P_{uc} + \frac{V_{uc}}{\eta}}{\phi R_{nt}} & \text{if } \eta = 0.50 \wedge l_{ar} \leq D \wedge P_{ut} < P_{uc} \\ \left( \frac{V_{ut}}{\phi R_{nv}} \right)^2 + \left( \frac{P_{ut}}{\phi R_{nt}} + \frac{M_{ut}}{\phi R_{mn}} \right)^2 & \text{if } \eta = 0.5 \wedge l_{ar} > D \wedge P_{ut} > P_{uc} \\ \left( \frac{V_{uc}}{\phi R_{nv}} \right)^2 + \left( \frac{P_{uc}}{\phi R_{nt}} + \frac{M_{uc}}{\phi R_{mn}} \right)^2 & \text{if } \eta = 0.5 \wedge l_{ar} > D \wedge P_{ut} < P_{uc} \end{cases}$$

$$SR_g = 0.334$$

**Anchor Rod Interaction Check**

TIA-222-H Section 4.9.9

$$SR_{Pt} := \begin{cases} \left(\frac{P_{ut}}{\phi R_{nt}}\right)^2 + \left(\frac{V_{ut}}{\phi R_{nv}}\right)^2 & \text{if } l_{ar} \leq D \\ \left(\frac{P_{ut}}{\phi R_{nt}}\right)^2 + \left(\frac{V_{ut}}{\phi R_{nv}}\right)^2 & \text{if } D < l_{ar} \leq 3 \cdot \text{in} \wedge \text{Grout} = \text{"Yes"} \\ \left(\frac{P_{ut}}{\phi R_{nt}} + \frac{M_{ut}}{\phi R_{mn}}\right)^2 + \left(\frac{V_{ut}}{\phi R_{nv}}\right)^2 & \text{if } 3 \cdot \text{in} < l_{ar} \wedge \text{Grout} = \text{"Yes"} \\ \left(\frac{P_{ut}}{\phi R_{nt}} + \frac{M_{ut}}{\phi R_{mn}}\right)^2 + \left(\frac{V_{ut}}{\phi R_{nv}}\right)^2 & \text{if } D < l_{ar} \wedge \text{Grout} = \text{"No"} \end{cases}$$

SR<sub>Pt</sub> = 0.076

$$SR_{Pc} := \begin{cases} \left(\frac{P_{uc}}{\phi R_{nc}}\right) + \left(\frac{V_{uc}}{\phi R_{nvc}}\right)^2 & \text{if } l_{ar} \leq D \\ \left(\frac{P_{uc}}{\phi R_{nc}}\right) + \left(\frac{V_{uc}}{\phi R_{nvc}}\right)^2 & \text{if } D < l_{ar} \leq 3 \cdot \text{in} \wedge \text{Grout} = \text{"Yes"} \\ \left(\frac{P_{uc}}{\phi R_{nc}} + \frac{M_{uc}}{\phi R_{mn}}\right) + \left(\frac{V_{uc}}{\phi R_{nvc}}\right)^2 & \text{if } 3 \cdot \text{in} < l_{ar} \wedge \text{Grout} = \text{"Yes"} \\ \left(\frac{P_{uc}}{\phi R_{nc}} + \frac{M_{uc}}{\phi R_{mn}}\right) + \left(\frac{V_{uc}}{\phi R_{nvc}}\right)^2 & \text{if } D < l_{ar} \leq 4 \cdot D \wedge \text{Grout} = \text{"No"} \\ \left(\frac{P_{uc}}{\phi R_{nb}} + \frac{M_{uc}}{\phi R_{mn}}\right) + \left(\frac{V_{uc}}{\phi R_{nvc}}\right)^2 & \text{if } l_{ar} > 4 \cdot D \wedge \text{Grout} = \text{"No"} \end{cases}$$

SR<sub>Pc</sub> = 0.306

$$SR := \begin{cases} SR_g & \text{if TIA} = \text{"Rev-G"} \\ \max(SR_{Pt}, SR_{Pc}) & \text{if TIA} = \text{"Rev-H"} \wedge S15 = \text{"No"} \\ \frac{\max(SR_{Pt}, SR_{Pc})}{1.05} & \text{if TIA} = \text{"Rev-H"} \wedge S15 = \text{"Yes"} \end{cases} = 0.291$$

$$Check_{SR} := \begin{cases} \text{"Passing"} & \text{if } SR \leq 1.00 \wedge \text{TIA} = \text{"Rev-G"} \wedge S105 = \text{"Yes"} \\ \text{"Acceptable"} & \text{if } 1.00 < SR \leq 1.05 \wedge \text{TIA} = \text{"Rev-G"} \wedge S105 = \text{"Yes"} \\ \text{"Failing"} & \text{if } SR > 1.05 \wedge \text{TIA} = \text{"Rev-G"} \wedge S105 = \text{"Yes"} \\ \text{"Passing"} & \text{if } SR \leq 1.00 \wedge \text{TIA} = \text{"Rev-G"} \wedge S105 = \text{"No"} \\ \text{"Failing"} & \text{if } SR > 1.00 \wedge \text{TIA} = \text{"Rev-G"} \wedge S105 = \text{"No"} \\ \text{"Passing"} & \text{if } SR \leq 1.0 \wedge \text{TIA} = \text{"Rev-H"} \\ \text{"Failing"} & \text{if } SR > 1.0 \wedge \text{TIA} = \text{"Rev-H"} \end{cases} = \text{"Passing"}$$

## Anchor Rod Results

Axial Tension Demand:	$P_{ut} = 15.333 \cdot \text{kip}$
Axial Tension Capacity:	$\phi R_{nt} = 56.788 \cdot \text{kip}$
Axial Compression Demand:	$P_{uc} = 18.5 \cdot \text{kip}$
Axial Compression Capacity:	$\phi R_{nc} = 63.603 \cdot \text{kip}$
Shear Tension Demand:	$V_{ut} = 2 \cdot \text{kip}$
Tension Shear Capacity:	$\phi R_{nv} = 36.816 \cdot \text{kip}$
Shear Compression Demand:	$V_{uc} = 2.333 \cdot \text{kip}$
Compression Shear Capacity:	$\phi R_{nvc} = 19.081 \cdot \text{kip}$
Moment Tension Demand:	$M_{ut} = \text{"Moment Not Considered"} \cdot \text{kip} \cdot \text{in}$
Moment Compression Demand:	$M_{uc} = \text{"Moment Not Considered"} \cdot \text{kip} \cdot \text{in}$
Moment Capacity:	$\phi R_{mn} = \text{"Moment Not Considered"} \cdot \text{kip} \cdot \text{in}$

## Governing Stress Ratio

$$SR = 29.126\%$$

$$Check_{SR} = \text{"Passing"}$$

# SST Unit Base Foundation

ES-154
EHamptonAWC

TIA-222 Revision: 

H
---

Top & Bot. Pad Rein. Different?:	<input type="checkbox"/>
Tower Centroid Offset?:	<input checked="" type="checkbox"/>
Block Foundation?:	<input type="checkbox"/>

Superstructure Analysis Reactions		
Global Moment, <b>M</b> :	1547	ft-kips
Global Axial, <b>P</b> :	17	kips
Global Shear, <b>V</b> :	23	kips
Leg Compression, <b>P<sub>comp</sub></b> :	111	kips
Leg Comp. Shear, <b>V<sub>u,comp</sub></b> :	14	kips
Leg Uplift, <b>P<sub>uplift</sub></b> :	92	kips
Leg Uplift. Shear, <b>V<sub>u,uplift</sub></b> :	12	kips
Tower Height, <b>H</b> :	120	ft
Base Face Width, <b>BW</b> :	17	ft
BP Dist. Above Fdn, <b>bp<sub>dist</sub></b> :	2	in

Foundation Analysis Checks				
	Capacity	Demand	Rating*	Check
<i>Lateral (Sliding) (kips)</i>	162.97	23.00	13.4%	Pass
<i>Bearing Pressure (ksf)</i>	9.00	1.14	12.0%	Pass
<i>Overturning (kip*ft)</i>	3952.16	1700.25	43.0%	Pass
<i>Pier Flexure (Comp.) (kip*ft)</i>	440.65	42.00	9.1%	Pass
<i>Pier Flexure (Tension) (kip*ft)</i>	297.91	36.00	11.5%	Pass
<i>Pier Compression (kip)</i>	3514.85	113.65	3.1%	Pass
<i>Pad Flexure (kip*ft)</i>	1510.81	120.07	7.6%	Pass
<i>Pad Shear - 1-way (kips)</i>	413.18	43.22	10.0%	Pass
<i>Pad Shear - Comp 2-way (ksi)</i>	0.201	0.063	30.0%	Pass
<i>Flexural 2-way (Comp) (kip*ft)</i>	845.77	25.20	2.8%	Pass
<i>Pad Shear - Tension 2-way (ksi)</i>	0.201	0.055	26.0%	Pass
<i>Flexural 2-way (Tension) (kip*ft)</i>	845.77	21.60	2.4%	Pass

\*Rating per TIA-222-H Section 15.5

Soil Rating*:	43.0%
Structural Rating*:	30.0%

Pier Properties		
Pier Shape:	Circular	
Pier Diameter, <b>dpier</b> :	2.5	ft
Ext. Above Grade, <b>E</b> :	0.50	ft
Pier Rebar Size, <b>Sc</b> :	7	
Pier Rebar Quantity, <b>mc</b> :	12	
Pier Tie/Spiral Size, <b>St</b> :	4	
Pier Tie/Spiral Quantity, <b>mt</b> :	5	
Pier Reinforcement Type:	Tie	
Pier Clear Cover, <b>cc<sub>pier</sub></b> :	3	in

Pad Properties		
Depth, <b>D</b> :	4.00	ft
Pad Width, <b>W</b> :	25.00	ft
Pad Thickness, <b>T</b> :	1.50	ft
Pad Rebar Size (Bottom), <b>Sp</b> :	7	
Pad Rebar Quantity (Bottom), <b>mp</b> :	43	
Pad Clear Cover, <b>cc<sub>pad</sub></b> :	3	in

Material Properties		
Rebar Grade, <b>Fy</b> :	60	ksi
Concrete Compressive Strength, <b>F'c</b> :	4.50	ksi
Dry Concrete Density, <b>δc</b> :	150	pcf

Soil Properties		
Total Soil Unit Weight, <b>γ</b> :	125	pcf
Ultimate Gross Bearing, <b>Qult</b> :	12.000	ksf
Cohesion, <b>Cu</b> :	0.000	ksf
Friction Angle, <b>φ</b> :	34	degrees
SPT Blow Count, <b>N<sub>blows</sub></b> :	13	
Base Friction, <b>μ</b> :	0.6	
Neglected Depth, <b>N</b> :	3.3	ft
Foundation Bearing on Rock?	No	
Groundwater Depth, <b>gw</b> :	26	ft

<-- Toggle between Gross and Net

## PHYSICAL PARAMETERS

Pier Height Above Water Table:	$h_{pier\_above} = (MIN(gw,D-T) + E)$	$h_{pier\_above} = 3$ ft
Pier Height Below Water Table:	$h_{pier\_below} = ((D-T) - MIN(gw,D-T))$	$h_{pier\_below} = 0$ ft
Buoyant Weight of Pier:	$W_{pier} = \frac{(\pi/4) * (d_{pier}^2) * h_{pier\_above} * \delta c + 1000 + (\pi/4) * (d_{pier}^2) * h_{pier\_below} * (\delta c - 62.4) / 1000}{}$	$W_{pier} = 2.21$ kips
Pad Height Above Water Table:	$h_{pad\_above} = IF(gw <= D-T, 0, IF(gw > D-T, (D-gw)))$	$h_{pad\_above} = 1.5$ ft
Pad Height Below Water Table:	$h_{pad\_below} = (T - IF(gw <= D-T, 0, IF(gw > D-T, (D-gw)))$	$h_{pad\_below} = 0$ ft
Buoyant Weight of Pad:	$W_{pad} = (W^2) * h_{pad\_above} * \delta c + 1000 + (W^2) * h_{pad\_below} * (\delta c - 62.4) / 1000$	$W_{pad} = 140.63$ kips
Concrete weight:	$W_c = V * \delta c$	$W_c = 147.3$ kips
Soil weight:	$W_s = (D - T) * (W^2 - 3 * (d_{pier}^2 / 4 * \pi)) * \gamma$	$W_s = 190.7$ kips
EIA/TIA-222 Load Factor:	$LF = 1$	$LF = 1.00$

## LATERAL RESISTANCE

Total Nominal Pp Resistance:	$P_{p\_total} = P_{p\_pier} * A_{p\_piers} + P_{p\_pad} * A_{p\_pad}$	$P_{p\_total} = 27.14$ kips
Factored Total Weight for Compression:	$P_{factored\_comp} = \phi D * (W_c + W_s + P / 1.2)$	$P_{factored\_comp} = 316.92$ kips
Nominal Base Friction Resistance (Comp):	$R_{s\_comp} = P * \mu$	$R_{s\_comp} = 190.15$ kips
Lateral Resistance (Comp):	$\phi V_n = \phi_s * (P_{p\_total} + R_{s\_comp})$	$\phi V_n = 162.97$ kips
Check	$\phi V_n = 162.97$ kips $\geq$ $V_u = 23.00$ kips	RATING: <b>14.11%</b> <b>OK</b>

## PIER REINFORCEMENT

## Pier / Column Compression

Pier Cross-Sectional Area:	$A_1 = d_{pier}^2 * \pi / 4$	$A_1 = 706.86$ in <sup>2</sup>
Support Area (2H:1V Slope):	$A_2 = (MIN((2 * (W/2 - (2/3) * BW * \cos(30^\circ) + Offset)), (W - BW), d_{pier} + 4 * T)) * (\pi / 4)$	$A_2 = 7238.23$ in <sup>2</sup>
Compressive Resistance (H/D < 3):	$\phi P_{n1} = 0.65 * 0.85 * F_c * A_1 * MIN(\sqrt{(A_2/A_1)}, 2)$	$\phi P_{n1} = 3514.85$ kips
Rebar:	$s_{pier} = 7$ $m_{pier} = 12$	$d_{b\_pier} = 0.875$ in $A_{b\_pier} = 0.6$ in <sup>2</sup>
Provided area of steel:	$A_{s\_pier} = A_{b\_pier} * m_{pier}$	$A_{s\_pier} = 7.20$ in <sup>2</sup>
Compressive Resistance (H/D >= 3):	$\phi P_{n2} = 0.65 * 0.8 * (0.85 * (F_c) * (A_1 - A_{s\_pier}) + ((F_y) * A_{s\_pier}))$	$\phi P_{n2} = 1616.26$ kips
	$H/D = (D - T + E) / d_{pier}$	$H/D = 1.20$
Utilized Compressive Resistance:	$\phi P_n = P_{n1}$	$\phi P_n = 3514.85$ kips
Applied Compressive Force:	$P_u = P_{comp} + 1.2 * W_{pier}$	$P_u = 113.65$ kips
Check	$\phi P_n = 3514.85$ kips $\geq$ $P_u = 113.65$ kips	RATING: <b>3.23%</b> <b>OK</b>

## Pier Flexure

Cross-sectional area:	$A_g = d_{pier}^2 * \pi / 4$	$A_g = 706.86$ in <sup>2</sup>
Min. area of steel (pier):	$A_{smin\_pier} = A_g * 0.005$	$A_{smin\_pier} = 3.53$ in <sup>2</sup>
Cage Diameter:	$d_o = d_{pier} - 2 * cc - 2 * tie - d_b$	$d_o = 22.13$ in
Check	$A_{s\_pier} = 7.20$ in <sup>2</sup> $\geq$ $A_{smin\_pier} = 3.53$ in <sup>2</sup>	<b>OK</b>
Applied Moment to DSMC (Compression):	$M_{u\_comp} = IF(T > D, E, (D - T + E)) * V_{u\_comp}$	$M_{u\_comp} = 42.00$ ft-kips
Pier Moment Capacity (Compression):	$\phi M_{n\_comp} = \text{from DSMC}$	$\phi M_{n\_comp} = 440.65$ ft-kips
Check	$M_{u\_comp} = 42.00$ ft-kips $\geq$ $\phi M_{n\_comp} = 440.65$ ft-kips	RATING: <b>9.53%</b> <b>OK</b>
Applied Moment to DSMC (Tension):	$M_{u\_tension} = IF(T > D, E, (D - T + E)) * V_{u\_uplift}$	$M_{u\_tension} = 36.00$ ft-kips
Pier Moment Capacity (Tension):	$\phi M_{n\_tension} = \text{from DSMC}$	$\phi M_{n\_tension} = 297.91$ ft-kips
Check	$M_{u\_tension} = 36.00$ ft-kips $\geq$ $\phi M_{n\_tension} = 297.91$ ft-kips	RATING: <b>12.08%</b> <b>OK</b>

## PAD REINFORCEMENT

## Elastic Bearing Pressure for Soil Checks

Tower Centroid offset from Fdn Centroid:	$Offset = (1/2 - 1/3) * BW * \sin(60^\circ)$	$Offset = 2.45$ ft
Distance from Leg to Edge of Pad:	$L_{edge} = (1/2) * W - Offset - (1/3) * BW * \sin(60^\circ)$	$L_{edge} = 5.14$ ft
Overturning Moment (0.9*D LC):	$M_{o\_0.9} = M + V * (D + E + bpdist/12) + (0.9/1.2) * (P + 3 * W_{pier} * 1.2) * Offset$	$M_{o\_0.9} = 1700.25$ ft-kips
Overturning Moment (1.2*D LC):	$M_{o\_1.2} = M + V * (D + E + bpdist/12) + (1.2/1.2) * (P + 3 * W_{pier} * 1.2) * Offset$	$M_{o\_1.2} = 1715.56$ ft-kips
Compressive Load for Bearing:	$P_{bearing} = W_c + W_s + P / 1.2$	$P_{bearing} = 352.13$ kips
Load Eccentricity (0.9*D LC):	$e_{c\_0.9} = M_o / 0.9 * P_{bearing}$	$e_{c\_0.9} = 5.36$ ft <span style="float: right;"><math>L/6 &lt; e &lt;= L/4</math></span>



Eq. Square Area of Concrete in Shear (2):	$A_{c\_sq\_2} = P_{crit\_sq\_2} * d_{c\_2}$	$A_{c\_sq\_2} = 2506.11$	in <sup>2</sup>
Eq. Square Area of Concrete in Shear (3):	$A_{c\_sq\_3} = P_{crit\_sq\_3} * d_{c\_2}$	$A_{c\_sq\_3} = 2892.16$	in <sup>2</sup>
Eq. Square Area of Concrete in Shear (4):	$A_{c\_sq\_4} = P_{crit\_sq\_4} * d_{c\_2}$	$A_{c\_sq\_4} = 2892.16$	in <sup>2</sup>
Eq. Square Area of Concrete in Shear (5):	$A_{c\_sq\_5} = P_{crit\_sq\_5} * d_{c\_2}$	$A_{c\_sq\_5} = 2124.08$	in <sup>2</sup>
Polar Moment of Inertia at assumed Critical Section:	$J_{c\_crit} = \frac{dc\_2^2 * (dpier1 + dc\_2)^3}{6} + \frac{(dpier1 + dc\_2) * (dc\_2^3)}{6} + \frac{(dc\_2^2 * (dpier1 + dc\_2) * (dpier1 + dc\_2)^2)}{2 * (IF(SL\$169=0,2,4))}$	$J_{c\_crit} = 829730.48$	in <sup>4</sup>
Eq. Square Polar Moment of Inertia at assumed Critical Section 1:	$J_{c\_sq\_1} = \frac{(dc\_2^2 * (dpier\_sq + dc\_2)^3)}{6} + \frac{(dpier\_sq + dc\_2) * (dc\_2^3)}{6} + \frac{(dc\_2^2 * (dpier\_sq + dc\_2) * (dpier\_sq + dc\_2)^2)}{2}$	$J_{c\_sq\_1} = 654538.36$	in <sup>4</sup>
Eq. Square Polar Moment of Inertia at assumed Critical Section:	$J_{c\_sq\_2} = \frac{(dc\_2^2 * (dpier\_sq + dc\_2)^3)}{12} + \frac{(dpier\_sq + dc\_2) * (dc\_2^3)}{12} + \frac{(dc\_2^2 * (dpier\_sq + dc\_2) * (dpier\_sq + dc\_2)^2)}{2}$	$J_{c\_sq\_2} = 565550.30$	in <sup>4</sup>
Eq. Square Polar Moment of Inertia at assumed Critical Section:	$J_{c\_sq\_3} = \frac{(dc\_2^2 * (dpier\_sq + dc\_2)^3)}{6} + \frac{(dpier\_sq + dc\_2) * (dc\_2^3)}{6} + \frac{(dc\_2^2 * (dpier\_sq + dc\_2) * (dpier\_sq + dc\_2)^2)}{4}$	$J_{c\_sq\_3} = 416257.25$	in <sup>4</sup>
Eq. Square Polar Moment of Inertia at assumed Critical Section:	$J_{c\_sq\_4} = \frac{(dc\_2^2 * (dpier\_sq + dc\_2)^3)}{6} + \frac{(dpier\_sq + dc\_2) * (dc\_2^3)}{6} + \frac{(dc\_2^2 * (dpier\_sq + dc\_2) * (dpier\_sq + dc\_2)^2)}{4}$	$J_{c\_sq\_4} = 416257.25$	in <sup>4</sup>
Eq. Square Polar Moment of Inertia at assumed Critical Section:	$J_{c\_sq\_5} = \frac{(dc\_2^2 * (dpier\_sq + dc\_2)^3)}{12} + \frac{(dpier\_sq + dc\_2) * (dc\_2^3)}{12} + \frac{(dc\_2^2 * (dpier\_sq + dc\_2) * (dpier\_sq + dc\_2)^2)}{4}$	$J_{c\_sq\_5} = 327269.18$	in <sup>4</sup>
Applied Shear Force (1.2*D LC):	$V_{u,1,2} = 1.2 * W_{pier} + 1.2 * IF(OR(\$B\$1="G",\$B\$1="H"), P_{comp} / 1.2, P_{comp})$	$V_{u,1,2} = 113.65$	kip
Controlling Shear Stress (1.2*D LC):	$V_{u,1,2\_controlling} = V_{u,1,2} / A_c + (Y_v * M_v * (d_{pier1} + dc\_2) / J_{c,1})$	$V_{u,1,2\_controlling} = 0.063$	ksi
Eq. Sq. Controlling Shear Stress (1.2*D LC):	$V_{u,1,2\_controlling\_sq} = V_{u,1,2} / A_c + (Y_v * M_v * (d_{pier\_sq} + dc\_2) / J_c)$	$V_{u,1,2\_controlling\_sq} = 0.066$	ksi
Shear Stress Capacity:	$\Phi V_n = \phi_s * 4 * (\sqrt{F_c * 1000}) / 1000$	$\Phi V_n = 0.201$	ksi
<b>Check</b>	$\Phi V_n = 0.201$ ksi	$\geq$	$V_{u\_demand} = 0.063$ ksi
		<b>RATING:</b>	<b>31.51% OK</b>

**Two-Way Shear (Compression, Flexural Component) [BOTTOM REINFORCEMENT]**

Distance To Outside Edge:	$dist_{outside} = MIN((W-BW)/2, BW/2) * 2$	$dist_{outside} = 8$	ft
Effective Pad Width:	$b_{pad} = MIN(dpier + 3 * T, W, dist_{outside})$	$b_{pad} = 7.00$	ft
Bar Spacing:	$B_{s\_pad} = B_{s\_pad}$ (see design checks below)	$B_{s\_pad} = 6.98$	in
Fraction of Bars in Effective Width:	$m_{effective} = IF(b_{pad} = W, mp, 12 * b_{pad} / B_{s\_pad})$	$m_{effective} = 12.04$	
Area of Steel in Effective Width:	$A_{s\_effective} = VLOOKUP(Sp, Ref\$A\$2:\$C\$12, 3, 0) * m_{slab}$	$A_{s\_effective} = 7.22$	in <sup>2</sup>
Depth of Equivalent Rectangular Stress Block:	$a_{effective} = A_{s\_effective} * F_y / (0.85 * F_c * b_{slab} * 12)$	$a_{effective} = 1.35$	in
	$\beta_{pad} = \beta_{pad}$ (see design checks below)	$\beta_{pad} = 0.825$	
Distance from Top to Neutral Axis:	$c_{effective} = a_{effective} / \beta_{pad}$	$c_{effective} = 1.63$	
Effective depth:	$dc = dc$ (see One-Way Shear check above)	$dc = 13.6875$	in
Modulus of Elasticity of Steel:	$E_s = 29000$ ksi	$E_s = 29000$	ksi
Strain in Steel:	$\epsilon_{s\_effective} = 0.003 * (dc - c) / c$	$\epsilon_{s\_effective} = 0.02212$	in/in
Compression-Controlled Strain Limit:	$\epsilon_c = F_y / E_s$	$\epsilon_c = 0.00207$	in/in
Tension-Controlled Strain Limit:	$\epsilon_t = 0.005$	$\epsilon_t = 0.00500$	in/in
Flexure Strength Reduction Factor:	$\phi_{flex\_effective} = IF(\epsilon_s \geq \epsilon_t, 0.9, IF(\epsilon_s < \epsilon_c, 0.65, 0.65 + (0.9 - 0.65) * ((\epsilon_s - \epsilon_c) / (\epsilon_t - \epsilon_c))))$	$\phi_{flex\_effective} = 0.9$	
Nominal Flexural Strength:	$M_{n\_effective} = A_{s\_effective} * (F_y) * (dc - a_{effective} / 2) * (1/12)$	$M_{n\_effective} = 469.87$	ft-kips
Design Flexural Strength:	$\phi M_{n\_effective} = \phi_{flex\_effective} * M_{n\_effective}$	$\phi M_{n\_effective} = 422.89$	ft-kips

**Two-Way Shear (Compression, Flexural Component) [TOP REINFORCEMENT]**

Bar Spacing:	$B_{s\_pad\_top} = IF(Input!\$S\$6=TRUE, (W * 12 - 2 * ccpad - VLOOKUP(sptop, Ref\$A\$2:\$C\$12, 2, 0)), B_{s\_pad})$	$B_{s\_pad\_top} = 7.00$	in
Fraction of Bars in Effective Width:	$m_{effective\_top} = IF(b_{pad} = W, mp, 12 * b_{pad} / B_{s\_pad\_top})$	$m_{effective\_top} = 12.04$	
Area of Steel in Effective Width:	$A_{s\_effective\_top} = VLOOKUP(Sptop, Ref\$A\$2:\$C\$12, 3, 0) * m_{slab}$	$A_{s\_effective\_top} = 7.22$	in <sup>2</sup>
Depth of Equivalent Rectangular Stress Block:	$a_{effective\_top} = A_{s\_effective\_top} * F_y / (0.85 * F_c * b_{slab} * 12)$	$a_{effective\_top} = 1.35$	in
Distance from Top to Neutral Axis:	$c_{effective\_top} = a_{effective\_top} / \beta_{pad}$	$c_{effective\_top} = 1.63$	
Effective depth:	$dc_{top} = T * 12 - ccpad - 1.5 * VLOOKUP(sptop, Ref\$A\$2:\$C\$12, 2, 0)$	$dc_{top} = 13.6875$	in
Strain in Steel:	$\epsilon_{s\_effective\_top} = 0.003 * (dc_{top} - c_{effective\_top}) / c_{effective\_top}$	$\epsilon_{s\_effective\_top} = 0.02212$	in/in
Flexure Strength Reduction Factor:	$\phi_{flex\_effective\_top} = IF(\epsilon_s \geq \epsilon_t, 0.9, IF(\epsilon_s < \epsilon_c, 0.65, 0.65 + (0.9 - 0.65) * ((\epsilon_s - \epsilon_c) / (\epsilon_t - \epsilon_c))))$	$\phi_{flex\_effective\_top} = 0.9$	
Nominal Flexural Strength:	$M_{n\_effective\_top} = A_{s\_effective\_top} * (F_y) * (dc_{top} - a_{effective\_top} / 2) * (1/12)$	$M_{n\_effective\_top} = 469.87$	ft-kips
Design Flexural Strength:	$\phi M_{n\_effective\_top} = \phi_{flex\_effective\_top} * M_{n\_effective\_top}$	$\phi M_{n\_effective\_top} = 422.89$	ft-kips

Applied Moment:  $Yf^*M_{u\_comp} = Yf^*M_{u\_comp}$   $Yf^*M_{u\_comp} = 25.2$  ft-kips

Check  $\phi M_{n\_effective} = 845.77$  ksi  $\geq Yf^*M_{u\_comp} = 25.20$  ksi RATING: **2.98%** **OK**

**Two-Way Shear (Uplift)**

Moment applied at base of Pier:	$M_{v\_tens} = M_{u\_tension} * 12$ in / ft	$M_{v\_tens} = 432.00$ kip*in
Diameter of Longitudinal Rebar Cage:	$d_{cage} = \text{dpier} * 12 - 2 * (\text{ccpier} + \text{VLOOKUP}(\text{St\_Ref!} \$A\$2 : \$C\$12, 2, 0)) - \text{VLOOKUP}(\text{Sc\_Ref!} \$A\$2 : \$C\$12, 2, 0)$	$d_{cage} = 22.13$ in
Eq. Sq. Diameter of Longitudinal Rebar Cage:	$d_{cage\_sq} = \text{SQRT}(\text{PI}()) * 2 * d_{cage}$	$d_{cage\_sq} = 19.61$ in
Steel Embedment Length:	$L_{embed} = dc\_2$ (see One-Way Shear check above)	$L_{embed} = 14.13$ in
Radius of Two-Way Shear Plane:	$r_{2way\_tens} = 0.5 * (d_{cage} / 12 + L_{embed} / 12)$	$r_{2way\_tens} = 1.51$ ft
	$r_{2way\_tens\_sq} = 0.5 * (\text{SQRT}(\text{PI}()) * 2 * d_{cage} / 12 + L_{embed} / 12)$	$r_{2way\_tens\_sq} = 1.41$ ft
Length of Shear Perimeter to Deduct:	$s_{tens} = r_{tens} * \text{RADIANS}(2 * \text{ACOS}(((r_{tens} - \text{MAX}(r_{tens} - \text{Ledge}, 0)) / r_{tens})) * 180 / \text{PI}())$	$s_{tens} = 0.00$ ft
Eq. Sq. Length of Shear Perimeter to Deduct:	$s_{tens\_sq} = 0$	$s_{tens\_sq} = 0.00$ ft
Circular Critical Perimeter:	$P_{crit\_tens} = ((d_{cage} / 12 + L_{embed} / 12) * \text{PI}() - s_{tens}) * 12$	$P_{crit\_tens} = 113.88$ in
Equivalent Square Critical Perimeter 1:	$P_{crit\_tens\_sq\_1} = 4 * (d_{cage\_sq} + L_{embed})$	$P_{crit\_tens\_sq\_1} = 134.93$ in
Equivalent Square Critical Perimeter 2:	$P_{crit\_tens\_sq\_2} = 2 * (d_{cage\_sq} + L_{embed}) + (W * 12 - BW * 12)$	$P_{crit\_tens\_sq\_2} = 163.47$ in
Equivalent Square Critical Perimeter 3:	$P_{crit\_tens\_sq\_3} = 2 * (d_{cage\_sq} + L_{embed}) + (W - BW * \text{COS}(\text{RADIANS}(30)) - \text{Ledge}2) * 12$	$P_{crit\_tens\_sq\_3} = 190.80$ in
Equivalent Square Critical Perimeter 4:	$P_{crit\_tens\_sq\_4} = 2 * (d_{cage\_sq} + L_{embed} + \text{Ledge}2 * 12)$	$P_{crit\_tens\_sq\_4} = 190.80$ in
Equivalent Square Critical Perimeter 5:	$P_{crit\_tens\_sq\_5} = d_{cage\_sq} + L_{embed} + 0.5 * (W - BW) * 12 + (W - BW * \text{COS}(\text{RADIANS}(30)) - L_{edge}2) * 12$	$P_{crit\_tens\_sq\_5} = 143.40$ in
Area of Concrete in Shear:	$A_{c\_tens} = P_{crit\_tens} * L_{embed}$	$A_{c\_tens} = 1608.59$ in <sup>2</sup>
Equivalent Square Area of Concrete in Shear:	$A_{c\_tens\_sq1} = P_{crit\_tens\_sq1} * L_{embed}$	$A_{c\_tens\_sq1} = 1905.90$ in <sup>2</sup>
	$A_{c\_tens\_sq2} = P_{crit\_tens\_sq2} * L_{embed}$	$A_{c\_tens\_sq2} = 2308.95$ in <sup>2</sup>
	$A_{c\_tens\_sq3} = P_{crit\_tens\_sq3} * L_{embed}$	$A_{c\_tens\_sq3} = 2695.00$ in <sup>2</sup>
	$A_{c\_tens\_sq4} = P_{crit\_tens\_sq4} * L_{embed}$	$A_{c\_tens\_sq4} = 2695.00$ in <sup>2</sup>
	$A_{c\_tens\_sq5} = P_{crit\_tens\_sq5} * L_{embed}$	$A_{c\_tens\_sq5} = 2025.50$ in <sup>2</sup>
Polar Moment of Inertia at assumed Critical Section:	$J_{c\_tens} = L_{embed} * (d_{cage} + L_{embed})^3 / 3 + ((d_{cage} + L_{embed}) * (L_{embed}^3)) / 6 + (L_{embed} * (d_{cage} + L_{embed})) * (d_{cage} + L_{embed})^2 / (IF(\text{Ledge}2 = 0, 2, 4))$	$J_{c\_tens} = 297376.82$ in <sup>4</sup>
Eq. Square Polar Moment of Inertia at assumed Critical Section 1:	$J_{c\_tens\_sq\_1} = ((L_{embed} * (d_{cage\_sq} + L_{embed})^3) / 3 + ((d_{cage\_sq} + L_{embed}) * (L_{embed}^3)) / 6 + (L_{embed} * (d_{cage\_sq} + L_{embed})) * (d_{cage\_sq} + L_{embed})^2) / 2$	$J_{c\_tens\_sq\_1} = 377298.22$ in <sup>4</sup>
Eq. Square Polar Moment of Inertia at assumed Critical Section 2:	$J_{c\_tens\_sq\_2} = ((L_{embed} * (d_{cage\_sq} + L_{embed})^3) / 12 + ((d_{cage\_sq} + L_{embed}) * (L_{embed}^3)) / 12 + (L_{embed} * (d_{cage\_sq} + L_{embed})) * (d_{cage\_sq} + L_{embed})^2) / 2$	$J_{c\_tens\_sq\_2} = 324194.42$ in <sup>4</sup>
Eq. Square Polar Moment of Inertia at assumed Critical Section 3:	$J_{c\_tens\_sq\_3} = ((L_{embed} * (d_{cage\_sq} + L_{embed})^3) / 6 + ((d_{cage\_sq} + L_{embed}) * (L_{embed}^3)) / 6 + (L_{embed} * (d_{cage\_sq} + L_{embed})) * (d_{cage\_sq} + L_{embed})^2) / 4$	$J_{c\_tens\_sq\_3} = 241752.90$ in <sup>4</sup>
Eq. Square Polar Moment of Inertia at assumed Critical Section 4:	$J_{c\_tens\_sq\_4} = ((L_{embed} * (d_{cage\_sq} + L_{embed})^3) / 3 + ((d_{cage\_sq} + L_{embed}) * (L_{embed}^3)) / 6 + (L_{embed} * (d_{cage\_sq} + L_{embed})) * (d_{cage\_sq} + L_{embed})^2) / 4$	$J_{c\_tens\_sq\_4} = 241752.90$ in <sup>4</sup>
Eq. Square Polar Moment of Inertia at assumed Critical Section 5:	$J_{c\_tens\_sq\_5} = ((L_{embed} * (d_{cage\_sq} + L_{embed})^3) / 12 + ((d_{cage\_sq} + L_{embed}) * (L_{embed}^3)) / 12 + (L_{embed} * (d_{cage\_sq} + L_{embed})) * (d_{cage\_sq} + L_{embed})^2) / 4$	$J_{c\_tens\_sq\_5} = 188649.11$ in <sup>4</sup>
Applied Shear Force (0.9*D LC):	$V_{u\_0.9\_tens} = \text{MAX}(-0.9 * W_{pier} + 0.9 * \text{IF}(\text{OR}(\$B\$1 = "G", \$B\$1 = "H"), \text{Puplift} / 0.9, \text{Puplift}), 0)$	$V_{u\_0.9\_tens} = 90.01$ kip
Controlling Shear Stress (0.9*D LC):	$V_{u\_0.9\_controlling\_tens} = V_{u\_0.9} / A_{c\_tens} + (Y_v * M_v * (d_{cage} + L_{embed}) / 2) / J_{c\_tens}$	$V_{u\_0.9\_controlling\_tens} = 0.066$ ksi
Equivalent Square Shear Stress (0.9*D LC):	$V_{u\_0.9\_tens\_sq} = V_{u\_0.9\_tens} / A_{c\_tens\_sq1} + (Y_v * M_v * (d_{cage\_sq} + L_{embed}) / 2) / J_{c\_tens\_sq1}$	$V_{u\_0.9\_tens\_sq} = 0.055$ ksi
Shear Stress Capacity:	$\phi V_n = \phi_s * 4 * (\sqrt{F_c} * 1000) / 1000$	$\phi V_n = 0.201$ ksi
Check $\phi V_n = 0.201$ ksi $\geq V_{u\_demand} = 0.055$ ksi RATING: <b>27.31%</b> <b>OK</b>		

**Two-Way Shear (Uplift, Flexural Component)**

Applied Moment:  $Yf^*M_{u\_tension} = Yf^*M_{u\_tension}$   $Yf^*M_{u\_tension} = 21.6$

Check  $\phi M_{n\_effective} = 845.77$  ksi  $\geq Yf^*M_{u\_tension} = 21.60$  ksi RATING: **2.55%** **OK**

**Pad Flexure (Net Bearing Pressure)**

$\beta_{pad} = \text{IF}(F_c < 4, 0.85, \text{IF}(F_c >= 8, 0.65, 0.85 - (F_c - 4) * 0.05))$   $\beta_{pad} = 0.825$

<i>Provided Steel:</i>	$A_{s\_pad} = A_{b\_pad} * m_{pad}$	$A_{s\_pad} = 25.80$	in <sup>2</sup>
<i>Depth of Equivalent Rectangular Stress Block:</i>	$a = A_{s\_pad} * F_y / (0.85 * F_c * W)$	$a = 1.35$	in
<i>Distance from Top to Neutral Axis:</i>	$c = a / \beta_{pad}$	$c = 1.64$	in
<i>Modulus of Elasticity of Steel:</i>	$E_s = 29000$	ksi	
<i>Strain in Steel:</i>	$\epsilon_s = 0.003 * (dc-c) / c$	$\epsilon_s = 0.02211$	in/in
<i>Compression-Controlled Strain Limit:</i>	$\epsilon_c = F_y / E_s$	$\epsilon_c = 0.00207$	in/in
<i>Tension-Controlled Strain Limit:</i>	$\epsilon_t = 0.005$	$\epsilon_t = 0.00500$	in/in
<i>Flexure Strength Reduction Factor:</i>	$\phi_{flex} = IF(\epsilon_s \geq \epsilon_t, 0.9, IF(\epsilon_s \leq \epsilon_c, 0.65, 0.65 + (0.9 - 0.65) * ((\epsilon_s - \epsilon_c) / (\epsilon_t - \epsilon_c))))$	$\phi_{flex} = 0.9$	
<i>Nominal Flexural Strength:</i>	$M_n = A_{s\_pad} * (F_y) * (dc - a / 2) * (1/12)$	$M_n = 1678.68$	ft-kips
<i>Design Flexural Strength:</i>	$\phi M_n = \phi_{flex} * M_n$	$\phi M_n = 1510.81$	ft-kips
<i>Bearing Press. at Crit. Section (0.9*D LC):</i>	$q_{mid\_0.9} = q_{u\_st\_0.9} - sqs_{0.9} * d'$	$q_{mid\_0.9} = 0.97$	ksf
<i>Bearing Press. at Crit. Section (1.2*D LC):</i>	$q_{mid\_1.2} = q_{u\_st\_1.2} - sqs_{1.2} * d'$	$q_{mid\_1.2} = 1.13$	ksf

*Resisting Weight above Critical Section:*

	Thickness (ft)	Unit Weight (kcf)	Weight (kip) (0.9*D LC)	Weight (kip) (1.2*D LC)	Moment Arm (ft)	Resisting Moment (ft-kips) (0.9*D LC)	Resisting Moment (ft-kips) (1.2*D LC)
Soil Above Water Table:	2.5	0.125	27.34	36.46	1.944392034	53.17	70.89
Soil Below Water Table:	0	0.063	0.00	0.00	1.944392034	0.00	0.00
Pad Above Water Table:	1.5	0.150	19.69	26.25	1.944392034	38.28	51.04
Pad Below Water Table:	0	0.088	0.00	0.00	1.944392034	0.00	0.00
Total:			47.03	62.71		91.44	121.93

*Factored Bending Moment (0.9\*D LC):*  $Mu\_pad\_0.9 = \text{'Pad Shear and Moment Diagrams'}\$AZ\$21$   $Mu\_pad\_0.9 = 120.07$  ft-kips

*Factored Bending Moment (1.2\*D LC):*  $Mu\_pad\_1.2 = \text{'Pad Shear and Moment Diagrams'}\$CH\$21$   $Mu\_pad\_1.2 = 119.09$  ft-kips

Check  $\phi M_n = 1510.81$  ft-kips  $\geq$   $Mu\_pad = 120.07$  ft-kips **RATING: 7.95% OK**

**PIER DESIGN CHECKS**

**Minimum Steel**

*Min. area of steel (pier):*  $A_{st\_c} = A_g * 0.005$   $A_{st\_c} = 3.53$  in<sup>2</sup>  
 Check  $A_{s\_pier} = 7.20$  in<sup>2</sup>  $\geq$   $A_{st\_c} = 3.53$  in<sup>2</sup>

**Bar Spacing**

*Bar separation:*  $B_{s\_pier} = (do * \pi) / m_{pier} - db_{pier}$   $B_{s\_pier} = 4.92$  in  
 Check  $18.00$  in  $\geq$   $B_{s\_pier} = 4.92$  in **RATING: 27.32% OK**

**Vertical Rebar Development Length**

*Reinforcement location:*  $\alpha_c =$  if space under bar > 12", 1.3, else use 1.0  $\alpha_c = 1.3$   
*Epoxy coating:*  $\beta_c =$  for non- epoxy coated, use 1.0  $\beta_c = 1.0$   
*Max term:*  $\alpha \beta_c =$  product of  $\alpha$  x  $\beta$  not to exceed 1.7  $\alpha \beta_c = 1.3$   
*Reinforcement size:*  $\gamma_c =$  if bar size is 6 or less, 0.8, else use 1.0  $\gamma_c = 1$   
*Light weight concrete:*  $\lambda_c = 1.0$   $\lambda_c = 1.0$   
*Spacing/cover:*  $c_{c\_c} =$  use smaller of half of bar spacing or concrete cover  $c_{c\_c} = 2.9$  in  
*Transverse bars:*  $k_{tr\_c} = 0$  in (per simplification)  $k_{tr\_c} = 0$  in  
*Max term:*  $c_c' = \text{MIN}(2.5, (c_{c\_c} + k_{tr\_c}) / db_{c\_c})$   $c_c' = 2.500$   
*Excess reinforcement:*  $R_e = A_{st\_c} / A_{s\_c}$   $R_e = 0.49$   
*Development (tensile):*  $L_{dt\_c} = (3 / 40) * (F_y * 1000 / \sqrt{F_c * 1000}) * \alpha \beta_c * \gamma_c * \lambda_c * R_e * db_{c\_c} / c_{c\_c}$   $L_{dt\_c} = 14.98$  in  
*Minimum length:*  $L_{d\_min} = 12$  inches  $L_{d\_min} = 12.0$  in  
*Development length:*  $L_{dt\_c} = \text{MAX}(L_{d\_min}, L_{dt\_c})$   $L_{dt\_c} = 14.98$  in  
*Development (comp.):*  $L_{dc\_c} = 0.02 * db_{c\_c} * F_y * 1000 / \sqrt{F_c * 1000}$   $L_{dc\_c} = 15.65$  in  
 $L_{dc\_c} = 0.0003 * db_{c\_c} * F_y * 1000$   $L_{dc\_c} = 15.75$  in  
*Development length:*  $L_{dc\_c} = \text{MAX}(\delta, L_{dc\_c}, L_{dc\_c})$   $L_{dc\_c} = 15.75$  in  
*Length available in pier:*  $L_{vc} = D - T + E - cc$   $L_{vc} = 33.0$  in

Check  $L_{vc} = 33.00$  in  $\geq$   $L_{dt\_c} = 14.98$  in **OK**

Check  $L_{vc} = 33.00$  in  $\geq$   $L_{dc\_c} = 15.75$  in **OK**

Length available in pad:  $L_{vp} = T - cc_{pad}$   $L_{vp} = 15.0$  in

Check  $L_{vp} = 15.00$  in  $\geq$   $L_{dl_c} = 14.98$  in OK

Check  $L_{vp} = 15.00$  in  $\geq$   $L_{dc_c} = 15.75$  in

**Vertical Rebar Hook Ending**

Bar size & clear cover:  $\alpha_n = \text{if bar} \leq 11, \text{ and cc} \geq 2.5", \text{ use } 0.7, \text{ else use } 1.0$   $\alpha_n = 0.7$

Epoxy coating:  $\beta_n = \text{for non- epoxy coated, use } 1.0$   $\beta_n = 1.0$

Light weight concrete:  $\lambda_n = 1.0$   $\lambda_n = 1.0$

Development (hook):  $L_{dh}' = 0.02 * dh * \beta_n * \lambda_n * F_y * 1000 / \sqrt{F_c * 1000} * db_c$   $L_{dh}' = 11.0$  in

Minimum length:  $L_{dh\_min} = \text{the larger of: } 8 * d_o \text{ or } 6 \text{ in}$   $L_{dh\_min} = 7.0$  in

Development length:  $L_{dh} = \text{MAX}(L_{dh\_min}, L_{dh}')$   $L_{dh} = 11.0$  in

Check  $L_{vp} = 15.00$  in  $\geq$   $L_{dh} = 10.96$  in OK

Hook tail length:  $L_{htail} = 12 * db$  beyond the bend radius  $L_{htail} = 14.0$  in

Length available in pad:  $L_{htail\_pad} = 12 * \text{MIN}((W/2 - (2/3) * BW * \cos(30^\circ) + \text{Offset-dpier})/2, (W - BW - dpier)/2) + cc_{pier} - cc_{pad}$   $L_{htail\_pad} = 33.0$  in

Check  $L_{htail\_pad} = 33.00$  in  $\geq$   $L_{dh\_tail} = 14.00$  in OK

**Pier Ties**

Minimum size:  $s_{t\_min} = \text{IF}(s_c \leq 10, 3, 4)$   $s_{t\_min} = 3$   
 [ACI 7.10.5.1]

z factor:  $z_{seismic} = 0.5$  if the SDC is A, B, or C, else 1.0  $z_{seismic} = 0.5$

Tie parameters:  $s_t = 4$   $d_{b,t} = 0.5$  in  
 $m_t = 5$   $A_{b,t} = 0.2$  in<sup>2</sup>

Allowable tie spacing per vertical rebar:  $B_{s\_t\_max1} = 8 / z * db_c$   $B_{s\_t\_max1} = 14$  in

per tie size:  $B_{s\_t\_max2} = 24 / z * db_t$   $B_{s\_t\_max2} = 24$  in

<i>per pier diameter:</i>	$B_{s\_t\_max3} = di / (4 * z^2)$	$B_{s\_t\_max3} = 30$	in	
<i>per seismic zone:</i>	$B_{s\_t\_max4} = 12"$ in active seismic zones, else 18"	$B_{s\_t\_max4} = 18$	in	
<i>Maximum tie spacing:</i>	$B_{s\_t\_max} = \text{MIN}(B_{s\_t\_max1}, B_{s\_t\_max2}, B_{s\_t\_max3}, B_{s\_t\_max4})$	$B_{s\_t\_max} = 14$	in	
<i>Minimum required ties:</i>	$m_{t\_min} = (D - T + E) / B_{s\_t\_max} + 2$	$m_{t\_min} = 5.00$		
<b>Check</b>	$m_t = 5.00$	$\geq$	$m_{t\_min} = 5.00$	<b>OK</b>

### PAD DESIGN CHECKS

#### Minimum Steel Required for Shrinkage

<i>Shrinkage:</i>	$\rho_{sh} = \text{IF}(F_y \geq 60, 0.0018, 0.002)$	$\rho_{sh} = 0.0018$				
<i>Min. Required Shrinkage Steel:</i>	$A_{st\_p\_sh} = \rho_{sh} * W * T$	$A_{st\_p\_sh} = 9.72$	in <sup>2</sup>			
<b>Check</b>	$A_{s\_p} = 25.80$	in <sup>2</sup>	$\geq$	$A_{st\_p} = 9.72$	in <sup>2</sup>	<b>OK</b>

#### Bar Separation

<i>Bar separation:</i>	$B_{s\_pad} = (W - 2 * cc - db) / (m - 1)$	$B_{s\_pad} = 6.98$	in				
<b>Check</b>	$18"$	$\geq$	$B_{s\_p} = 6.98$	in	$\geq$	$2"$	<b>OK</b>

#### Pad Development Length

<i>Reinforcement location:</i>	$\alpha_p =$ if space under bar > 12", 1.3, else use 1.0	$\alpha_p = 1$				
<i>Epoxy coating:</i>	$\beta_p =$ for non- epoxy coated, use 1.0	$\beta_p = 1.0$				
<i>Max term:</i>	$\alpha\beta_p =$ product of $\alpha$ x $\beta$ not to exceed 1.7	$\alpha\beta_p = 1$				
<i>Reinforcement size:</i>	$\gamma_p =$ if bar size is 6 or less, 0.8, else use 1.0	$\gamma_p = 1$				
<i>Light weight concrete:</i>	$\lambda_p = 1.0$	$\lambda_p = 1.0$				
<i>Spacing/cover:</i>	$c_p =$ use smaller of half of bar spacing or concrete cover	$c_p = 3.44$	in			
<i>Transverse bars:</i>	$k_{tr\_p} = 0$ in (per simplification)	$k_{tr\_p} = 0$	in			
<i>Max term:</i>	$c_p' = \text{MIN}(2.5, (c + k_{tr}) / db)$	$c_p' = 2.500$				
<i>Required moment (<math>\phi_t = 0.9</math>):</i>	$M_{tr} = M_{u\_pad} / \phi_{flex}$	$M_{tr} = 133.4$	ft-kips			
<i>Steel estimate:</i>	$A_{st\_p}' = M_n / (\phi_t * F_y * dc)$	$A_{st\_p}' = 2.166$	in <sup>2</sup>			
	$a_p = A_{st}' * F_y / (\beta * F_c' * W)$	$a_p = 0.12$	in			
<i>Required steel:</i>	$A_{st\_p\_st} = M_{tr} / (F_y * (dc - a_p / 2))$	$A_{st\_p\_st} = 1.958$	in <sup>2</sup>			
<i>Excess reinforcement:</i>	$R_p = A_{st\_p} / A_{s\_p}$	$R_p = 0.38$				
<i>Development (tensile):</i>	$L_d = (3 / 40) * (F_y * 1000 / \sqrt{(F_c' * 1000)}) * \alpha\beta * \gamma * \lambda * R * db / c'$	$L_d = 8.85$	in			
<i>Minimum length:</i>	$L_{d\_min} = 12$ inches	$L_{d\_min} = 12.0$	in			
<i>Development length:</i>	$L_{dp} = \text{MAX}(L_{d\_min}, L_{dp}')$	$L_{dp} = 12.00$	in			
<i>Length available in pad:</i>	$L_{pad} = 12 * \text{MIN}((W/2 - (2/3) * BW * \cos(30^\circ)) + \text{Offset-dpier}/2), (W - BW - dpier)/2) - cc_{pad}$	$L_{pad} = 43.67$	in			
<b>Check</b>	$L_{pad} = 43.67$	in	$\geq$	$L_{dp} = 12.00$	in	<b>OK</b>

## Moment Capacity of Drilled Concrete Shaft (Caisson) for TIA Rev F, G, or H

**Note:** Shaft assumed to have ties, not spiral, transverse reinforcing

### Site Data

ES-154  
EHamptonAWC

### Loads Already Factored

For M (WL):	1.00	
For P (DL):	1.00	

### Pier Properties

#### Concrete:

Pier Diameter = 2.5 ft  
Concrete Area = 706.9 in<sup>2</sup>

#### Reinforcement:

Clear Cover to Tie = 3.00 in  
Horiz. Tie Bar Size = 4  
Vert. Cage Diameter = 1.84 ft  
Vert. Cage Diameter = 22.13 in  
**Vertical Bar Size = 7**  
Bar Diameter = 0.88 in  
Bar Area = 0.6 in<sup>2</sup>  
Number of Bars = 12  
As Total = 7.2 in<sup>2</sup>  
A s / Acon, Rho: 0.0102 1.02%

ACI 10.5, ACI 21.10.4, and IBC 1810.  
Min As for Flexural, Tension Controlled, Shafts:  
(3)\*(Sqrt(f'c)/Fy: 0.0034  
200 / Fy: 0.0033

#### Minimum Rho Check:

Assumed Min. Rho: 0.50%  
Provided Rho: 1.02% **OK**

Ref. Shaft Max Axial Capacities, $\phi$ Max(Pn or Tn):		
Max Pu = ( $\phi=0.65$ ) Pn. Pn per ACI 318 (10-2)	1616.26	kips
at Mu=( $\phi=0.65$ )Mn=	335.24	ft-kips
Max Tu, ( $\phi=0.9$ ) Tn =	388.8	kips
at Mu= $\phi=(0.90)$ Mn=	0.00	ft-kips

### Maximum Shaft Superimposed Forces

TIA Revision:	H	
Max. Factored Shaft Mu:	36	ft-kips (* Note)
Max. Factored Shaft Pu:	92	kips
Max Axial Force Type:	Tension	

(\* Note: Max Shaft Superimposed Moment does not necessarily equal to the shaft top reaction moment

Load Factor	Shaft Factored Loads		
1.00	Mu:	36	ft-kips
1.00	Pu:	92	kips

### Material Properties

Concrete Comp. strength, f'c =	4500	psi
Reinforcement yield strength, Fy =	60	ksi
Reinforcing Modulus of Elasticity, E =	29000	ksi
Reinforcement yield strain =	0.00207	
Limiting compressive strain =	0.003	

### ACI 318 Code


Select Analysis ACI Code= 2014

SOLVE

<-- Press Upon Completing All Input

### Results:

Governing Orientation Case: 2



Case 1

Case 2

Dist. From Edge to Neutral Axis: 5.03 in

Extreme Steel Strain,  $\epsilon_t$ : 0.0123

**$\epsilon_t > 0.0050$ , Tension Controlled**

Reduction Factor,  $\phi$ : 0.900

**Output Note:** Negative Pu=Tension  
For Axial Compression,  $\phi$  Pn = Pu: -82.80 kips  
Drilled Shaft Moment Capacity,  $\phi$ Mn: 297.91 ft-kips  
Drilled Shaft Superimposed Mu: 36.00 ft-kips

**(Mu/ $\phi$ Mn, Drilled Shaft Flexure CSR): 12.1%**



**Maximum Allowable Moment of a Circular Pier**

Pu = **92** kips (from Results Tab)  
 Axial Force type: **Tension** (from Results Tab)  
 For Internal Calculations:  
 Axial Load (Negative for Compression) = **92.00** kips


	Case 1	Case 2
Reduction factor, φ <sub>2002</sub>	0.90	0.90
Reduction factor, φ <sub>2005</sub>	0.90	0.90
Reduction factor, φ <sub>2014</sub>	0.90	0.90
ACI code	0.90	0.90

← φ based on ACI 318 2002, Section 9.3.2.2 and corresponding commentaries. Transition zone equation for ties: φ=0.48\*(et). Transition zone equation for spirals: φ=0.57\*(et).  
 ← φ based on ACI 318 2005, Section 9.3.2.2 and corresponding commentaries. Transition zone equation for ties: φ=0.65\*(et)-0.002(250/3). Transition zone equation for spirals: φ=0.70\*(et)-0.002(200/3).  
 ← φ based on ACI 318 2014, Section 21.2 and corresponding commentaries. Transition zone equation for ties: φ=0.65+0.25(et-ety)(0.005-ety). Transition zone equation for spirals: φ=0.75+0.15(et-ety)(0.005-ety).

**Case 1: Single Bar Near the Extreme Fiber**



**Case 2: (2) Equidistant Bars Near the Extreme Fiber**



General Sketch (Variables) for both cases

**Neutral Axis**  
 Distance from extreme edge to neutral axis, h = **5.08** in  
 Equivalent compression zone factor = **0.825**  
 Distance from extreme edge to equivalent compression zone factor, a = **4.19** in  
 Distance from centroid to neutral axis = **9.92** in

**Compression Zone**  
 Area of steel in compression zone, Asc = **0.60** in<sup>2</sup>  
 Angle from centroid of pier to intersection of equivalent compression zone and edge of pier = **43.90** deg  
 Area of concrete in compression, Acc = **59.99** in<sup>2</sup>  
 Force in concrete = 0.85 \* f'c \* Acc, Fc = **229.48** kips  
 Total reinforcement forces, F<sub>s</sub> = **-321.48** kips  
 Case 1, φ = **0.900**  
 Axial (compressive), P<sub>u</sub> = **92.00** kips  
 Balance Force in concrete, F<sub>b</sub>+F<sub>u</sub> = **229.48** kips  
 Shaft Comp. Capacity, φP<sub>n</sub> = **-82.80** kips  
 Sum of the axial forces in the shaft = **0.00** kips **OK**

**Maximum Moment**  
 First moment of the concrete area in compression about the centroid = **750.31** in<sup>3</sup>  
 Distance between centroid of concrete in compression and centroid of pier = **12.51** in  
 Moment of concrete in compression = **2869.94** in-kips  
 Total reinforcement moment = **1192.51** in-kips  
 Nominal Moment strength of Drilled Shaft M<sub>n</sub> = **3996.15** in-kips  
 Moment Capacity of Drilled Shaft, φM<sub>n</sub> = **3596.54** in-kips

Case 1, φM<sub>n</sub> = **299.71** ft-kips

**Neutral Axis**  
 Distance from extreme edge to neutral axis, h = **5.03** in  
 Equivalent compression zone factor = **0.825**  
 Distance from extreme edge to equivalent compression zone factor, a = **4.15** in  
 Distance from centroid to neutral axis = **9.97** in

**Compression Zone**  
 Area of steel in compression zone, Asc = **0.00** in<sup>2</sup>  
 Angle from centroid of pier to intersection of equivalent compression zone and edge of pier = **43.65** deg  
 Area of concrete in compression, Acc = **59.05** in<sup>2</sup>  
 Force in concrete = 0.85 \* f'c \* Acc, Fc = **225.87** kips  
 Total reinforcement forces, F<sub>s</sub> = **-317.87** kips  
 Case 2, φ = **0.900**  
 Axial (compressive), P<sub>u</sub> = **92.00** kips  
 Balance Force in concrete, F<sub>b</sub>+F<sub>u</sub> = **-225.87** kips  
 Shaft Comp. Capacity, φP<sub>n</sub> = **-82.80** kips  
 Sum of the axial forces in the shaft = **0.00** kips **OK**

**Maximum Moment**  
 First moment of the concrete area in compression about the centroid = **740.11** in<sup>3</sup>  
 Distance between centroid of concrete in compression and centroid of pier = **12.53** in  
 Moment of concrete in compression = **2830.90** in-kips  
 Total reinforcement moment = **1141.25** in-kips  
 Nominal Moment strength of Drilled Shaft M<sub>n</sub> = **3972.15** in-kips  
 Moment Capacity of Drilled Shaft, φM<sub>n</sub> = **3574.93** in-kips

Case 2, φM<sub>n</sub> = **297.91** ft-kips

**Case 3: = Case 1, but Pu set at Max Axial Compression per ACI 318 (10-2) and phi=0.65.**

**Neutral Axis**  
 Distance from extreme edge to neutral axis, h = **28.04** in  
 Equivalent compression zone factor = **0.825**  
 Distance from extreme edge to equivalent compression zone factor, a = **23.13** in  
 Distance from centroid to neutral axis = **-13.04** in

**Compression Zone**  
 Area of steel in compression zone, Asc = **5.40** in<sup>2</sup>  
 Angle from centroid of pier to intersection of equivalent compression zone and edge of pier = **122.83** deg  
 Area of concrete in compression, Acc = **584.84** in<sup>2</sup>  
 Force in concrete = 0.85 \* f'c \* Acc, Fc = **2237.01** kips  
 Total reinforcement forces, F<sub>s</sub> = **249.54** kips  
 φ = **0.65**  
 Magnified, Max Axial Comp, P<sub>n</sub>, per ACI 318 (10-2)(φ=0.65) = **-2486.55** kips  
 Balance Force in concrete, F<sub>b</sub>+F<sub>u</sub> = **-2237.01** kips  
 Shaft Comp. Capacity, (φ=0.65)P<sub>n</sub> = **1616.26** kips  
 Sum of the axial forces in the shaft = **0.00** kips **OK**

**Maximum Moment**  
 First moment of the concrete area in compression about the centroid = **1335.04** in<sup>3</sup>  
 Distance between centroid of concrete in compression and centroid of pier = **2.28** in  
 Moment of concrete in compression = **425.5443** in-kips  
 Total reinforcement moment = **80.2053** in-kips  
 Nominal Moment strength of Drilled Shaft M<sub>n</sub> = **6188.99** in-kips  
 Moment Capacity of Drilled Shaft, (φ=0.65)M<sub>n</sub> = **4022.85** in-kips

Case 3, at P<sub>max</sub>, (φ=0.65)M<sub>n</sub> = **332.24** ft-kips

Final Results	
Governing Orientation Case=	<b>2</b>
phi, φ=	<b>0.900</b>
Shaft φ <sub>n</sub> M <sub>n</sub> =	<b>297.91</b> ft-kips
Distance from Edge of Shaft to N.A.=	<b>5.03</b> in
Shaft Beta=	<b>0.83</b>
Maximum Tensile Strain=	<b>-0.01233</b> ← et > 0.0050, Tension Controlled
Shaft Tension Cap. φ <sub>n</sub> P <sub>n</sub> (φ=0.90)(0.85)F <sub>y</sub> A <sub>st</sub> =	<b>308.80</b> kips
Shaft Max Comp. (φ=0.65)(0.80)(0.85)F <sub>c</sub> (A <sub>c</sub> -A <sub>st</sub> )F <sub>y</sub> =	<b>1616.26</b> kips

TC

**Individual Bars**

Bar #	Angle from first bar (deg)	Distance to center of shaft (in)	Distance to neutral axis (in)	Distance to equivalent comp. zone (in)	Strain	Area of steel in compression (in <sup>2</sup> )	Stress (ksi)	Axial force (kips)	Moment (in-kips)
1	0.00	11.06	1.14	0.26	0.00068	0.60	18.99	9.46	104.65
2	30.00	9.68	-0.34	-1.23	-0.00020	0.00	-9.78	-3.47	-33.24
3	60.00	5.53	-4.39	-0.02259	0.00	-60.00	-36.00	-199.13	
4	90.00	0.00	-9.92	-10.81	-0.00586	0.00	-60.00	-36.00	0.00
5	120.00	-5.53	-15.45	-16.34	-0.00912	0.00	-60.00	-36.00	199.13
6	150.00	-9.58	-19.50	-20.39	-0.01151	0.00	-60.00	-36.00	344.89
7	180.00	-11.06	-20.98	-21.87	-0.01239	0.00	-60.00	-36.00	398.25
8	210.00	-9.58	-19.50	-20.39	-0.01151	0.00	-60.00	-36.00	344.89
9	240.00	-5.53	-15.45	-16.34	-0.00912	0.00	-60.00	-36.00	199.13
10	270.00	0.00	-9.92	-10.81	-0.00586	0.00	-60.00	-36.00	0.00
11	300.00	5.53	-4.39	-0.02259	0.00	-60.00	-36.00	-199.13	
12	330.00	9.68	-0.34	-1.23	-0.00020	0.00	-9.78	-3.47	-33.24
					Min→	-0.01239	0.60	-321.48	1126.21

93.85119

**Individual Bars**

Bar #	Angle from first bar (deg)	Distance to center of shaft (in)	Distance to neutral axis (in)	Distance to equivalent comp. zone (in)	Strain	Area of steel in compression (in <sup>2</sup> )	Stress (ksi)	Axial force (kips)	Moment (in-kips)
1	0.00	11.06	24.10	19.19	0.00258	0.60	60.00	33.71	372.96
2	30.00	9.68	22.62	17.71	0.00242	0.60	60.00	33.71	322.91
3	60.00	5.53	18.67	13.66	0.00199	0.60	57.62	32.28	178.53
4	90.00	0.00	13.04	8.13	0.00140	0.60	40.46	21.98	0.00
5	120.00	-5.53	7.51	2.60	0.00080	0.60	23.29	11.68	-64.61
6	150.00	-9.58	3.46	-1.45	0.00037	0.00	10.73	6.44	-61.68
7	180.00	-11.06	1.98	-2.93	0.00021	0.00	6.13	3.68	-40.69
8	210.00	-9.58	3.46	-1.45	0.00037	0.00	10.73	6.44	-61.68
9	240.00	-5.53	7.51	2.60	0.00080	0.60	23.29	11.68	-64.61
10	270.00	0.00	13.04	8.13	0.00140	0.60	40.46	21.98	0.00
11	300.00	5.53	18.67	13.66	0.00199	0.60	57.62	32.28	178.53
12	330.00	9.68	22.62	17.71	0.00242	0.60	60.00	33.71	322.91
					Min→	0.00021	5.40	249.54	1082.46

90.2053

## FACTORED LOADS

Axial Load 0.9D:	$P_{0.9D} = 0.9 * P / 1.2$	$P_{0.9D} = 12.75$ kip
Axial Load 1.2D:	$P_{1.2D} = 1.2 * P / 1.2$	$P_{1.2D} = 17.00$ kip
Shear Load:	$V_u = V$	$V_u = 23.00$ kip
Moment:	$M_u = M_u$	$M_u = 1547.00$ kip*ft

## PASSIVE PRESSURE RESISTANCE

Force of Pp Applied on Pier:	$Force_{pier} = \text{MIN}(V_u, \text{Sum}(PpIM2:M7))$	$Force_{pier} = 0.00$ kip
Moment Arm of Pp on Pier:	$M_{arm\_pier} = D-T-PpIO2 + T$	$M_{arm\_pier} = 4.00$ ft
Force of Pp Applied on Pad:	$Force_{pad} = \text{MIN}(V_u - Force_{pier}, \text{SUM}(PpIM8:M13))$	$Force_{pad} = 23.00$ kip
Moment Arm of Pp on Pad:	$M_{arm\_pad} = D-PpIO8$	$M_{arm\_pad} = 0.32$ ft
Unfactored Moment Resistance due to Passive Pressure:	$M_{R\_Pp} = Force_{pier} * M_{arm\_pier} + Force_{pad} * M_{arm\_pad}$	$M_{R\_Pp} = 7.47$ kip*ft
Factored Moment Resistance due to Passive Pressure:	$\Phi M_{R\_Pp} = \Phi_s * M_{R\_Pp}$	$\Phi M_{R\_Pp} = 5.60$ kip*ft

## PLASTIC BEARING PRESSURE &amp; OVERTURNING MOMENT

Compressive Load for Bearing (0.9*D LC):	$P_{bearing\_0.9} = P_{0.9D} + 0.9 * (W_s + W_c) + 0.75 * W_{wedges\_0.9\_bearing}$	$P_{bearing\_0.9} = 316.92$ kip
Compressive Load for Bearing (1.2*D LC):	$P_{bearing\_1.2} = P_{1.2D} + 1.2 * (W_s + W_c) + 0.75 * W_{wedges\_1.2\_bearing}$	$P_{bearing\_1.2} = 422.55$ kip
Factored Overturning Moment (0.9*D LC):	$M_{overturning\_0.9} = M + V * (\text{MAX}(T,D) + E + bpdist/12) + (0.9) * (P/1.2 + 3 * W_{pier}) * \text{Offset}$	$M_{overturning\_0.9} = 1700.25$ kip*ft
Factored Overturning Moment (1.2*D LC):	$M_{overturning\_1.2} = M + V * (\text{MAX}(T,D) + E + bpdist/12) + (1.2) * (P/1.2 + 3 * W_{pier}) * \text{Offset}$	$M_{overturning\_1.2} = 1715.56$ kip*ft
Area of Pad:	$Area = W^2$	$Area = 625.00$ ft <sup>2</sup>
Plastic Section Modulus of Pad:	$Z = W^3 / 4$	$Z = 3906.25$ ft <sup>3</sup>
Preliminary Load Eccentricity (0.9*D LC):	$pre\_ec_{0.9,p} = M_{overturning} / P_{bearing\_0.9}$	$pre\_ec_{0.9,p} = 5.36$ ft
Preliminary Load Eccentricity (1.2*D LC):	$pre\_ec_{1.2,p} = M_{overturning} / P_{bearing\_1.2}$	$pre\_ec_{1.2,p} = 4.06$ ft
[Goal Seek] Load Eccentricity Iteration (0.9*D LC):	$ec_{0.9,p} = \text{goal seek}$	$ec_{0.9,p} = 5.35$ ft e <= L/4
[Goal Seek] Load Eccentricity Iteration (1.2*D LC):	$ec_{1.2,p} = \text{goal seek}$	$ec_{1.2,p} = 4.05$ ft e <= L/4
Non-Bearing Length (0.9*D LC):	$NBL_{0.9} = 0$	$NBL_{0.9} = 0.00$ ft
Non-Bearing Length (1.2*D LC):	$NBL_{1.2} = 0$	$NBL_{1.2} = 0.00$ ft
Total Factored Resisting Moment due to Pp and Soil Wedges / Shear (0.9*D LC):	$\Phi M_{Resisting\_0.9} = \Phi M_{R\_Pp} + \text{SUM}(\Phi M_{R\_wedges\_0.9}, \Phi M_{R\_shear\_0.9})$	$\Phi M_{Resisting\_0.9} = 5.60$ kip*ft
Total Factored Resisting Moment due to Pp and Soil Wedges / Shear (1.2*D LC):	$\Phi M_{Resisting\_1.2} = \Phi M_{R\_Pp} + \text{SUM}(\Phi M_{R\_wedges\_1.2}, \Phi M_{R\_shear\_1.2})$	$\Phi M_{Resisting\_1.2} = 5.60$ kip*ft
Adjusted Overturning Moment (0.9*D LC):	$M_{overturning\_adj\_0.9} = M_{overturning} - \Phi M_{Resisting\_0.9}$	$M_{overturning\_adj\_0.9} = 1694.65$ kip*ft
Adjusted Overturning Moment (1.2*D LC):	$M_{overturning\_adj\_1.2} = M_{overturning} - \Phi M_{Resisting\_1.2}$	$M_{overturning\_adj\_1.2} = 1709.96$ kip*ft
Total Resistance to Overturning (0.9*D LC):	$\Phi M_{Resisting\_qu\_0.9} = P_{bearing\_0.9} * ec_{0.9,p} + \Phi M_{Resisting\_0.9}$	$\Phi M_{Resisting\_qu\_0.9} = 1700.25$ kip*ft
Total Resistance to Overturning (1.2*D LC):	$\Phi M_{Resisting\_qu\_1.2} = P_{bearing\_1.2} * ec_{1.2,p} + \Phi M_{Resisting\_1.2}$	$\Phi M_{Resisting\_qu\_1.2} = 1715.56$ kip*ft
[Goal Seek] Moment Comparison Iteration (0.9D LC):	$\Delta M_{0.9} = M_{overturning\_adj\_0.9} - \Phi M_{Resisting\_qu\_0.9}$	$\Delta M_{0.9} = 0.00$ ft
[Goal Seek] Moment Comparison Iteration (1.2D LC):	$\Delta M_{1.2} = M_{overturning\_adj\_1.2} - \Phi M_{Resisting\_qu\_1.2}$	$\Delta M_{1.2} = 0.00$ ft

## Bearing Pressures

Orthogonal Bearing Pressure (0.9*D LC):	$q_{u\_orth\_0.9} = \text{MAX}(P_{bearing\_0.9}/Area + M_{overturning\_0.9}/Z, P_{bearing\_0.9}/Area - M_{overturning\_0.9}/Z)$	$q_{u\_orth\_0.9} = 0.94$ ksf
Orthogonal Bearing Pressure (1.2*D LC):	$q_{u\_orth\_1.2} = \text{MAX}(P_{bearing\_1.2}/Area + M_{overturning\_1.2}/Z, P_{bearing\_1.2}/Area - M_{overturning\_1.2}/Z)$	$q_{u\_orth\_1.2} = 1.11$ ksf
Ultimate Gross Bearing Pressure:	$Q_{ult} = \text{Quit}$	$Q_{ult} = 12.00$ ksf
Factored Ultimate Gross Bearing Pressure:	$\Phi Q_{ult} = \phi_s * \text{Quit}$	$Q_a = 9.00$ ksf
Check	$\Phi Q_{ult} = 9.00$ ksf	$q_u = 1.11$ ksf
		RATING: 12.38% OK

## Soil Wedges (Cohesionless Soil)

Soil (above pad) Height:	$soilht = D-T$	$soilht = 2.50$ ft
Soil (above pad & under water table) Height:	$soilht\_gw = \text{MIN}(soilht-gw, D-T)$	$soilht\_gw = 0.00$ ft
Soil Wedge Projection Grade:	$Wedge\_proj = \text{TAN}(\phi * \text{PI}() / 180) * soilht$	$Wedge\_proj = 1.69$ ft
Soil Wedge Projection at Water Table:	$Wedge\_proj\_gw = \text{TAN}(\phi * \text{PI}() / 180) * (soilht\_gw)$	$Wedge\_proj\_gw = 0.00$ ft

## Soil Wedges (Cohesionless Soil) (0.9\*D LC)

Soil	Volume (ft <sup>3</sup> )	Soil Weight (kips)	Moment Arm (ft)	Unfactored Resisting Moment (kip*ft)
------	---------------------------	--------------------	-----------------	--------------------------------------

(2) End Prisms (above Water Table)	0.00	0.00	25.00	0.00		
(2) End Prisms (below Water Table)	0.00	0.00	0.00	0.00		
(2) Partial Sides (above Water Table)	0.00	0.00	25.00	0.00		
(2) Partial Sides (below Water Table)	0.00	0.00	25.00	0.00		
(1) Rear (above Water Table)	0.00	0.00	25.56	0.00	Total Moment Arm (ft) =	0.00
(1) Rear (below Water Table)	0.00	0.00	0.00	0.00		
<b>Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	Soil Wedge Wt (kip)=	<b>0.00</b>

Unfactored Resisting Moment of Wedges (0.9\*D LC):  $M_{R\_wedges\_0.9} = \text{Total Moment Arm} * \text{Soil Wedge Wt}$   $M_{R\_wedges\_0.9} = 0.00 \text{ kip*ft}$

Factored Resisting Moment of Wedges (0.9\*D LC):  $\Phi M_{R\_wedges\_0.9} = 0.75 * M_{R\_wedges\_0.9}$   $\Phi M_{R\_wedges\_0.9} = 0.00 \text{ kip*ft}$

**Soil Wedges (Cohesionless Soil) (1.2\*D LC)**

Soil	Volume (ft³)	Soil Weight (kips)	Moment Arm (ft)	Unfactored Resisting Moment (kip*ft)		
(2) End Prisms (above Water Table)	0.00	0.00	25.00	0.00		
(2) End Prisms (below Water Table)	0.00	0.00	0.00	0.00		
(2) Partial Sides (above Water Table)	0.00	0.00	25.00	0.00		
(2) Partial Sides (below Water Table)	0.00	0.00	25.00	0.00		
(1) Rear (above Water Table)	0.00	0.00	25.56	0.00	Total Moment Arm (ft) =	0.00
(1) Rear (below Water Table)	0.00	0.00	0.00	0.00		
<b>Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	Soil Wedge Wt (kip)=	<b>0.00</b>

Unfactored Resisting Moment of Wedges (1.2\*D LC):  $M_{R\_wedges\_1.2} = \text{Total Moment Arm} * \text{Soil Wedge Wt}$   $M_{R\_wedges\_1.2} = 0.00 \text{ kip*ft}$

Factored Resisting Moment of Wedges (1.2\*D LC):  $\Phi M_{R\_wedges\_1.2} = 0.75 * M_{R\_wedges\_1.2}$   $\Phi M_{R\_wedges\_1.2} = 0.00 \text{ kip*ft}$

**Soil Shear Strength (Cohesive Soil)**

Effective Soil Unit Weight:  $Y_{eff\_shear} = Y$   $Y_{eff\_shear} = 0.1250 \text{ kcf}$   
Depth to Mid-Layer of Soil:  $H_{shear} = ((D - T) - N) / 2 + N$   $H_{shear} = 2.92 \text{ ft}$   
Cohesion at Mid-Layer of Soil:  $S_u = 0$   $S_u = 0.00 \text{ ksf}$

**Soil Shear Strength (Cohesive Soil) (0.9\*D LC)**

Plane	Area (ft²)	Resistance (kip)	Moment Arm (ft)	Unfactored Resisting Moment (kip*ft)		
Rear	0.00	0.00	25.00	0.00	Total Moment Arm (ft) =	0.00
(2) Partial Sides	0.00	0.00	25.00	0.00		
<b>Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	Soil Shear Strength (kip)=	<b>0.00</b>

Unfactored Resisting Moment of Soil Shear (0.9\*D LC):  $M_{R\_shear\_0.9} = \text{Total Moment Arm} * \text{Soil Shear Strength}$   $M_{R\_shear\_0.9} = 0.00 \text{ kip*ft}$

Factored Resisting Moment of Soil Shear (0.9\*D LC):  $\Phi M_{R\_shear\_0.9} = 0.75 * (\text{Total Moment Arm} * \text{Soil Shear Strength})$   $\Phi M_{R\_shear\_0.9} = 0.00 \text{ kip*ft}$

**Soil Shear Strength (Cohesive Soil) (1.2\*D LC)**

Plane	Area (ft²)	Resistance (kip)	Moment Arm (ft)	Unfactored Resisting Moment (kip*ft)		
Rear	0.00	0.00	25.00	0.00	Total Moment Arm (ft) =	0.00
(2) Partial Sides	0.00	0.00	25.00	0.00		
<b>Total</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	<b>0.00</b>	Soil Shear Strength (kip)=	<b>0.00</b>

Unfactored Resisting Moment of Soil Shear (1.2\*D LC):  $M_{R\_shear\_1.2} = \text{Total Moment Arm} * \text{Soil Shear Strength}$   $M_{R\_shear\_1.2} = 0.00 \text{ kip*ft}$

Factored Resisting Moment of Soil Shear (1.2\*D LC):  $\Phi M_{R\_shear\_1.2} = 0.75 * (\text{Total Moment Arm} * \text{Soil Shear Strength})$   $\Phi M_{R\_shear\_1.2} = 0.00 \text{ kip*ft}$

**DETERMINE MOMENT THAT WOULD CAUSE 100% OVERTURNING (ORTHOGONAL)**

Compressive Load for Bearing (0.9\*D LC):  $P_{100} = P_{0.9D} + 0.9 * (W_s + W_c) + 0.75 * W_{wedges\_100}$   $P_{100} = 331.51 \text{ kip}$   
Preliminary Factored Overturning Moment:  $pre\_M_{overturning\_100} = (W/2 - (P_{100} / \Phi Q_{ult})) * (2 * W) * P_{100}$   $pre\_M_{overturning\_100} = 3868.38 \text{ kip*ft}$   
Preliminary Load Eccentricity (0.9\*D LC):  $pre\_ec_{100} = pre\_M_{overturning\_100} / P_{100}$   $pre\_ec_{100} = 11.67 \text{ ft}$   
[Goal Seek] Load Eccentricity Iteration (0.9\*D LC):  $ec_{100} = goal\_seek$   $ec_{100} = 11.65 \text{ ft}$   $L/4 < e <= L/2$   
Non-Bearing Length (0.9\*D LC):  $NBL_{100} = 2 * ec_{100}$   $NBL_{100} = 23.30 \text{ ft}$   
Total Factored Resisting Moment due to Pp and Soil Wedges / Shear (0.9\*D LC):  $\Phi M_{Resisting\_100} = \Phi M_{R\_Pp} + \text{SUM}(\Phi M_{R\_wedges\_100}, \Phi M_{R\_shear\_100})$   $\Phi M_{Resisting\_100} = 83.78 \text{ kip*ft}$   
Moment Created by Shear:  $M_{shear} = V_u * (D + E + b_{pdist} / 12)$   $M_{shear} = 107.33 \text{ kip*ft}$   
Adjusted Overturning Moment (0.9\*D LC):  $M_{overturning\_100} = M_{u\_max\_100} - \Phi M_{R\_Pp}$   $M_{overturning\_100} = 3946.55 \text{ kip*ft}$   
Total Resistance to Overturning (0.9\*D LC):  $\Phi M_{Resisting\_qu\_100} = P_{100} * ec_{100} + \Phi M_{Resisting\_100}$   $\Phi M_{Resisting\_qu\_100} = 3946.55 \text{ kip*ft}$   
[Goal Seek] Moment Comparison Iteration (0.9D LC):  $\Delta M_{100} = M_{overturning\_100} - \Phi M_{Resisting\_qu\_100}$   $\Delta M_{100} = 0.00 \text{ ft}$   
Maximum Applied Moment from Superstructure Analysis:  $M_{u\_max\_100} = pre\_M_{overturning\_100} + \Phi M_{Resisting\_100}$   $M_{u\_max\_100} = 3952.16 \text{ kip*ft}$

Check  $M_{u\_max\_100} = 3952.16 \text{ kip*ft} >= M_u = 1700.25 \text{ kip*ft}$  **RATING: 43.02% OK**

**Soil Wedges (Cohesionless Soil) (0.9\*D LC)**

Soil	Volume (ft³)	Soil Weight (kips)	Moment Arm (ft)	Unfactored Resisting Moment (kip*ft)
(2) End Prisms (above Water Table)	4.74	0.59	25.63	15.18

(2) End Prisms (below Water Table)	0.00	0.00	0.00	0.00		
(2) Partial Sides (above Water Table)	98.24	12.28	13.35	163.92		
(2) Partial Sides (below Water Table)	0.00	0.00	13.35	0.00		
(1) Rear (above Water Table)	52.70	6.59	25.56	168.38	Wedge Eccentricity relative to W/2:	Total Moment Arm (ft) = 5.36
(1) Rear (below Water Table)	0.00	0.00	0.00	0.00		
<b>Total</b>	155.68	19.46		347.48	Soil Wedge Wt (kip)=	19.46

Unfactored Resisting Moment of Wedges (0.9\*D LC):  $M_{R\_wedges\_100} = \text{Total Moment Arm} * \text{Soil Wedge Wt}$   $M_{R\_wedges\_100} = 104.23 \text{ kip*ft}$   
 Factored Resisting Moment of Wedges (0.9\*D LC):  $\Phi M_{R\_wedges\_100} = 0.75 * MR\_wedges\_100$   $\Phi M_{R\_wedges\_100} = 78.17 \text{ kip*ft}$

Soil Shear Strength (Cohesive Soil) (0.9*D LC)						
Plane	Area (ft²)	Resistance (kip)	Moment Arm (ft)	Unfactored Resisting Moment (kip*ft)	Wedge Eccentricity relative to W/2:	
Rear	0.00	0.00	25.00	0.00	Total Moment	
(2) Partial Sides	0.00	0.00	13.35	0.00	Arm (ft) =	0.00
<b>Total</b>		0.00		0.00	Soil Shear Strength (kip)=	0.00

Unfactored Resisting Moment of Soil Shear (0.9\*D LC):  $M_{R\_shear\_100} = \text{Total Moment Arm} * \text{Soil Shear Strength}$   $M_{R\_shear\_100} = 0.00 \text{ kip*ft}$   
 Factored Resisting Moment of Soil Shear (0.9\*D LC):  $\Phi M_{R\_shear\_100} = 0.75 * (\text{Total Moment Arm} * \text{Soil Shear Strength})$   $\Phi M_{R\_shear\_100} = 0.00 \text{ kip*ft}$

**PASSIVE PRESSURE RESISTANCE (DIAGONAL DIRECTION)**

Force of Pp Applied on Pier:  $\text{Force}_{pier} = \text{MIN}(V_u, \text{Sum}(PpIM2:M7))$   $\text{Force}_{pier} = 0.00 \text{ kip}$   
 Moment Arm of Pp on Pier:  $M_{arm\_pier} = D - T - PpIO2 + T$   $M_{arm\_pier} = 4.00 \text{ ft}$   
 Force of Pp Applied on Pad:  $\text{Force}_{pad\_dia} = \text{MIN}(V_u - \text{Force}_{pier}, \text{SUM}(PpIM8:M13))$   $\text{Force}_{pad\_dia} = 23.00 \text{ kip}$   
 Moment Arm of Pp on Pad:  $M_{arm\_pad} = D - PpIO8$   $M_{arm\_pad} = 0.32 \text{ ft}$   
 Unfactored Moment Resistance due to Passive Pressure:  $M_{R\_pp\_dia} = \text{Force}_{pier} * M_{arm\_pier} + \text{Force}_{pad} * M_{arm\_pad}$   $M_{R\_pp\_dia} = 7.47 \text{ kip*ft}$   
 Factored Moment Resistance due to Passive Pressure:  $\Phi M_{R\_pp\_dia} = \Phi_s * M_{R\_pp\_dia}$   $\Phi M_{R\_pp\_dia} = 5.60 \text{ kip*ft}$

**PLASTIC BEARING PRESSURE & OVERTURNING MOMENT (DIAGONAL DIRECTION)**

Compressive Load for Bearing (0.9\*D LC):  $P_{bearing\_0.9\_dia} = P_{0.9D} + 0.9 * (Ws + Wc) + 0.75 * Wwedges_{0.9\_bearing\_dia}$   $P_{bearing\_0.9\_dia} = 330.18 \text{ kip}$   
 Compressive Load for Bearing (1.2\*D LC):  $P_{bearing\_1.2\_dia} = P_{1.2D} + 1.2 * (Ws + Wc) + 0.75 * Wwedges_{1.2\_bearing\_dia}$   $P_{bearing\_1.2\_dia} = 422.55 \text{ kip}$   
 Factored Overturning Moment:  $M_{overturning} = M_u + V_u * (D + E + bp_{soil} / 12)$   $M_{overturning} = 1654.33 \text{ kip*ft}$   
 Area of Pad:  $\text{Area} = W^2$   $\text{Area} = 625.00 \text{ ft}^2$   
 Plastic Section Modulus of Pad:  $Z_{dia} = W^3 / (3 * \text{SQRT}(2))$   $Z_{dia} = 3682.85 \text{ ft}^3$   
 Preliminary Load Eccentricity (0.9\*D LC):  $pre\_ec_{0.9\_p\_dia} = M_{overturning} / P_{bearing\_0.9\_dia}$   $pre\_ec_{0.9\_p\_dia} = 5.15 \text{ ft}$   
 Preliminary Load Eccentricity (1.2\*D LC):  $pre\_ec_{1.2\_p\_dia} = M_{overturning} / P_{bearing\_1.2\_dia}$   $pre\_ec_{1.2\_p\_dia} = 4.02 \text{ ft}$   
 [Goal Seek] Load Eccentricity Iteration (0.9\*D LC):  $ec_{0.9\_p\_dia} = \text{goal seek}$   $ec_{0.9\_p\_dia} = 4.87 \text{ ft}$   $(L/4) * \text{SQRT}(2) / 2 < e <$   
 [Goal Seek] Load Eccentricity Iteration (1.2\*D LC):  $ec_{1.2\_p\_dia} = \text{goal seek}$   $ec_{1.2\_p\_dia} = 4.01 \text{ ft}$   $e <= (L/4) * \text{SQRT}(2) / 2$   
 Non-Bearing Length (0.9\*D LC):  $NBL_{0.9\_dia} = \text{SQRT}(2) * ec_{0.9\_p\_dia}$   $NBL_{0.9\_dia} = 6.89 \text{ ft}$   
 Non-Bearing Length (1.2\*D LC):  $NBL_{1.2\_dia} = 0$   $NBL_{1.2\_dia} = 0.00 \text{ ft}$   
 Total factored resisting moment due to pp and soil Wedges / Shear (0.9\*D LC):  $\Phi M_{Resisting\_0.9} = \Phi M_{R\_pp\_dia} + \text{SUM}(\Phi M_{R\_wedges\_0.9\_dia}, \Phi M_{R\_shear\_0.9\_dia})$   $\Phi M_{Resisting\_0.9\_dia} = 92.50 \text{ kip*ft}$   
 Total factored resisting moment due to pp and soil Wedges / Shear (1.2\*D LC):  $\Phi M_{Resisting\_1.2} = \Phi M_{R\_pp\_dia} + \text{SUM}(\Phi M_{R\_wedges\_1.2\_dia}, \Phi M_{R\_shear\_1.2\_dia})$   $\Phi M_{Resisting\_1.2\_dia} = 5.60 \text{ kip*ft}$   
 Adjusted Overturning Moment (0.9\*D LC):  $M_{overturning\_0.9\_dia} = M_{overturning} - \Phi M_{Resisting\_0.9\_dia}$   $M_{overturning\_0.9\_dia} = 1607.75 \text{ kip*ft}$   
 Adjusted Overturning Moment (1.2\*D LC):  $M_{overturning\_1.2\_dia} = M_{overturning} - \Phi M_{Resisting\_1.2\_dia}$   $M_{overturning\_1.2\_dia} = 1694.65 \text{ kip*ft}$   
 Total Resistance to Overturning (0.9\*D LC):  $\Phi M_{Resisting\_qu\_0.9\_dia} = P_{bearing\_0.9\_dia} * ec_{0.9\_p\_dia} + \Phi M_{Resisting\_0.9\_dia}$   $\Phi M_{Resisting\_qu\_0.9\_dia} = 1700.25 \text{ kip*ft}$   
 Total Resistance to Overturning (1.2\*D LC):  $\Phi M_{Resisting\_qu\_1.2\_dia} = P_{bearing\_1.2\_dia} * ec_{1.2\_p\_dia} + \Phi M_{Resisting\_1.2\_dia}$   $\Phi M_{Resisting\_qu\_1.2\_dia} = 1700.25 \text{ kip*ft}$   
 [Goal Seek] Moment Comparison Iteration (0.9D LC):  $\Delta M_{0.9\_dia} = M_{overturning\_0.9\_dia} - \Phi M_{Resisting\_qu\_0.9\_dia}$   $\Delta M_{0.9\_dia} = 0.00 \text{ kip*ft}$   
 [Goal Seek] Moment Comparison Iteration (1.2D LC):  $\Delta M_{1.2\_dia} = M_{overturning\_1.2\_dia} - \Phi M_{Resisting\_qu\_1.2\_dia}$   $\Delta M_{1.2\_dia} = 0.00 \text{ kip*ft}$

**Bearing Pressures**

Diagonal Bearing Pressure (0.9\*D LC):  $q_{u\_dia\_0.9} = P_{bearing\_0.9\_dia} / (W - (\text{SQRT}(2)) * ec_{0.9\_p\_dia})^2$   $q_{u\_dia\_0.9} = 1.01 \text{ ksf}$   
 Diagonal Bearing Pressure (1.2\*D LC):  $q_{u\_dia\_1.2} = P_{bearing\_1.2\_dia} / \text{Area} + M_{overturning\_1.2\_dia} / Z_{dia}$   $q_{u\_dia\_1.2} = 1.14 \text{ ksf}$   
 Ultimate Gross Bearing Pressure:  $Q_{ult} = \text{Quit}$   $Q_{ult} = 12.00 \text{ ksf}$   
 Factored Ultimate Gross Bearing Pressure:  $\Phi Q_{ult} = \phi_s * \text{Quit}$   $Q_a = 9.00 \text{ ksf}$   
**Check**  $\Phi Q_{ult} = 9.00 \text{ ksf} \geq Q_a = 1.14 \text{ ksf}$  **RATING: 12.62% OK**

**Soil Wedges (Cohesionless Soil)**

Soil (above pad) Height:  $\text{soilht} = D - T$   $\text{soilht} = 2.50 \text{ ft}$   
 Soil (above pad & under water table) Height:  $\text{soilht\_gw} = \text{MIN}(\text{soilht} - gw, D - T)$   $\text{soilht\_gw} = 0.00 \text{ ft}$   
 Soil Wedge Projection at Grade:  $\text{Wedge}_{proj} = \text{TAN}(\phi * \text{PI} / 180) * \text{soilht}$   $\text{Wedge}_{proj} = 1.69 \text{ ft}$

Soil Wedge Projection at Water Table:

$$\text{Wedge}_{proj,gw} = \tan(\phi) \cdot \pi / (180) \cdot (\text{soilht}_{gw})$$

$$\text{Wedge}_{proj,gw} = 0.00 \text{ ft}$$

**Soil Wedges (Cohesionless Soil) (0.9\*D LC)**

Soil	Volume (ft³)	Soil Weight (kips)	Moment Arm (ft)	Unfactored Resisting Moment (kip*ft)	Eccentricity relative to W/2*SQRT(2):	
(2) End Prisms (above Water Table)	4.74	0.59	17.68	10.47	Total Moment Arm (ft) =	6.55
(2) End Prisms (below Water Table)	0.00	0.00	0.00	0.00		
(1) End Prism (above Water Table)	2.37	0.30	35.95	10.65	Total Moment Arm (ft) =	6.55
(1) End Prisms (below Water Table)	0.00	0.00	0.00	0.00		
(2) Partial Sides (above Water Table)	29.03	3.63	14.94	54.23	Total Moment Arm (ft) =	6.55
(2) Partial Sides (below Water Table)	0.00	0.00	0.00	0.00		
(2) Rear (above Water Table)	105.39	13.17	26.81	353.26	Total Moment Arm (ft) =	6.55
(2) Rear (below Water Table)	0.00	0.00	0.00	0.00		
<b>Total</b>	<b>141.53</b>	<b>17.69</b>		<b>428.61</b>	Soil Wedge Wt (kip) =	<b>17.69</b>

Unfactored Resisting Moment of Wedges (0.9\*D LC):

$$M_{R\_wedges\_0.9} = \text{Total Moment Arm} \cdot \text{Soil Wedge Wt}$$

$$M_{R\_wedges\_0.9\_dia} = 115.87 \text{ kip*ft}$$

Factored Resisting Moment of Wedges (0.9\*D LC):

$$\Phi M_{R\_wedges\_0.9} = 0.75 \cdot M_{R\_wedges\_0.9\_dia}$$

$$\Phi M_{R\_wedges\_0.9\_dia} = 86.90 \text{ kip*ft}$$

**Soil Wedges (Cohesionless Soil) (1.2\*D LC)**

Soil	Volume (ft³)	Soil Weight (kips)	Moment Arm (ft)	Unfactored Resisting Moment (kip*ft)	Eccentricity relative to W/2*SQRT(2):	
(2) End Prisms (above Water Table)	0.00	0.00	0.00	0.00	Total Moment Arm (ft) =	0.00
(2) End Prisms (below Water Table)	0.00	0.00	0.00	0.00		
(1) End Prism (above Water Table)	0.00	0.00	0.00	0.00	Total Moment Arm (ft) =	0.00
(1) End Prisms (below Water Table)	0.00	0.00	0.00	0.00		
(2) Partial Sides (above Water Table)	0.00	0.00	17.38	0.00	Total Moment Arm (ft) =	0.00
(2) Partial Sides (below Water Table)	0.00	0.00	0.00	0.00		
(2) Rear (above Water Table)	0.00	0.00	26.81	0.00	Total Moment Arm (ft) =	0.00
(2) Rear (below Water Table)	0.00	0.00	0.00	0.00		
<b>Total</b>	<b>0.00</b>	<b>0.00</b>		<b>0.00</b>	Soil Wedge Wt (kip) =	<b>0.00</b>

Unfactored Resisting Moment of Wedges (1.2\*D LC):

$$M_{R\_wedges\_1.2} = \text{Total Moment Arm} \cdot \text{Soil Wedge Wt}$$

$$M_{R\_wedges\_1.2\_dia} = 0.00 \text{ kip*ft}$$

Factored Resisting Moment of Wedges (1.2\*D LC):

$$\Phi M_{R\_wedges\_1.2} = 0.75 \cdot M_{R\_wedges\_1.2\_dia}$$

$$\Phi M_{R\_wedges\_1.2\_dia} = 0.00 \text{ kip*ft}$$

**Soil Shear Strength (Cohesive Soil)**

**Soil Shear Strength (Cohesive Soil) (0.9\*D LC)**

Plane	Area (ft²)	Resistance (kip)	Moment Arm (ft)	Unfactored Resisting Moment (kip*ft)	Eccentricity relative to W/2*SQRT(2):	
(2) Rear	0.00	0.00	26.52	0.00	Total Moment Arm (ft) =	0.00
(2) Partial Sides	0.00	0.00	15.24	0.00		
<b>Total</b>		<b>0.00</b>		<b>0.00</b>	Soil Shear Strength (kip) =	<b>0.00</b>

Unfactored Resisting Moment of Soil Shear (0.9\*D LC):

$$M_{R\_shear\_0.9} = \text{Total Moment Arm} \cdot \text{Soil Shear Strength}$$

$$M_{R\_shear\_0.9\_dia} = 0.00 \text{ kip*ft}$$

Factored Resisting Moment of Soil Shear (0.9\*D LC):

$$\Phi M_{R\_shear\_0.9} = 0.75 \cdot (\text{Total Moment Arm} \cdot \text{Soil Shear Strength})$$

$$\Phi M_{R\_shear\_0.9\_dia} = 0.00 \text{ kip*ft}$$

**Soil Shear Strength (Cohesive Soil) (1.2\*D LC)**

Plane	Area (ft²)	Resistance (kip)	Moment Arm (ft)	Unfactored Resisting Moment (kip*ft)	Eccentricity relative to W/2*SQRT(2):	
(2) Rear	0.00	0.00	26.52	0.00	Total Moment Arm (ft) =	0.00
(2) Partial Sides	0.00	0.00	17.68	0.00		
<b>Total</b>		<b>0.00</b>		<b>0.00</b>	Soil Shear Strength (kip) =	<b>0.00</b>

Unfactored Resisting Moment of Soil Shear (1.2\*D LC):

$$M_{R\_shear\_1.2} = \text{Total Moment Arm} \cdot \text{Soil Shear Strength}$$

$$M_{R\_shear\_1.2\_dia} = 0.00 \text{ kip*ft}$$

Factored Resisting Moment of Soil Shear (1.2\*D LC):

$$\Phi M_{R\_shear\_1.2} = 0.75 \cdot (\text{Total Moment Arm} \cdot \text{Soil Shear Strength})$$

$$\Phi M_{R\_shear\_1.2\_dia} = 0.00 \text{ kip*ft}$$

**DETERMINE MOMENT THAT WOULD CAUSE 100% OVERTURNING (DIAGONAL)**

Compressive Load for Bearing (0.9\*D LC):

$$P_{100\_dia} = P_{0.9D} + 0.9 \cdot (W_s + W_c) + 0.75 \cdot W_{wedges\_100\_dia}$$

$$P_{100\_dia} = 334.92 \text{ kip}$$

Preliminary Factored Overturning Moment:

$$pre\_M_{overturning\_100\_dia} = \frac{(P_{100\_dia} \cdot \sqrt{2}) \cdot (W - \sqrt{2} \cdot P_{100\_dia} / \phi_{Qult})}{\sqrt{2}}$$

$$pre\_M_{overturning\_100\_dia} = 4475.95 \text{ kip*ft}$$

Preliminary Load Eccentricity (0.9\*D LC):

$$pre\_ec_{100\_dia} = pre\_M_{overturning\_100\_dia} / P_{bearing\_0.9}$$

$$pre\_ec_{100\_dia} = 13.36 \text{ ft}$$

[Goal Seek] Load Eccentricity Iteration (0.9\*D LC):

$$ec_{100\_dia} = \text{goal seek}$$

$$ec_{100\_dia} = 13.35 \text{ ft}$$

$$(L/4) \cdot \sqrt{2} / 2 < e <$$

Non-Bearing Length (0.9\*D LC):

$$NBL_{100\_dia} = \sqrt{2} \cdot ec_{100\_dia}$$

$$NBL_{100\_dia} = 18.88 \text{ ft}$$

Total factored resisting moment due to pp and soil wedges / shear (0.9\*D LC):

$$\Phi M_{Resisting\_100\_dia} = \Phi M_{R\_pp\_dia} + \text{SUM}(\Phi M_{R\_wedges\_100\_dia}, \Phi M_{R\_shear\_100\_dia})$$

$$\Phi M_{Resisting\_100\_dia} = 47.93 \text{ kip*ft}$$

Moment Created by Shear:

$$M_{shear} = V_u \cdot (D + E + bp_{dist} / 12)$$

$$M_{shear} = 107.33 \text{ kip*ft}$$

Adjusted Overturning Moment (0.9\*D LC):

$$M_{overturning\_100\_dia} = M_{u\_max\_100\_dia} - \Phi M_{R\_pp\_dia}$$

$$M_{overturning\_100\_dia} = 4518.28 \text{ kip*ft}$$

Total Resistance to Overturning (0.9\*D LC):

$$\Phi M_{Resisting\_qu\_100\_dia} = P_{bearing\_0.9} \cdot ec_{100\_dia} + \Phi M_{Resisting\_100\_dia}$$

$$\Phi M_{Resisting\_qu\_100\_dia} = 4518.27 \text{ kip*ft}$$

[Goal Seek] Moment Comparison Iteration (0.9D LC):

$$\Delta M_{100\_dia} = M_{overturning} - \Phi M_{Resisting\_qu\_100\_dia}$$

$$\Delta M_{100\_dia} = 0.00 \text{ ft}$$

Maximum Applied Moment from Superstructure Analysis:

$$M_{u\_max\_100\_dia} = pre\_M_{overturning\_100\_dia} + \Phi M_{Resisting\_100\_dia}$$

$$M_{u\_max\_100\_dia} = 4523.88 \text{ kip*ft}$$

Check

Mu\_max\_100\_dia = 4523.88 kip\*ft

>=

Mu = 1700.25 kip\*ft

RATING: 37.58% OK

**Soil Wedges (Cohesionless Soil) (0.9\*D LC)**

Soil	Volume (ft³)	Soil Weight (kips)	Moment Arm (ft)	Unfactored Resisting Moment (kip*ft)	Eccentricity relative to W/2*SQRT(2):	
(2) End Prisms (above Water Table)	4.74	0.59	17.68	10.47		
(2) End Prisms (below Water Table)	0.00	0.00	0.00	0.00		
(1) End Prism (above Water Table)	2.37	0.30	35.95	10.65		
(1) End Prisms (below Water Table)	0.00	0.00	0.00	0.00		
(2) Partial Sides (above Water Table)	79.58	9.95	10.71	106.49		
(2) Partial Sides (below Water Table)	0.00	0.00	0.00	0.00		
(2) Rear (above Water Table)	105.39	13.17	26.81	353.26	Total Moment Arm (ft) =	2.35
(2) Rear (below Water Table)	0.00	0.00	0.00	0.00		
<b>Total</b>	<b>192.08</b>	<b>24.01</b>		<b>480.87</b>	Soil Wedge Wt (kip)=	<b>24.01</b>

Unfactored Resisting Moment of Wedges (0.9\*D LC):

$$M_{R\_wedges\_100\_dia} = \text{Total Moment Arm} * \text{Soil Wedge Wt}$$

$$M_{R\_wedges\_100\_dia} = 56.43 \text{ kip*ft}$$

Factored Resisting Moment of Wedges (0.9\*D LC):

$$\Phi M_{R\_wedges\_100\_dia} = 0.75 * M_{R\_wedges\_100\_dia}$$

$$\Phi M_{R\_wedges\_100\_dia} = 42.33 \text{ kip*ft}$$

**Soil Shear Strength (Cohesive Soil) (0.9\*D LC)**

Plane	Area (ft²)	Resistance (kip)	Moment Arm (ft)	Unfactored Resisting Moment (kip*ft)	Eccentricity relative to W/2*SQRT(2):	
(2) Rear	0.00	0.00	26.52	0.00	Total Moment Arm (ft) =	0.00
(2) Partial Sides	0.00	0.00	11.00	0.00		
<b>Total</b>		<b>0.00</b>		<b>0.00</b>	Soil Shear Strength (kip)=	<b>0.00</b>

Unfactored Resisting Moment of Soil Shear (0.9\*D LC):

$$M_{R\_shear\_100\_dia} = \text{Total Moment Arm} * \text{Soil Shear Strength}$$

$$M_{R\_shear\_100\_dia} = 0.00 \text{ kip*ft}$$

Factored Resisting Moment of Soil Shear (0.9\*D LC):

$$\Phi M_{R\_shear\_100\_dia} = 0.75 * (\text{Total Moment Arm} * \text{Soil Shear Strength})$$

$$\Phi M_{R\_shear\_100\_dia} = 0.00 \text{ kip*ft}$$


# EHamptonAWC

Exposure C

Frost Depth: 40"  
(per TIA-222-G,  
Middlesex County)

## Legend

-  41.58175 -72.502861
-  Circle Measure 3250'
-  open area



41.58175 -72.502861

East Hampton



ATTACHMENT D – PROOF OF DELIVERY OF NOTICE

ORIGIN ID:RSPA (860) 663-1697  
SCOTT M. CHASSE  
ALL-POINTS TECHNOLOGY CORP, P.C  
3 SADDLEBROOK DRIVE

SHIP DATE: 08SEP20  
ACTWGT: 1.00 LB  
CAD: 476240/IN/ET4280

KILLINGWORTH, CT 06419  
UNITED STATES US


BILL SENDER

TO **ATTN: DAVID COX, TOWN MANAGER**  
**TOWN OF EAST HAMPTON**  
**1 COMMUNITY DRIVE**

**EAST HAMPTON CT 06424**

REF: (860) 267-4468  
INV:  
PO:

DEPT:



J202020071401uv


56BJ6/1545/B766

TRK# 7714 7068 5440  
0201

WED - 09 SEP 4:30P  
STANDARD OVERNIGHT

**00 SKKA**

06424  
CT-US BDL



**After printing this label:**

1. Use the 'Print' button on this page to print your label to your laser or inkjet printer.
2. Fold the printed page along the horizontal line.
3. Place label in shipping pouch and affix it to your shipment so that the barcode portion of the label can be read and scanned.

**Warning:** Use only the printed original label for shipping. Using a photocopy of this label for shipping purposes is fraudulent and could result in additional billing charges, along with the cancellation of your FedEx account number.

Use of this system constitutes your agreement to the service conditions in the current FedEx Service Guide, available on fedex.com. FedEx will not be responsible for any claim in excess of \$100 per package, whether the result of loss, damage, delay, non-delivery, misdelivery, or misinformation, unless you declare a higher value, pay an additional charge, document your actual loss and file a timely claim. Limitations found in the current FedEx Service Guide apply. Your right to recover from FedEx for any loss, including intrinsic value of the package, loss of sales, income interest, profit, attorney's fees, costs, and other forms of damage whether direct, incidental, consequential, or special is limited to the greater of \$100 or the authorized declared value. Recovery cannot exceed actual documented loss. Maximum for items of extraordinary value is \$1,000, e.g. jewelry, precious metals, negotiable instruments and other items listed in our Service Guide. Written claims must be filed within strict time limits, see current FedEx Service Guide.

ORIGIN ID:RSPA (860) 663-1697  
SCOTT M. CHASSE  
ALL-POINTS TECHNOLOGY CORP, P.C  
3 SADDLEBROOK DRIVE

SHIP DATE: 08SEP20  
ACTWGT: 1.00 LB  
CAD: 476240/INLET4280


KILLINGWORTH, CT 06419  
UNITED STATES US

BILL SENDER

TO **ATTN: JEREMY DECARLI, AICP**  
**TOWN OF EAST HAMPTON**  
**1 COMMUNITY DRIVE**

**EAST HAMPTON CT 06424**

REF: (860) 267-7450  
INV:  
PO: DEPT:




56BJ6/1545/B766

TRK# 7714 7078 8073  
0201

WED - 09 SEP 4:30P  
STANDARD OVERNIGHT

**00 SKKA**

06424  
CT-US BDL



**After printing this label:**

1. Use the 'Print' button on this page to print your label to your laser or inkjet printer.
2. Fold the printed page along the horizontal line.
3. Place label in shipping pouch and affix it to your shipment so that the barcode portion of the label can be read and scanned.

**Warning:** Use only the printed original label for shipping. Using a photocopy of this label for shipping purposes is fraudulent and could result in additional billing charges, along with the cancellation of your FedEx account number.

Use of this system constitutes your agreement to the service conditions in the current FedEx Service Guide, available on fedex.com. FedEx will not be responsible for any claim in excess of \$100 per package, whether the result of loss, damage, delay, non-delivery, misdelivery, or misinformation, unless you declare a higher value, pay an additional charge, document your actual loss and file a timely claim. Limitations found in the current FedEx Service Guide apply. Your right to recover from FedEx for any loss, including intrinsic value of the package, loss of sales, income interest, profit, attorney's fees, costs, and other forms of damage whether direct, incidental, consequential, or special is limited to the greater of \$100 or the authorized declared value. Recovery cannot exceed actual documented loss. Maximum for items of extraordinary value is \$1,000, e.g. jewelry, precious metals, negotiable instruments and other items listed in our ServiceGuide. Written claims must be filed within strict time limits, see current FedEx Service Guide.

ORIGIN ID:RSPA (860) 663-1697  
SCOTT M. CHASSE  
ALL-POINTS TECHNOLOGY CORP. P.C  
3 SADDLEBROOK DRIVE

SHIP DATE: 08SEP20  
ACTWGT: 1.00 LB  
CAD: 476240/INLET4280


KILLINGWORTH, CT 06419  
UNITED STATES US

BILL SENDER

TO **ATTN: HONORABLE PETE BROWN**  
**TOWN OF EAST HAMPTON**  
**1 COMMUNITY DRIVE**

**EAST HAMPTON CT 06424**

REF: (860) 267-2519 X310  
INV/ PO: DEPT:



J202020071401uv


56BJ6/1545/B766

TRK# 7714 7072 7108  
0201

WED - 09 SEP 4:30P  
STANDARD OVERNIGHT

**00 SKKA**

06424  
CT-US BDL



**After printing this label:**

1. Use the 'Print' button on this page to print your label to your laser or inkjet printer.
2. Fold the printed page along the horizontal line.
3. Place label in shipping pouch and affix it to your shipment so that the barcode portion of the label can be read and scanned.

**Warning:** Use only the printed original label for shipping. Using a photocopy of this label for shipping purposes is fraudulent and could result in additional billing charges, along with the cancellation of your FedEx account number.

Use of this system constitutes your agreement to the service conditions in the current FedEx Service Guide, available on fedex.com. FedEx will not be responsible for any claim in excess of \$100 per package, whether the result of loss, damage, delay, non-delivery, misdelivery, or misinformation, unless you declare a higher value, pay an additional charge, document your actual loss and file a timely claim. Limitations found in the current FedEx Service Guide apply. Your right to recover from FedEx for any loss, including intrinsic value of the package, loss of sales, income interest, profit, attorney's fees, costs, and other forms of damage whether direct, incidental, consequential, or special is limited to the greater of \$100 or the authorized declared value. Recovery cannot exceed actual documented loss. Maximum for items of extraordinary value is \$1,000, e.g. jewelry, precious metals, negotiable instruments and other items listed in our ServiceGuide. Written claims must be filed within strict time limits, see current FedEx Service Guide.

ATTACHMENT E - POWER DENSITY REPORT



C Squared Systems, LLC  
65 Dartmouth Drive  
Auburn, NH 03032  
603-644-2800  
[support@csquaredsystems.com](mailto:support@csquaredsystems.com)

---

Calculated Radio Frequency Emissions Report



**ES-154**

22 East High Street

East Hampton, CT 06242

---

June 22, 2020

## Table of Contents

1. Introduction.....	1
2. FCC Guidelines for Evaluating RF Radiation Exposure Limits.....	1
3. Power Density Calculation Methods .....	2
4. Calculated % MPE Results .....	3
5. Conclusion .....	4
6. Statement of Certification.....	4
Attachment A: References .....	5
Attachment B: FCC Limits for Maximum Permissible Exposure (MPE) .....	6
Attachment C: Eversource Antenna Data Sheet and Electrical Patterns .....	8

## List of Tables

Table 1: Proposed Facility % MPE .....	3
Table 2: FCC Limits for Maximum Permissible Exposure (MPE) .....	6

## List of Figures

Figure 1: Graph of FCC Limits for Maximum Permissible Exposure (MPE).....	7
---	---

## 1. Introduction

The purpose of this report is to investigate compliance with applicable FCC regulations for the proposed Eversource installation on the self-support tower at 22 East High Street in East Hampton, CT. Eversource is proposing to install one omnidirectional antenna as part of its 220 MHz communications system.

This report considers the proposed antenna configuration as detailed by Eversource along with power density information for the existing antennas to calculate the cumulative % MPE of the facility at ground level.

## 2. FCC Guidelines for Evaluating RF Radiation Exposure Limits

In 1985, the FCC established rules to regulate radio frequency (RF) exposure from FCC licensed antenna facilities. In 1996, the FCC updated these rules, which were further amended in August 1997 by OET Bulletin 65 Edition 97-01. These new rules include Maximum Permissible Exposure (MPE) limits for transmitters operating between 300 kHz and 100 GHz. The FCC MPE limits are based upon those recommended by the National Council on Radiation Protection and Measurements (NCRP), developed by the Institute of Electrical and Electronics Engineers, Inc., (IEEE) and adopted by the American National Standards Institute (ANSI).

The FCC general population/uncontrolled limits set the maximum exposure to which most people may be subjected. General population/uncontrolled exposures apply in situations in which the general public may be exposed, or in which persons that are exposed as a consequence of their employment may not be fully aware of the potential for exposure or cannot exercise control over their exposure.

Public exposure to radio frequencies is regulated and enforced in units of milliwatts per square centimeter ( $\text{mW}/\text{cm}^2$ ). The general population exposure limits for the various frequency ranges are defined in the attached “FCC Limits for Maximum Permissible Exposure (MPE)” in Attachment B of this report.

Higher exposure limits are permitted under the occupational/controlled exposure category, but only for persons who are exposed as a consequence of their employment and who have been made fully aware of the potential for exposure, and they must be able to exercise control over their exposure. General population/uncontrolled limits are five times more stringent than the levels that are acceptable for occupational, or radio frequency trained individuals. Attachment B contains excerpts from OET Bulletin 65 and defines the Maximum Exposure Limit.

Finally, it should be noted that the MPE limits adopted by the FCC for both general population/uncontrolled exposure and for occupational/controlled exposure incorporate a substantial margin of safety and have been established to be well below levels generally accepted as having the potential to cause adverse health effects.

### 3. Power Density Calculation Methods

The power density calculation results were generated using the following formula as outlined in FCC bulletin OET 65, and Connecticut Siting Council recommendations:

$$\text{Power Density} = \left( \frac{1.6^2 \times 1.64 \times \text{ERP}}{4\pi \times R^2} \right) \times \text{Off Beam Loss}$$

Where:

EIRP = Effective Isotropic Radiated Power = 1.64 x ERP

R = Radial Distance =  $\sqrt{(H^2 + V^2)}$

H = Horizontal Distance from antenna

V = Vertical Distance from radiation center of antenna

Ground reflection factor of 1.6

Off Beam Loss is determined by the selected antenna pattern

These calculations assume that the antennas are operating at 100 percent capacity and full power, and that all antenna channels are transmitting simultaneously. Obstructions (trees, buildings, etc.) that would normally attenuate the signal are not taken into account. The calculations assume even terrain in the area of study and do not consider actual terrain elevations which could attenuate the signal. As a result, the calculated power density and corresponding % MPE levels reported below are much higher than the actual levels will be from the final installation.

#### 4. Calculated % MPE Results

Table 1 below outlines the power density information for the site. The proposed Eversource omnidirectional transmit antenna has a vertical beamwidths of 30°; therefore, the majority of the RF power is focused out towards the horizon. Please refer to Attachment C, for the vertical patterns of the proposed Eversource antenna. Likewise, the other transmit antennas exhibit directionality of varying vertical beamwidths. As a result, there will be less RF power directed below the antennas relative to the horizon, and consequently lower power density levels around the base of the facility. The calculated results in Table 1 include a nominal 10 dB off-beam pattern loss for the proposed antenna and a nominal 30 dB off-beam pattern loss for the highly directional point-to-point microwave antenna to account for the lower relative gain below these antennas. Any inactive or receive-only antennas are not included in the table, as they are irrelevant in terms of the % MPE calculations. The blue shaded entry represent the proposed antenna, whereas the green shaded entries represent the existing Eversource transmit antennas on the tower. The greyed entries reflect those that were included in this site’s original MPE filing in 2016 but are not currently installed at this location per the Black & Veatch Structural Analysis Report (6/15/2020); therefore, these entries have not been included in the calculated total % MPE.

Carrier	Antenna Height (Feet)	Operating Frequency (MHz)	Number of Trans.	ERP Per Transmitter (Watts)	Power Density (mw/cm <sup>2</sup> )	Limit	% MPE
<i>Eversource</i>	130	900	1	240	0.0006	0.6000	0.09%
<i>Eversource</i>	130	450	1	1000	0.0023	0.3000	0.78%
<i>Eversource</i>	105	154	1	180	0.0066	0.2000	3.30%
Eversource	127	48.38	1	100	0.0025	0.2000	1.23%
Eversource	117	6004.5	1	4266	0.0001	1.0000	0.01%
Eversource	117	6256.54	1	4266	0.0001	1.0000	0.01%
Eversource	103	49.1	1	100	0.0038	0.2000	1.91%
Eversource	87	49.28	1	100	0.0055	0.2000	2.74%
Eversource	123.5	217	4	124	0.0013	0.2000	0.65%
						<b>Total</b>	<b>6.55%</b>

**Table 1: Proposed Facility % MPE <sup>1 2</sup>**

<sup>1</sup> Antenna heights listed for all existing and proposed antennas are based on the Black & Veatch Structural Analysis Report dated June 15, 2020.

<sup>2</sup> The power density information for each Eversource antenna was provided by Eversource through its agents. Please note that % MPE values listed are rounded to two decimal points and the total % MPE listed is a summation of each unrounded contribution. Therefore, summing each rounded value may not identically match the total value reflected in the table.

## 5. Conclusion

The above analysis concludes that RF exposure at ground level with the proposed antenna installation will be below the maximum power density limits as outlined by the FCC in the OET Bulletin 65 Ed. 97-01. Using the conservative calculation methods discussed herein, the highest composite percent of Maximum Permissible Exposure expected at ground level with the proposed installation is **6.55% of the FCC General Population/Uncontrolled limit**.

As noted previously, the calculated % MPE levels are more conservative (higher) than the actual levels will be from the finished installation.

## 6. Statement of Certification

I certify to the best of my knowledge that the statements in this report are true and accurate. The calculations follow guidelines set forth in FCC OET Bulletin 65 Edition 97-01, IEEE Std. C95.1, and IEEE Std. C95.3.

*Keith Vellante*

June 22, 2020

Report Prepared By: Keith Vellante  
Director of RF Services  
C Squared Systems, LLC

Date

## **Attachment A: References**

OET Bulletin 65 - Edition 97-01 - August 1997 Federal Communications Commission Office of Engineering & Technology

IEEE C95.1-2005, IEEE Standard Safety Levels With Respect to Human Exposure to Radio Frequency Electromagnetic Fields, 3 kHz to 300 GHz IEEE-SA Standards Board

IEEE C95.3-2002 (R2008), IEEE Recommended Practice for Measurements and Computations of Radio Frequency Electromagnetic Fields With Respect to Human Exposure to Such Fields, 100 kHz-300 GHz IEEE-SA Standards Board

**Attachment B: FCC Limits for Maximum Permissible Exposure (MPE)**

**(A) Limits for Occupational/Controlled Exposure<sup>3</sup>**

Frequency Range (MHz)	Electric Field Strength (E) (V/m)	Magnetic Field Strength (E) (A/m)	Power Density (S) (mW/cm <sup>2</sup> )	Averaging Time  E  <sup>2</sup> ,  H  <sup>2</sup> or S (minutes)
0.3-3.0	614	1.63	(100)*	6
3.0-30	1842/f	4.89/f	(900/f <sup>2</sup> )*	6
30-300	61.4	0.163	1.0	6
300-1500	-	-	f/300	6
1500-100,000	-	-	5	6

**(B) Limits for General Population/Uncontrolled Exposure<sup>4</sup>**

Frequency Range (MHz)	Electric Field Strength (E) (V/m)	Magnetic Field Strength (E) (A/m)	Power Density (S) (mW/cm <sup>2</sup> )	Averaging Time  E  <sup>2</sup> ,  H  <sup>2</sup> or S (minutes)
0.3-1.34	614	1.63	(100)*	30
1.34-30	824/f	2.19/f	(180/f <sup>2</sup> )*	30
30-300	27.5	0.073	0.2	30
300-1500	-	-	f/1500	30
1500-100,000	-	-	1.0	30

f = frequency in MHz \* Plane-wave equivalent power density

**Table 2: FCC Limits for Maximum Permissible Exposure (MPE)**

<sup>3</sup> Occupational/controlled limits apply in situations in which persons are exposed as a consequence of their employment provided those persons are fully aware of the potential for exposure and can exercise control over their exposure. Limits for occupational/controlled exposure also apply in situations when an individual is transient through a location where occupational/controlled limits apply provided he or she is made aware of the potential for exposure

<sup>4</sup> General population/uncontrolled exposures apply in situations in which the general public may be exposed, or in which persons that are exposed as a consequence of their employment may not be fully aware of the potential for exposure or cannot exercise control over their exposure







Figure 1: Graph of FCC Limits for Maximum Permissible Exposure (MPE)

### Attachment C: Eversource Antenna Data Sheet and Electrical Patterns<sup>5</sup>



<sup>5</sup> In the case where pattern data was unavailable from the manufacturer, vertical patterns shown are for antennas with similar specifications.