

November 16, 2015

VIA EMAIL AND OVERNIGHT DELIVERY

Ms. Melanie A. Bachman
Acting Executive Director
Connecticut Siting Council
Ten Franklin Square
New Britain, CT 06051

RE: T-Mobile Northeast LLC - CT11360
Notice of Exempt Modification
Route 136 (Westport Turnpike), Fairfield, CT
LAT: 41-12-05.83" N
LNG: 73-19-55.42" W

Dear Ms. Bachman:

T-Mobile Northeast LLC ("T-Mobile") currently maintains two (2) antennas at the 96' level on the existing 81' tall steel transmission structure #910 located at Route 136 (Westport Turnpike) in Fairfield, CT. The property is owned by the Connecticut Light and Power Company d/b/a Eversource Energy. T-Mobile now intends to replace the two (2) existing antennas with two (2) new 1900 and 2100 MHz antennas. These antennas would be installed at the 96' level of the tower. T-Mobile also intends to remove one (1) existing microwave dish, remove one (1) 7/8" coax cable and replace one (1) existing equipment cabinet on existing concrete pad at grade.

This facility was approved by the Siting Council in Petition No. 471 on July 25, 2000. This approval included an approval for four (4) panel antennas installed on a 17' pipe mast to the existing 81' tall steel lattice electric transmission structure; the total height of the structure with all antennas would be 98' - 4". The proposed replacement antennas are 53.1". Accordingly, this modification complies with the aforementioned conditions.

Please accept this letter as notification pursuant to Regulations of Connecticut State Agencies 16-50j-73, for construction that constitutes an exempt modification pursuant to R.C.S.A. 16-50j-72(b)(2). In accordance with R.C.S.A. 16-50j-73, a copy of this letter is being sent to Michael Tetreau, First Selectman for the Town of Fairfield, as well as the property owner and the tower owner.


The planned modifications to the facility fall squarely within those activities explicitly provided for in R.C.S.A. 16-50j-72(b)(s).

1. The proposed modifications will not result in an increase in the height of the existing structure. T-Mobile proposes to replace two (2) existing antennas at a centerline height of 96' on the existing pipe mast.

2. The proposed modifications will not require the extension of the site boundary. T-Mobile will replace an existing cabinet on an existing pad at grade. Thus, there will be no effect on the site compound or T-Mobile's leased area.
3. The proposed modifications will not increase noise levels at the facility by six decibels or more, or to levels that exceed state and local criteria. The incremental effect of the proposed changes will be negligible.
4. The operation of the replacement antennas will not increase radio frequency emissions at the facility to a level at or above the Federal Communications Commission safety standard. As indicated in the attached power density calculations, T-Mobile's operations at the site will result in a power density of 3.44%; the combined site operations will result in a total power density of 3.44%.
5. The proposed modifications will not cause a change or alteration in the physical or environmental characteristics of the site. T-Mobile will replace existing antennas and an existing equipment cabinet on an existing pad at grade.
6. The existing structure and its foundation can support the proposed loading. As indicated in the attached structural analysis the subject utility tower is adequate to support the proposed T-Mobile equipment upgrade.

For the foregoing reasons, T-Mobile respectfully submits that the proposed modifications to the above-referenced telecommunications facility constitute an exempt modification under R.C.S.A. 16-50j-72(b)(2).

Respectfully submitted,

By: 
Eric Dahl, Agent for T-Mobile
edahl@comcast.net
860-227-1975

Attachments

cc: Michael Tetreau, First Selectman for the Town of Fairfield - as elected official
Hank O'Brien, Eversource Energy - as tower and property owner



56 Prospect Street,
Hartford, CT 06103

P.O. Box 270
Hartford, CT 06141-0270
(860) 665-5000

September 25, 2015

Mr. Mark Richard
T-Mobile
35 Griffin Rd.
Bloomfield, CT 06002

RE: T-Mobile Antenna Site, CT-11 360A, Westport Tpke., Fairfield CT, structure 910.

Dear Mr. Richard:

Based on our reviews of the site drawings, the structural analysis and foundation review provided by Centek Engineering, along with a third party review performed by Paul J. Ford we have reviewed for acceptance this modification.

Since there are no outstanding structural or site related issues to resolve at this time, construction at these locations may begin as soon as scheduling allows. You may contact Mr. O'Brien (860-665-6987); for lease requirements.

Sincerely,


Robert Gray
Transmission Line Engineering

Ref: 15019.001 - CT11360A - CDs Rev.0 15.08.11.pdf


Ref: 15019.001 - CT11360A Structural Analysis Rev1 15-07-16.pdf

LEASE EXHIBIT

THIS LEASE PLAN IS DIAGRAMMATIC IN NATURE AND IS INTENDED TO PROVIDE GENERAL INFORMATION REGARDING THE LOCATION AND SIZE OF THE PROPOSED WIRELESS COMMUNICATION FACILITY. THE SITE LAYOUT WILL BE FINALIZED UPON COMPLETION OF SITE SURVEY AND FACILITY DESIGN.

SITE COORDINATES: LAT.: 41°-12'-05.83" N
LNG.: 73°-19'-55.42" W

GROUND ELEVATION: 215.0' ± A.M.S.L.
(SITE COORDINATES AND GROUND ELEVATION PROVIDED BY T-MOBILE.)



1 SITE /COMPOUND PLAN

SCALE: 1" = 10'



REV.	DATE	DATE	DATE	DESCRIPTION
0	10/14/15	TUL	DMD	LEASE EXHIBIT - CLIENT REVIEW
		BY	BY	



Mobile
CENTEK engineering
Center on Solutions™
www.Centek.com
Tel: 860-638-2200
Fax: 860-638-2202
402 North Bedford Road, Bedford, CT 06824

T-MOBILE NORTHEAST LLC
SITE NO.: CT11360A
S/N: WESTPORT/RT 136
EVERSOURCE STRUCTURE NO. 910
WESTPORT TURNPIKE
FAIRFIELD, CT 06824

DATE:	10/13/15
SCALE:	AS SHOWN
JOB NO.:	15019.001


SHRIT NO.
L-1

LEASE EXHIBIT

THIS LEASE PLAN IS DIAGRAMMATIC IN NATURE AND IS INTENDED TO PROVIDE GENERAL INFORMATION REGARDING THE LOCATION AND SIZE OF THE PROPOSED WIRELESS COMMUNICATION FACILITY. THE SITE LAYOUT WILL BE FINALIZED UPON COMPLETION OF SITE SURVEY AND FACILITY DESIGN.

NOTE:

PROPOSED T-MOBILE ANTENNA/COAX QUANTITY & MOUNT TYPE DEPENDENT ON STRUCTURAL ANALYSIS OF EXISTING EVERSOURCE TRANSMISSION TOWER #910 & EVERSOURCE APPROVAL.



1 EAST ELEVATION

SCALE: 1" = 15'



LE-2

SHEET NO.

L-2

T-MOBILE NORTHEAST LLC
SITE NO.: CT11360A
S/N: WESTPORT/RT 136
EVERSOURCE STRUCTURE NO. 910
WESTPORT TURNPIKE
FAIRFIELD, CT 06824

Mobile
CENTEK engineering
Continued on Solutions™
203.484.6550
200 Westport Road, Fairfield, CT 06824

REV.	DATE	TITLE	DRAWN BY	CHECKED BY	DESCRIPTION
0	10/14/15				LEASE EXHIBIT - CLIENT REVIEW

Structural Analysis of
Antenna Mast &
Transmission Tower


T-Mobile Site Ref: CT11360A

Eversource Structure No. 910
81' Electric Transmission Tower

Westport Turnpike
Fairfield, CT

CEN TEK Project No. 15019.001

~~Date: May 27, 2015~~
Rev 1: July 16, 2015



Prepared for:
T-Mobile USA
35 Griffin Road
Bloomfield, CT 06002

Table of Contents

SECTION 1 - REPORT

- INTRODUCTION
- PRIMARY ASSUMPTIONS USED IN THE ANALYSIS
- ANALYSIS
- DESIGN BASIS
- RESULTS
- CONCLUSION

SECTION 2 - CONDITIONS & SOFTWARE

- STANDARD ENGINEERING CONDITIONS
- GENERAL DESCRIPTION OF STRUCTURAL ANALYSIS PROGRAMS
 - RISA 3-D
 - PLS TOWER

SECTION 3 - DESIGN CRITERIA

- CRITERIA FOR DESIGN OF PCS FACILITIES ON OR EXTENDING ABOVE METAL ELECTRIC TRANSMISSION TOWERS
- NU DESIGN CRITERIA TABLE
- PCS SHAPE FACTOR CRITERIA
- WIRE LOADS SHEET

SECTION 4 - DRAWINGS

- EL-1 TOWER AND MAST ELEVATION

SECTION 5 - EIA/TIA-222-F LOAD CALCULATIONS FOR ANTENNA MAST DESIGN

- ANTENNA MAST WIND & ICE LOAD

SECTION 6 - ANTENNA MAST DESIGN PER EIA/TIA-222F LOADS

- LOAD CASES AND COMBINATIONS (TIA/EIA LOADING) - ANTENNA MAST
- RISA 3-D ANALYSIS REPORT – ANTENNA MAST
- CONNECTION ANALYSIS

**SECTION 7 - NECS/NU LOAD CALCULATIONS FOR UTILITY
STRUCTURE ANALYSIS**

- EQUIPMENT WIND LOAD CALCULATION
- COAX CABLE LOAD ON TOWER

SECTION 8 - PLS TOWER RESULTS FROM NESC/NU LOAD CRITERIA

- PLS REPORT
- FOUNDATION ANALYSIS
- LOCAL STRESS CHECK

SECTION 9 - REFERENCE MATERIAL

- EQUIPMENT CUT SHEETS

Introduction

The purpose of this report is to analyze the existing Antenna Mast and 81' transmission tower located on Westport Turnpike in Fairfield, CT for the proposed T-Mobile antenna upgrade.

The proposed loads consist of the following:

- **T-MOBILE (Existing to Remain):**
Coax Cables: Four (4) 1-5/8" \varnothing coax cables running on a face of the tower as indicated in section 4 of this report.
- **T-MOBILE (Existing to Remove):**
Antennas: Two (2) EMS RR90-17-02DP panel antennas flush mounted with a RAD center elevation of 96-ft above grade and one (1) microwave dish.
Coax Cables: One (1) 7/8" \varnothing coax cable running on a face of the tower as indicated in section 4 of this report.
- **T-MOBILE (Proposed):**
Antennas: Two (2) RFS APXV18-206516S-C panel antennas flush mounted with a RAD center elevation of 96-ft above grade.

Primary assumptions used in the analysis

- Allowable steel stresses are defined by AISC-ASD 9th edition for design of the Antenna Mast and antenna supporting elements.
- ASCE Manual No. 10-97, "Design of Latticed Steel Transmission Structures", defines allowable steel stresses for evaluation of the CL&P utility tower.
- All utility tower members are adequately protected to prevent corrosion of steel members.
- All proposed antenna mounts are modeled as listed above.
- All coaxial cable will be installed within the Antenna Mast unless specified otherwise.
- Antenna Mast will be properly installed and maintained.
- No residual stresses exist due to incorrect tower erection.
- All bolts are appropriately tightened providing the necessary connection continuity.
- All welds conform to the requirements of AWS D1.1.
- Antenna Mast and utility tower will be in plumb condition.
- Utility tower was properly installed and maintained and all members were properly designed, detailed, fabricated, and installed and have been properly maintained since erection.
- Any deviation from the analyzed loading will require a new analysis for verification of structural adequacy.

Analysis

Structural analysis of the existing *Antenna Mast Structure* was independently completed using the current version of RISA-3D computer program licensed to CENTEK Engineering, Inc.

The existing mast consisting of a 6-in SCH. 40 pipe (O.D. = 6.625") connected at twelve points to the existing tower was analyzed for its ability to resist loads prescribed by the TIA/EIA standard. Section 5 of this report details these gravity and lateral wind loads. Load cases and combinations used in RISA-3D for TIA/EIA loading are listed in report Sections 6.

Structural analysis of the existing CL&P tower structure was completed using the current version of PLS-Tower computer program licensed to CENTEK Engineering, Inc. The NESC program contains a library of all AISC angle shapes and corresponding section properties are computed and applied directly within the program. The program's Steel Code Check option was also utilized.

The existing 81-ft tall CL&P lattice tower was analyzed for its ability to resist loads prescribed by the NESC standard. Maximum usage for the tower was calculated considering the additional forces from the Antenna Mast and associated appurtenances. Section 7 of this report details these gravity and lateral wind loads.

Design Basis

Our analysis was performed in accordance with EIA-222-F-1996, ASCE Manual No. 10-97, "Design of Latticed Steel Transmission Structures", NESC C2-2007 and Northeast Utilities Design Criteria.

The CL&P tower structure, considering existing and future conductor and shield wire loading, with the proposed antenna mast was analyzed under two conditions:

▪ UTILITY TOWER ANALYSIS

The purpose of this analysis is to determine the adequacy of the existing utility structure to support the proposed antenna loads. The loading and design requirements were analyzed in accordance with the NU Design Criteria Table, NESC C2-2007 ~ Construction Grade B, and ASCE Manual No. 10-97, "Design of Latticed Steel Transmission Structures".

Load cases considered:

Load Case 1: NESC Heavy

Wind Pressure.....	4.0 psf
Radial Ice Thickness.....	0.5"
Vertical Overload Capacity Factor.....	1.50
Wind Overload Capacity Factor.....	2.50
Wire Tension Overload Capacity Factor.....	1.65

Load Case 2: NESC Extreme

Wind Speed.....	110 mph ⁽¹⁾
Radial Ice Thickness.....	0"

Note 1: NESC C2-2007, Section 25, Rule 250C: Extreme Wind Loading, 1.25 x Gust Response Factor (wind speed: 3-second gust)

▪ ANTENNA MAST ANALYSIS

Antenna Mast, appurtenances and connections to the utility tower were analyzed and designed in accordance with the NU Design Criteria Table, TIA/EIA-222-F, and AISC-ASD standards.

Load cases considered:

Load Case 1:

Wind Speed..... 85 mph ⁽²⁾
 Radial Ice Thickness..... 0"

Load Case 2:

Wind Pressure..... 75% of 85 mph wind pressure
 Radial Ice Thickness..... 0.5"

| Note 2: Per NU Mast Design Criteria Exception 1.

Results

▪ ANTENNA MAST

The Antenna Mast was determined to be structurally adequate.

Member	Stress Ratio (% of capacity)	Result
6" Std. Pipe	85.9%	PASS
L3x3x1/4 Brace	16.4%	PASS
Mast Connection to CL&P Tower	38.69% ⁽¹⁾	PASS

Note 1 – 1/3 increase in allowable stress not used for connection to tower per OTRM 059.

▪ UTILITY TOWER

This analysis finds that the subject utility structure is adequate to support the existing PCS mast and related appurtenances. The tower stresses meet the requirements set forth by the ASCE Manual No. 10-97, "Design of Latticed Steel Transmission Structures", for the applied NESC Heavy and Hi-Wind load cases. The detailed analysis results are provided in Section 9 of this report. The analysis results are summarized as follows:

A maximum usage of **94.57%** occurs in the utility tower under the **NESC Extreme** loading condition.

TOWER SECTION:

The utility structure was found to be within allowable limits.

Tower Member	Stress Ratio (% of capacity)	Result
Angle g31XY	94.57%	PASS

▪ FOUNDATION AND ANCHORS

The existing foundation consists of four (4) 1.67-ft square tapering to 2.33-ft square x 5.25-ft long reinforced concrete piers on four (4) 5-ft square x 2-ft thick reinforced concrete pads. The base of the tower is connected to the foundation by one (1) anchor stub per leg. Foundation information was obtained from NUSCO drawing # 01064-60003. Three (3) of the tower leg foundations were reinforced with 8-ft square by 3.5-ft thick reinforced concrete blocks. **Size of the reinforcement blocks was verified in the field.**

BASE REACTIONS:

From PLS-Tower analysis of CL&P tower based on NESC/NU prescribed loads.

Load Case	Shear	Uplift	Compression
NESC Heavy Wind	5.52 kips	15.51 kips	28.43 kips
NESC Extreme Wind	9.45 kips	33.05 kips	39.51 kips

Note 1 – 10% increase to be applied to the above tower base reactions for foundation verification per OTRM 051

FOUNDATION:

The foundation was found to be within allowable limits.

Foundation	Design Limit	Allowable Limit	Proposed Loading ⁽²⁾	Result
Reinforced Conc. Pad and Pier	Uplift	1.0 FS ⁽¹⁾	1.05 FS ⁽¹⁾	PASS

Note 1: FS denotes Factor of Safety

Note 2: 10% increase to PLS base reactions used in foundation analysis per OTRM 051.


Conclusion

This analysis shows that the subject utility tower **is adequate** to support the proposed T-Mobile equipment upgrade.

The analysis is based, in part, on the information provided to this office by Eversource and T-Mobile. If the existing conditions are different than the information in this report, Centek Engineering, Inc. must be contacted for resolution of any potential issues.

Please feel free to call with any questions or comments.

Respectfully Submitted by:



Timothy J. Lynn, PE
 Structural Engineer



STANDARD CONDITIONS FOR FURNISHING OF
PROFESSIONAL ENGINEERING SERVICES ON
EXISTING STRUCTURES

All engineering services are performed on the basis that the information used is current and correct. This information may consist of, but is not necessarily limited to:

- Information supplied by the client regarding the structure itself, its foundations, the soil conditions, the antenna and feed line loading on the structure and its components, or other relevant information.
- Information from the field and/or drawings in the possession of CEN TEK engineering, Inc. or generated by field inspections or measurements of the structure.
- It is the responsibility of the client to ensure that the information provided to CEN TEK engineering, Inc. and used in the performance of our engineering services is correct and complete. In the absence of information to the contrary, we assume that all structures were constructed in accordance with the drawings and specifications and are in an un-corroded condition and have not deteriorated. It is therefore assumed that its capacity has not significantly changed from the "as new" condition.
- All services will be performed to the codes specified by the client, and we do not imply to meet any other codes or requirements unless explicitly agreed in writing. If wind and ice loads or other relevant parameters are to be different from the minimum values recommended by the codes, the client shall specify the exact requirement. In the absence of information to the contrary, all work will be performed in accordance with the latest revision of ANSI/ASCE10 & ANSI/EIA-222.
- All services are performed, results obtained, and recommendations made in accordance with generally accepted engineering principles and practices. CEN TEK engineering, Inc. is not responsible for the conclusions, opinions and recommendations made by others based on the information we supply.

GENERAL DESCRIPTION OF STRUCTURAL ANALYSIS PROGRAM ~ RISA - 3D

RISA-3D Structural Analysis Program is an integrated structural analysis and design software package for buildings, bridges, tower structures, etc.

Modeling Features:

- Comprehensive CAD-like graphic drawing/editing capabilities that let you draw, modify and load elements as well as snap, move, rotate, copy, mirror, scale, split, merge, mesh, delete, apply, etc.
- Versatile drawing grids (orthogonal, radial, skewed)
- Universal snaps and object snaps allow drawing without grids
- Versatile general truss generator
- Powerful graphic select/unselect tools including box, line, polygon, invert, criteria, spreadsheet selection, with locking
- Saved selections to quickly recall desired selections
- Modification tools that modify single items or entire selections
- Real spreadsheets with cut, paste, fill, math, sort, find, etc.
- Dynamic synchronization between spreadsheets and views so you can edit or view any data in the plotted views or in the spreadsheets
- Simultaneous view of multiple spreadsheets
- Constant in-stream error checking and data validation
- Unlimited undo/redo capability
- Generation templates for grids, disks, cylinders, cones, arcs, trusses, tanks, hydrostatic loads, etc.
- Support for all units systems & conversions at any time
- Automatic interaction with RISASection libraries
- Import DXF, RISA-2D, STAAD and ProSteel 3D files
- Export DXF, SDNF and ProSteel 3D files

Analysis Features:

- Static analysis and P-Delta effects
- Multiple simultaneous dynamic and response spectra analysis using Gupta, CQC or SRSS mode combinations
- Automatic inclusion of mass offset (5% or user defined) for dynamic analysis
- Physical member modeling that does not require members to be broken up at intermediate joints
- State of the art 3 or 4 node plate/shell elements
- High-end automatic mesh generation — draw a polygon with any number of sides to create a mesh of well-formed quadrilateral (NOT triangular) elements.
- Accurate analysis of tapered wide flanges - web, top and bottom flanges may all taper independently
- Automatic rigid diaphragm modeling
- Area loads with one-way or two-way distributions
- Multiple simultaneous moving loads with standard AASHTO loads and custom moving loads for bridges, cranes, etc.
- Torsional warping calculations for stiffness, stress and design
- Automatic Top of Member offset modeling
- Member end releases & rigid end offsets
- Joint master-slave assignments
- Joints detachable from diaphragms
- Enforced joint displacements
- 1-Way members, for tension only bracing, slipping, etc.

- 1-Way springs, for modeling soils and other effects
- Euler members that take compression up to their buckling load, then turn off.
- Stress calculations on any arbitrary shape
- Inactive members, plates, and diaphragms allows you to quickly remove parts of structures from consideration
- Story drift calculations provide relative drift and ratio to height
- Automatic self-weight calculations for members and plates
- Automatic subgrade soil spring generator

Graphics Features:

- Unlimited simultaneous model view windows
- Extraordinary “true to scale” rendering, even when drawing
- High-speed redraw algorithm for instant refreshing
- Dynamic scrolling stops right where you want
- Plot & print virtually everything with color coding & labeling
- Rotate, zoom, pan, scroll and snap views
- Saved views to quickly restore frequent or desired views
- Full render or wire-frame animations of deflected model and dynamic mode shapes with frame and speed control
- Animation of moving loads with speed control
- High quality customizable graphics printing

Design Features:

- Designs concrete, hot rolled steel, cold formed steel and wood
- ACI 1999/2002, BS 8110-97, CSA A23.3-94, IS456:2000, EC 2-1992 with consistent bar sizes through adjacent spans
- Exact integration of concrete stress distributions using parabolic or rectangular stress blocks
- Concrete beam detailing (Rectangular, T and L)
- Concrete column interaction diagrams
- Steel Design Codes: AISC ASD 9th, LRFD 2nd & 3rd, HSS Specification, CAN/CSA-S16.1-1994 & 2004, BS 5950-1-2000, IS 800-1984, Euro 3-1993 including local shape databases
- AISI 1999 cold formed steel design
- NDS 1991/1997/2001 wood design, including Structural Composite Lumber, multi-ply, full sawn
- Automatic spectra generation for UBC 1997, IBC 2000/2003
- Generation of load combinations: ASCE, UBC, IBC, BOCA, SBC, ACI
- Unbraced lengths for physical members that recognize connecting elements and full lengths of members
- Automatic approximation of K factors
- Tapered wide flange design with either ASD or LRFD codes
- Optimization of member sizes for all materials and all design codes, controlled by standard or user-defined lists of available sizes and criteria such as maximum depths
- Automatic calculation of custom shape properties
- Steel Shapes: AISC, HSS, CAN, ARBED, British, Euro, Indian, Chilean
- Light Gage Shapes: AISI, SSMA, Dale / Incor, Dietrich, MarinoWARE
- Wood Shapes: Complete NDS species/grade database
- Full seamless integration with RISAFoot (Ver 2 or better) for advanced footing design and detailing
- Plate force summation tool

Results Features:

- Graphic presentation of color-coded results and plotted designs
- Color contours of plate stresses and forces with quadratic smoothing, the contours may also be animated
- Spreadsheet results with sorting and filtering of: reactions, member & joint deflections, beam & plate forces/stresses, optimized sizes, code designs, concrete reinforcing, material takeoffs, frequencies and mode shapes
- Standard and user-defined reports
- Graphic member detail reports with force/stress/deflection diagrams and detailed design calculations and expanded diagrams that display magnitudes at any dialed location
- Saved solutions quickly restore analysis and design results.

GENERAL DESCRIPTION OF STRUCTURAL ANALYSIS PROGRAM ~ PLS - TOWER

PLS-TOWER is a Microsoft Windows program for the analysis and design of steel latticed towers used in electric power lines or communication facilities. Both self-supporting and guyed towers can be modeled. The program performs design checks of structures under user specified loads. For electric power structures it can also calculate maximum allowable wind and weight spans and interaction diagrams between different ratios of allowable wind and weight spans.

Modeling Features:

- Powerful graphics module (stress usages shown in different colors)
- Graphical selection of joints and members allows graphical editing and checking
- Towers can be shown as lines, wire frames or can be rendered as 3-d polygon surfaces
- Can extract geometry and connectivity information from a DXF CAD drawing
- CAD design drawings, title blocks, drawing borders or photos can be tied to structure model
- XML based post processor interface
- Steel Detailing Neutral File (SDNF) export to link with detailing packages
- Can link directly to line design program PLS-CADD
- Automatic generation of structure files for PLS-CADD
- Databases of steel angles, rounds, bolts, guys, etc.
- Automatic generation of joints and members by symmetries and interpolations
- Automated mast generation (quickly builds model for towers that have regular repeating sections) via graphical copy/paste
- Steel angles and rounds modeled either as truss, beam or tension-only elements
- Guys are easily handled (can be modeled as exact cable elements)

Analysis Features:

- Automatic handling of tension-only members
- Automatic distribution of loads in 2-part suspension insulators (v-strings, horizontal vees, etc.)
- Automatic calculation of tower dead, ice, and wind loads as well as drag coefficients according to:
 - ASCE 74-1991
 - NESC 2002
 - NESC 2007
 - IEC 60826:2003
 - EN50341-1:2001 (CENELEC)
 - EN50341-3-9:2001 (UK NNA)
 - EN50341-3-17:2001 (Portugal NNA)
 - ESAA C(b)1-2003 (Australia)
 - TPNZ (New Zealand)
 - REE (Spain)
 - EIA/TIA 222-F
 - ANSI/TIA 222-G
 - CSA S37-01
- Automated microwave antenna loading as per EIA/TIA 222-F and ANSI/TIA 222-G
- Minimization of problems caused by unstable joints and mechanisms
- Automatic bandwidth minimization and ability to solve large problems
- Design checks according to (other standards can be added easily):
 - ASCE Standard 10-90

CENTEK Engineering, Inc.
Structural Analysis – 81-ft Tower # 910
T-Mobile Antenna Upgrade – CT11360A
Fairfield, CT
Rev 1 ~ July 16, 2015

- AS 3995 (Australian Standard 3995)
- BS 8100 (British Standard 8100)
- EN50341-1 (CENELEC, both empirical and analytical methods are available)
- ECCS 1985
- NGT-ECCS
- PN-90/B-03200
- EIA/TIA 222-F
- ANSI/TIA 222-G
- CSA S37-01
- EDF/RTE Resal
- IS 802 (India Standard 802)

Results Features:

- Design summaries printed for each group of members
 - Easy to interpret text, spreadsheet and graphics design summaries
 - Automatic determination of allowable wind and weight spans
 - Automatic determination of interaction diagrams between allowable wind and weight spans
 - Capability to batch run multiple tower configurations and consolidate the results
 - Automated optimum angle member size selection and bolt quantity determination
- Tool for interactive angle member sizing and bolt quantity determination.

Criteria for Design of PCS Facilities On or
Extending Above Metal Electric Transmission
Towers & Analysis of Transmission Towers
Supporting PCS Masts ⁽¹⁾

Introduction

This criteria is the result from an evaluation of the methods and loadings specified by the separate standards, which are used in designing telecommunications towers and electric transmission towers. That evaluation is detailed elsewhere, but in summary; the methods and loadings are significantly different. This criteria specifies the manner in which the appropriate standard is used to design PCS facilities including masts and brackets (hereafter referred to as "masts"), and to evaluate the electric transmission towers to support PCS masts. The intent is to achieve an equivalent level of safety and security under the extreme design conditions expected in Connecticut and Massachusetts.

ANSI Standard TIA/EIA-222 (Rev. F) covering the design of telecommunications structures specifies a working strength/allowable stress design approach. This approach applies the loads from extreme weather loading conditions, and designs the structure so that it does not exceed some defined percentage of failure strength (allowable stress).

ANSI Standard C2-2007 (National Electrical Safety Code) covering the design of electric transmission metal structures is based upon an ultimate strength/yield stress design approach. This approach applies a multiplier (overload capacity factor) to the loads possible from extreme weather loading conditions, and designs the structure so that it does not exceed its ultimate strength (yield stress).

Each standard defines the details of how loads are to be calculated differently. Most of the NU effort in "unifying" both codes was to establish what level of strength each approach would provide, and then increasing the appropriate elements of each to achieve a similar level of security under extreme weather loadings.

Two extreme weather conditions are considered. The first is an extreme wind condition (hurricane) based upon a 50-year recurrence (2% annual probability). The second is a winter condition combining wind and ice loadings.

The following sections describe the design criteria for any PCS mast extending above the top of an electric transmission tower, and the analysis criteria for evaluating the loads on the transmission tower from such a mast from the lower portions of such a mast, and loads on the pre-existing electric lower portions of such a mast, and loads on the pre-existing electric transmission tower and the conductors it supports.

Note 1: Prepared from documentation provide from Northeast Utilities.

PCS Mast

The PCS facility (mast, external cable/trays, including the initial and any planned future support platforms, antennas, etc. extending the full height above the top level of the electric transmission structure) shall be designed in accordance with the provisions of TIA/EIA-222 (Rev. F) with two exceptions:

1. An 85 mph extreme wind speed shall be used for locations in all counties throughout the NU system.
2. The allowable stress increase of TIA Section 3.1.1.1 is allowed for the mast section, but is disallowed for the mast to structure connection design.

The combined wind and ice condition shall consider ½" radial ice in combination with the wind load (0.75 Wi) as specified in TIA section 2.3.16.

ELECTRIC TRANSMISSION TOWER

The electric transmission tower shall be analyzed using yield stress theory in accordance with the attached table titled "NU Design Criteria". This specifies uniform loadings (different from the TIA loadings) on the each of the following components of the installed facility:

- PCS mast for its total height above ground level, including the initial and planned future support platforms, antennas, etc. above the top of an electric transmission structure.
- Conductors are related devices and hardware.
- Electric transmission structure. The loads from the PCS facility and from the electric conductors shall be applied to the structure at conductor and PCS mast attachment points, where those load transfer to the tower.

The uniform loadings and factors specified for the above components in the table are based upon the National Electrical Safety Code 2007 Edition Extreme Wind (Rule 250C) and Combined Ice and Wind (Rule 250B-Heavy) Loadings. These provide equivalent loadings compared to TIA and its loads and factors with the exceptions noted above. (Note that the NESC does not require the projected wind surfaces of structures and equipment to be increased by the ice covering.)

In the event that the electric transmission tower is not sufficient to support the additional loadings of the PCS mast, reinforcement will be necessary to upgrade the strength of the overstressed members.



Attachment A

NU Design Criteria

		Basic Wind Speed	Pressure	Height Factor	Gust Factor	Load or Stress Factor	Force Coef - Shape Factor	
		V (MPH)	Q (PSF)	Kz	Gh			
Ice Condition	TIA/EIA	Antenna Mount	TIA	TIA (.75Wi)	TIA	TIA	TIA, Section 3.1.1.1 disallowed for connection design	TIA
	NESC Heavy	Tower/Pole Analysis with antennas extending above top of Tower/Pole (Yield Stress)	---	4	1.00	1.00	2.50	1.6 Flat Surfaces 1.3 Round Surfaces
		Tower/Pole Analysis with Antennas below top of Tower/Pole (on two faces)	---	4	1.00	1.00	2.50	1.6 Flat Surfaces 1.3 Round Surfaces
	Conductors:		Conductor loads provided by NU					
High Wind Condition	TIA/EIA	Antenna Mount	85	TIA	TIA	TIA	TIA, Section 3.1.1.1 disallowed for connection design	TIA
	NESC Extreme Wind	Tower/Pole Analysis with antennas extending above top of Tower/Pole	Use NESC C2-2007, Section 25, Rule 250C: Extreme Wind Loading 1.25 x Gust Response Factor Height above ground level based on top of Mast/Antenna				1.6 Flat Surfaces 1.3 Round Surfaces	
		Tower/Pole Analysis with Antennas below top of Tower/Pole	Use NESC C2-2007, Section 25, Rule 250C: Extreme Wind Loading Height above ground level based on top of Tower/Pole				1.6 Flat Surfaces 1.3 Round Surfaces	
	Conductors:		Conductor loads provided by NU					
NESC Extreme Ice with Wind Condition*		Tower/Pole Analysis with antennas extending above top of Tower/Pole	Use NESC C2-2007, Section 25, Rule 250D: Extreme Ice with Wind Loading 4PSF Wind Load 1.25 x Gust Response Factor Height above ground level based on top of Mast/Antenna				1.6 Flat Surfaces 1.3 Round Surfaces	
		Tower/Pole Analysis with Antennas below top of Tower/Pole	Use NESC C2-2007, Section 25, Rule 250D: Extreme Ice with Wind Loading 4PSF Wind Load Height above ground level based on top of Tower/Pole				1.6 Flat Surfaces 1.3 Round Surfaces	
	Conductors:		Conductor loads provided by NU					

* Only for Structures Installed after 2007

Communication Antennas on Transmission Structures (CL&P & WMECo Only)

Northeast Utilities Approved by: KMS (NU)	Design NU Confidential Information	OTRM 059	Rev.1 03/17/2011
		Page 7 of 9	



Shape Factor Criteria shall be per TIA Shape Factors.

- 2) STEP 2 - The electric transmission structure analysis and evaluation shall be performed in accordance with NESC requirements and shall include the mast and antenna loads determined from NESC applied loading conditions (not TIA/EIA Loads) on the structure and mount as specified below, and shall include the wireless communication mast and antenna loads per NESC criteria)

The structure shall be analyzed using yield stress theory in accordance with Attachment A, "NU Design Criteria." This specifies uniform loadings (different from the TIA loadings) on each of the following components of the installed facility:

- a) Wireless communication mast for its total height above ground level, including the initial and any planned future equipment (Support Platforms, Antennas, TMA's etc.) above the top of an electric transmission structure.
- b) Conductors and related devices and hardware (wire loads will be provided by NU).
- c) Electric Transmission Structure
 - i) The loads from the wireless communication equipment components based on NESC and NU Criteria in Attachment A, and from the electric conductors shall be applied to the structure at conductor and wireless communication mast attachment points, where those loads transfer to the tower.
 - ii) Shape Factor Multiplier:

NESC Structure Shape	Cd
Polyround (for polygonal steel poles)	1.3
Flat	1.6
Open Lattice	3.2

- iii) When Coaxial Cables are mounted along side the pole structure, the shape multiplier shall be:

Mount Type	Cable Cd	Pole Cd
Coaxial Cables on outside periphery (One layer)	1.45	1.45
Coaxial Cables mounted on stand offs	1.6	1.3

- d) The uniform loadings and factors specified for the above components in Attachment A, "NU Design Criteria" are based upon the National Electric Safety Code 2007 Edition Extreme Wind (Rule 250C) and Combined Ice and Wind (Rule 250B-Heavy) Loadings. These provide equivalent loadings compared to the TIA and its loads and factors with the exceptions noted above.

Note: The NESC does not require ice load be included in the supporting structure. (Ice on conductors and shield wire only, and NU will provide these loads).

- e) Mast reaction loads shall be evaluated for local effects on the transmission structure members at the attachment points.

Communication Antennas on Transmission Structures (CL&P & WMECo Only)

Northeast Utilities
Approved by: KMS (NU)

Design
NU Confidential Information

OTRM 059
Page 3 of 9

Rev.1
03/17/2011

Wire Ld

TITLE Omnipoint Site 360A, Fairfield, CT.
 STRUCT #910

03/09/2000

Fiber Optic Conductor (Shield Wire)

	AHEAD	BACK
	OPGW-120 ▼	OPGW-120 ▼
	6-Groove 10/9 FOCAS	6-Groove 10/9 FOCAS
DIAM =	0.738	0.738
WEIGHT =	0.518	0.518
TENSION (LBS)	AHEAD 6,000	BACK 6,000

LOADCASE	NESC HEAVY ▼
WIND (PSF)	4
ICE (IN)	0.50
OLF ANG	1.65
OLF WIND	2.50
OLF WT	1.50

STR	ANGLE	WIND SPAN	WGT SPAN	NESC HEAVY		
				H	L	V
BACK	0	364	298	527	-9900	576
AHEAD	0	364	298	527	9900	576
TOTALS	0.0	728	596	1054	0	1151

Wire Ld

TITLE OmniPoint Site 360A, Fairfield, CT.
 STRUCT #910

03/09/2000

FIBER OPTIC CONDUCTOR (SHIELD WIRE)

	AHEAD	BACK
	OPGW-120 ▼	OPGW-120 ▼
	6-Groove 10/9 FOCAS	6-Groove 10/9 FOCAS
DIAM =	0.738	0.738
WEIGHT =	0.518	0.518
TENSION (LBS)	AHEAD 4,442	BACK 4,442

LOADCASE	HI WIND ▼
WIND (PSF)	20
ICE (IN)	0.00
OLF ANG	1.15
OLF WIND	1.15
OLF WT	1.15

STR	ANGLE	WIND SPAN	WGT SPAN	HI WIND		
				H	L	V
BACK	0	364	298	515	-5108	178
AHEAD	0	364	298	515	5108	178
TOTALS	0.0	728	596	1030	0	355

Wire Ld

TITLE OMNIPONT SITE CT-360A, FAIRFIELD, CT.
 STRUCT #910

03/09/2000

CONDUCTOR

	AHEAD	BACK
	DOVE ▼	DOVE ▼
	556	556
	26/7 ACSR	26/7 ACSR
DIAM =	0.927	0.927
WEIGHT =	0.765	0.765
TENSION (LBS)	AHEAD 7,000	BACK 7,000

LOADCASE	NESC HEAVY ▼
WIND (PSF)	4
ICE (IN)	0.50
OLF ANG	1.65
OLF WIND	2.50
OLF WT	1.50

STR	ANGLE	WIND SPAN	WGT SPAN	NESC HEAVY		
				H	L	V
BACK	0	364	298	585	-11550	739
AHEAD	0	364	298	585	11550	739
TOTALS	0.0	728	596	1169	0	1477

Wire Ld

TITLE OMNIPONT SITE CT-360A, FANFIELD, CT.
 STRUCT #910

03/09/2000

		CONDUCTOR	
		AHEAD	BACK
		DOVE ▼	DOVE ▼
		556	556
		26/7 ACSR	26/7 ACSR
DIAM =		0.927	0.927
WEIGHT =		0.765	0.765
TENSION (LBS)		AHEAD 5,403	BACK 5,403
		LOADCASE	HI WIND ▼
		WIND (PSF)	20
		ICE (IN)	0.00
		OLF ANG	1.15
		OLF WIND	1.15
		OLF WT	1.15

STR	ANGLE	WIND SPAN	WGT SPAN	HI WIND		
				H	L	V
BACK	0	364	298	647	-6213	262
AHEAD	0	364	298	647	6213	262
TOTALS	0.0	728	596	1293	0	524

Wire Ld

TITLE Omnipoint Site CT-360A, Fairfield, CT
 STRUCT #910

03/09/2000

SHIELD WIRE CONDUCTOR

	AHEAD	BACK
	11/32 CW ▼	11/32 CW ▼
	0.000	0.000
	7 #9 Cu Weld	7 #9 Cu Weld
DIAM =	0.343	0.343
WEIGHT =	0.257	0.257
TENSION (LBS)	AHEAD 3,600	BACK 3,600
	LOADCASE	NESC HEAVY ▼
	WIND (PSF)	4
	ICE (IN)	0.50
	OLF ANG	1.65
	OLF WIND	2.50
	OLF WT	1.50

STR	ANGLE	WIND SPAN	WGT SPAN	NESC HEAVY		
				H	L	V
BACK	0	364	298	407	-5940	349
AHEAD	0	364	298	407	5940	349
TOTALS	0.0	728	596	815	0	698

Wire Ld

TITLE Omnipoint Site CT-360A, Fairfield, CT

03/09/2000

STRUCT #910

SHIELD WIRE CONDUCTOR

	AHEAD	BACK
	11/32 CW ▼	11/32 CW ▼
	0.000	0.000
	7 #9 Cu Weld	7 #9 Cu Weld
DIAM =	0.343	0.343
WEIGHT =	0.257	0.257
TENSION (LBS)	AHEAD 2,089	BACK 2,089

LOADCASE	HI WIND ▼
WIND (PSF)	20
ICE (IN)	0.00
OLF ANG	1.15
OLF WIND	1.15
OLF WT	1.15

STR	ANGLE	WIND SPAN	WGT SPAN	HI WIND		
				H	L	V
BACK	0	364	298	239	-2402	88
AHEAD	0	364	298	239	2402	88
TOTALS	0.0	728	596	479	0	176

☉ T-MOBILE ANTENNAS
EL. ±96'-0" AGL

LEGEND:

1. A.G.L.= ABOVE GROUND LEVEL
2. A.T.B.= ABOVE TOWER BASE

T-MOBILE (TO BE REMOVED):
TWO (2) EMS RR-90-17-02DP
PANEL ANTENNAS AND ONE (1)
MICROWAVE DISH FLUSH MOUNTED
T-MOBILE (PROPOSED):
TWO (2) RFS APXV18-206516S-C
PANEL ANTENNAS FLUSH MOUNTED

☉ TOP CONNECTION
EL. ±73'-0" ATB

EXISTING 6" SCH. 40
(O.D. = 6.625") X
42' LONG PIPE MAST

☉ MID CONNECTION
EL. ±66'-0" ATB

☉ BOTTOM CONNECTION
EL. ±57'-0" ATB

T-MOBILE EXISTING ONE
(1) 7/8" DIA. COAX
CABLE TO BE REMOVED

EXISTING 81' TALL STEEL
TRANSMISSION STRUCTURE
NO. 910

T-MOBILE EXISTING FOUR
(4) 1-5/8" DIA. COAX
CABLES MOUNTED ON
COAX CABLE BRACKET TO
NORTHWEST TOWER LEG

APPROX. GRADE

1
EL-1

TOWER & MAST ELEVATION

SCALE: NOT TO SCALE

REVISIONS		
0	5/27/15	ISSUED FOR REVIEW
1	7/16/15	ISSUED FOR REVIEW

CEN TEK engineering
Centered on Solutions™
www.CentekEng.com
(203) 499-0593
(203) 499-0587 Fax
43-2 North Branford Road, Branford, CT 06405

CT11360A
EVERSOURCE 910
WESTPORT TURNPIKE
FAIRFIELD, CT 06824

PROJECT NO: 15019.001
DRAWN BY: T.J.L.
CHECKED BY: CFC
SCALE: AS NOTED
DATE: 5/27/15



TOWER AND MAST
ELEVATION
EL-1
DWG. 1 OF 1

**RADIO FREQUENCY EMISSIONS ANALYSIS REPORT
EVALUATION OF HUMAN EXPOSURE POTENTIAL
TO NON-IONIZING EMISSIONS**

T-Mobile Existing Facility

Site ID: CT11360A

**Westport / Rt 136
Westport Turnpike
Fairfield, CT 06824**

November 9, 2015

EBI Project Number: 6215005599

Site Compliance Summary	
Compliance Status:	COMPLIANT
Site total MPE% of FCC general public allowable limit:	3.44 %

November 9, 2015

T-Mobile USA
Attn: Jason Overbey, RF Manager
35 Griffin Road South
Bloomfield, CT 06002

Emissions Analysis for Site: **CT11360A – Westport / Rt 136**

EBI Consulting was directed to analyze the proposed T-Mobile facility located at **Westport Turnpike, Fairfield, CT**, for the purpose of determining whether the emissions from the Proposed T-Mobile Antenna Installation located on this property are within specified federal limits.

All information used in this report was analyzed as a percentage of current Maximum Permissible Exposure (% MPE) as listed in the FCC OET Bulletin 65 Edition 97-01 and ANSI/IEEE Std C95.1. The FCC regulates Maximum Permissible Exposure in units of microwatts per square centimeter ($\mu\text{W}/\text{cm}^2$). The number of $\mu\text{W}/\text{cm}^2$ calculated at each sample point is called the power density. The exposure limit for power density varies depending upon the frequencies being utilized. Wireless Carriers and Paging Services use different frequency bands each with different exposure limits, therefore it is necessary to report results and limits in terms of percent MPE rather than power density.

All results were compared to the FCC (Federal Communications Commission) radio frequency exposure rules, 47 CFR 1.1307(b)(1) – (b)(3), to determine compliance with the Maximum Permissible Exposure (MPE) limits for General Population/Uncontrolled environments as defined below.

General population/uncontrolled exposure limits apply to situations in which the general public may be exposed or in which persons who are exposed as a consequence of their employment may not be made fully aware of the potential for exposure or cannot exercise control over their exposure. Therefore, members of the general public would always be considered under this category when exposure is not employment related, for example, in the case of a telecommunications tower that exposes persons in a nearby residential area.

Public exposure to radio frequencies is regulated and enforced in units of microwatts per square centimeter ($\mu\text{W}/\text{cm}^2$). The general population exposure limit for the 1900 MHz (PCS) and 2100 MHz (AWS) bands is $1000 \mu\text{W}/\text{cm}^2$. Because each carrier will be using different frequency bands, and each frequency band has different exposure limits, it is necessary to report percent of MPE rather than power density.

Occupational/controlled exposure limits apply to situations in which persons are exposed as a consequence of their employment and in which those persons who are exposed have been made fully aware of the potential for exposure and can exercise control over their exposure. Occupational/controlled exposure limits also apply where exposure is of a transient nature as a result of incidental passage through a location where exposure levels may be above general population/uncontrolled limits (see below), as long as the exposed person has been made fully aware of the potential for exposure and can exercise control over his or her exposure by leaving the area or by some other appropriate means.

Additional details can be found in FCC OET 65.

CALCULATIONS

Calculations were done for the proposed T-Mobile Wireless antenna facility located at **Westport Turnpike, Fairfield, CT**, using the equipment information listed below. All calculations were performed per the specifications under FCC OET 65. Since T-Mobile is proposing highly focused directional panel antennas, which project most of the emitted energy out toward the horizon, all calculations were performed assuming a lobe representing the maximum gain of the antenna per the antenna manufactures supplied specifications, minus 10 dB, was focused at the base of the tower. For this report the sample point is the top of a 6 foot person standing at the base of the tower.

For all calculations, all equipment was calculated using the following assumptions:

- 1) 2 GSM / UMTS channels (PCS Band - 1900 MHz) were considered for each sector of the proposed installation. These Channels have a transmit power of 30 Watts per Channel
- 2) 2 UMTS channels (AWS Band – 2100 MHz) were considered for each sector of the proposed installation. These Channels have a transmit power of 30 Watts per Channel.
- 3) 2 LTE channels (AWS Band – 2100 MHz) were considered for each sector of the proposed installation. These Channels have a transmit power of 60 Watts per Channel.
- 4) Since the radios are ground mounted there are additional cabling losses accounted for. For each RF path the following losses were calculated. 1.18 dB of additional cable loss for all 1900 MHz channels and 1.22 dB of additional cable loss at 2100 MHz were used in this analysis. This is based on manufacturers Specifications for 115 feet of 1-5/8" coax cable on each path.



- 5) All radios at the proposed installation were considered to be running at full power and were uncombined in their RF transmissions paths per carrier prescribed configuration. Per FCC OET Bulletin No. 65 - Edition 97-01 recommendations to achieve the maximum anticipated value at each sample point, all power levels emitting from the proposed antenna installation are increased by a factor of 2.56 to account for possible in-phase reflections from the surrounding environment. This is rarely the case, and if so, is never continuous.
- 6) For the following calculations the sample point was the top of a six foot person standing at the base of the tower. The maximum gain of the antenna per the antenna manufactures supplied specifications minus 10 dB was used in this direction. This value is a very conservative estimate as gain reductions for these particular antennas are typically much higher in this direction.
- 7) The antennas used in this modeling are the **RFS APXV18-206516S-C-A20** for 1900 MHz (PCS) and 2100 MHz (AWS). This is based on feedback from the carrier with regards to anticipated antenna selection. The **RFS APXV18-206516S-C-A20** has a maximum gain of **16.3 dBd** at their main lobe at 1900 MHz and 2100 MHz. The maximum gain of the antenna per the antenna manufactures supplied specifications, minus 10 dB, was used for all calculations. This value is a very conservative estimate as gain reductions for these particular antennas are typically much higher in this direction.
- 8) The antenna mounting height centerline of the proposed antennas is **96 feet** above ground level (AGL). There are two sectors at this facility./
- 9) Emissions values for additional carriers were taken from the Connecticut Siting Council active database. Values in this database are provided by the individual carriers themselves.

All calculations were done with respect to uncontrolled / general public threshold limits.



T-Mobile Site Inventory and Power Data

Sector:	A	Sector:	B
Antenna #:	I	Antenna #:	I
Make / Model:	RFS APXV18-206516S-C-A20	Make / Model:	RFS APXV18-206516S-C-A20
Gain:	16.3 dBd	Gain:	16.3 dBd
Height (AGL):	96	Height (AGL):	96
Frequency Bands	1900 MHz(PCS) / 2100 MHz (AWS)	Frequency Bands	1900 MHz(PCS) / 2100 MHz (AWS)
Channel Count	6	Channel Count	6
Total TX Power:	240	Total TX Power:	240
ERP (W):	7,748.45	ERP (W):	7,748.45
Antenna A1 MPE%	3.44	Antenna B1 MPE%	3.44

Site Composite MPE%		T-Mobile Sector 1 Total:	3.44 %
Carrier	MPE%	T-Mobile Sector 2 Total:	3.44 %
T-Mobile (Per Sector Max)	3.44 %	Site Total:	3.44 %
No Additional Carriers On Site	0.00 %		
Site Total MPE %:	3.44 %		

T-Mobile_per sector	# Channels	Watts ERP (Per Channel)	Height (feet)	Total Power Density ($\mu\text{W}/\text{cm}^2$)	Frequency (MHz)	Allowable MPE ($\mu\text{W}/\text{cm}^2$)	Calculated % MPE
T-Mobile 2100 MHz (AWS) LTE	2	1932.64	96	17.16	2100	1000	1.72 %
T-Mobile 1900 MHz (PCS) GSM/UMTS	2	975.26	96	8.66	1900	1000	0.87 %
T-Mobile 2100 MHz (AWS) UMTS	2	966.32	96	8.58	2100	1000	0.86 %
						Total:	3.44%



Summary

All calculations performed for this analysis yielded results that were **within** the allowable limits for general public exposure to RF Emissions.

The anticipated maximum composite contributions from the T-Mobile facility as well as the site composite emissions value with regards to compliance with FCC's allowable limits for general public exposure to RF Emissions are shown here:

T-Mobile Sector	Power Density Value (%)
Sector 1:	3.44 %
Sector 2:	3.44 %
T-Mobile Per Sector Maximum:	3.44 %
Site Total:	3.44 %
Site Compliance Status:	COMPLIANT

The anticipated composite MPE value for this site assuming all carriers present is **3.44%** of the allowable FCC established general public limit sampled at the ground level. This is based upon values listed in the Connecticut Siting Council database for existing carrier emissions.

FCC guidelines state that if a site is found to be out of compliance (over allowable thresholds), that carriers over a 5% contribution to the composite value will require measures to bring the site into compliance. For this facility, the composite values calculated were well within the allowable 100% threshold standard per the federal government.

Scott Heffernan

RF Engineering Director

EBI Consulting

21 B Street
Burlington, MA 01803