

July 1, 2015

Melanie A. Bachman
Acting Executive Director
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051

Re: **EM-VER-057-140609 – Cellco Partnership d/b/a Verizon Wireless
1081 North Street, Greenwich, Connecticut**

Dear Ms. Bachman:

On July 10, 2014, the Siting Council acknowledged receipt of Cellco's notice of intent to modify its telecommunications facility at 1081 North Street in Greenwich, Connecticut. The modifications involved the replacement of certain antennas and installation of remote radio heads and a fiber optic antenna cable.

As a condition of that acknowledgement, Cellco was required to provide the Council with a letter stating that the modifications referenced in the structural report were completed. Attached is a Professional Engineer's Certification Letter verifying that the tower and foundation modifications were installed. All construction associated with these modifications has now been completed.

If you have any questions please do not hesitate to contact me.

Sincerely,



Kenneth C. Baldwin

Copy to:
Tim Parks

June 30, 2015

Mr. Tim Parks

Verizon Wireless
99 East River Drive
East Hartford, Connecticut 06108

Re: Tower Modification Certification

Project: Verizon Banksville
1081 North Street, Greenwich, CT

Tower Owner: Crown Castle
8 Parkmeadow Drive, Pittsford, NY

Engineer: Paul J. Ford and Company
250 E. Broad Street, Suite 600, Columbus, OH

Centek Project No.: 14055.032

CSC Exempt Mod Reference No.: EM-VER-057-140609

Dear Mr. Parks,

We are providing this "Tower Modification Certification" with regard to the structural components at the above referenced project.

The following are the basis for substantiating compliance with the tower modification documents prepared by Paul J. Ford and Company (PJF Group Project Number: 37513-2761 BP):

- Review of the Paul J. Ford and Company Structural Analysis dated 04/16/2014.
- Review of the Paul F. Ford and Company Modification Drawings T-1 and S-1 thru S-6 dated 04/16/2014.
- Review of the Sinnott Gering and Schmitt Towers Inc. Modification Inspection Report dated 11/18/2014.
- Field observations by Centek Engineering personnel on 06/30/2015 of the completed modifications which determined all modifications were installed in general compliance with the recommendations of the structural analysis report prepared by Paul J. Ford and Company on 04/16/2014.

The modification design prepared by Paul J. Ford and Company demonstrates the tower will not exceed 100 percent of the post construction structural rating. The work under this Contract has been reviewed and found, to the Engineer's best knowledge, information and belief, to be completed in general compliance with the documents referenced above. This certification is not a review of the adequacy or effectiveness of the modification/reinforcement solution.

Sincerely,


Carlo F. Centore, PE
Principal - Structural

