

August 24, 2016

Melanie A. Bachman  
Acting Executive Director  
Connecticut Siting Council  
10 Franklin Square  
New Britain, CT 06051

Re: **EM-VER-057-150821 – Cellco Partnership d/b/a Verizon Wireless  
9 Sound Shore Drive, Greenwich, Connecticut**

Dear Ms. Bachman:

On September 15, 2015, the Siting Council acknowledged receipt of Cellco's notice of intent to modify its existing telecommunications facility at 9 Sound Shore Drive in Greenwich, Connecticut. The modifications involved the replacement of antennas and the installation of additional coaxial cables.

As a condition of the acknowledgement, Cellco was required to provide the Council with a letter stating that it had complied with the recommendations made in the structural report attached to that filing. Attached is a Professional Engineer's Tower Modification Certification letter verifying that the installation was completed according to that structural report.

If you have any questions please do not hesitate to contact me.

Sincerely,



Kenneth C. Baldwin

Attachment

Copy to:

Tim Parks

15144045-v1

August 23, 2016

**Mr. Tim Parks**  
Verizon Wireless  
99 East River Drive  
East Hartford, Connecticut 06108

**Re: Tower Modification Certification**

**Project:** Verizon Greenwich 3  
9 Sound Shore Drive

**Tower Owner:** Eversource  
56 Prospect Street, Hartford, CT 06103

**Engineer:** Centek Engineering, Inc.  
63-2 North Branford Road, Branford, CT

**Centek Project No.:** 16003.18

**CSC Exempt Mod Reference No.:** EM-VER-057-150821

Dear Mr. Parks,

We are providing this "Tower Modification Certification" with regard to the structural components at the above referenced project.

The following are the basis for substantiating compliance with the Structural Analysis documents prepared by Centek Engineering, Inc. (Centek Project Number: 15001.017):

- Review of Centek Engineering, Inc. Structural Analysis dated 04/17/15.
- Review of Centek Engineering, Inc. Modification Drawings dated 04/17/15.
- Field observations by Centek Engineering personnel on 07/26/16 of the completed modifications which determined all modifications were installed in general compliance with the recommendations of the structural analysis report prepared by Centek Engineering, Inc. on 04/17/15.

The modification design prepared by Centek Engineering, Inc. demonstrates the tower will not exceed 100 percent of the post construction structural rating. The work under this Contract has been reviewed and found, to the Engineer's best knowledge, information and belief, to be completed in general compliance with the documents referenced above. This certification is not a review of the adequacy or effectiveness of the modification/reinforcement solution.

Sincerely,



Carlo F. Centore, PE  
Principal - Structural

