

April 9, 2020

Attorney Melanie Bachman
Acting Executive Director
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06501

RE: EM-T-Mobile-084-190118
T-Mobile Site #CT11082E
528 Wheelers Farm Road
Milford, CT
Notice of Construction Completion

Dear Attorney Bachman,

This office represents T-Mobile Northeast LLC (“T-Mobile”) and has been retained to notify the Connecticut Siting Council (“Council”) that the exempt modification decision conditions has been met and constructed in accordance with the documentation provided at the time of filing.

The Council acknowledge the above reference T-Mobile notice of exempt modification 2/11/2019. T-Mobile hereby notifies the Council that construction of the acknowledged modification was complete as of 3/7/2020.

Statement of inspections is also enclosed as requested.

Sincerely,

Audra Maher
Project Coordinator
Transcend Wireless LLC on behalf of T-Mobile
10 Industrial Ave, Suite 3
Mahwah, NJ 07430

March 19, 2020

Mr. Joseph Griffith
City of Milford Building Department
70 West River St.
Milford, CT 06460

Re: Letter of Professional Opinion

Project: CT11082E – Stratford/MP X 53/Main
528 Wheelers Farm Road
Milford, CT 06460

Owner: Crown Castle

Engineer: Hudson Design Group, LLC
45 Beechwood Drive, N. Andover, MA 01845

Contractor: Ramapo Communication Corp.
20 Romanelly Ave, South Hackensack, NJ 07606

Centek Project No.: 20035.01

Dear Mr. Griffith,

We are providing this “Letter of Professional Opinion” with regard to the structural components at the above referenced project.

The following are the basis for substantiating compliance with construction documents prepared by Hudson Design Group, LLC dated 10/25/18 Rev.2, and Structural Analysis Report prepared by Tower Engineering Professionals dated November 15, 2018 Rev.0:

- Field observations of completed site on 03/12/2020.

The work under this Contract has been reviewed and found, to the Engineer’s best knowledge, information and belief, to be completed in general compliance with the documents prepared by Hudson Design Group, LLC and issued for construction on 10/25/18 Rev.2.

Sincerely,



Camilo A. Gaviria, PE
Senior Project Manager



Cc: File

FINAL REPORT OF SPECIAL INSPECTIONS

Project: CT11082E - Stratford/MP X 53/Main **Scope:**67D92M Outdoor

Location: 528 Wheelers Farm Road, Milford, CT 06460

Owner Crown Castle

Design Professional in Responsible Charge: Camilo A. Gaviria, PE (Centek Engineering, Inc.)

To the best of my information, knowledge and belief, the Special Inspections required for this project, and itemized in the **Statement of Special Inspections** submitted for permit, have been performed and all discovered discrepancies have been reported and resolved.

The following discrepancies that were outstanding since the last interim report dated (n/a), have been corrected:


No outstanding discrepancies exist.

(Attach 8 1/2 x 11 continuation sheets(s) if required to complete the description of corrections)

The Letter of Professional Opinion dated 03/19/2020 and supporting documentation submitted along with this Final Report form the basis for, and are to be considered an integral part of this Final Report.

Respectfully Submitted,
Special Inspector

Camilo A. Gaviria, PE (CT PE#27517)
(type or printed name)



Signature

03/19/2020
Date



F I E L D V I S I T R E P O R T

DATE: March 12, 2020

TIME: 10:00 AM

TO: Transcend Wireless

PHONE: 203.592.8291

ATTN: Dan Reid

EMAIL: dreid@transcendwireless.com

PREPARED BY: Logan G. Lisieski

PHONE: 203.488.0580 ext. 104

EMAIL: llisieski@centekeng.com

SUBMITTED BY: Camilo A. Gaviria, PE

PHONE: 203.488.0580 ext. 119

EMAIL: cgaviria@centekeng.com


CEN TEK NO.: 20035.01

PROJECT NAME: T-Mobile CT11082E

CC: (Ramapo Communication Corp.)

The following was observed, discussed, reviewed and/or resolved at the site, which requires action by the Contractor unless noted otherwise. Items shall remain on this ongoing report until resolved to the satisfaction of this office.

200312. 1	Purpose of field visit was to confirm compliance with the HDG CC# 876320 Wireless Site Upgrade Drawing dated 10/25/18 (Rev.2).	
200312. 2	Weather conditions were overcast skies with intermittent light drizzle and temperature of 34°F.	
200312. 3	Elevation view of the existing 120' monopole structure taken post upgrades.	

<p>200312. 4</p>	<p>Mount, antennas & radio equipment placement was observed to be consistent with the antenna plan prepared by Hudson Design Group CC# 876320 on drawing A-2 (Rev.2 dated 10/25/18).</p>	
<p>200312. 5</p>	<p>(See note 200312.4 above)</p>	
<p>200312. 6</p>	<p>Hybrid cable quantity, size & routing confirmed as consistent with "Proposed Equipment Plan" on HDG CC# 876320 drawing A-1 Rev.2 dated 10/25/18.</p>	
<p>200312. 7</p>	<p>(See note 200312.6 above)</p>	

200312. 8	200A power panel installed to be consistent with HDG CC# 876320 drawing A-1 Rev.2 Dated 10/25/18.	
200312. 9	(See note 200312.8 above)	
200312. 10	Installations of all specified upgrades are confirmed as completed.	