



STATE OF CONNECTICUT

CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: siting.council@ct.gov

www.ct.gov/csc

April 3, 2018

Aaron Meyers
Site Acquisition
c/o New Cingular Wireless PCS LLC (AT&T)
Centerline Communications, LLC
94 Ryan Drive, Suite 1
Raynham, MA 02767

RE: **EM-CING-101-180322** – New Cingular Wireless PCS, LLC notice of intent to modify an existing telecommunications facility located at 15 Dwight Street, North Haven, Connecticut.

Dear Mr. Meyers:

The Connecticut Siting Council (Council) hereby denies your request to modify the above-referenced existing telecommunications facility, pursuant to Section 16-50j-73 of the Regulations of Connecticut State Agencies. The requested modification, as proposed, would load the tower to a maximum of 102 percent of its capacity, which is above the 100 percent limit established by the Council under guidance from the Connecticut State Building Inspector.

In accordance with the Council's November 6, 2017 memorandum to telecommunications carriers and their representatives (attached), the Council will accept filings with tower overstresses "if the filing is accompanied by a formal opinion from the Connecticut State Building Inspector specifically regarding the structure in question stating that such overstress of the specific structure is allowable." The above-referenced exempt modification filing is not accompanied by a formal opinion from the Connecticut State Building Inspector. Additionally, the exempt modification filing did not account for an exempt modification filing submitted to the Council by Cellco Partnership d/b/a Verizon Wireless on March 12, 2018 for modifications to the same facility. See Cellco's exempt modification filing for this facility, which may be found on the Council's website under Decisions page in North Haven under the filing number EM-VER-101-180312 or by following the link: http://www.ct.gov/csc/lib/csc/ems/northhaven/dwightst/verizon/em-ver-101-180312_filing_dwightst.pdf

Thus, the proposed modification is not in compliance with the exemption criteria in Section 16-50j-72 (b) of the Regulations of Connecticut State Agencies.

Sincerely,

Melanie Bachman
Executive Director

MAB/CW

enclosure

c: The Honorable Michael J. Freda, First Selectman, Town of North Haven
Laura Magaraci, Zoning Enforcement Officer, Town of North Haven
American Tower Corporation, tower owner
15 Dwight Street LLC, property owner





DEPARTMENT OF ADMINISTRATIVE SERVICES

April 27, 2017

Melanie A. Bachman, Esq.
Executive Director/Staff Attorney
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051

Re: Interpretation of 2016 CT State Building Code IBC Section 3404
Acceptable Loading of Existing Structures

Ms. Bachman,

In your email of March 24, 2017 you requested an interpretation regarding the structural stresses allowed during an alteration of an existing communication tower, specifically whether an overstress up to 5% would be allowed by the State Building Code.

Answer:

These alterations are regulated by chapter 34 – Existing Buildings and Structures of the 2012 IBC portion of the 2016 State Building Code. Section 3404.3 discusses gravity loading and states in salient part “Any existing gravity load-carrying structural element for which an alteration causes an increase in design gravity load of more than 5 percent shall be strengthened...”. Section 3404.4 discusses lateral loads and includes an exception which states in salient part “Any existing lateral load-carrying structural element whose demand-capacity ratio with the alteration considered is no more than 10 percent greater than its demand-capacity ratio with the alteration ignored shall be permitted to remain unaltered.” This exception continues to require that the effects of all additions and alterations must be included in this analysis.

Therefore, the State Building Code would allow limited overstresses under certain conditions for existing towers.

Sincerely,

A handwritten signature in black ink, appearing to read "JCassidy", is written over the typed name.

Joseph V. Cassidy, P.E.
State Building Inspector



STATE OF CONNECTICUT

CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: siting.council@ct.gov

www.ct.gov/csc

MEMORANDUM

Date: November 6, 2017

To: Telecommunications Carriers and their Representatives

From: Melanie Bachman, Executive Director *MAB*

Re: Exempt Modification/Tower Share Filing
Acceptable Overstress for Communications Towers

The Connecticut Siting Council (Council) has received requests for exempt modifications to existing jurisdictional towers that include statements relating to allowable potential "overstress" in the structural analysis reports submitted with exempt modification filings. Given the statement in the Connecticut State Building Inspector's April 27, 2017 correspondence to the Council, a copy of which is attached, indicating that "the State Building Code would allow limited overstresses under certain conditions for existing towers," the Council will accept such filings if the filing is accompanied by a formal opinion from the Connecticut State Building Inspector specifically regarding the structure in question stating that such overstress of the specific structure is allowable. If the exempt modification filing with an overstress situation does not include this formal opinion specific to the structure, the filing will be denied.

Thank you in advance for your cooperation.

MAB/CMW/laf

Enclosure: State Building Inspector Letter, dated April 27, 2017

c: Joseph V. Cassidy, P.E., State Building Inspector