



10 INDUSTRIAL AVE,
SUITE 3
MAHWAH NJ 07430

PHONE: 201.684.0055
FAX: 201.684.0066

February 9, 2021

Members of the Siting Council
Connecticut Siting Council
Ten Franklin Square
New Britain, CT 06051

RE: Notice of Exempt Modification
652 Glenbrook Road, Stamford, CT 06906 (also known as 650 Glenbrook Road)
Latitude: 41.07548400
Longitude: -73.51914100
T-Mobile Site#: CT11334A – Anchor

Dear Ms. Bachman:

T-Mobile currently maintains nine (9) antennas at the 85-foot level of the existing 108-foot water tower at 652 Glenbrook Road, Stamford, CT (also known as 650 Glenbrook Road). The 108-foot water tower and property are owned by Glenbrook Industrial Park LLC. T-Mobile now intends to remove three (3) existing antennas and add three (3) new 2500 MHz antennas. The new antennas support 5G services and will be installed at the same 85-foot level of the water tower.

Planned Modifications:

Tower:

Remove

(6) 1-5/8" coax

Remove and Replace:

(3) AIR 21 1900/2100 MHz for (3) AIR 6449 B41 2500 MHz

Install New:

(3) Ericsson Radio 4415 B25

(3) SDX1926Q-43 Diplexers

(3) 1-5/8" Hybrid

Existing to Remain:

(3) AIR 32 1900/2100 MHz

(3) APXVARR24_43-U-NA20 600/700/1900/2100 MHz

(3) Radio 4449 B71+B12 RRU

(3) TMA

Ground:

Install New: 6160 Cabinet and B160 Battery Cabinet

T-Mobile was approved (as VoiceStream) for tower-sharing at this facility on December 14, 2000. T-Mobile has been approved by the Council for subsequent modifications at their facility, and the City of Stamford has issued building permits to approve proposed work at the facility. The proposed modification complies with all known previous conditions of approval.

Please accept this letter as notification pursuant to Regulations of Connecticut State Agencies § 16-50j-73, for construction that constitutes an exempt modification pursuant to R.C.S.A. § 16-50j-72(b)(2). In accordance with R.C.S.A. § 16-50j-73, a copy of this letter is being sent to Mayor -David Martin, Elected Official, and Ralph Blessing, Land Use Bureau Chief for the City of Stamford.

The planned modifications to the facility fall squarely within those activities explicitly provided for in R.C.S.A. § 16-50j-72(b)(2).

1. The proposed modifications will not result in an increase in the height of the existing structure.
2. The proposed modifications will not require the extension of the site boundary.
3. The proposed modifications will not increase noise levels at the facility by six decibels or more, or to levels that exceed state and local criteria.
4. The operation of the replacement antennas will not increase radio frequency emissions at the facility to a level at or above the Federal Communications Commission safety standard.
5. The proposed modifications will not cause a change or alteration in the physical or environmental characteristics of the site.
6. The existing structure and its foundation can support the proposed loading.

For the foregoing reasons, T-Mobile respectfully submits that the proposed modifications to the above referenced telecommunications facility constitute an exempt modification under R.C.S.A. § 16-50j-72(b)(2).

Sincerely,

Kyle Richers

Transcend Wireless

Cell: 908-447-4716

Email: krichers@transcendwireless.com

Attachments

cc: David Martin– Mayor of the City of Stamford

Ralph Blessing– Land Use Bureau Chief – City of Stamford

Glenbrook Industrial Park LLC - owner

View/Print Label

1. **Ensure there are no other shipping or tracking labels attached to your package.** Select the Print button on the print dialogue box that appears. Note: If your browser does not support this function, select Print from the File menu to print the label.

2. **Fold the printed label at the solid line below.** Place the label in a UPS Shipping Pouch. If you do not have a pouch, affix the folded label using clear plastic shipping tape over the entire label.

3. GETTING YOUR SHIPMENT TO UPS

Customers with a scheduled Pickup

- o Your driver will pickup your shipment(s) as usual.

Customers without a scheduled Pickup




- o Schedule a Pickup on ups.com to have a UPS driver pickup all of your packages.
- o Take your package to any location of The UPS Store®, UPS Access Point(TM) location, UPS Drop Box, UPS Customer Center, Staples® or Authorized Shipping Outlet near you. To find the location nearest you, please visit the 'Locations' Quick link at ups.com.

UPS Access Point™
 MICHAELS STORE # 7773
 75 INTERSTATE SHOP CTR
 RAMSEY NJ 07446-1130

UPS Access Point™
 THE UPS STORE
 115 FRANKLIN TPKE
 MAHWAH NJ 07430-1325

UPS Access Point™
 THE UPS STORE
 120 E MAIN ST
 RAMSEY NJ 07446-1925

FOLD HERE

<p>NEIL GUERRIERO 3473040176 TRANSCEND WIRELESS 10 INDUSTRIAL AVE MAHWAH NJ 07430</p> <p>SHIP TO: RALPH BLESSING 7TH FLOOR 888 WASHINGTON BOULEVARD STAMFORD CT 06901</p>	<p>1 LBS</p> <p>1 OF 1</p>	<p>CT 069 9-02</p> 	<p>UPS GROUND</p> <p>TRACKING #: 1Z V25 742 42 9989 2718</p> 	<p>BILLING: P/P SIGNATURE REQUIRED</p> <p>Reference #1: CT11334A CSC ZO</p> <p><small>XOL 21.02.07 NV45 42.0A 01/2021*</small></p> 
---	--	---	--	---

View/Print Label

1. **Ensure there are no other shipping or tracking labels attached to your package.** Select the Print button on the print dialogue box that appears. Note: If your browser does not support this function, select Print from the File menu to print the label.

2. **Fold the printed label at the solid line below.** Place the label in a UPS Shipping Pouch. If you do not have a pouch, affix the folded label using clear plastic shipping tape over the entire label.

3. GETTING YOUR SHIPMENT TO UPS

Customers with a scheduled Pickup

- o Your driver will pickup your shipment(s) as usual.

Customers without a scheduled Pickup




- o Schedule a Pickup on ups.com to have a UPS driver pickup all of your packages.
- o Take your package to any location of The UPS Store®, UPS Access Point(TM) location, UPS Drop Box, UPS Customer Center, Staples® or Authorized Shipping Outlet near you. To find the location nearest you, please visit the 'Locations' Quick link at ups.com.

UPS Access Point™
 MICHAELS STORE # 7773
 75 INTERSTATE SHOP CTR
 RAMSEY NJ 07446-1130

UPS Access Point™
 THE UPS STORE
 115 FRANKLIN TPKE
 MAHWAH NJ 07430-1325

UPS Access Point™
 THE UPS STORE
 120 E MAIN ST
 RAMSEY NJ 07446-1925

FOLD HERE

<p>NEIL GUERRIERO 3473040176 TRANSCEND WIRELESS 10 INDUSTRIAL AVE MAHWAH NJ 07430</p> <p>SHIP TO: DAVID MARTIN 10TH FLOOR 888 WASHINGTON BOULEVARD STAMFORD CT 06901</p>	<p>CT 069 9-02</p> 	<p>UPS GROUND</p> <p>TRACKING #: 1Z V25 742 42 9534 2720</p>		<p>BILLING: P/P SIGNATURE REQUIRED</p> <p>Reference #1: CT11334A CSC EO</p> <p>XOL 21.02.07 NV45 42.0A 01/2021*</p> 
--	---	---	--	--

View/Print Label

1. **Ensure there are no other shipping or tracking labels attached to your package.** Select the Print button on the print dialogue box that appears. Note: If your browser does not support this function, select Print from the File menu to print the label.

2. **Fold the printed label at the solid line below.** Place the label in a UPS Shipping Pouch. If you do not have a pouch, affix the folded label using clear plastic shipping tape over the entire label.

3. GETTING YOUR SHIPMENT TO UPS

Customers with a scheduled Pickup

- o Your driver will pickup your shipment(s) as usual.

Customers without a scheduled Pickup




- o Schedule a Pickup on ups.com to have a UPS driver pickup all of your packages.
- o Take your package to any location of The UPS Store®, UPS Access Point(TM) location, UPS Drop Box, UPS Customer Center, Staples® or Authorized Shipping Outlet near you. To find the location nearest you, please visit the 'Locations' Quick link at ups.com.

UPS Access Point™
 MICHAELS STORE # 7773
 75 INTERSTATE SHOP CTR
 RAMSEY NJ 07446-1130

UPS Access Point™
 THE UPS STORE
 115 FRANKLIN TPKE
 MAHWAH NJ 07430-1325

UPS Access Point™
 THE UPS STORE
 120 E MAIN ST
 RAMSEY NJ 07446-1925

FOLD HERE

<p>NEIL GUERRIERO 3473040176 TRANSCEND WIRELESS 10 INDUSTRIAL AVE MAHWAH NJ 07430</p> <p>SHIP TO: GLENBROOK INDUSTRIAL PARK LLC SUITE 100 1 N. WATER STREET NORWALK CT 06854</p>	<p>CT 069 9-04</p> 	<p>UPS GROUND</p> <p>TRACKING #: 1Z V25 742 42 9581 2730</p> 	<p>1 LBS</p> <p>1 OF 1</p> <p>BILLING: P/P SIGNATURE REQUIRED</p> <p>Reference #1: CT11334A CSC Owner</p> <p><small>XOL 21.02.07 NV45 42.0A 01/2021*</small></p> 
--	---	--	--

650 GLENBROOK ROAD

Location 650 GLENBROOK ROAD

Mblu 003/ 8507/ / /

Acct# 003-8507

Owner GLENBROOK INDUSTRIAL
PARK LLC

Assessment \$7,641,150

Appraisal \$10,915,890

PID 35719

Building Count 5

Current Value

Appraisal			
Valuation Year	Improvements	Land	Total
2020	\$5,175,490	\$5,740,400	\$10,915,890

Assessment			
Valuation Year	Improvements	Land	Total
2020	\$3,622,870	\$4,018,280	\$7,641,150

Owner of Record

Owner GLENBROOK INDUSTRIAL PARK LLC
Co-Owner C/O SPINNAKER RE PARTNERS
Address 1 N WATER STREET
SUITE 100
NORWALK, CT 06854

Sale Price \$0
Book & Page 7365/0192
Sale Date 01/29/2004
Instrument 25

Ownership History

Ownership History				
Owner	Sale Price	Book & Page	Instrument	Sale Date
GLENBROOK INDUSTRIAL PARK LLC	\$0	7365/0192	25	01/29/2004
GLENBROOK INDUSTRIAL PARK ASC	\$0	5077/0267		09/01/1998
GLENBROOK INDUSTRIAL PARK ASC	\$0	5077/0267		08/31/1998
GLENBROOK INDUSTRIAL PARK ASC	\$0	1691/0178	25	11/04/1997

Building Information

Building 1 : Section 1

Year Built: 1943
Living Area: 134,160

Building Attributes


Field	Description
Style:	Industry Light
Model	Ind/Comm
Grade	C-
Stories:	2
Occupancy	29.00
Exterior Wall 1	Brick
Exterior Wall 2	Stucco Mas
Roof Structure	Flat
Roof Cover	T&G/Rubber
Interior Wall 1	Drywall/Plaste
Interior Wall 2	
Interior Floor 1	Concrete Slab
Interior Floor 2	
Heating Fuel	Gas/LP
Heating Type	Forced Air-Duc
AC Type	None
Struct Class	
Bldg Use	Industrial MDL-96
Total Rooms	
Total Bedrms	00
Total Baths	0
1st Floor Use:	300
Heat/AC	None
Frame Type	Steel
Baths/Plumbing	Average
Ceiling/Wall	Sus-Ceil/Mn WL
Rooms/Prtns	Average
Wall Height	14.00
% Comn Wall	

Building Photo



(<http://images.vgsi.com/photos/StamfordCTPhotos/\A00\11\45\00.jpg>)

Building Layout



(http://images.vgsi.com/photos/StamfordCTPhotos/Sketches/35719_35719)

Building Sub-Areas (sq ft)			Legend
Code	Description	Gross Area	Living Area
FUS	Upper Story, Finished	85,927	85,927
BAS	First Floor	48,233	48,233
CLP	Loading Platform	2,807	0
RP4	Porch Enclosed	168	0
UBM	Basement, Unfinished	44,249	0
		181,384	134,160

Building 2 : Section 1

Year Built: 1958
 Living Area: 2,555

Building Attributes : Bldg 2 of 5

Field	Description
Style:	Industry Light
Model	Comm/Ind


Grade	C
Stories:	3
Occupancy	1.00
Exterior Wall 1	Brick
Exterior Wall 2	
Roof Structure	Flat
Roof Cover	T&G/Rubber
Interior Wall 1	Drywall/Plaste
Interior Wall 2	
Interior Floor 1	Hardwood
Interior Floor 2	
Heating Fuel	Gas/LP
Heating Type	Hot Wtr Bbd
AC Type	Unit/AC
Struct Class	
Bldg Use	Commercial MDL-94
Total Rooms	
Total Bedrms	00
Total Baths	0
1st Floor Use:	200
Heat/AC	None
Frame Type	Steel
Baths/Plumbing	Average
Ceiling/Wall	Sus-Ceil&Wall
Rooms/Prtns	Average
Wall Height	14.00
% Comn Wall	

Building Photo



(<http://images.vgsi.com/photos/StamfordCTPhotos/\A00\11\45\03.jpg>)

Building Layout



(http://images.vgsi.com/photos/StamfordCTPhotos//Sketches/35719_3720;

Building Sub-Areas (sq ft)			Legend
Code	Description	Gross Area	Living Area
BAS	First Floor	1,924	1,924
EAF	Attic, Expansion, Finished	1,804	631
		3,728	2,555

Building 3 : Section 1

Year Built: 1950
Living Area: 2,238

Building Attributes : Bldg 3 of 5	
Field	Description
Style:	Industry Light
Model	Ind/Comm
Grade	C
Stories:	3
Occupancy	1.00


Exterior Wall 1	Brick
Exterior Wall 2	
Roof Structure	Flat
Roof Cover	T&G/Rubber
Interior Wall 1	Minimum
Interior Wall 2	
Interior Floor 1	Concrete Slab
Interior Floor 2	
Heating Fuel	Gas/LP
Heating Type	Hot Air-no Duc
AC Type	None
Struct Class	
Bldg Use	Industrial MDL-96
Total Rooms	
Total Bedrms	00
Total Baths	0
1st Floor Use:	300
Heat/AC	None
Frame Type	Steel
Baths/Plumbing	Average
Ceiling/Wall	Ceiling Only
Rooms/Prtns	Average
Wall Height	20.00
% Comn Wall	

Building Photo



(<http://images.vgsi.com/photos/StamfordCTPhotos/A0011145\05.jpg>)

Building Layout



BLDG 3 - BOILER ROOM

(http://images.vgsi.com/photos/StamfordCTPhotos/Sketches/35719_3720)

Building Sub-Areas (sq ft)			<u>Legend</u>
Code	Description	Gross Area	Living Area
BAS	First Floor	2,238	2,238
		2,238	2,238

Building 4 : Section 1

Year Built: 1950
Living Area: 2,040

Building Attributes : Bldg 4 of 5	
Field	Description
Style:	Auto Repair
Model	Ind/Comm
Grade	C
Stories:	3
Occupancy	1.00
Exterior Wall 1	Concr/Cinder

Exterior Wall 2	
Roof Structure	Flat
Roof Cover	T&G/Rubber
Interior Wall 1	Minimum
Interior Wall 2	
Interior Floor 1	Concrete Slab
Interior Floor 2	
Heating Fuel	Gas/LP
Heating Type	Hot Air-no Duc
AC Type	None
Struct Class	
Bldg Use	Industrial MDL-96
Total Rooms	
Total Bedrms	00
Total Baths	0
1st Floor Use:	300
Heat/AC	None
Frame Type	Masonry
Baths/Plumbing	Average
Ceiling/Wall	Sus-Ceil/Mn WL
Rooms/Prtns	Average
Wall Height	14.00
% Comn Wall	

Building Photo



(<http://images.vgsi.com/photos/StamfordCTPhotos//A00\11\45\09.jpg>)

Building Layout



BLDG 4 - AUTO BODY SHOP

(http://images.vgsi.com/photos/StamfordCTPhotos//Sketches/35719_3720!)

Building Sub-Areas (sq ft)			<u>Legend</u>
Code	Description	Gross Area	Living Area
BAS	First Floor	2,040	2,040
		2,040	2,040

Building 5 : Section 1

Year Built: 1950
Living Area: 1,368

Building Attributes : Bldg 5 of 5	
Field	Description
Style:	Auto Repair
Model	Comm/Ind
Grade	C-
Stories:	3
Occupancy	1.00
Exterior Wall 1	Concr/Cinder


Exterior Wall 2	
Roof Structure	Flat
Roof Cover	Rolled Compos
Interior Wall 1	Minimum
Interior Wall 2	Drywall/Plaste
Interior Floor 1	Concrete Slab
Interior Floor 2	
Heating Fuel	Gas/LP
Heating Type	Hot Air-no Duc
AC Type	None
Struct Class	
Bldg Use	Industrial MDL-96
Total Rooms	
Total Bedrms	
Total Baths	
1st Floor Use:	
Heat/AC	None
Frame Type	Masonry
Baths/Plumbing	None
Ceiling/Wall	Ceiling Only
Rooms/Prtns	Average
Wall Height	8.00
% Comn Wall	

Building Photo



(<http://images.vgsi.com/photos/StamfordCTPhotos//A001114512.jpg>)

Building Layout



BLDG 5 - GARAGE

(http://images.vgsi.com/photos/StamfordCTPhotos//Sketches/35719_1025)

Building Sub-Areas (sq ft)			<u>Legend</u>
Code	Description	Gross Area	Living Area
BAS	First Floor	1,368	1,368
		1,368	1,368

Extra Features

Extra Features				<u>Legend</u>
Code	Description	Size	Value	Bldg #
OH1	Door Overhd Co	1.00 UNITS	\$2,590	4
OH2	Door Overhd Re	3.00 UNITS	\$7,770	5
SPR1	Sprinklers - Wet	1804.00 S.F.	\$2,160	2
SPR1	Sprinklers - Wet	132518.00 S.F.	\$86,930	1
H04	Air Con/Sfla	32000.00 S.F	\$32,800	1
EL1	Elev Frght	3.00 STOPS	\$67,650	1
EL1	Elev Frght	3.00 STOPS	\$67,650	1

EL1	Elev Frght	3.00 STOPS	\$67,650	1
EL1	Elev Frght	3.00 STOPS	\$67,650	1
HL1	Hydro Lift Com	3.00 UNITS	\$11,070	1

Land

Land Use

Use Code 300
Description Industrial MDL-96
Zone MZN
Neighborhood 0400
Alt Land Appr No
Category

Land Line Valuation

Size (Acres) 4.28
Depth
Assessed Value \$4,018,280
Appraised Value \$5,740,400

Outbuildings

Outbuildings						<u>Legend</u>
Code	Description	Sub Code	Sub Description	Size	Value	Bldg #
AP1	Fence Chn Lk			1800.00 L.F.	\$15,530	1
CEL1	Cell Tower			1.00 SITES	\$146,250	3
AP1	Fence Chn Lk			3636.00 L.F.	\$31,360	1
CSHD	Cell Equipment			330.00 S.F.	\$8,980	3
FC4	Shed Finishd			128.00 S.F.	\$2,740	1
LP4	Pavng Aspht			80000.00 S.F.	\$96,000	1

Valuation History

Appraisal			
Valuation Year	Improvements	Land	Total
2019	\$5,175,490	\$5,740,400	\$10,915,890
2018	\$5,175,490	\$5,740,400	\$10,915,890
2017	\$5,175,490	\$5,740,400	\$10,915,890

Assessment			
Valuation Year	Improvements	Land	Total
2019	\$3,622,870	\$4,018,280	\$7,641,150
2018	\$3,622,870	\$4,018,280	\$7,641,150
2017	\$3,622,870	\$4,018,280	\$7,641,150

T-Mobile

WIRELESS COMMUNICATIONS FACILITY

STAMFORD-3/HOPE ST

SITE ID: CT11334A

652 GLENBROOK ROAD STAMFORD, CT 06906

T-MOBILE RF CONFIGURATION

67D5997DB_2xAIR+1OP

GENERAL NOTES

- ALL WORK SHALL BE IN ACCORDANCE WITH THE 2015 INTERNATIONAL BUILDING CODE AS MODIFIED BY THE 2018 CONNECTICUT SUPPLEMENT, INCLUDING THE I/A/E/A-222 REVISION "G" STRUCTURAL STANDARDS FOR STEEL ANTENNA TOWERS AND SUPPORTING STRUCTURES, 2017 CONNECTICUT FIRE SAFETY CODE, NATIONAL ELECTRICAL CODE AND LOCAL CODES.
- CONTRACTOR SHALL REVIEW ALL DRAWINGS AND SPECIFICATIONS IN THE CONTRACT DOCUMENT SET. CONTRACTOR SHALL COORDINATE ALL WORK SHOWN IN THE SET OF DRAWINGS. THE CONTRACTOR SHALL PROVIDE A COMPLETE SET OF DRAWINGS TO ALL SUBCONTRACTORS AND ALL RELATED PARTIES. THE SUBCONTRACTORS SHALL EXAMINE ALL THE DRAWINGS AND SPECIFICATIONS FOR THE INFORMATION THAT AFFECTS THEIR WORK.
- CONTRACTOR SHALL PROVIDE A COMPLETE BUILD-OUT WITH ALL FINISHES, STRUCTURAL, MECHANICAL, AND ELECTRICAL COMPONENTS AND PROVIDE ALL ITEMS AS SHOWN OR INDICATED ON THE DRAWINGS OR IN THE WRITTEN SPECIFICATIONS.
- CONTRACTOR SHALL FURNISH ALL MATERIAL, LABOR AND EQUIPMENT TO COMPLETE THE WORK AND FURNISH A COMPLETED JOB ALL IN ACCORDANCE WITH LOCAL AND STATE GOVERNING AUTHORITIES AND OTHER AUTHORITIES HAVING LAWFUL JURISDICTION OVER THE WORK.
- CONTRACTOR SHALL SECURE AND PAY FOR ALL PERMITS AND ALL INSPECTIONS REQUIRED AND SHALL ALSO PAY FEES REQUIRED FOR THE GENERAL CONSTRUCTION, PLUMBING, ELECTRICAL, AND HVAC. PERMITS SHALL BE PAID FOR BY THE RESPECTIVE SUBCONTRACTORS.
- CONTRACTOR SHALL MAINTAIN A CURRENT SET OF DRAWINGS AND SPECIFICATIONS ON SITE AT ALL TIMES AND INSURE DISTRIBUTION AND SPECIFICATIONS ON SITE AT ALL TIMES AND INSURE DISTRIBUTION OF NEW DRAWINGS TO SUBCONTRACTORS AND OTHER RELEVANT PARTIES AS SOON AS THEY ARE MADE AVAILABLE. ALL OLD DRAWINGS SHALL BE MARKED VOID AND REMOVED FROM THE CONTRACT AREA. THE CONTRACTOR SHALL FURNISH AN "AS-BUILT" SET OF DRAWINGS TO OWNER UPON COMPLETION OF PROJECT.
- LOCATION OF EQUIPMENT, AND WORK SUPPLIED BY OTHERS THAT IS DIAGRAMMATICALLY INDICATED ON THE DRAWINGS SHALL BE DETERMINED BY THE CONTRACTOR. THE CONTRACTOR SHALL DETERMINE LOCATIONS AND DIMENSIONS SUBJECT TO STRUCTURAL CONDITIONS AND WORK OF THE SUBCONTRACTORS.
- THE CONTRACTOR IS SOLELY RESPONSIBLE TO DETERMINE CONSTRUCTION PROCEDURE AND SEQUENCE AND TO ENSURE THE SAFETY OF THE EXISTING STRUCTURES AND ITS COMPONENT PARTS DURING CONSTRUCTION. THIS INCLUDES THE ADDITION OF WHATEVER SHORING, BRACING, UNDERPINNING, ETC. THAT MAY BE NECESSARY.
- DRAWINGS INDICATE THE MINIMUM STANDARDS, BUT IF ANY WORK SHOULD BE INDICATED TO BE SUBSTANDARD TO ANY ORDINANCES, LAWS, CODES, RULES, OR REGULATIONS BEARING ON THE WORK, THE CONTRACTOR SHALL INCLUDE IN HIS WORK AND SHALL EXECUTE THE WORK CORRECTLY IN ACCORDANCE WITH SUCH ORDINANCES, LAWS, CODES, RULES OR REGULATIONS WITH NO INCREASE IN COSTS.
- ALL UTILITY WORK SHALL BE IN ACCORDANCE WITH LOCAL UTILITY COMPANY REQUIREMENTS AND SPECIFICATIONS.
- ALL EQUIPMENT AND PRODUCTS PURCHASED ARE TO BE REVIEWED BY CONTRACTOR AND ALL APPLICABLE SUBCONTRACTORS FOR ANY CONDITION PER MANUFACTURER'S RECOMMENDATIONS. CONTRACTOR TO SUPPLY THESE ITEMS AT NO COST TO OWNER OR CONSTRUCTION MANAGER.
- ANY AND ALL ERRORS, DISCREPANCIES, AND 'MISSED' ITEMS ARE TO BE BROUGHT TO THE ATTENTION OF THE T-MOBILE CONSTRUCTION MANAGER DURING THE BIDDING PROCESS BY THE CONTRACTOR. ALL THESE ITEMS ARE TO BE INCLUDED IN THE BID. NO 'EXTRA' WILL BE ALLOWED FOR MISSED ITEMS.
- CONTRACTOR SHALL BE RESPONSIBLE FOR ALL ON-SITE SAFETY FROM THE TIME THE JOB IS AWARDED UNTIL ALL WORK IS COMPLETE AND ACCEPTED BY THE OWNER.
- CONTRACTOR TO REVIEW ALL SHOP DRAWINGS AND SUBMIT COPY TO ENGINEER FOR APPROVAL. DRAWINGS MUST BEAR THE CHECKER'S INITIALS BEFORE SUBMITTING TO THE CONSTRUCTION MANAGER FOR REVIEW.
- THE CONTRACTOR SHALL FIELD VERIFY ALL DIMENSIONS, ELEVATIONS, ANGLES AND EXISTING CONDITIONS AT THE SITE, PRIOR TO FABRICATION AND/OR INSTALLATION OF ANY WORK IN THE CONTRACT AREA.
- COORDINATION, LAYOUT, FURNISHING AND INSTALLATION OF CONDUITS AND ALL APPURTENANCES REQUIRED FOR PROPER INSTALLATION OF ELECTRICAL AND TELECOMMUNICATION SERVICE SHALL BE THE SOLE RESPONSIBILITY OF THE CONTRACTOR.
- ALL DAMAGE CAUSED TO ANY EXISTING STRUCTURE SHALL BE THE SOLE RESPONSIBILITY OF THE CONTRACTOR. THE CONTRACTOR WILL BE HELD LIABLE FOR ALL REPAIRS REQUIRED FOR EXISTING STRUCTURES IF DAMAGED DURING CONSTRUCTION ACTIVITIES.
- THE CONTRACTOR SHALL CONTACT "CALL BEFORE YOU DIG" AT LEAST 48 HOURS PRIOR TO ANY EXCAVATIONS AT 1-800-922-4455. ALL UTILITIES SHALL BE IDENTIFIED AND CLEARLY MARKED. CONTRACTOR SHALL MAINTAIN AND PROTECT MARKED UTILITIES THROUGHOUT PROJECT COMPLETION.
- CONTRACTOR SHALL COMPLY WITH THE OWNER'S ENVIRONMENTAL ENGINEER ON ALL METHODS AND PROVISIONS FOR ALL EXCAVATION ACTIVITIES INCLUDING SOIL DISPOSAL. ALL BACKFILL MATERIALS TO BE PROVIDED BY THE CONTRACTOR.


SITE DIRECTIONS

FROM: 35 GRIFFIN ROAD SOUTH BLOOMFIELD, CT 06002 **TO:** 652 GLENBROOK ROAD STAMFORD, CT 06906

- HEAD NORTH ON GRIFFIN ROAD S. TOWARD HARTMAN RD. 0.30 MI.
- TAKE THE 2ND RIGHT ONTO DAY HILL RD. 0.14 MI.
- TAKE THE 1ST RIGHT ONTO BLUE HILLS AVENUE EXT/CT-187. CONTINUE TO FOLLOW CT-187. 0.64 MI.
- STAY STRAIGHT TO GO ONTO BLUE HILLS AVE/CT-187. 2.72 MI.
- TURN LEFT ONTO E WINTONBURY AVE/CT-178. CONTINUE TO FOLLOW CT-178. 1.77 MI.
- MERGE ONTO I-91 S TOWARD HARTFORD. 23.74 MI.
- MERGE ONTO CT-15 S VIA EXIT 17 TOWARD E MAIN ST. 51.6 MI.
- TAKE THE CT-106/OLD STAMFORD RD EXIT, EXIT 36. 0.11 MI.
- TURN RIGHT ONTO OLD STAMFORD RD/CT-106. CONTINUE TO FOLLOW CT-106. 3.03 MI.
- TURN SLIGHT RIGHT ONTO MIDDLESEX RD/CT-106. CONTINUE TO FOLLOW CT-106. 0.34 MI.
- 652 GLENBROOK RD, STAMFORD, CT 06906-1408, 652 GLENBROOK RD IS ON THE RIGHT.

SITE COORDINATES: LATITUDE: 41° 04' 31" N
LONGITUDE: 73° 31' 09" W
GROUND ELEVATION: ±43' AMSL

COORDINATES AND GROUND ELEVATION ARE REFERENCED FROM GOOGLE EARTH



VICINITY MAP



PROJECT SUMMARY

THE PROPOSED SCOPE OF WORK CONSISTS OF A MODIFICATION TO THE EXISTING UNMANNED TELECOMMUNICATIONS FACILITY INCLUDING THE FOLLOWING:

- INSTALL (1) ENCLOSURE 6160 AND (1) BATTERY CABINET B160.
- INSTALL (1) IRXE ROUTER TO ENCLOSURE 6160.
- REMOVE (6) EXISTING COAX LINES
- INSTALL (3) 6X12 HCS
- INSTALL (1) BB6630 FOR L2500, (1) BB6648 FOR N2500 TO ENCLOSURE 6160.
- INSTALL (1) PSU 4813 TO ENCLOSURE 6160.
- INSTALL (1) AIR6449 B41 ANTENNA PER SECTOR, TOTAL OF (3).
- INSTALL (1) RADIO 4415 B25 PER SECTOR, TOTAL OF (3).
- INSTALL (1) PCS/AWS DIPLEXER PER SECTOR, TOTAL OF (3).

PROJECT SUMMARY (STRUCTURAL)

FOR REQUIRED STRUCTURAL MODIFICATIONS, SEE SHEET(S) S-1 FOR ADDITIONAL DETAILS. STEEL NEEDED FOR EQUIPMENT PLATFORM EXPANSION.



PROJECT INFORMATION

SITE NAME: STAMFORD-3/HOPE ST
SITE ID: CT11334A
SITE ADDRESS: 652 GLENBROOK ROAD STAMFORD, CT 06906
APPLICANT: T-MOBILE NORTHEAST, LLC 35 GRIFFIN ROAD SOUTH BLOOMFIELD, CT 06002
CONTACT PERSON: DAN REID (PROJECT MANAGER) TRANSCEND WIRELESS, LLC (203) 592-8291
ENGINEER OF RECORD: CENTEK ENGINEERING, INC. 63-2 NORTH BRANFORD RD. BRANFORD, CT 06405 CARLO F. CENTORE, PE (203) 488-0580 EXT. 122
PROJECT COORDINATES: LATITUDE: 41°-04'-31" N
LONGITUDE: 73°-31'-09" W
GROUND ELEVATION: 43' ± AMSL
SITE COORDINATES AND GROUND ELEVATION REFERENCED FROM GOOGLE EARTH.

SHEET INDEX

SHT. NO.	DESCRIPTION	REV.
T-1	TITLE SHEET	0
N-1	GENERAL NOTES AND SPECIFICATIONS	0
D-1	SITE LOCATION PLAN	0
D-2	COMPOUND PLAN AND ELEVATION	0
D-3	EQUIPMENT PLANS	0
D-4	ANTENNA PLANS AND ELEVATIONS	0
D-5	TYPICAL EQUIPMENT DETAILS	0
S-1	EXISTING/MODIFIED PLATFORM AND DETAILS	0
E-1	TYPICAL ELECTRICAL DETAILS	0

PROFESSIONAL ENGINEER SEAL



CENTEK engineering

Centered on Solutions
(203) 488-0580
(203) 488-8587 Fax
63-2 North Branford Road
Branford, CT 06405
www.CentekEng.com

T-MOBILE NORTHEAST LLC
WIRELESS COMMUNICATIONS FACILITY

STAMFORD-3/HOPE ST
SITE ID: CT11334A
652 GLENBROOK ROAD
STAMFORD, CT 06906

DATE: 09/04/20

SCALE: AS NOTED

JOB NO. 20074.67

TITLE SHEET

T-1

Sheet No. 1 of 9

CONSTRUCTION DRAWINGS - ISSUED FOR CONSTRUCTION

DATE

REV.

10/21/20

ASC


TJR

DRAWN BY/CHK'D BY

DESCRIPTION

NOTE:
ALL COAX LENGTHS TO BE MEASURED
AND VERIFIED IN FIELD BEFORE ORDERING



ANTENNA SCHEDULE								
SECTOR	EXISTING/PROPOSED	ANTENNA	SIZE (INCHES) (L x W x D)	ANTENNA ϕ HEIGHT	AZIMUTH	(E/P) RRU (QTY)	(E/P) TMA/DIPLEXER (QTY)	(QTY) PROPOSED COAX (LENGTH)
A1	PROPOSED	ERICSSON (AIR6449 B41)	33.1 x 20.6 x 8.6	85'	60°			(1) 6x12 HYBRID CABLE ($\pm 110'$)
A2	EXISTING	ERICSSON (AIR32 KR901146-1_B66A_B2A)	56.6 x 12.9 x 8.7	85'	60°			
A3	EXISTING	RFS - APXVAARR24_43-U-NA20	95.9 x 24 x 8.7	85'	60°	(E) RRU 4449 B12+B71 (1), (P) RRU 4415 B25 (1)	(E) GENERIC TWIN STYLE 1B (1), (P) COMMSCOPE SDX1926Q-43 (1)	
B1	PROPOSED	ERICSSON (AIR6449 B41)	33.1 x 20.6 x 8.6	85'	170°			(1) 6x12 HYBRID CABLE ($\pm 110'$)
B2	EXISTING	ERICSSON (AIR32 KR901146-1_B66A_B2A)	56.6 x 12.9 x 8.7	85'	170°			
B3	EXISTING	RFS - APXVAARR24_43-U-NA20	95.9 x 24 x 8.7	85'	170°	(E) RRU 4449 B12+B71 (1), (P) RRU 4415 B25 (1)	(E) GENERIC TWIN STYLE 1B (1), (P) COMMSCOPE SDX1926Q-43 (1)	
C1	PROPOSED	ERICSSON (AIR6449 B41)	33.1 x 20.6 x 8.6	85'	300°			(1) 6x12 HYBRID CABLE ($\pm 110'$)
C2	EXISTING	ERICSSON (AIR32 KR901146-1_B66A_B2A)	56.6 x 12.9 x 8.7	85'	300°			
C3	EXISTING	RFS - APXVAARR24_43-U-NA20	95.9 x 24 x 8.7	85'	300°	(E) RRU 4449 B12+B71 (1), (P) RRU 4415 B25 (1)	(E) GENERIC TWIN STYLE 1B (1), (P) COMMSCOPE SDX1926Q-43 (1)	



1 SITE LOCATION PLAN
C-1 SCALE: NOT TO SCALE



REV.	DATE	DESCRPTION
0	10/21/20	ASC DRAWN BY:CHK'D BY:
		TJR CONSTRUCTION DRAWINGS - ISSUED FOR CONSTRUCTION



CENTER engineering
Centered on Solutions
(203) 488-0580
(203) 488-8587 Fax
652 North Branford Road
Branford, CT 06405
www.CenterEng.com

T-MOBILE NORTHEAST LLC
WIRELESS COMMUNICATIONS FACILITY
STAMFORD-3/HOPE ST
SITE ID: CT11334A
652 GLENBROOK ROAD
STAMFORD, CT 06906

DATE: 09/04/20
SCALE: AS NOTED
JOB NO. 20074.67

SITE LOCATION PLAN

C-1
Sheet No. 3 of 9



STRUCTURAL COMPLIANCE

ANTENNA MOUNTS & EQUIPMENT PLATFORM

A STRUCTURAL ANALYSIS OF THE ANTENNA MOUNTS AND EQUIPMENT PLATFORM WAS PERFORMED FOR THE PROPOSED EQUIPMENT INSTALLATION AND THEY WERE FOUND TO BE STRUCTURALLY DEFICIENT AND WARRANTING MODIFICATION PRIOR TO INSTALLATION OF THE PROPOSED EQUIPMENT. FOR REQUIRED STRUCTURAL MODIFICATIONS, SEE SHEET(S) S-1 FOR DETAILS.

REFER TO THE STRUCTURAL ANALYSIS REPORT PREPARED BY CENTEK ENGINEERING (PROJECT # 20074.67) DATED 10/09/20 FOR ADDITIONAL INFORMATION AND REQUIREMENTS.


NOTE: NO EQUIPMENT SHALL BE INSTALLED ON THE HOSTING STRUCTURE WITHOUT A PASSING STRUCTURAL ANALYSIS REPORT AND CONTRACTOR PRIOR CONFIRMATION THAT ANY AND ALL REQUISITE MODIFICATIONS HAVE BEEN COMPLETED.



1
C-2
PROPOSED COMPOUND PLAN
SCALE: 1/8" = 1'
APPROXIMATE NORTH



NOTE:
SOME ANTENNA EQUIPMENT NOT SHOWN FOR CLARITY.

2
C-2
PROPOSED ELEVATION
SCALE: 1" = 10'





PROFESSIONAL ENGINEER SEAL							
T-MOBILE NORTHEAST LLC WIRELESS COMMUNICATIONS FACILITY STAMFORD-3/HOPE ST SITE ID: CT11334A 652 GLENBROOK ROAD STAMFORD, CT 06906				(203) 488-0580 (203) 488-8587 Fax 65-2 North Branford Road Branford, CT 06405 www.CentekEng.com			
DATE: 09/04/20		SCALE: AS NOTED		JOB NO. 20074.67			
COMPOUND PLAN AND ELEVATION							
C-2							
Sheet No. 4 of 9							

10/21/20 DATE
 0 REV.
 TJR DRAWN BY
 ASC CHECK'D BY
 CONSTRUCTION DRAWINGS - ISSUED FOR CONSTRUCTION DESCRIPTION



REV.	DATE	DESCRPTION
0	10/21/20	ASC DRAWN BY/TJR
		TJR
		CONSTRUCTION DRAWINGS - ISSUED FOR CONSTRUCTION




CENTER engineering
 Centered on Solutions™
 (203) 488-0580
 (203) 488-8587 Fax
 652 North Branford Road
 Branford, CT 06405
 www.CenterEng.com

T-MOBILE NORTHEAST LLC
 WIRELESS COMMUNICATIONS FACILITY
STAMFORD-3/HOPE ST
SITE ID: CT11334A
 652 GLENBROOK ROAD
 STAMFORD, CT 06906


DATE: 09/04/20
 SCALE: AS NOTED
 JOB NO. 20074.67

EQUIPMENT PLANS


C-3
 Sheet No. 5 of 9




1 EXISTING ANTENNA MOUNTING CONFIGURATION (TYP. SECTOR) APPROXIMATE NORTH
C-4 SCALE: 1/2" = 1'



2 EXISTING ANTENNA ELEVATION (TYP. SECTOR)
C-4 SCALE: 1/2" = 1'




1A PROPOSED ANTENNA MOUNTING CONFIGURATION (TYP. SECTOR) APPROXIMATE NORTH
C-4 SCALE: 1/2" = 1'



2A PROPOSED ANTENNA ELEVATION (TYP. SECTOR)
C-4 SCALE: 1/2" = 1'


PROFESSIONAL ENGINEER SEAL	CONSTRUCTION DRAWINGS - ISSUED FOR CONSTRUCTION
	DATE: 10/21/20
	ASC: TJR
	DESCRIBED BY: TJR
CENTEK engineering Centered on Solutions (203) 488-0380 (203) 488-8587 Fax 65-2 North Branford Road Branford, CT 06405 www.CentekEng.com	DATE: 09/04/20
T-MOBILE NORTHEAST LLC WIRELESS COMMUNICATIONS FACILITY STAMFORD-3/HOPE ST SITE ID: CT11334A 652 GLENBROOK ROAD STAMFORD, CT 06906	SCALE: AS NOTED
	JOB NO. 20074.67
	ANTENNA PLANS AND ELEVATIONS
C-4	
Sheet No. 6 of 9	



NOTES:


1. T-MOBILE SHALL SUPPLY RRU, AND RRU POLE-MOUNTING BRACKET. CONTRACTOR SHALL SUPPLY POLE/PIPE AND INSTALL ALL MOUNTING HARDWARE INCLUDING ERICSSON RRU POLE-MOUNTING BRACKET. CONTRACTOR SHALL INSTALLS RRU AND MAKES CABLE TERMINATIONS.
2. NO PAINTING OF THE RRU OR SOLAR SHIELD IS ALLOWED.

1 TYPICAL RRU MOUNTING DETAIL
C-5 SCALE: NOT TO SCALE



ALPHA/BETA/GAMMA ANTENNA		
EQUIPMENT	DIMENSIONS	WEIGHT
MAKE: ERICSSON MODEL: AIR6449 B41	33.1"L x 20.6"W x 8.6"D	±104 LBS.
NOTES: 1. CONTRACTOR TO COORDINATE FINAL EQUIPMENT MODEL SELECTION WITH T-MOBILE CONSTRUCTION MANAGER PRIOR TO ORDERING.		

2 PROPOSED ANTENNA DETAIL
C-5 SCALE: NOT TO SCALE



RRU (REMOTE RADIO UNIT)			
EQUIPMENT	DIMENSIONS	WEIGHT	CLEARANCES
MAKE: ERICSSON MODEL: RADIO 4415 B25	16.5"L x 13.4"W x 5.9"D	±46 LBS.	BEHIND ANT.: 8" MIN. BELOW ANT.: 20" MIN. BELOW RRU: 16" MIN.
NOTES: 1. CONTRACTOR TO COORDINATE FINAL EQUIPMENT MODEL SELECTION WITH T-MOBILE CONSTRUCTION MANAGER PRIOR TO ORDERING.			

3 PROPOSED RRU DETAIL
C-5 SCALE: NOT TO SCALE



EQUIPMENT CABINET		
EQUIPMENT	DIMENSIONS	WEIGHT
MAKE: ERICSSON MODEL: ENCLOSURE 6160	62.0"H x 26.0"W x 26.0"D	±1200 LBS

4 ENCLOSURE 6160 CABINET DETAIL
C-5 SCALE: NOT TO SCALE



EQUIPMENT CABINET		
EQUIPMENT	DIMENSIONS	WEIGHT
MAKE: ERICSSON MODEL: BATTERY CABINET B160	62.0"H x 26.0"W x 26.0"D	±1883 LBS

5 BATTERY B160 CABINET DETAIL
C-5 SCALE: NOT TO SCALE



DIPLEXER		
EQUIPMENT	DIMENSIONS	WEIGHT
MAKE: COMMSCOPE MODEL: SDX1926Q-43(E14F05P86)	4.2"L x 7.0"W x 3.0"D	-
NOTES: 1. CONTRACTOR TO COORDINATE FINAL EQUIPMENT MODEL SELECTION WITH T-MOBILE CONSTRUCTION MANAGER PRIOR TO ORDERING.		

6 PROPOSED DIPLEXER DETAIL
C-5 SCALE: NOT TO SCALE

CONSTRUCTION DRAWINGS - ISSUED FOR CONSTRUCTION

DATE: 09/04/20
SCALE: AS NOTED
JOB NO. 20074.67

TYPICAL EQUIPMENT DETAILS

C-5

Sheet No. 7 of 9


PROFESSIONAL ENGINEER SEAL

STATE OF CONNECTICUT
REGISTERED PROFESSIONAL ENGINEER
No. 14328-0001
T. J. RAY

T-Mobile
T-Mobile
T-Mobile

CENTEX engineering
Centered on Solutions
(203) 488-0380
(203) 488-8587 Fax
65-2 North Branford Road
Branford, CT 06405
www.CentexEng.com


T-MOBILE NORTHEAST LLC
WIRELESS COMMUNICATIONS FACILITY
STAMFORD-3/HOPE ST
SITE ID: CT11334A
652 GLENBROOK ROAD
STAMFORD, CT 06906



SITE KEY PLAN
SCALE: 1" = 40'-0"
APPROXIMATE NORTH

- PLAN NOTES**
1. VERIFY ALL DIMENSIONS, ELEVATIONS, EXISTING FRAMING MEMBER SIZES AND GENERAL CONDITIONS PRIOR TO COMMENCEMENT OF WORK. NOTIFY ENGINEER OF RECORD OF ANY DISCREPANCIES BETWEEN THESE DRAWINGS AND EXISTING CONDITIONS.
 2. DIMENSIONS APPLY TO THE CENTER OF MEMBERS UNLESS NOTED OTHERWISE.
 3. REFER TO CIVIL DRAWINGS FOR EQUIPMENT LAYOUT AND CONFIGURATIONS.


- LEGEND**
- P1 DENOTES (E) HSS6X6X1/2 DUNNAGE SUPPORT POST
 - W.P. DENOTES WORKING POINT.
 - INDICATES SPAN DIRECTION OF GALVANIZED BAR GRATING - Mc. NICHOLS GW-100A, 1 1/4" x 1/8" BAR GRATING WITH STANDARD SADDLE CLIP FASTENERS. REFER TO FRAMING PLAN FOR DECK SPAN DIRECTION.




1 PARTIAL EXISTING ROOF PLAN
SCALE: 1/8" = 1'-0"
APPROXIMATE NORTH

2 EQUIPMENT PLATFORM DEMOLITION PLAN
SCALE: 3/8" = 1'-0"
APPROXIMATE NORTH


3 EQUIPMENT PLATFORM FRAMING PLAN
SCALE: 3/8" = 1'-0"
APPROXIMATE NORTH




9 TYP. VERT. LADDER DET.
SCALE: 1/2" = 1'-0"




8A TYP. GUARDRAIL CONNECTION
SCALE: 1/2" = 1'-0"




6 (P)W12 TO (P)W8 BRACE CONNECTION DET.
SCALE: 1" = 1'-0"




5 (E)W12 TO (P)W8 BRACE CONNECTION DET.
SCALE: 1" = 1'-0"




4 (E)W12 TO (P)W8 BEAM CONNECTION DET.
SCALE: 1-1/2" = 1'-0"




9A VERT. LADDER CONNECTION
SCALE: 3/8" = 1'-0"




8 TYP. GUARDRAIL DET.
SCALE: 1/2" = 1'-0"



7 (E)W8 TO (P)L4 BEAM CONNECTION DET.
SCALE: 1-1/2" = 1'-0"



5A BRACE CONNECTION PARTIAL SECTION
SCALE: 1" = 1'-0"



6 (E)W8 TO (P)W8 BEAM CONNECTION DET.
SCALE: 1-1/2" = 1'-0"

PROFESSIONAL ENGINEER SEAL


T-MOBILE NORTHEAST LLC
WIRELESS COMMUNICATIONS FACILITY
STAMFORD-3/HOPE ST
SITE ID: CT11334A
652 GLENBROOK ROAD
STAMFORD, CT 06906

DATE: 09/04/20
SCALE: AS NOTED
JOB NO. 20074.67


EXIST. / MODIFIED PLATFORM PLANS & DETAILS

S-1

Sheet No. 8 of 9




1 TYPICAL ANTENNA/RRU GROUNDING DETAILS
E-1 SCALE: NOT TO SCALE



- NOTES:**
1. BOND COAXIAL CABLE GROUND KITS TO EACH OWNER'S GROUND BAR ALONG ENTIRE COAX RUN FROM ANTENNA TO SHELTER.
 2. BOND ALL EQUIPMENT TO GROUND PER NEC AND MANUFACTURERS SPECIFICATIONS.
 3. DETAIL IS TYPICAL FOR ALL ANTENNA SECTORS, INCLUDING GPS ANTENNA.


2 TYPICAL ANTENNA GROUNDING DETAIL
E-1 SCALE: NOT TO SCALE



GROUNDING SCHEMATIC NOTES

- 1 #2 AWG
 - 2 #6 AWG
- GENERAL NOTES:**
1. ALL SURGE SUPPRESSION EQUIPMENT SHALL BE BONDED TO GROUND PER MANUFACTURER'S SPECIFICATIONS
 2. UNLESS OTHERWISE NOTED OR REQUIRED BY CODE, GROUND CONDUCTORS SHOWN SHALL BE #2 AWG (SOLID TINNED BCW - EXTERIOR; STRANDED GREEN INSULATED - INTERIOR).
 3. ALL SECTOR GROUND BARS SHALL BE BONDED TOGETHER WITH #2 AWG SOLID TINNED BCW.
 4. BOND ALL EQUIPMENT CABINETS AND BATTERY CABINETS TO GROUND PER MANUFACTURER'S SPECIFICATIONS.
 5. COORDINATE ALL ROOF MOUNTED EQUIPMENT WITH OWNER.
 6. ALL ROOF MOUNTED AMPLIFIERS AND ASSOCIATED EQUIPMENT SHALL BE BONDED TO THE SECTOR GROUND BAR PER MANUFACTURER'S SPECIFICATIONS.
 7. ALL GROUNDING SHALL BE IN ACCORDANCE WITH NEC AND OWNER'S REQUIREMENTS.


4 TYPICAL GROUNDING SCHEMATIC DETAIL
E-1 SCALE: NOT TO SCALE



3 PROPOSED PLUMBING DIAGRAM
E-1 SCALE: NOT TO SCALE

RISER DIAGRAM NOTES

- 1 EXISTING 200A, 120/240V, SINGLE PHASE PANEL TO REMAIN.
- 2 NEW 100A/2P CIRCUIT BREAKER TO SERVE NEW EQUIPMENT CABINET
- 3 EXISTING CONDUITS AND CONDUCTORS TO REMAIN.
- 4 (3) #1 AWG, (1) #8 AWG GROUND, 1-1/4" CONDUIT.
- 5 EXISTING EQUIPMENT CABINET TO REMAIN.
- 6 NEW RADIO EQUIPMENT CABINET.
- 7 NEW BATTERY CABINET.
- 8 DC CONDUIT AND CONDUCTORS FOR BATTERY CABINET CONNECTION PER MANUFACTURERS SPECIFICATIONS.



5 ELECTRICAL POWER RISER DIAGRAM
E-1 SCALE: NOT TO SCALE

PROFESSIONAL ENGINEER SEAL

T-Mobile

T-MOBILE NORTHEAST LLC
WIRELESS COMMUNICATIONS FACILITY
STAMFORD-3/HOPE ST
SITE ID: CT11334A
652 GLENBROOK ROAD
STAMFORD, CT 06906

DATE: 09/04/20
SCALE: AS NOTED
JOB NO. 20074.67

TYPICAL ELECTRICAL DETAILS

E-1

Sheet No. 9 of 9

CONSTRUCTION DRAWINGS - ISSUED FOR CONSTRUCTION

TJR
DATE 10/21/20
ASC
DRAWN BY CHK'D BY
REV.

CENTER engineering
Centered on Solutions
(203) 488-0380
(203) 488-8387 Fax
652 North Branford Road
Branford, CT 06405
www.CenterEng.com

Structural Analysis Report

Antenna Frames & Equipment Platform

*Proposed T-Mobile
Antenna Upgrade*


Site Ref: CT11334A

*652 Glenbrook Road
Stamford, CT*

CEN TEK Project No. 20074.67

~~*Date: September 2, 2020*~~

Rev 2: October 9, 2020



Prepared for:
T-Mobile USA
35 Griffin Road
Bloomfield, CT 06002

Table of Contents

SECTION 1 - REPORT

- INTRODUCTION
- PRIMARY ASSUMPTIONS USED IN THE ANALYSIS
- ANTENNA AND EQUIPMENT INSTALLATION SUMMARY
- ANALYSIS
- DESIGN LOADING
- RESULTS
- CONCLUSION

SECTION 2 – CONDITIONS & SOFTWARE

- STANDARD ENGINEERING CONDITIONS
- GENERAL DESCRIPTION OF STRUCTURAL ANALYSIS PROGRAM

SECTION 3 – CALCULATIONS

- ANTENNAE – WIND LOAD CALCULATION
- CABINETS – WIND LOAD CALCULATION
- RISA 3D OUTPUT REPORT – A/B/C ANTENNA MOUNTS
- RISA 3D OUTPUT REPORT – EQUIPMENT PLATFORM
- HOST BUILDING COLUMNS USAGE ANALYSIS

SECTION 4 – REFERENCE MATERIAL

- RF DATA SHEET
- STRUCTURAL ANALYSIS REPORT PREPARED BY ATLANTIS GROUP DATED FEBRUARY, 5 2015 (not attached within this report)
- CONSTRUCTION DOCUMENTS REV.2 PREPARED BY NATCOMM CONSULTING ENGINEERS DATED MAY, 13 2009
- VOICE STREAM WIRELESS CONSTRUCTION DOCUMENTS PREPARED BY NATCOMM CONSULTING ENGINEERS DATED DECEMBER, 18 2000

Introduction

The purpose of this structural analysis report (SAR) is to summarize the results, of the impacted structural components, by the equipment upgrade proposed by T-Mobile on the existing host building located in Stamford, CT.

The antennas are mounted on steel frames attached to the water tank catwalk. The T-Mobile equipment cabinets are mounted on a structural steel platform on the roof of the building.

The mounts member sizes information and roof structural information were obtained from site visit performed by Centek personnel on August 24, 2020, a structural analysis report as prepared by Atlantis Group, dated February, 5 2015, construction documents REV.2 as prepared by Natcomm Consulting Engineers, dated May, 13 2009 and Voice Stream construction documents as prepared by Natcom Consulting Engineers, dated December 18 2000. Proposed/existing antenna and appurtenance information was taken from a RF data sheet dated 08/17/2020 provided by T-Mobile.

The existing roof framing consists of concrete slabs supported on 16-in x16-in concrete columns. The antenna mounts were modeled based on visual inspection from the host building roof level, information presented on the aforementioned structural analysis report and conservative engineering judgement. The T-Mobile modified equipment platform is attached to the existing building bearing directly on top of four (4) building columns.

Primary Assumptions Used in the Analysis

- The host structure's theoretical capacity not including any assessment of the condition of the host structure.
- The existing elevated steel antenna frames carry the horizontal and vertical loads due to the weight of equipment, and wind and transfers into host structure.
- Proposed reinforcement and support steel will be properly installed and maintained.
- Structure is in plumb condition.
- Loading for equipment and enclosure as listed in this report.
- All bolts are appropriately tightened providing the necessary connection continuity.
- All welds are fabricated with ER-70S-6 electrodes.
- All members are assumed to be as observed during roof framing mapping.
- All members are "hot dipped" galvanized in accordance with ASTM A123 and ASTM A153 Standards.
- All member protective coatings are in good condition.

Antenna and Equipment Summary

Location	Appurtenance / Equipment		Rad Center Elevation (AGL)	Mount Type
Alpha	(1) RFS APXVAARR24_43 Antenna (1) Ericsson AIR32 B66A B2A Antenna (1) Ericsson AIR21 B2A B4P Antenna (1) TMA (1) Ericsson AIR6449 B41 Antenna (1) Ericsson 4449 B71+B85 RRU (1) Ericsson 4415 B25 RRU (1) Commscope SDX1926Q-43 Diplexer		85-ft	(E) Antenna mounts
Beta Sector	(1) RFS APXVAARR24_43 Antenna (1) Ericsson AIR32 B66A B2A Antenna (1) Ericsson AIR21 B2A B4P Antenna (1) TMA (1) Ericsson AIR6449 B41 Antenna (1) Ericsson 4449 B71+B85 RRU (1) Ericsson 4415 B25 RRU (1) Commscope SDX1926Q-43 Diplexer		85-ft	(E) Antenna mounts
Gamma Sector	(1) RFS APXVAARR24_43 Antenna (1) Ericsson AIR32 B66A B2A Antenna (1) Ericsson AIR21 B2A B4P Antenna (1) TMA (1) Ericsson AIR6449 B41 Antenna (1) Ericsson 4449 B71+B85 RRU (1) Ericsson 4415 B25 RRU (1) Commscope SDX1926Q-43 Diplexer		85-ft	(E) Antenna mounts
Equipment Platform	(1) Generac 25kW	1265 lbs.	-	Steel dunnage platform on building roof
	(1) Ericsson RBS 6131	2593 lbs.		
	(1) Transformer	405 lbs.		
	(1) Ericsson B160	1883 lbs.		
	(1) Ericsson 6160	1200 lbs.	-	

~~Equipment~~ – Indicates equipment to be removed.

Equipment – Indicates equipment to be installed.

Analysis

The equipment platform and antenna frames were analyzed using a comprehensive computer program titled Risa3D. The program analyzes the equipment platform and antenna mounts considering the worst case code prescribed loading condition. The structures were considered to be loaded by concentric forces, and the model assumes that the members are subjected to bending, axial, and shear forces.

Design Loading

Loading was determined per the requirements of the 2015 International Building Code amended by the 2018 CSBC and ASCE 7-10 “Minimum Design Loads for Buildings and Other Structures”.

Wind Speed:	$V_{ult} = 120$ mph	Appendix N of the 2018 CT State Building Code
Risk Category:	II (Mounts) / III (Tank)	2015 IBC; Table 1604.05
Exposure Category:	Surface Roughness C	ASCE 7-10; Section 26.7.2
Ground Snow Load	30 psf	Appendix N of the 2018 CT State Building Code
Dead Load	Equipment and framing self-weight	Identified within SAR design calculations
Live Load	20 psf	ASCE 7-10; Table 4-1 “Roofs – All Other Construction”

Reference Standards

2015 International Building Code:

1. ACI 318-14, *Building Code Requirements for Structural Concrete*.
2. ACI 530-13, *Building Code Requirements for Masonry Structures*.
3. AISC 360-10, *Specification for Structural Steel Buildings*
4. AWS D1.1 – 00, *Structural Welding Code – Steel*.

Results

Structure stresses were calculated utilizing the structural analysis software RISA 3D. The stresses were determined based on the AISC standard.

- Calculated stresses for the antenna mounts & equipment platform and host building were found to **be within allowable** limits.

Component	Member	Stress Ratio (percentage of capacity)	Result
Antenna Mounts	Pipe 2.0 STD (Antenna Mast)	36.7%	PASS
	Pipe 2.0 STD (Existing Horz. Member)	30.4%	PASS
Water Tank	Tank Leg	67.6%	PASS
Equipment Platform	W12X26 (Existing Platform Girder)	49.9%	PASS
	HSS6X6X1/2 (Existing Platform Member)	10.4%	PASS
	W8X18 (Existing Platform Member)	30.6%	PASS
	W12X14 (Proposed Platform Member)	46.5%	PASS
	W8X10 (Proposed Platform Member)	29.2%	PASS
	Concrete Building Column (Column D4)	48.5%	PASS

Conclusion

This analysis shows that the subject antenna frames & modified equipment platform **HAVE SUFFICIENT CAPACITY** to support the proposed modified antenna configuration.


The analysis is based, in part, on the information provided to this office by T-Mobile. If the existing conditions are different than the information in this report, Centek Engineering, Inc. must be contacted for resolution of any potential issues.

Please feel free to call with any questions or comments.

Respectfully Submitted by:



Timothy J. Lynn, PE
 Structural Engineer



Prepared by:



Fernando J. Palacios
 Engineer

*Standard Conditions for Furnishing of
Professional Engineering Services on
Existing Structures*

All engineering services are performed on the basis that the information used is current and correct. This information may consist of, but is not necessarily limited to:

- Information supplied by the client regarding the structure itself, its foundations, the soil conditions, the antenna and feed line loading on the structure and its components, or other relevant information.
- Information from the field and/or drawings in the possession of Centek Engineering, Inc. or generated by field inspections or measurements of the structure.
- It is the responsibility of the client to ensure that the information provided to Centek Engineering, Inc. and used in the performance of our engineering services is correct and complete. In the absence of information to the contrary, we assume that all structures were constructed in accordance with the drawings and specifications and are in an uncorroded condition and have not deteriorated. It is therefore assumed that its capacity has not significantly changed from the “as new” condition.
- All services will be performed to the codes specified by the client, and we do not imply to meet any other codes or requirements unless explicitly agreed in writing. If wind and ice loads or other relevant parameters are to be different from the minimum values recommended by the codes, the client shall specify the exact requirement. In the absence of information to the contrary, all work will be performed in accordance with the latest revision of ANSI/ASCE10 & ANSI/EIA-222
- All services performed, results obtained, and recommendations made are in accordance with generally accepted engineering principles and practices. Centek Engineering, Inc. is not responsible for the conclusions, opinions and recommendations made by others based on the information we supply.

Exposure Constant =	$Z_{min} := \begin{cases} \text{if Exp} = \text{B} \\ 30 \\ \text{if Exp} = \text{C} \\ 15 \\ \text{if Exp} = \text{D} \\ 7 \end{cases} = 15$	(Table 26.9-1)
Exposure Coefficient =	$K_z := \begin{cases} \text{if } 15 \leq Z \leq z_g \\ 2.01 \cdot \left(\frac{Z}{z_g}\right)^{\left(\frac{2}{\alpha}\right)} \\ \text{if } Z < 15 \\ 2.01 \cdot \left(\frac{15}{z_g}\right)^{\left(\frac{2}{\alpha}\right)} \end{cases} = 1.22$	(Table 29.3-1)
Topographic Factor =	$K_{zt} := 1$	(Eq. 26.8-2)
Wind Directionality Factor =	$K_d = 0.9$	(Table 26.6-1)
Velocity Pressure =	$q_z := 0.00256 \cdot K_z \cdot K_{zt} \cdot K_d \cdot V^2 = 40.58$	(Eq. 29.3-1)
Peak Factor for Background Response =	$g_Q = 3.4$	(Sec 26.9.4)
Peak Factor for Wind Response =	$g_v = 3.4$	(Sec 26.9.4)
Equivalent Height of Structure =	$z := \begin{cases} \text{if } Z_{min} > 0.6 \cdot \text{Height} \\ Z_{min} \\ \text{else} \\ 0.6 \cdot \text{Height} \end{cases} = 15$	(Sec 26.9.4)
Intensity of Turbulence =	$I_z := c \cdot \left(\frac{33}{z}\right)^{\left(\frac{1}{6}\right)} = 0.228$	(Eq. 26.9-7)
Integral Length Scale of Turbulence =	$L_z := 1 \cdot \left(\frac{z}{33}\right)^E = 427.057$	(Eq. 26.9-9)
Background Response Factor =	$Q := \sqrt{\frac{1}{1 + 0.63 \cdot \left(\frac{\text{Width} + \text{Height}}{L_z}\right)^{0.63}}} = 0.972$	(Eq. 26.9-8)
Gust Response Factor =	$G := 0.925 \cdot \left(\frac{(1 + 1.7 \cdot g_Q \cdot I_z \cdot Q)}{1 + 1.7 \cdot g_v \cdot I_z}\right) = 0.91$	(Eq. 26.9-6)
Force Coefficient =	$C_f = 1.35$	(Fig 29.5-1 - 29.5-3)
Wind Force =	$F := q_z \cdot G \cdot C_f = 50$	psf

Development of Wind on Antennas

Antenna Data:

Antenna Model =	Ericsson AIR6449 B41	
Antenna Shape =	Flat	(User Input)
Antenna Height =	$L_{ant} := 33.1$	in (User Input)
Antenna Width =	$W_{ant} := 20.6$	in (User Input)
Antenna Thickness =	$T_{ant} := 8.6$	in (User Input)
Antenna Weight =	$WT_{ant} := 104$	lbs (User Input)
Number of Antennas =	$N_{ant} := 1$	(User Input)

Wind Load (Front)

Surface Area for One Antenna =	$SA_{ant} := \frac{L_{ant} \cdot W_{ant}}{144} = 4.7$	sf
Antenna Projected Surface Area =	$A_{ant} := SA_{ant} \cdot N_{ant} = 4.7$	sf
Total Antenna Wind Force =	$F_{ant} := F \cdot A_{ant} = 236$	lbs

Wind Load (Side)

Surface Area for One Antenna =	$SA_{ant} := \frac{L_{ant} \cdot T_{ant}}{144} = 2$	sf
Antenna Projected Surface Area =	$A_{ant} := SA_{ant} \cdot N_{ant} = 2$	sf
Total Antenna Wind Force =	$F_{ant} := F \cdot A_{ant} = 99$	lbs

Gravity Load (without ice)

Weight of All Antennas =	$WT_{ant} \cdot N_{ant} = 104$	lbs
---------------------------------	--	------------

Development of Wind on Antennas

Antenna Data:

Antenna Model =	RFS - APXVAARR24_43-U-NA20	
Antenna Shape =	Flat	(User Input)
Antenna Height =	$L_{ant} := 95.5$	in (User Input)
Antenna Width =	$W_{ant} := 24$	in (User Input)
Antenna Thickness =	$T_{ant} := 8.7$	in (User Input)
Antenna Weight =	$WT_{ant} := 153$	lbs (User Input)
Number of Antennas =	$N_{ant} := 1$	(User Input)

Wind Load (Front)

Surface Area for One Antenna =	$SA_{ant} := \frac{L_{ant} \cdot W_{ant}}{144} = 15.9$	sf
Antenna Projected Surface Area =	$A_{ant} := SA_{ant} \cdot N_{ant} = 15.9$	sf
Total Antenna Wind Force =	$F_{ant} := F \cdot A_{ant} = 794$	lbs

Wind Load (Side)

Surface Area for One Antenna =	$SA_{ant} := \frac{L_{ant} \cdot T_{ant}}{144} = 5.8$	sf
Antenna Projected Surface Area =	$A_{ant} := SA_{ant} \cdot N_{ant} = 5.8$	sf
Total Antenna Wind Force =	$F_{ant} := F \cdot A_{ant} = 288$	lbs

Gravity Load (without ice)

Weight of All Antennas =	$WT_{ant} \cdot N_{ant} = 153$	lbs
---------------------------------	--	------------

Development of Wind on Antennas

Antenna Data:

Antenna Model =	Ericsson AIR32 B66 B2A	
Antenna Shape =	Flat	(User Input)
Antenna Height =	$L_{ant} := 56.6$	in (User Input)
Antenna Width =	$W_{ant} := 12.9$	in (User Input)
Antenna Thickness =	$T_{ant} := 8.7$	in (User Input)
Antenna Weight =	$WT_{ant} := 133$	lbs (User Input)
Number of Antennas =	$N_{ant} := 1$	(User Input)

Wind Load (Front)

Surface Area for One Antenna =	$SA_{ant} := \frac{L_{ant} \cdot W_{ant}}{144} = 5.1$	sf
Antenna Projected Surface Area =	$A_{ant} := SA_{ant} \cdot N_{ant} = 5.1$	sf
Total Antenna Wind Force =	$F_{ant} := F \cdot A_{ant} = 253$	lbs

Wind Load (Side)

Surface Area for One Antenna =	$SA_{ant} := \frac{L_{ant} \cdot T_{ant}}{144} = 3.4$	sf
Antenna Projected Surface Area =	$A_{ant} := SA_{ant} \cdot N_{ant} = 3.4$	sf
Total Antenna Wind Force =	$F_{ant} := F \cdot A_{ant} = 170$	lbs

Gravity Load (without ice)

Weight of All Antennas =	$WT_{ant} \cdot N_{ant} = 133$	lbs
---------------------------------	--	------------

Development of Wind & Ice Load on RRHs

RRH Data:

RRH Model =	Ericsson 4449 B71+B85	
RRH Shape =	Flat	(User Input)
RRH Height =	$L_{RRH} := 17.9$	in (User Input)
RRH Width =	$W_{RRH} := 13.2$	in (User Input)
RRH Thickness =	$T_{RRH} := 9.5$	in (User Input)
RRH Weight =	$WT_{RRH} := 75$	lbs (User Input)
Number of RRHs =	$N_{RRH} := 1$	(User Input)

Wind Load (Front)

Surface Area for One RRH =	$SA_{RRH} := \frac{L_{RRH} \cdot W_{RRH}}{144} = 1.6$	sf
RRH Projected Surface Area =	$A_{RRH} := SA_{RRH} \cdot N_{RRH} = 1.6$	sf
Total RRH Wind Force =	$F_{RRH} := F \cdot A_{RRH} = 82$	lbs

Wind Load (Side)

Surface Area for One RRH =	$SA_{RRH} := \frac{L_{RRH} \cdot T_{RRH}}{144} = 1.2$	sf
RRH Projected Surface Area =	$A_{RRH} := SA_{RRH} \cdot N_{RRH} = 1.2$	sf
Total RRH Wind Force =	$F_{RRH} := F \cdot A_{RRH} = 59$	lbs

Gravity Load (without ice)

Weight of All RRHs =	$WT_{RRH} \cdot N_{RRH} = 75$	lbs
-----------------------------	---	------------

Development of Wind & Ice Load on RRHs

RRH Data:

RRH Model =	Ericsson 4415 B25	
RRH Shape =	Flat	(User Input)
RRH Height =	$L_{RRH} := 14.9$	in (User Input)
RRH Width =	$W_{RRH} := 13.2$	in (User Input)
RRH Thickness =	$T_{RRH} := 5.4$	in (User Input)
RRH Weight =	$WT_{RRH} := 46.3$	lbs (User Input)
Number of RRHs =	$N_{RRH} := 1$	(User Input)

Wind Load (Front)

Surface Area for One RRH =	$SA_{RRH} := \frac{L_{RRH} \cdot W_{RRH}}{144} = 1.4$	sf
RRH Projected Surface Area =	$A_{RRH} := SA_{RRH} \cdot N_{RRH} = 1.4$	sf
Total RRH Wind Force =	$F_{RRH} := F \cdot A_{RRH} = 68$	lbs

Wind Load (Side)

Surface Area for One RRH =	$SA_{RRH} := \frac{L_{RRH} \cdot T_{RRH}}{144} = 0.6$	sf
RRH Projected Surface Area =	$A_{RRH} := SA_{RRH} \cdot N_{RRH} = 0.6$	sf
Total RRH Wind Force =	$F_{RRH} := F \cdot A_{RRH} = 28$	lbs

Gravity Load (without ice)

Weight of All RRHs =	$WT_{RRH} \cdot N_{RRH} = 46$	lbs
-----------------------------	---	------------

Development of Wind on Equipment

Equipment Data:

Equipment Model =	Commscope - SDX1926Q-43	
Equipment Shape =	Flat	(User Input)
Equipment Height =	$L_{Eq} := 4.2$	in (User Input)
Equipment Width =	$W_{Eq} := 6.1$	in (User Input)
Equipment Thickness =	$T_{Eq} := 6.9$	in (User Input)
Equipment Weight =	$WT_{Eq} := 6.6$	lbs (User Input)
Number of Equipment =	$N_{Eq} := 1$	(User Input)

Wind Load (Front)

Surface Area for One Equipment =	$SA_{Eq} := \frac{L_{Eq} \cdot W_{Eq}}{144} = 0.2$	sf
Equipment Projected Surface Area =	$A_{Eq} := SA_{Eq} \cdot N_{Eq} = 0.2$	sf

Total Equipment Wind Force = $F_{Eq} := F \cdot A_{Eq} = 9$ **lbs**

Wind Load (Side)

Surface Area for One Equipment =	$SA_{Eq} := \frac{L_{Eq} \cdot T_{Eq}}{144} = 0.2$	sf
Equipment Projected Surface Area =	$A_{Eq} := SA_{Eq} \cdot N_{Eq} = 0.2$	sf

Total Equipment Wind Force = $F_{Eq} := F \cdot A_{Eq} = 10$ **lbs**

Gravity Load (without ice)

Weight of All Equipments = $WT_{Eq} \cdot N_{Eq} = 7$ **lbs**

Development of Wind & Ice Load on TMAs

TMA Data:

TMA Model =	Ericsson KRY112 TMA	
TMA Shape =	Flat	(User Input)
TMA Height =	$L_{TMA} := 6.9$	in (User Input)
TMA Width =	$W_{TMA} := 6.1$	in (User Input)
TMA Thickness =	$T_{TMA} := 2.8$	in (User Input)
TMA Weight =	$WT_{TMA} := 11$	lbs (User Input)
Number of TMAs =	$N_{TMA} := 1$	(User Input)

Wind Load (Front)

Surface Area for One TMA=	$SA_{TMA} := \frac{L_{TMA} \cdot W_{TMA}}{144} = 0.3$	sf
TMA Projected Surface Area =	$A_{TMA} := SA_{TMA} \cdot N_{TMA} = 0.3$	sf
Total TMA Wind Force =	$F_{TMA} := F \cdot A_{TMA} = 15$	lbs

Wind Load (Side)

Surface Area for One TMA =	$SA_{TMA} := \frac{L_{TMA} \cdot T_{TMA}}{144} = 0.1$	sf
TMA Projected Surface Area =	$A_{TMA} := SA_{TMA} \cdot N_{TMA} = 0.1$	sf
Total TMA Wind Force =	$F_{TMA} := F \cdot A_{TMA} = 7$	lbs

Gravity Load (without ice)

Weight of All TMA=	$WT_{TMA} \cdot N_{TMA} = 11$	lbs
---------------------------	---	------------

Design Wind Load on Other Structures:

(Based on IBC 2015, CSBC 2018 and ASCE 7-10)

Wind Speed =	V := 120	mph	(User Input)	(CSBC Appendix-N)
Risk Category =	BC := I1		(User Input)	(IBC Table 1604.5)
Exposure Category =	Exp := B		(User Input)	
Height Above Grade =	Z := 41.33	ft	(User Input)	
Structure Type =	Structuretype := Square_Chimney		(User Input)	
Structure Height =	Height := 4.5	ft	(User Input)	
Horizontal Dimension of Structure =	Width := 7.0	ft	(User Input)	

Terrain Exposure Constants:

Nominal Height of the Atmospheric Boundary Layer =

$$z_g := \begin{cases} \text{if Exp} = \text{B} \\ \quad \parallel \\ \quad 1200 \\ \text{if Exp} = \text{C} \\ \quad \parallel \\ \quad 900 \\ \text{if Exp} = \text{D} \\ \quad \parallel \\ \quad 700 \end{cases} = 1.2 \cdot 10^3 \quad \text{(Table 26.9-1)}$$

3-Sec Gust Speed Power Law Exponent =

$$\alpha := \begin{cases} \text{if Exp} = \text{B} \\ \quad \parallel \\ \quad 7 \\ \text{if Exp} = \text{C} \\ \quad \parallel \\ \quad 9.5 \\ \text{if Exp} = \text{D} \\ \quad \parallel \\ \quad 11.5 \end{cases} = 7 \quad \text{(Table 26.9-1)}$$

Integral Length Scale Factor =

$$l := \begin{cases} \text{if Exp} = \text{B} \\ \quad \parallel \\ \quad 320 \\ \text{if Exp} = \text{C} \\ \quad \parallel \\ \quad 500 \\ \text{if Exp} = \text{D} \\ \quad \parallel \\ \quad 650 \end{cases} = 320 \quad \text{(Table 26.9-1)}$$

Integral Length Scale Power Law Exponent =

$$E := \begin{cases} \text{if Exp} = \text{B} \\ \quad \parallel \\ \quad \frac{1}{3} \\ \text{if Exp} = \text{C} \\ \quad \parallel \\ \quad \frac{1}{5} \\ \text{if Exp} = \text{D} \\ \quad \parallel \\ \quad \frac{1}{8} \end{cases} = 0.333 \quad \text{(Table 26.9-1)}$$

Turbulence Intensity Factor =

$$c := \begin{cases} \text{if Exp} = \text{B} \\ \quad \parallel \\ \quad 0.3 \\ \text{if Exp} = \text{C} \\ \quad \parallel \\ \quad 0.2 \\ \text{if Exp} = \text{D} \\ \quad \parallel \\ \quad 0.15 \end{cases} = 0.3 \quad \text{(Table 26.9-1)}$$

Exposure Constant = $Z_{min} := \begin{cases} \text{if Exp} = \text{B} \\ 30 \\ \text{if Exp} = \text{C} \\ 15 \\ \text{if Exp} = \text{D} \\ 7 \end{cases} = 30$ (Table 26.9-1)

Exposure Coefficient = $K_z := \begin{cases} \text{if } 15 \leq Z \leq z_g \\ 2.01 \cdot \left(\frac{Z}{z_g}\right)^{\left(\frac{2}{\alpha}\right)} \\ \text{if } Z < 15 \\ 2.01 \cdot \left(\frac{15}{z_g}\right)^{\left(\frac{2}{\alpha}\right)} \end{cases} = 0.77$ (Table 29.3-1)

Topographic Factor = $K_{zt} := 1$ (Eq. 26.8-2)

Wind Directionality Factor = $K_d := 0.9$ (Table 26.6-1)

Velocity Pressure = $q_z := 0.00256 \cdot K_z \cdot K_{zt} \cdot K_d \cdot V^2 = 25.47$ (Eq. 29.3-1)

Peak Factor for Background Response = $g_O := 3.4$ (Sec 26.9.4)

Peak Factor for Wind Response = $g_v := 3.4$ (Sec 26.9.4)

Equivalent Height of Structure = $z := \begin{cases} \text{if } Z_{min} > 0.6 \cdot \text{Height} \\ Z_{min} \\ \text{else} \\ 0.6 \cdot \text{Height} \end{cases} = 30$ (Sec 26.9.4)

Intensity of Turbulence = $I_z := c \cdot \left(\frac{33}{z}\right)^{\left(\frac{1}{6}\right)} = 0.305$ (Eq. 26.9-7)

Integral Length Scale of Turbulence = $L_z := 1 \cdot \left(\frac{z}{33}\right)^E = 309.993$ (Eq. 26.9-9)

Background Response Factor = $Q := \sqrt{\frac{1}{1 + 0.63 \cdot \left(\frac{\text{Width} + \text{Height}}{L_z}\right)^{0.63}}} = 0.963$ (Eq. 26.9-8)

Gust Response Factor = $G := 0.925 \cdot \left(\frac{1 + 1.7 \cdot g_O \cdot I_z \cdot Q}{1 + 1.7 \cdot g_v \cdot I_z}\right) = 0.903$ (Eq. 26.9-6)

Force Coefficient = $GC_r := 1.9$ (Section 29.5-1)

Wind Force = $F := q_z \cdot GC_r = 48$ psf

Development of Wind on Equipment

Equipment Data:

Equipment Model =	Ericsson B160 Battery Cabinet	
Equipment Shape =	Flat	(User Input)
Equipment Height =	$L_{Eq} := 63$	in (User Input)
Equipment Width =	$W_{Eq} := 26$	in (User Input)
Equipment Thickness =	$T_{Eq} := 26$	in (User Input)
Equipment Weight =	$WT_{Eq} := 1883$	lbs (User Input)
Equipment Bearing Points =	$N_{Bp} := 4$	(User Input)
Number of Equipment =	$N_{Eq} := 1$	(User Input)

Wind Load (Front)

Surface Area for One Equipment =	$SA_{Eq} := \frac{L_{Eq} \cdot W_{Eq}}{144} = 11.4$	sf
Equipment Projected Surface Area =	$A_{Eq} := SA_{Eq} \cdot N_{Eq} = 11.4$	sf

Total Equipment Wind Force =

$$F_{Eq} := \frac{F \cdot A_{Eq} \cdot \left(\frac{L_{Eq}}{12}\right)}{\frac{T_{Eq}}{12} \cdot 2} = 333 \quad \text{lbs}$$

Total Equipment Shear Wind Force =

$$F_{Eq} := \frac{F \cdot A_{Eq}}{N_{Bp}} = 138 \quad \text{lbs}$$

Wind Load (Side)

Surface Area for One Equipment =	$SA_{Eq} := \frac{L_{Eq} \cdot T_{Eq}}{144} = 11.4$	sf
Equipment Projected Surface Area =	$A_{Eq} := SA_{Eq} \cdot N_{Eq} = 11.4$	sf

Total Equipment Wind Force =

$$F_{Eq} := \frac{F \cdot A_{Eq} \cdot \left(\frac{L_{Eq}}{12}\right)}{\frac{W_{Eq}}{12} \cdot 2} = 333 \quad \text{lbs}$$

Total Equipment Shear Wind Force =

$$F_{Eq} := \frac{F \cdot A_{Eq}}{N_{Bp}} = 138 \quad \text{lbs}$$

Gravity Load (without ice)

Weight of All Equipments =

$$\frac{WT_{Eq}}{N_{Bp}} = 471 \quad \text{lbs}$$

Development of Wind on Equipment

Equipment Data:

Equipment Model =	Ericsson 6160 Cabinet	
Equipment Shape =	Flat	(User Input)
Equipment Height =	$L_{Eq} := 63$	in (User Input)
Equipment Width =	$W_{Eq} := 26$	in (User Input)
Equipment Thickness =	$T_{Eq} := 26$	in (User Input)
Equipment Weight =	$WT_{Eq} := 1200$	lbs (User Input)
Equipment Bearing Points =	$N_{Bp} := 4$	(User Input)
Number of Equipment =	$N_{Eq} := 1$	(User Input)

Wind Load (Front)

Surface Area for One Equipment =	$SA_{Eq} := \frac{L_{Eq} \cdot W_{Eq}}{144} = 11.4$	sf
Equipment Projected Surface Area =	$A_{Eq} := SA_{Eq} \cdot N_{Eq} = 11.4$	sf

Total Equipment Wind Force =

$$F_{Eq} := \frac{F \cdot A_{Eq} \cdot \left(\frac{L_{Eq}}{12}\right)}{\frac{T_{Eq}}{12} \cdot 2} = 333 \quad \text{lbs}$$

Total Equipment Shear Wind Force =

$$F_{Eq} := \frac{F \cdot A_{Eq}}{N_{Bp}} = 138 \quad \text{lbs}$$

Wind Load (Side)

Surface Area for One Equipment =	$SA_{Eq} := \frac{L_{Eq} \cdot T_{Eq}}{144} = 11.4$	sf
Equipment Projected Surface Area =	$A_{Eq} := SA_{Eq} \cdot N_{Eq} = 11.4$	sf

Total Equipment Wind Force =

$$F_{Eq} := \frac{F \cdot A_{Eq} \cdot \left(\frac{L_{Eq}}{12}\right)}{\frac{W_{Eq}}{12} \cdot 2} = 333 \quad \text{lbs}$$

Total Equipment Shear Wind Force =

$$F_{Eq} := \frac{F \cdot A_{Eq}}{N_{Bp}} = 138 \quad \text{lbs}$$

Gravity Load (without ice)

Weight of All Equipments =

$$\frac{WT_{Eq}}{N_{Bp}} = 300 \quad \text{lbs}$$

Development of Wind on Equipment

Equipment Data:

Equipment Model =	Generac 25 kW Natural Gas Generator		
Equipment Shape =	Flat		(User Input)
Equipment Height =	$L_{Eq} := 53.5$	in	(User Input)
Equipment Width =	$W_{Eq} := 35.0$	in	(User Input)
Equipment Thickness =	$T_{Eq} := 84.2$	in	(User Input)
Equipment Weight =	$WT_{Eq} := 1265$	lbs	(User Input)
Number of Equipments =	$N_{Eq} := 1$		(User Input)
Equipment Bearing Points =	$n_{bp} := 4$		(User Input)

Wind Load (Front)

Surface Area for One Equipment =	$SA_{Eq} := \frac{L_{Eq} \cdot W_{Eq}}{144} = 13$	sf
Equipment Projected Surface Area =	$A_{Eq} := SA_{Eq} \cdot N_{Eq} = 13$	sf

Total Equipment Wind Force =

$$F_{Eq} := \frac{F \cdot A_{Eq} \cdot \left(\frac{L_{Eq}}{12}\right)}{\frac{T_{Eq}}{12} \cdot 2} = 100 \quad \text{lbs}$$

Equipment Shear Wind Force =

$$F_{EqS} := \frac{F \cdot A_{Eq}}{n_{bp}} = 157 \quad \text{lbs}$$

Wind Load (Side)

Surface Area for One Equipment =	$SA_{Eq} := \frac{L_{Eq} \cdot T_{Eq}}{144} = 31.3$	sf
Equipment Projected Surface Area =	$A_{Eq} := SA_{Eq} \cdot N_{Eq} = 31.3$	sf

Total Equipment Wind Force =

$$F_{Eq} := \frac{F \cdot A_{Eq} \cdot \left(\frac{L_{Eq}}{12}\right)}{\frac{W_{Eq}}{12} \cdot 2} = 579 \quad \text{lbs}$$

Equipment Shear Wind Force =

$$F_{EqS} := \frac{F \cdot A_{Eq}}{n_{bp}} = 378 \quad \text{lbs}$$

Gravity Load (without ice)

Weight of All Equipments =

$$\frac{WT_{Eq}}{n_{bp}} = 316.25 \quad \text{lbs}$$

Development of Wind on Equipment

Equipment Data:

Equipment Model =	Automatic Transfer Switch	
Equipment Shape =	Flat	(User Input)
Equipment Height =	$L_{Eq} := 36$	in (User Input)
Equipment Width =	$W_{Eq} := 24$	in (User Input)
Equipment Thickness =	$T_{Eq} := 11.29$	in (User Input)
Equipment Weight =	$WT_{Eq} := 500$	lbs (User Input)
Number of Equipments =	$N_{Eq} := 1$	(User Input)

Wind Load (Front)

Surface Area for One Equipment =	$SA_{Eq} := \frac{L_{Eq} \cdot W_{Eq}}{144} = 6$	sf
Equipment Projected Surface Area =	$A_{Eq} := SA_{Eq} \cdot N_{Eq} = 6$	sf
Total Equipment Wind Force =	$F_{Eq} := F \cdot A_{Eq} = 290$	lbs

Wind Load (Side)

Surface Area for One Equipment =	$SA_{Eq} := \frac{L_{Eq} \cdot T_{Eq}}{144} = 2.8$	sf
Equipment Projected Surface Area =	$A_{Eq} := SA_{Eq} \cdot N_{Eq} = 2.8$	sf
Total Equipment Wind Force =	$F_{Eq} := F \cdot A_{Eq} = 137$	lbs

Gravity Load (without ice)

Weight of All Equipments =	$WT_{Eq} = 500$	lbs
-----------------------------------	-----------------------------------	------------

Development of Wind on Equipment

Equipment Data:

Equipment Model =	RBS 6131	
Equipment Shape =	Flat	(User Input)
Equipment Height =	$L_{Eq} := 63.62$	in (User Input)
Equipment Width =	$W_{Eq} := 51.19$	in (User Input)
Equipment Thickness =	$T_{Eq} := 36.38$	in (User Input)
Equipment Weight =	$WT_{Eq} := 2593$	lbs (User Input)
Number of Equipments =	$N_{Eq} := 1$	(User Input)
Equipment Bearing Points =	$n_{bp} := 4$	(User Input)

Wind Load (Front)

Surface Area for One Equipment =	$SA_{Eq} := \frac{L_{Eq} \cdot W_{Eq}}{144} = 22.6$	sf
Equipment Projected Surface Area =	$A_{Eq} := SA_{Eq} \cdot N_{Eq} = 22.6$	sf

Total Equipment Wind Force =

$$F_{Eq} := \frac{F \cdot A_{Eq} \cdot \left(\frac{L_{Eq}}{12}\right)}{\frac{T_{Eq}}{12} \cdot 2} = 479 \quad \text{lbs}$$

Equipment Shear Wind Force =

$$F_{EqS} := \frac{F \cdot A_{Eq}}{n_{bp}} = 274 \quad \text{lbs}$$

Wind Load (Side)

Surface Area for One Equipment =	$SA_{Eq} := \frac{L_{Eq} \cdot T_{Eq}}{144} = 16.1$	sf
Equipment Projected Surface Area =	$A_{Eq} := SA_{Eq} \cdot N_{Eq} = 16.1$	sf

Total Equipment Wind Force =

$$F_{Eq} := \frac{F \cdot A_{Eq} \cdot \left(\frac{L_{Eq}}{12}\right)}{\frac{W_{Eq}}{12} \cdot 2} = 242 \quad \text{lbs}$$

Equipment Shear Wind Force =

$$F_{EqS} := \frac{F \cdot A_{Eq}}{n_{bp}} = 194 \quad \text{lbs}$$

Gravity Load (without ice)

Weight of All Equipments =

$$\frac{WT_{Eq}}{n_{bp}} = 648.25 \quad \text{lbs}$$

Development of Wind on Equipments

Equipment Data:

Equipment Model =	T-Mobile Transformer	
Equipment Shape =	Flat	(User Input)
Equipment Height =	$L_{Eq} := 32$	in (User Input)
Equipment Width =	$W_{Eq} := 17$	in (User Input)
Equipment Thickness =	$T_{Eq} := 26.5$	in (User Input)
Equipment Weight =	$WT_{Eq} := 405$	lbs (User Input)
Number of Equipments =	$N_{Eq} := 1$	(User Input)
Equipment Bearing Points=	$n_{bp} := 4$	(User Input)

Wind Load (Front)

Surface Area for One Equipment =	$SA_{Eq} := \frac{L_{Eq} \cdot W_{Eq}}{144} = 3.8$	sf
Equipment Projected Surface Area =	$A_{Eq} := SA_{Eq} \cdot N_{Eq} = 3.8$	sf
Total Equipment Wind Force =	$F_{Eq} := \frac{F \cdot A_{Eq} \cdot \left(\frac{L_{Eq}}{12}\right)}{\frac{T_{Eq} \cdot 2}{12}} = 55$	lbs
Equipment Shear Wind Force =	$F_{EqS} := \frac{F \cdot A_{Eq}}{n_{bp}} = 46$	lbs

Wind Load (Side)

Surface Area for One Equipment =	$SA_{Eq} := \frac{L_{Eq} \cdot T_{Eq}}{144} = 5.9$	sf
Equipment Projected Surface Area =	$A_{Eq} := SA_{Eq} \cdot N_{Eq} = 5.9$	sf
Total Equipment Wind Force =	$F_{Eq} := \frac{F \cdot A_{Eq} \cdot \left(\frac{L_{Eq}}{12}\right)}{\frac{W_{Eq} \cdot 2}{12}} = 134$	lbs
Equipment Shear Wind Force =	$F_{EqS} := \frac{F \cdot A_{Eq}}{n_{bp}} = 71$	lbs

Gravity Load (without ice)

Weight of All Equipments =	$\frac{WT_{Eq}}{n_{bp}} = 101.25$	lbs
-----------------------------------	-----------------------------------	------------

Development of Wind on Equipment

Equipment Data:

Equipment Model =	T-Mobile Telco Box		
Equipment Shape =	Flat		(User Input)
Equipment Height =	$L_{Eq} := 33$	in	(User Input)
Equipment Width =	$W_{Eq} := 30$	in	(User Input)
Equipment Thickness =	$T_{Eq} := 13$	in	(User Input)
Equipment Weight =	$WT_{Eq} := 200$	lbs	(User Input)
Number of Equipments =	$N_{Eq} := 1$		(User Input)

Wind Load (Front)

Surface Area for One Equipment =	$SA_{Eq} := \frac{L_{Eq} \cdot W_{Eq}}{144} = 6.9$	sf
Equipment Projected Surface Area =	$A_{Eq} := SA_{Eq} \cdot N_{Eq} = 6.9$	sf
Total Equipment Wind Force =	$F_{Eq} := F \cdot A_{Eq} = 333$	lbs

Wind Load (Side)

Surface Area for One Equipment =	$SA_{Eq} := \frac{L_{Eq} \cdot T_{Eq}}{144} = 3$	sf
Equipment Projected Surface Area =	$A_{Eq} := SA_{Eq} \cdot N_{Eq} = 3$	sf
Total Equipment Wind Force =	$F_{Eq} := F \cdot A_{Eq} = 144$	lbs

Gravity Load (without ice)

Weight of All Equipments =	$WT_{Eq} = 200$	lbs
-----------------------------------	-----------------------------------	------------

Development of Wind on Equipment

Equipment Data:

Equipment Model =	T-Mobile Existing Electric Panel	
Equipment Shape =	Flat	(User Input)
Equipment Height =	$L_{Eq} := 28$	in (User Input)
Equipment Width =	$W_{Eq} := 15$	in (User Input)
Equipment Thickness =	$T_{Eq} := 4$	in (User Input)
Equipment Weight =	$WT_{Eq} := 150$	lbs (User Input)
Number of Equipments =	$N_{Eq} := 1$	(User Input)

Wind Load (Front)

Surface Area for One Equipment =	$SA_{Eq} := \frac{L_{Eq} \cdot W_{Eq}}{144} = 2.9$	sf
Equipment Projected Surface Area =	$A_{Eq} := SA_{Eq} \cdot N_{Eq} = 2.9$	sf
Total Equipment Wind Force =	$F_{Eq} := F \cdot A_{Eq} = 141$	lbs

Wind Load (Side)

Surface Area for One Equipment =	$SA_{Eq} := \frac{L_{Eq} \cdot T_{Eq}}{144} = 0.8$	sf
Equipment Projected Surface Area =	$A_{Eq} := SA_{Eq} \cdot N_{Eq} = 0.8$	sf
Total Equipment Wind Force =	$F_{Eq} := F \cdot A_{Eq} = 38$	lbs

Gravity Load (without ice)

Weight of All Equipments =	$WT_{Eq} = 150$	lbs
-----------------------------------	-----------------------------------	------------

Development of Wind on Equipment

Equipment Data:

Equipment Model =	T-Mobile Existing Transformer Switch		
Equipment Shape =	Flat		(User Input)
Equipment Height =	$L_{Eq} := 17$	in	(User Input)
Equipment Width =	$W_{Eq} := 10$	in	(User Input)
Equipment Thickness =	$T_{Eq} := 5$	in	(User Input)
Equipment Weight =	$WT_{Eq} := 50$	lbs	(User Input)
Number of Equipments =	$N_{Eq} := 1$		(User Input)

Wind Load (Front)



Surface Area for One Equipment =	$SA_{Eq} := \frac{L_{Eq} \cdot W_{Eq}}{144} = 1.2$	sf
Equipment Projected Surface Area =	$A_{Eq} := SA_{Eq} \cdot N_{Eq} = 1.2$	sf
Total Equipment Wind Force =	$F_{Eq} := F \cdot A_{Eq} = 57$	lbs

Wind Load (Side)

Surface Area for One Equipment =	$SA_{Eq} := \frac{L_{Eq} \cdot T_{Eq}}{144} = 0.6$	sf
Equipment Projected Surface Area =	$A_{Eq} := SA_{Eq} \cdot N_{Eq} = 0.6$	sf
Total Equipment Wind Force =	$F_{Eq} := F \cdot A_{Eq} = 29$	lbs

Gravity Load (without ice)

Weight of All Equipments =	$WT_{Eq} = 50$	lbs
-----------------------------------	----------------------------------	------------



Member Code Checks Displayed (Enveloped)
Envelope Only Solution

Centek
FJP
20074.67

CT11334A_AMA
Member Unity Check

Sept 2, 2020 at 12:04 PM
CT11334A_AMA.R3D

Design Wind Load on Water Tanks:

Wind Speed = $V := 120$ mph (User Input)
 Exposure Category = $Exp := C$ (User Input)
 Importance Factor = $I := 1.15$ (User Input) (AWWA D100-05 Sec. 3.1.4)

Component = Tank Roof (User Input)
 Type of Surface = TOS := DC (User Input) (AWWA D100-05 Table 2)
 Height Above Grade = $Z := 100$ ft (User Input)
 Area = $A := 72$ sf (User Input)
 Distance from Bot Tank to Centroid = $D_1 := 60$ ft (User Input)

Nominal Height of the Atmospheric Boundary Layer = $z_g := \begin{cases} 1200 & \text{if } Exp = B \\ 900 & \text{if } Exp = C \\ 700 & \text{if } Exp = D \end{cases} = 900$

3-Sec Gust Speed Power Law Exponent = $\alpha := \begin{cases} 7 & \text{if } Exp = B \\ 9.5 & \text{if } Exp = C \\ 11.5 & \text{if } Exp = D \end{cases} = 9.5$

Exposure Coefficient = $K_z := \begin{cases} 2.01 \left(\frac{Z}{z_g}\right)^{\left(\frac{2}{\alpha}\right)} & \text{if } 15 \leq Z \leq z_g \\ 2.01 \left(\frac{15}{z_g}\right)^{\left(\frac{2}{\alpha}\right)} & \text{if } Z < 15 \end{cases} = 1.27$

Velocity Pressure = $q_z := 0.00256 \cdot K_z \cdot V^2 \cdot I = 53.65$ (AWWA D100-05 Eq. 3-2)

Force Coefficient = $C_f = 0.5$ (AWWA D100-05 Table 2)

Gust Effect Factor = $G := 1.0$ (AWWA D100-05 Sec. 3.1.4)

Wind Pressure = $P_w := q_z \cdot G \cdot C_f = 27$ psf (AWWA D100-05 Eq. 3.1)

Wind Force = $F_1 := P_w \cdot A = 1932$ lbs

Overtuning Moment @ Base = $M_1 := F_1 \cdot D_1 = 115893$ ft-lbs

Component =	TankWall	(User Input)	
Type of Surface =	TOS := Cyl	(User Input)	(AWWA D100-05 Table 2)
Height Above Grade =	Z := 92 ft	(User Input)	
Area =	A := 398 sf	(User Input)	
Distance from Bot Tank to Centroid =	D ₂ := 53 ft		
Nominal Height of the Atmospheric Boundary Layer =	$z_g := \begin{cases} 1200 & \text{if Exp} = B = 900 \\ 900 & \text{if Exp} = C \\ 700 & \text{if Exp} = D \end{cases}$		
3-Sec Gust Speed Power Law Exponent =	$\alpha := \begin{cases} 7 & \text{if Exp} = B = 9.5 \\ 9.5 & \text{if Exp} = C \\ 11.5 & \text{if Exp} = D \end{cases}$		
Exposure Coefficient =	$K_z := \begin{cases} 2.01 \left(\frac{Z}{z_g} \right)^{\left(\frac{2}{\alpha} \right)} & \text{if } 15 \leq Z \leq z_g = 1.24 \\ 2.01 \left(\frac{15}{z_g} \right)^{\left(\frac{2}{\alpha} \right)} & \text{if } Z < 15 \end{cases}$		
Velocity Pressure =	q _z := 0.00256 · K _z · V ² · I = 52.72		(AWWA D100-05 Eq. 3-2)
Force Coefficient =	C _f = 0.6		(AWWA D100-05 Table 2)
Gust Effect Factor =	G := 1.0		(AWWA D100-05 Sec. 3.1.4)
Wind Pressure =	P _w := q _z · G · C _f = 32	psf	(AWWA D100-05 Eq. 3.1)
Wind Force =	F ₂ := P _w · A = 12590	lbs	
Overtuning Moment @ Base =	M ₂ := F ₂ · D ₂ = 667252	ft-lbs	

Component =	Tank Bottom	(User Input)	
Type of Surface =	TOS := DC	(User Input)	(AWWA D100-05 Table 2)
Height Above Grade =	Z := 90 ft	(User Input)	
Area =	A := 92 sf	(User Input)	
Distance from Bot Tank to Centroid =	D ₃ := 43 ft		
Nominal Height of the Atmospheric Boundary Layer =	$z_g := \begin{cases} 1200 & \text{if Exp} = \text{B} = 900 \\ 900 & \text{if Exp} = \text{C} \\ 700 & \text{if Exp} = \text{D} \end{cases}$		
3-Sec Gust Speed Power Law Exponent =	$\alpha := \begin{cases} 7 & \text{if Exp} = \text{B} = 9.5 \\ 9.5 & \text{if Exp} = \text{C} \\ 11.5 & \text{if Exp} = \text{D} \end{cases}$		
Exposure Coefficient =	$K_z := \begin{cases} 2.01 \left(\frac{Z}{z_g} \right)^{\left(\frac{2}{\alpha} \right)} & \text{if } 15 \leq Z \leq z_g = 1.24 \\ 2.01 \left(\frac{15}{z_g} \right)^{\left(\frac{2}{\alpha} \right)} & \text{if } Z < 15 \end{cases}$		
Velocity Pressure =	q _z := 0.00256 · K _z · V ² · I = 52.48		(AWWA D100-05 Eq. 3-2)
Force Coefficient =	C _f = 0.5		(AWWA D100-05 Table 2)
Gust Effect Factor =	G := 1.0		(AWWA D100-05 Sec. 3.1.4)
Wind Pressure =	P _w := q _z · G · C _f = 26	psf	(AWWA D100-05 Eq. 3.1)
Wind Force =	F ₃ := P _w · A = 2414	lbs	
Overturing Moment @ Base =	M ₃ := F ₃ · D ₃ = 103800	ft-lbs	

<u>Component</u> =	Tank Leg	(User Input)	
Type of Surface =	TOS := Flat	(User Input)	(AWWA D100-05 Table 2)
Height Above Grade =	Z := 65 ft	(User Input)	
Area =	A := 1.5 $\frac{\text{sf}}{\text{ft}}$	(User Input)	
Distance from Bot Tank to Centroid =	D ₄ := 20 ft		
Leg Height =	H _{Leg} := 40 ft		
Nominal Height of the Atmospheric Boundary Layer =	$z_g := \begin{cases} 1200 & \text{if Exp} = \text{B} = 900 \\ 900 & \text{if Exp} = \text{C} \\ 700 & \text{if Exp} = \text{D} \end{cases}$		
3-Sec Gust Speed Power Law Exponent =	$\alpha := \begin{cases} 7 & \text{if Exp} = \text{B} = 9.5 \\ 9.5 & \text{if Exp} = \text{C} \\ 11.5 & \text{if Exp} = \text{D} \end{cases}$		
Exposure Coefficient =	$K_z := \begin{cases} 2.01 \left(\frac{Z}{z_g} \right)^{\left(\frac{2}{\alpha} \right)} & \text{if } 15 \leq Z \leq z_g = 1.16 \\ 2.01 \left(\frac{15}{z_g} \right)^{\left(\frac{2}{\alpha} \right)} & \text{if } Z < 15 \end{cases}$		
Velocity Pressure =	q _z := 0.00256 · K _z · V ² · I = 49		(AWWA D100-05 Eq. 3-2)
Force Coefficient =	C _f = 1		(AWWA D100-05 Table 2)
Gust Effect Factor =	G := 1.0		(AWWA D100-05 Sec. 3.1.4)
Wind Pressure =	P _w := q _z · G · C _f = 49	psf	(AWWA D100-05 Eq. 3.1)
Wind Force Top =	F ₄ := P _w · A = 74	lb/ft	
Overtuning Moment @ Base =	M ₄ := F ₄ · H _{Leg} · D ₄ = 58803	ft-lbs	

<u>Component</u> =	Tank Steel Riser	(User Input)	
Type of Surface =	TOS := Cyl	(User Input)	(AWWA D100-05 Table 2)
Height Above Grade =	Z := 100 ft	(User Input)	
Area =	A := 3 $\frac{\text{sf}}{\text{ft}}$	(User Input)	
Distance from Bot Tank to Centroid =	D ₅ := 20 ft		
Nominal Height of the Atmospheric Boundary Layer =	$z_g := \begin{cases} 1200 & \text{if Exp} = \text{B} = 900 \\ 900 & \text{if Exp} = \text{C} \\ 700 & \text{if Exp} = \text{D} \end{cases}$		
3-Sec Gust Speed Power Law Exponent =	$\alpha := \begin{cases} 7 & \text{if Exp} = \text{B} = 9.5 \\ 9.5 & \text{if Exp} = \text{C} \\ 11.5 & \text{if Exp} = \text{D} \end{cases}$		
Exposure Coefficient =	$K_z := \begin{cases} 2.01 \left(\frac{Z}{z_g} \right)^{\left(\frac{2}{\alpha} \right)} & \text{if } 15 \leq Z \leq z_g = 1.27 \\ 2.01 \left(\frac{15}{z_g} \right)^{\left(\frac{2}{\alpha} \right)} & \text{if } Z < 15 \end{cases}$		
Velocity Pressure =	q _z := 0.00256 · K _z · V ² · 1 = 53.65		(AWWA D100-05 Eq. 3-2)
Force Coefficient =	C _f = 0.6		(AWWA D100-05 Table 2)
Gust Effect Factor =	G := 1.0		(AWWA D100-05 Sec. 3.1.4)
Wind Pressure =	P _w := q _z · G · C _f = 32	psf	(AWWA D100-05 Eq. 3.1)
Wind Force Top =	F ₅ := P _w · A = 97	lb/ft	
Overtuning Moment @ Base =	M ₅ := F ₅ · H _{Leg} · D ₅ = 77262	ft·lbs	

<u>Component</u> =	AT & T Equipment	(User Input)	
Type of Surface =	TOS := Flat	(User Input)	(AWWA D100-05 Table 2)
Height Above Grade =	Z := 100 ft	(User Input)	
Area =	A := 34 sf	(User Input)	
	(Assumes one sector of equipment consisting of (3) antennas and (4) RRHS)		
Distance from Bot Tank to Centroid =	D ₆ := 60 ft		
Nominal Height of the Atmospheric Boundary Layer =	$z_g := \begin{cases} 1200 & \text{if Exp} = B = 900 \\ 900 & \text{if Exp} = C \\ 700 & \text{if Exp} = D \end{cases}$		
3-Sec Gust Speed Power Law Exponent =	$\alpha := \begin{cases} 7 & \text{if Exp} = B = 9.5 \\ 9.5 & \text{if Exp} = C \\ 11.5 & \text{if Exp} = D \end{cases}$		
Exposure Coefficient =	$K_z := \begin{cases} 2.01 \left(\frac{Z}{z_g} \right)^{\left(\frac{2}{\alpha} \right)} & \text{if } 15 \leq Z \leq z_g = 1.27 \\ 2.01 \left(\frac{15}{z_g} \right)^{\left(\frac{2}{\alpha} \right)} & \text{if } Z < 15 \end{cases}$		
Velocity Pressure =	q _z := 0.00256 · K _z · V ² · I = 53.65		(AWWA D100-05 Eq. 3-2)
Force Coefficient =	C _f = 1		(AWWA D100-05 Table 2)
Gust Effect Factor =	G := 1.0		(AWWA D100-05 Sec. 3.1.4)
Wind Pressure =	P _w := q _z · G · C _f = 54	psf	(AWWA D100-05 Eq. 3.1)
Wind Force =	F ₆ := P _w · A = 1824	lb	
Overtuning Moment @ Base =	M ₆ := F ₆ · D ₆ = 109454	ft-lbs	

Component =	Sprint Equipment	(User Input)	
Type of Surface =	TOS := Flat	(User Input)	(AWWA D100-05 Table 2)
Height Above Grade =	Z := 93 ft	(User Input)	
Area =	A := 25 sf	(User Input)	
	(Assumes one sector of equipment consisting of (2) antennas and (3) RRHS)		
Distance from Bot Tank to Centroid =	D ₇ := 53 ft		
Nominal Height of the Atmospheric Boundary Layer =	$z_g := \begin{cases} 1200 & \text{if Exp} = B = 900 \\ 900 & \text{if Exp} = C \\ 700 & \text{if Exp} = D \end{cases}$		
3-Sec Gust Speed Power Law Exponent =	$\alpha := \begin{cases} 7 & \text{if Exp} = B = 9.5 \\ 9.5 & \text{if Exp} = C \\ 11.5 & \text{if Exp} = D \end{cases}$		
Exposure Coefficient =	$K_z := \begin{cases} 2.01 \left(\frac{Z}{z_g} \right)^{\left(\frac{2}{\alpha} \right)} & \text{if } 15 \leq Z \leq z_g = 1.25 \\ 2.01 \left(\frac{15}{z_g} \right)^{\left(\frac{2}{\alpha} \right)} & \text{if } Z < 15 \end{cases}$		
Velocity Pressure =	q _z := 0.00256 · K _z · V ² · I = 52.84		(AWWA D100-05 Eq. 3-2)
Force Coefficient =	C _f = 1		(AWWA D100-05 Table 2)
Gust Effect Factor =	G := 1.0		(AWWA D100-05 Sec. 3.1.4)
Wind Pressure =	P _w := q _z · G · C _f = 53	psf	(AWWA D100-05 Eq. 3.1)
Wind Force =	F ₇ := P _w · A = 1321	lb	
Overturing Moment @ Base =	M ₇ := F ₇ · D ₇ = 70014	ft-lbs	

Component =	T-Mobile Equipment	(User Input)	
Type of Surface =	TOS := Flat	(User Input)	(AWWA D100-05 Table 2)
Height Above Grade =	Z := 85 ft	(User Input)	
Area =	A := 30 sf	(User Input)	
	(Assumes one sector of equipment consisting of (3) antennas and (2) RRHS)		
Distance from Bot Tank to Centroid =	D _g := 45 ft		
Nominal Height of the Atmospheric Boundary Layer =	$z_g := \begin{cases} 1200 & \text{if Exp} = B = 900 \\ 900 & \text{if Exp} = C \\ 700 & \text{if Exp} = D \end{cases}$		
3-Sec Gust Speed Power Law Exponent =	$\alpha := \begin{cases} 7 & \text{if Exp} = B = 9.5 \\ 9.5 & \text{if Exp} = C \\ 11.5 & \text{if Exp} = D \end{cases}$		
Exposure Coefficient =	$K_Z := \begin{cases} 2.01 \left(\frac{Z}{z_g} \right)^{\left(\frac{2}{\alpha} \right)} & \text{if } 15 \leq Z \leq z_g = 1.22 \\ 2.01 \left(\frac{15}{z_g} \right)^{\left(\frac{2}{\alpha} \right)} & \text{if } Z < 15 \end{cases}$		
Velocity Pressure =	q _Z := 0.00256 · K _Z · V ² · I = 51.85		(AWWA D100-05 Eq. 3-2)
Force Coefficient =	C _f = 1		(AWWA D100-05 Table 2)
Gust Effect Factor =	G := 1.0		(AWWA D100-05 Sec. 3.1.4)
Wind Pressure =	P _w := q _Z · G · C _f = 52	psf	(AWWA D100-05 Eq. 3.1)
Wind Force =	F _g := P _w · A = 1555	lb	
Overturning Moment @ Base =	M _g := F _g · D _g = 69997	ft·lbs	

Component =	Cables	(User Input)	
Type of Surface =	TOS := Cyl	(User Input)	(AWWA D100-05 Table 2)
Height Above Grade =	Z := 50 ft	(User Input)	
Area =	A := 0.51 $\frac{\text{sf}}{\text{ft}}$	(User Input)	
	(Three 1-5/8" dia cable exposed Typ. of 2 legs)		
Distance from Bot Tank to Centroid =	D _g := 20 ft		
Nominal Height of the Atmospheric Boundary Layer =	z _g := $\begin{cases} 1200 & \text{if Exp} = \text{B} = 900 \\ 900 & \text{if Exp} = \text{C} \\ 700 & \text{if Exp} = \text{D} \end{cases}$		(ACSE 7-02 Table 6-2)
3-Sec Gust Speed Power Law Exponent =	α := $\begin{cases} 7 & \text{if Exp} = \text{B} = 9.5 \\ 9.5 & \text{if Exp} = \text{C} \\ 11.5 & \text{if Exp} = \text{D} \end{cases}$		(ACSE 7-02 Table 6-2)
Exposure Coefficient =	K _Z := $\begin{cases} 2.01 \left(\frac{Z}{z_g}\right)^{\left(\frac{2}{\alpha}\right)} & \text{if } 15 \leq Z \leq z_g = 1.09 \\ 2.01 \left(\frac{15}{z_g}\right)^{\left(\frac{2}{\alpha}\right)} & \text{if } Z < 15 \end{cases}$		(ACSE 7-02 Table 6-3)
Velocity Pressure =	q _Z := 0.00256 · K _Z · V ² · I = 46.37		(AWWA D100-05 Eq. 3-2)
Force Coefficient =	C _f = 0.6		(AWWA D100-05 Table 2)
Gust Effect Factor =	G := 1.0		(AWWA D100-05 Sec. 3.1.4)
Wind Pressure =	P _w := q _Z · G · C _f = 28	psf	(AWWA D100-05 Eq. 3.1)
Wind Force =	F _g := P _w · A = 14	lb/ft	
Overtuning Moment @ Base =	M _g := F _g · H _{Leg} · D _g · 2 = 22702	ft-lbs	

Total Overtuning Moment = $M_{ot} := M_1 + M_2 + M_3 + M_4 + M_5 + M_6 + M_7 + M_8 + M_9 = 1295177$ ft-lbs

Weights:

Weight of Water =	$W_{water} := 60000 \cdot gal \cdot 62.4 \cdot pcf = 500500 \text{ lb}$	Assumed 60,000 Tank
Weight of Tank Shell =	$W_{shell} := 25000 \cdot \text{lb}$	Assumed 1/4" Thick Plate
Weight of Tank Leg =	$W_{Leg} := 19.57 \cdot in^2 \cdot .490 \cdot pcf \cdot H_{Leg} \cdot ft \cdot 4 = 10655 \text{ lb}$	
Weight of Bracing =	$W_{bracing} := 3000 \cdot \text{lb}$	
Weight of Catwalk =	$W_{catwalk} := 1250 \cdot \text{lb}$	
Weight of Misc. =	$W_{misc} := 10000 \cdot \text{lb}$	
Weight of AT & T =	$W_{ATT} := 2200 \cdot \text{lb}$	
Weight of Sprt =	$W_{Sprt} := 1500 \cdot \text{lb}$	
Weight of TMO =	$W_{TMO} := 2000 \cdot \text{lb}$	


Total Weight =

$W_{tot} := W_{water} + W_{shell} + W_{Leg} + W_{bracing} + W_{catwalk} + W_{misc} + W_{ATT} + W_{Sprt} + W_{TMO} = 556105 \text{ lb}$

Member Stress Check:

(Based on AWWAD100-05)

Component =	Tank Leg	(User Input)	
Number of Legs =	$N_{Leg} := 4$	(User Input)	
Leg Spread =	$D_{Leg} := 19.5\text{-ft}$	(User Input)	
Area =	$Area := 19.57\text{-in}^2$	(User Input)	
Section Modulus =	$S := 81.1\text{-in}^3$	(User Input)	
Unbraced Length =	$L := 41\text{-ft}$	(User Input)	
Radius of Gyration =	$r := 5.9\text{-in}$	(User Input)	
Effective Length Factor =	$K := 1$	(User Input)	
Modulus of Elasticity =	$E := 29000\text{-ksi}$	(User Input)	
Material Class =	$MC := 2$	(User Input)	(AWWA D100-05 Table 9)
Allowable Local Buckling Stress =	$F_L = 18\text{-ksi}$		(AWWA D100-05 Sec. 3.4.2)
Column Slenderness Ratio =	$C_c := \sqrt{\frac{2 \cdot \pi^2 \cdot E}{F_L}} = 126.099$		(AWWA D100-05 Eq. 3-10)
Slenderness Reduction Factor =	$K_{\phi} := \begin{cases} 1 - 0.5 \left[\left(\frac{K \cdot L}{C_c} \right)^2 \right] & \text{if } 25 < \frac{K \cdot L}{r} < C_c = 0.7813 \\ 0.5 \left(\frac{C_c}{\frac{K \cdot L}{r}} \right)^2 & \text{if } \frac{K \cdot L}{r} \geq C_c \\ 1.0 & \text{if } \frac{K \cdot L}{r} \leq 25 \end{cases}$		(AWWA D100-05 Eq. 3-7) (AWWA D100-05 Eq. 3-8) (AWWA D100-05 Eq. 3-9)
Allowable Compressive Stress Due to Axial Load =	$F_a := F_L \cdot K_{\phi} = 14.064\text{-ksi}$		(AWWA D100-05 Eq. 3-4)
Allowable Compressive Stress Due to Bending Moment =	$F_b := F_L = 18\text{-ksi}$		(AWWA D100-05 Eq. 3-5)
Axial Stress =	$f_a := \frac{W_{tot}}{Area \cdot N_{Leg}} + \frac{M_{ot} \cdot \text{ft} \cdot \text{lb}}{\left(\frac{D_{Leg}}{2} \right)^{2.0} \cdot Area} = 9.504\text{-ksi}$		
Combined Stress Check =	$Tank_Leg := \text{if} \left(\frac{f_a}{F_a} \leq 1.0, \text{"OK"}, \text{"Overstressed"} \right)$		(AWWA D100-05 Eq. 3-6)
	Tank_Leg = "OK"		
	$\frac{f_a}{F_a} = 67.6\%$		



Centek Engineering

FJP

20074.67

CT11334A
Member Framing


Oct 8, 2020 at 4:51 PM

CT11334A_Equipment Platform_1_Rev.1.r3d



Code Check
(Env)

Black	No Calc
Red	> 1.0
Yellow	90-1.0
Green	.75-.90
Cyan	.50-.75
Blue	0-.50



Member Code Checks Displayed (Enveloped)
Envelope Only Solution
Y-direction Reaction Units are k and k-ft (Enveloped)

Centek Engineering
FJP
20074.67

CT11334A
Platform Reactions to Host Building Columns

Oct 8, 2020 at 4:53 PM
CT11334A_Equipment Platform_1_Rev.1.r3d



Subject:	Existing Construction Floor by Floor Column Loads and Capacities		
Project:	CT11334A Stamford-3/Hope St		
Prepared:	10/8/2020	Revision:	2
		Job No.:	20074.67

Loads Carried by Interior Column D-4 Below Risa-3D Node N26

Summary of Floor Dead Loads		Summary of Roof Dead Loads	
Assume 8" concrete slab, ave. 16"Ø concrete columns, and 8'x8' drop panels	125	Assume 8" concrete slab, ave. 16"Ø concrete columns, and 8'x8' drop panels	125
Interior non-bearing partitions	10	Roofing	5
Finish floor and ceiling	5	Insulation	2
M/E/P	5	M/E/P	5
Subtotal Floor Dead Loads	145 psf	Subtotal Roof Dead Loads	137
Heavy Manufacturing Live Load	250 psf	Roof Live (Snow) Load	30
Area Tributary to Column: [(21.5 * (20.1) =	430 S.F.	Special Loading at Roof Level:	
		None	0 lbs
		None	0 lbs

Existing Building Dead and Live Loads							Existing Columns			Proposed Platform Total Loads			Results	Capacity
Floor (Roof)	Ref. Elev.	Area Trib. to Col.	Uniform Floor/Roof Loads (Lbs)			Accum. Total (Lbs)	Column Size	Column Area (S.I.)	Col. Cap. (Lbs)	Additional Load	% Increase Above Exist.	Accum. Total (Lbs)		
Roof Level		430	58,910	0	12,900	71,810	16"x16"	256	365,000	9,100	12.7%	80,910	Col. Okay	48.5%
7th Floor			0		0	71,810					0.0%	71,810	Col. N.G.	
6th Floor			0		0	71,810					0.0%	71,810	Col. N.G.	
5th Floor			0		0	71,810					0.0%	71,810	Col. N.G.	
4th Floor			0		0	71,810					0.0%	71,810	Col. N.G.	
3rd Floor		430	62,350		107,500	241,660	20"x20"	400	550,000	9,100	3.8%	250,760	Col. Okay	
2nd Floor		430	62,350		107,500	411,510	24"x24"	576	805,000	9,100	2.5%	377,610	Col. Okay	
1st Floor		430	62,350		107,500	581,360	28"x28"	784	1,085,000	9,100	1.8%	525,960	Col. Okay	
Totals			245,960	0	335,400	581,360								

Comments:

Floor and roof dead loads are based on field measurements.

Floor Live Loads used in calculations are provided in the building code. Live load reduction = 20% of accumulated floor load for columns supporting 2 or more floors.

Existing reinforced concrete columns are based on f_c = 4.0 ksi and f_y = 60.0 ksi with minimum (1.12% or less) vertical reinforcement. Column sizes were field measured.

Existing columns capacity is based on an assumed 1 percent eccentricity and are fully braced at each level.

Refer to Enercalc computations for column capacities.

CEN TEK engineering
 Centered on SolutionsSM www.centekeng.com
 63-2 North Branford Road P: (203) 488-0580
 Branford, CT 06405 F: (203) 488-8587

Subject:	Existing Construction Floor by Floor Column Loads and Capacities		
Project:	CT11334A Stamford-3/Hope St		
Prepared:	10/8/2020	Revision:	2
		Job No.	20074.67

Loads Carried by Interior Column D-5 Below Risa-3D Node N25

Summary of Floor Dead Loads		Summary of Roof Dead Loads	
Assume 8" concrete slab, ave. 16"Ø concrete columns, and 8'x8' drop panels	125	Assume 8" concrete slab, ave. 16"Ø concrete columns, and 8'x8' drop panels	125
Interior non-bearing partitions	10	Roofing	5
Finish floor and ceiling	5	Insulation	2
M/E/P	5	M/E/P	5
Subtotal Floor Dead Loads	145 psf	Subtotal Roof Dead Loads	137
Heavy Manufacturing Live Load	250 psf	Roof Live (Snow) Load	30
Area Tributary to Column: [(21.5 * (20.1) =	430 S.F.	Special Loading at Roof Level:	
		None	0 lbs
		None	0 lbs

Existing Building Dead and Live Loads							Existing Columns			Proposed Platform Total Loads			Results	Capacity			
Floor (Roof)	Ref. Elev.	Area Trib. to Col.	Uniform Floor/Roof Loads (Lbs)			Accum. Total (Lbs)	L.L. Red.	Adjusted Total (Lbs)	Column Size	Column Area (S.I.)	Col. Cap. (Lbs)	Additional Load			% Increase Above Exist.	Accum. Total (Lbs)	
Roof Level		430	58,910	0	12,900	71,810	71,810	N/A	71,810	16"x16"	256	365,000	7,700	10.72%	79,510	Col. Okay	48.3%
7th Floor			0		0	71,810	71,810	0	71,810					0.0%	71,810	Col. N.G.	
6th Floor			0		0	71,810	71,810	0	71,810					0.0%	71,810	Col. N.G.	
5th Floor			0		0	71,810	71,810	0	71,810					0.0%	71,810	Col. N.G.	
4th Floor			0		0	71,810	71,810	0	71,810					0.0%	71,810	Col. N.G.	
3rd Floor		430	62,350		107,500	169,850	241,660	0	241,660	20"x20"	400	550,000	7,700	3.2%	249,360	Col. Okay	
2nd Floor		430	62,350		107,500	169,850	411,510	43,000	368,510	24"x24"	576	805,000	7,700	2.1%	376,210	Col. Okay	
1st Floor		430	62,350		107,500	169,850	581,360	64,500	516,860	28"x28"	784	1,085,000	7,700	1.5%	524,560	Col. Okay	
Totals			245,960	0	335,400	581,360											

Comments:

Floor and roof dead loads are based on field measurements.

Floor Live Loads used in calculations are provided in the building code. Live load reduction = 20% of accumulated floor load for columns supporting 2 or more floors.

Existing reinforced concrete columns are based on f_c = 4.0 ksi and f_y = 60.0 ksi with minimum (1.12% or less) vertical reinforcement. Column sizes were field measured.

Existing columns capacity is based on an assumed 1 percent eccentricity and are fully braced at each level.

Refer to Enercalc computations for column capacities.



Subject:	Existing Construction Floor by Floor Column Loads and Capacities		
Project:	CT11334A Stamford-3/Hope St		
Prepared:	10/8/2020	Revision:	2
		Job No.:	20074.67

Loads Carried by Interior Column E-4 Below Risa-3D Node N28

Summary of Floor Dead Loads		Summary of Roof Dead Loads	
Assume 8" concrete slab, ave. 16"Ø concrete columns, and 8'x8' drop panels	125	Assume 8" concrete slab, ave. 16"Ø concrete columns, and 8'x8' drop panels	125
Interior non-bearing partitions	10	Roofing	5
Finish floor and ceiling	5	Insulation	2
M/E/P	5	M/E/P	5
Subtotal Floor Dead Loads	145 psf	Subtotal Roof Dead Loads	137
Heavy Manufacturing Live Load	250 psf	Roof Live (Snow) Load	30
Area Tributary to Column: [(21.5 * (20.1) =	430 S.F.	Special Loading at Roof Level:	
		None	0 lbs
		None	0 lbs

Existing Building Dead and Live Loads							Existing Columns			Proposed Platform Total Loads			Results	Capacity
Floor (Roof)	Ref. Elev.	Area Trib. to Col.	Uniform Floor/Roof Loads (Lbs)			Accum. Total (Lbs)	Column Size	Column Area (S.I.)	Col. Cap. (Lbs)	Additional Load	% Increase Above Exist.	Accum. Total (Lbs)		
Roof Level		430	58,910	0	12,900	71,810	16"x16"	256	365,000	3,800	5.3%	75,610	Col. Okay	48.0%
7th Floor			0		0	71,810					0.0%	71,810	Col. N.G.	
6th Floor			0		0	71,810					0.0%	71,810	Col. N.G.	
5th Floor			0		0	71,810					0.0%	71,810	Col. N.G.	
4th Floor			0		0	71,810					0.0%	71,810	Col. N.G.	
3rd Floor		430	62,350		107,500	241,660	20"x20"	400	550,000	3,800	1.6%	245,460	Col. Okay	
2nd Floor		430	62,350		107,500	411,510	24"x24"	576	805,000	3,800	1.0%	372,310	Col. Okay	
1st Floor		430	62,350		107,500	581,360	28"x28"	784	1,085,000	3,800	0.7%	520,660	Col. Okay	
Totals			245,960	0	335,400	581,360								

Comments:

Floor and roof dead loads are based on field measurements.

Floor Live Loads used in calculations are provided in the building code. Live load reduction = 20% of accumulated floor load for columns supporting 2 or more floors.

Existing reinforced concrete columns are based on f_c = 4.0 ksi and f_y = 60.0 ksi with minimum (1.12% or less) vertical reinforcement. Column sizes were field measured.

Existing columns capacity is based on an assumed 1 percent eccentricity and are fully braced at each level.

Refer to Enercalc computations for column capacities.



Subject:	Existing Construction Floor by Floor Column Loads and Capacities		
Project:	CT11334A Stamford-3/Hope St		
Prepared:	10/8/2020	Revision:	2
		Job No.:	20074.67

Loads Carried by Interior Column E-5 Below Risa-3D Node N27

Summary of Floor Dead Loads		Summary of Roof Dead Loads	
Assume 8" concrete slab, ave. 16"Ø concrete columns, and 8'x8' drop panels	125	Assume 8" concrete slab, ave. 16"Ø concrete columns, and 8'x8' drop panels	125
Interior non-bearing partitions	10	Roofing	5
Finish floor and ceiling	5	Insulation	2
M/E/P	5	M/E/P	5
Subtotal Floor Dead Loads	145 psf	Subtotal Roof Dead Loads	137
Heavy Manufacturing Live Load	250 psf	Roof Live (Snow) Load	30
Area Tributary to Column: [(21.5 * (20.1) =	430 S.F.	Special Loading at Roof Level:	
		None	0 lbs
		None	0 lbs

Existing Building Dead and Live Loads							Existing Columns			Proposed Platform Total Loads			Results	Capacity		
Floor (Roof)	Ref. Elev.	Area Trib. to Col.	Uniform Floor/Roof Loads (Lbs)			Accum. Total (Lbs)	L.L. Red.	Adjusted Total (Lbs)	Column Size	Column Area (S.I.)	Col. Cap. (Lbs)	Additional Load			% Increase Above Exist.	Accum. Total (Lbs)
Roof Level		430	58,910	0	12,900	71,810	N/A	71,810	16"x16"	256	365,000	3,700	5.2%	75,510	Col. Okay	48.0%
7th Floor			0		0	71,810	0	71,810					0.0%	71,810	Col. N.G.	
6th Floor			0		0	71,810	0	71,810					0.0%	71,810	Col. N.G.	
5th Floor			0		0	71,810	0	71,810					0.0%	71,810	Col. N.G.	
4th Floor			0		0	71,810	0	71,810					0.0%	71,810	Col. N.G.	
3rd Floor		430	62,350		107,500	169,850	0	241,660	20"x20"	400	550,000	3,700	1.5%	245,360	Col. Okay	
2nd Floor		430	62,350		107,500	169,850	43,000	368,510	24"x24"	576	805,000	3,700	1.0%	372,210	Col. Okay	
1st Floor		430	62,350		107,500	169,850	64,500	516,860	28"x28"	784	1,085,000	3,700	0.7%	520,560	Col. Okay	
Totals			245,960	0	335,400	581,360										

Comments:

Floor and roof dead loads are based on field measurements.

Floor Live Loads used in calculations are provided in the building code. Live load reduction = 20% of accumulated floor load for columns supporting 2 or more floors.

Existing reinforced concrete columns are based on f_c = 4.0 ksi and f_y = 60.0 ksi with minimum (1.12% or less) vertical reinforcement. Column sizes were field measured.

Existing columns capacity is based on an assumed 1 percent eccentricity and are fully braced at each level.

Refer to Enercalc computations for column capacities.

RAN Template: 67D5A997DB Outdoor	A&L Template: 67D5997DB_2xAIR+1OP (U21 Market)
--	--

Section 1 - Site Information

Site ID: CT11334A
Status: Draft
Version: 4
Project Type: Anchor
Approved: Not Approved
Approved By: Not Approved
Last Modified: 8/17/2020 8:0:48 PM
Last Modified By: Dominic.Kallas2@T-Mobile.com


Site Name: Stamford-3/Hope St
Site Class: Watertank
Site Type: Structure Non Building
Plan Year: 2020
Market: CONNECTICUT CT
Vendor: Ericsson
Landlord: <undefined>

Latitude: 41.07548400
Longitude: -73.51914100
Address: 652 Glenbrook Road
City, State: Stamford, CT
Region: NORTHEAST

RAN Template: 67D5A997DB Outdoor		AL Template: 67D5997DB_2xAIR+1OP (U21 Market)		
Sector Count: 3	Antenna Count: 9	Coax Line Count: 6	TMA Count: 3	RRU Count: 6

Section 2 - Existing Template Images


67D92DB_2xAIR+1OP.JPG



Notes:

Section 3 - Proposed Template Images

67D5997DB_2xAIR+1OP.JPG



Notes:

Section 4 - Siteplan Images

----- This section is intentionally blank. -----

RAN Template: 67D5A997DB Outdoor	A&L Template: 67D5997DB_2xAIR+1OP (U21 Market)
--	--

Section 5 - RAN Equipment

Existing RAN Equipment

Template: 67D92DB Outdoor

Enclosure	1	2
Enclosure Type	RBS 6131	Ancillary Equipment (Ericsson)
Baseband	DUW30 (U1900 (DECOMMISSIONED)) DUW30 (U2100) DUG20 (G1900) BB 6630 (L2100, L1900) BB 6630 (L700, L600, N600)	
Hybrid Cable System		Ericsson 6x12 HCS 6AWG 40m (x 2) Ericsson 6x12 HCS 4AWG 60m
Radio	RU22 (x 6) U2100	

Proposed RAN Equipment

Template: 67D5A997DB Outdoor

Enclosure	1	2	3	4
Enclosure Type	RBS 6131	Ancillary Equipment (Ericsson)	Enclosure 6160	B160
Baseband	DUW30 (U2100) DUG20 (G1900) BB 6630 (L2100, L1900) BB 6630 (L700, L600, N600)		BB 6630 (L2500) BB 6648 (N2500)	
Hybrid Cable System		Ericsson 6x12 HCS 6AWG 40m (x 2) Ericsson 6x12 HCS 4AWG 60m	PSU 4813	
Radio	RU22 (x 6) U2100			

RAN Scope of Work:

Generator is installed at site.

Add (1) Enclosure 6160.

Add (1) Battery Cabinet B160.

Add (1) iXRe Router to new Enclosure 6160.

Add (1) BB6630 for L2500 to new Enclosure 6160.

Add (1) BB6648 for N2500 to new Enclosure 6160.

Add (1) PSU 4813 to new Enclosure 6160.

Existing: (12) Coaxial Lines; (3) 6X12 HCS

Remove (6) Coaxial Lines for new total of (6) Coaxial Lines.

DC and Fiber Pairs on each HCS to be allocated among A&L equipment on that sector.

RAN Template: 67D5A997DB Outdoor	A&L Template: 67D5997DB_2xAIR+1OP (U21 Market)
--	--

CT11334A_Anchor_4_draft
 Print Name: Preliminary (RFDS_for_Scoping)
 PORs: Anchor_Phase 3

Section 6 - A&L Equipment

Existing Template: 67D92DB_2xAIR+1OP
 Proposed Template: 67D5997DB_2xAIR+1OP (U21 Market)

Sector 1 (Existing) view from behind

Coverage Type	A - Outdoor Macro									
Antenna	1		2				3		4	
Antenna Model	Ericsson - AIR21 KRC118023-1_B2A_B4P (Quad)		Ericsson - AIR32 KRD901146-1_B66A_B2A (Octo)				RFS - APXVAARR24_43-U-NA20 (Octo)		Occupied Mount (Placeholder)	
Azimuth	60		60				60			
M. Tilt	0		0				0			
Height	85		85				85			
Ports	P1	P2	P3	P4	P5	P6	P7	P8	P9	P10
Active Tech.	G1900	U2100	L2100	L2100	L1900	L1900	L700 L600 N600	L700 L600 N600		
Dark Tech.										
Restricted Tech.										
Decomm. Tech.	U1900									
E. Tilt										
Cables		Generic Feeder Coax (x2) Coax Jumper (x2)					Coax Jumper (x2)	Coax Jumper (x2)		
TMA's		Generic Twin Style 1B - AWS (AtAntenna)								
Diplexers / Combiners										
Radio							Radio 4449 B71+ B85 (At Antenna)			
Sector Equipment										

Unconnected Equipment:

Scope of Work:

RAN Template: 67D5A997DB Outdoor	A&L Template: 67D5997DB_2xAIR+1OP (U21 Market)
--	--

Sector 1 (Proposed) view from behind

Coverage Type	A - Outdoor Macro									
Antenna	1		2				3			4
Antenna Model	Ericsson - AIR6449 B41 (Active Antenna - Massive MIMO)		Ericsson - AIR32 KRD901146-1_B66A_B2A (Octo)				RFS - APXVAARR24_43-U-NA20 (Octo)			Occupied Mount (Placeholder)
Azimuth	60		60				60			
M. Tilt	0		0				0			
Height	85		85				85			
Ports	P1	P2	P3	P4	P5	P6	P7	P8	P9	P10
Active Tech.	L2500 N2500	L2500 N2500	L2100	L2100	G1900 L1900	L1900	L700 L600 N600	L700 L600 N600	L1900	U2100 L1900
Dark Tech.										
Restricted Tech.										
Decomm. Tech.										
E. Tilt										
Cables							Coax Jumper (x2)	Coax Jumper (x2)	Coax Jumper (x2)	Coax Jumper (x2) Generic Feeder Coax (x2)
TMA's										Generic Twin Style 1B - AWS (Antenna)
Diplexers / Combiners									Commscope - SDX 1926 Q-43 (E14 F05 P86) (Antenna)	SHARED Commscope - SDX 1926 Q-43 (E14 F05 P86) (Antenna)
Radio							Radio 4449 B71 +B85 (Antenna)	SHARED Radio 4449 B71 +B85 (Antenna)	Radio 4415 B25 (Antenna)	SHARED Radio 4415 B25 (Antenna)
Sector Equipment										

Unconnected Equipment:

Scope of Work:

Remove AIR21 B2A/B4P from Position 1.

Install AIR6449 B41 for L2500 and N2500 in Position 1.

Move GSM to AIR32 DB in Position 2. GSM will share B2 Radios with L1900 1st Carrier.

Add (1) PCS/AWS 8:4 diplexer to Position 3 at antenna, and connect its four output ports to the Mid-Band ports of the Octo antenna.

Add (1) Radio 4415 B25 for L1900 2nd Carrier to Position 3 near antenna, and connect its ports to the four PCS input ports of the diplexer.

Move coaxial lines and AWS TMA for U2100 to Position 3, and connect them to two AWS input ports of the diplexer.

Make sure to install metal caps on all empty ports of PCS/AWS diplexer for load balancing.

Ensure RET control is enabled for all technology layers according to the Design Documents.

*A dashed border indicates shared equipment. Any connected equipment is denoted with the SHARED keyword.

RAN Template: 67D5A997DB Outdoor	A&L Template: 67D5997DB_2xAIR+1OP (U21 Market)
--	--

Sector 2 (Existing) view from behind										
Coverage Type	A - Outdoor Macro									
Antenna	1		2				3		4	
Antenna Model	Ericsson - AIR21 KRC118023-1_B2A_B4P (Quad)		Ericsson - AIR32 KRD901146-1_B66A_B2A (Octo)				RFS - APXVAARR24_43-U-NA20 (Octo)		Occupied Mount (Placeholder)	
Azimuth	170		170				170			
M. Tilt	0		0				0			
Height	85		85				85			
Ports	P1	P2	P3	P4	P5	P6	P7	P8	P9	P10
Active Tech.	G1900	U2100	L2100	L2100	L1900	L1900	L700 L600 N600	L700 L600 N600		
Dark Tech.										
Restricted Tech.										
Decomm. Tech.	U1900									
E. Tilt										
Cables		Generic Feeder Coax (x2) Coax Jumper (x2)					Coax Jumper (x2)	Coax Jumper (x2)		
TMA's		Generic Twin Style 1B - AWS (AtAntenna)								
Diplexers / Combiners										
Radio							Radio 4449 B71+ B85 (At Antenna)			
Sector Equipment										
Unconnected Equipment:										
Scope of Work:										

RAN Template: 67D5A997DB Outdoor	A&L Template: 67D5997DB_2xAIR+1OP (U21 Market)
--	--

Sector 2 (Proposed) view from behind

Coverage Type	A - Outdoor Macro										
Antenna	1		2				3			4	
Antenna Model	Ericsson - AIR6449 B41 (Active Antenna - Massive MIMO)		Ericsson - AIR32 KRD901146-1_B66A_B2A (Octo)				RFS - APXVAARR24_43-U-NA20 (Octo)			Occupied Mount (Placeholder)	
Azimuth	170		170				170				
M. Tilt	0		0				0				
Height	85		85				85				
Ports	P1	P2	P3	P4	P5	P6	P7	P8	P9	P10	
Active Tech.	L2500 N2500	L2500 N2500	L2100	L2100	G1900 L1900	L1900	L700 L600 N600	L700 L600 N600	L1900	U2100 L1900	
Dark Tech.											
Restricted Tech.											
Decomm. Tech.											
E. Tilt											
Cables							Coax Jumper (x2)	Coax Jumper (x2)	Coax Jumper (x2)	Coax Jumper (x2) Generic Feeder Coax (x2)	
TMA's										Generic Twin Style 1B - AWS (At Antenna)	
Diplexers / Combiners									Commscope - SDX 1926 Q-43 (E14 F05 P86) (At Antenna)	SHARED Commscope - SDX 1926 Q-43 (E14 F05 P86) (At Antenna)	
Radio							Radio 4449 B71 +B85 (At Antenna)	SHARED Radio 4449 B71 +B85 (At Antenna)	Radio 4415 B25 (At Antenna)	SHARED Radio 4415 B25 (At Antenna)	
Sector Equipment											

Unconnected Equipment:

Scope of Work:

Remove AIR21 B2A/B4P from Position 1.

Install AIR6449 B41 for L2500 and N2500 in Position 1.

Move GSM to AIR32 DB in Position 2. GSM will share B2 Radios with L1900 1st Carrier.

Add (1) PCS/AWS 8:4 diplexer to Position 3 at antenna, and connect its four output ports to the Mid-Band ports of the Octo antenna.

Add (1) Radio 4415 B25 for L1900 2nd Carrier to Position 3 near antenna, and connect its ports to the four PCS input ports of the diplexer.

Move coaxial lines and AWS TMA for U2100 to Position 3, and connect them to two AWS input ports of the diplexer.

Make sure to install metal caps on all empty ports of PCS/AWS diplexer for load balancing.

Ensure RET control is enabled for all technology layers according to the Design Documents.

*A dashed border indicates shared equipment. Any connected equipment is denoted with the SHARED keyword.

RAN Template: 67D5A997DB Outdoor	A&L Template: 67D5997DB_2xAIR+1OP (U21 Market)
--	--

Sector 3 (Existing) view from behind										
Coverage Type	A - Outdoor Macro									
Antenna	1		2				3		4	
Antenna Model	Ericsson - AIR21 KRC118023-1_B2A_B4P (Quad)		Ericsson - AIR32 KRD901146-1_B66A_B2A (Octo)				RFS - APXVAARR24_43-U-NA20 (Octo)		Occupied Mount (Placeholder)	
Azimuth	300		300				300			
M. Tilt	0		0				0			
Height	85		85				85			
Ports	P1	P2	P3	P4	P5	P6	P7	P8	P9	P10
Active Tech.	G1900	U2100	L2100	L2100	L1900	L1900	L700 L600 N600	L700 L600 N600		
Dark Tech.										
Restricted Tech.										
Decomm. Tech.	U1900									
E. Tilt										
Cables		Generic Feeder Coax (x2) Coax Jumper (x2)					Coax Jumper (x2)	Coax Jumper (x2)		
TMA's		Generic Twin Style 1B - AWS (AtAntenna)								
Diplexers / Combiners										
Radio							Radio 4449 B71+ B85 (At Antenna)			
Sector Equipment										
Unconnected Equipment:										
Scope of Work:										

RAN Template: 67D5A997DB Outdoor	A&L Template: 67D5997DB_2xAIR+1OP (U21 Market)
--	--

Sector 3 (Proposed) view from behind

Coverage Type	A - Outdoor Macro									
Antenna	1		2				3			4
Antenna Model	Ericsson - AIR6449 B41 (Active Antenna - Massive MIMO)		Ericsson - AIR32 KRD901146-1_B66A_B2A (Octo)				RFS - APXVAARR24_43-U-NA20 (Octo)			Occupied Mount (Placeholder)
Azimuth	300		300				300			
M. Tilt	0		0				0			
Height	85		85				85			
Ports	P1	P2	P3	P4	P5	P6	P7	P8	P9	P10
Active Tech.	L2500 N2500	L2500 N2500	L2100	L2100	G1900 L1900	L1900	L700 L600 N600	L700 L600 N600	L1900	U2100 L1900
Dark Tech.										
Restricted Tech.										
Decomm. Tech.										
E. Tilt										
Cables							Coax Jumper (x2)	Coax Jumper (x2)	Coax Jumper (x2)	Coax Jumper (x2) Generic Feeder Coax (x2)
TMA's										Generic Twin Style 1B - AWS (At Antenna)
Diplexers / Combiners									Commscope - SDX 1926 Q-43 (E14 F05 P86) (At Antenna)	SHARED Commscope - SDX 1926 Q-43 (E14 F05 P86) (At Antenna)
Radio							Radio 4449 B71 +B85 (At Antenna)	SHARED Radio 4449 B71 +B85 (At Antenna)	Radio 4415 B25 (At Antenna)	SHARED Radio 4415 B25 (At Antenna)
Sector Equipment										

Unconnected Equipment:

Scope of Work:

Remove AIR21 B2A/B4P from Position 1.

Install AIR6449 B41 for L2500 and N2500 in Position 1.

Move GSM to AIR32 DB in Position 2. GSM will share B2 Radios with L1900 1st Carrier.

Add (1) PCS/AWS 8:4 diplexer to Position 3 at antenna, and connect its four output ports to the Mid-Band ports of the Octo antenna.

Add (1) Radio 4415 B25 for L1900 2nd Carrier to Position 3 near antenna, and connect its ports to the four PCS input ports of the diplexer.

Move coaxial lines and AWS TMA for U2100 to Position 3, and connect them to two AWS input ports of the diplexer.

Make sure to install metal caps on all empty ports of PCS/AWS diplexer for load balancing.

Ensure RET control is enabled for all technology layers according to the Design Documents.

*A dashed border indicates shared equipment. Any connected equipment is denoted with the SHARED keyword.

RAN Template: 67D5A997DB Outdoor	A&L Template: 67D5997DB_2xAIR+1OP (U21 Market)
--	--

Section 7 - Power Systems Equipment

Existing Power Systems Equipment

----- This section is intentionally blank. -----

Proposed Power Systems Equipment

RADIO FREQUENCY EMISSIONS ANALYSIS REPORT
EVALUATION OF HUMAN EXPOSURE POTENTIAL
TO NON-IONIZING EMISSIONS

T-Mobile Existing Facility

Site ID: CT11334A

Stamford-3/Hope St
652 Glenbrook Road
Stamford, Connecticut 06906

February 9, 2021

EBI Project Number: 6221000529

Site Compliance Summary	
Compliance Status:	COMPLIANT
Site total MPE% of FCC general population allowable limit:	51.30%

February 9, 2021

T-Mobile

Attn: Jason Overbey, RF Manager
35 Griffin Road South
Bloomfield, Connecticut 06002

Emissions Analysis for Site: CT11334A - Stamford-3/Hope St

EBI Consulting was directed to analyze the proposed T-Mobile facility located at **652 Glenbrook Road** in **Stamford, Connecticut** for the purpose of determining whether the emissions from the Proposed T-Mobile Antenna Installation located on this property are within specified federal limits.

All information used in this report was analyzed as a percentage of current Maximum Permissible Exposure (% MPE) as listed in the FCC OET Bulletin 65 Edition 97-01 and ANSI/IEEE Std C95.1. The FCC regulates Maximum Permissible Exposure in units of microwatts per square centimeter ($\mu\text{W}/\text{cm}^2$). The number of $\mu\text{W}/\text{cm}^2$ calculated at each sample point is called the power density. The exposure limit for power density varies depending upon the frequencies being utilized. Wireless Carriers and Paging Services use different frequency bands each with different exposure limits; therefore, it is necessary to report results and limits in terms of percent MPE rather than power density.

All results were compared to the FCC (Federal Communications Commission) radio frequency exposure rules, 47 CFR 1.1307(b)(1) – (b)(3), to determine compliance with the Maximum Permissible Exposure (MPE) limits for General Population/Uncontrolled environments as defined below.

General population/uncontrolled exposure limits apply to situations in which the general population may be exposed or in which persons who are exposed as a consequence of their employment may not be made fully aware of the potential for exposure or cannot exercise control over their exposure. Therefore, members of the general population would always be considered under this category when exposure is not employment related, for example, in the case of a telecommunications tower that exposes persons in a nearby residential area.

Public exposure to radio frequencies is regulated and enforced in units of microwatts per square centimeter ($\mu\text{W}/\text{cm}^2$). The general population exposure limits for the 600 MHz and 700 MHz frequency bands are approximately $400 \mu\text{W}/\text{cm}^2$ and $467 \mu\text{W}/\text{cm}^2$, respectively. The general population exposure limit for the 1900 MHz (PCS), 2100 MHz (AWS) and 11 GHz frequency bands is $1000 \mu\text{W}/\text{cm}^2$. Because each carrier will be using different frequency bands, and each frequency band has different exposure limits, it is necessary to report percent of MPE rather than power density.

Occupational/controlled exposure limits apply to situations in which persons are exposed as a consequence of their employment and in which those persons who are exposed have been made fully aware of the potential for exposure and can exercise control over their exposure. Occupational/controlled exposure limits also apply where exposure is of a transient nature as a result of incidental passage through a location where exposure levels may be above general population/uncontrolled limits (see below), as long as the exposed person has been made fully aware of the potential for exposure and can exercise control over his or her exposure by leaving the area or by some other appropriate means.

Additional details can be found in FCC OET 65.

CALCULATIONS

Calculations were done for the proposed T-Mobile Wireless antenna facility located at 652 Glenbrook Road in Stamford, Connecticut using the equipment information listed below. All calculations were performed per the specifications under FCC OET 65. Since T-Mobile is proposing highly focused directional panel antennas, which project most of the emitted energy out toward the horizon, all calculations were performed assuming a lobe representing the maximum gain of the antenna per the antenna manufacturer's supplied specifications, minus 10 dB for directional panel antennas and 20 dB for highly focused parabolic microwave dishes, was focused at the base of the tower. For this report, the sample point is the top of a 6-foot person standing at the base of the tower.

For all calculations, all equipment was calculated using the following assumptions:

- 1) 2 LTE channels (600 MHz Band) were considered for each sector of the proposed installation. These Channels have a transmit power of 30 Watts per Channel.
- 2) 1 NR channel (600 MHz Band) was considered for each sector of the proposed installation. This Channel has a transmit power of 80 Watts.
- 3) 2 LTE channels (700 MHz Band) were considered for each sector of the proposed installation. These Channels have a transmit power of 30 Watts per Channel.
- 4) 4 GSM channels (PCS Band - 1900 MHz) were considered for each sector of the proposed installation. These Channels have a transmit power of 30 Watts per Channel.
- 5) 4 LTE channels (PCS Band - 1900 MHz) were considered for each sector of the proposed installation. These Channels have a transmit power of 60 Watts per Channel.
- 6) 2 UMTS channels (AWS Band - 2100 MHz) were considered for each sector of the proposed installation. These Channels have a transmit power of 30 Watts per Channel.

- 7) 2 LTE channels (AWS Band – 2100 MHz) were considered for each sector of the proposed installation. These Channels have a transmit power of 60 Watts per Channel.
- 8) 1 LTE channel (BRS Band - 2500 MHz) was considered for each sector of the proposed installation. This Channel has a transmit power of 120 Watts.
- 9) 1 NR channel (BRS Band - 2500 MHz) was considered for each sector of the proposed installation. This Channel has a transmit power of 120 Watts.
- 10) All radios at the proposed installation were considered to be running at full power and were uncombined in their RF transmissions paths per carrier prescribed configuration. Per FCC OET Bulletin No. 65 - Edition 97-01 recommendations to achieve the maximum anticipated value at each sample point, all power levels emitting from the proposed antenna installation are increased by a factor of 2.56 to account for possible in-phase reflections from the surrounding environment. This is rarely the case, and if so, is never continuous.
- 11) For the following calculations, the sample point was the top of a 6-foot person standing at the base of the tower. The maximum gain of the antenna per the antenna manufacturer's supplied specifications, minus 10 dB for directional panel antennas and 20 dB for highly focused parabolic microwave dishes, was used in this direction. This value is a very conservative estimate as gain reductions for these particular antennas are typically much higher in this direction.
- 12) The antennas used in this modeling are the Ericsson AIR 6449 for the 2500 MHz / 2500 MHz channel(s), the Ericsson AIR 32 for the 1900 MHz / 1900 MHz / 2100 MHz channel(s), the RFS APXVAARR24_43-U-NA20 for the 600 MHz / 600 MHz / 700 MHz / 1900 MHz / 2100 MHz channel(s) in Sector A, the Ericsson AIR 6449 for the 2500 MHz / 2500 MHz channel(s), the Ericsson AIR 32 for the 1900 MHz / 1900 MHz / 2100 MHz channel(s), the RFS APXVAARR24_43-U-NA20 for the 600 MHz / 600 MHz / 700 MHz / 1900 MHz / 2100 MHz channel(s) in Sector B, the Ericsson AIR 6449 for the 2500 MHz / 2500 MHz channel(s), the Ericsson AIR 32 for the 1900 MHz / 1900 MHz / 2100 MHz channel(s), the RFS APXVAARR24_43-U-NA20 for the 600 MHz / 600 MHz / 700 MHz / 1900 MHz / 2100 MHz channel(s) in Sector C. This is based on feedback from the carrier with regard to anticipated antenna selection. All Antenna gain values and associated transmit power levels are shown in the Site Inventory and Power Data table below. The maximum gain of the antenna per the antenna manufacturer's supplied specifications, minus 10 dB for directional panel antennas and 20 dB for highly focused parabolic microwave dishes, was used for all calculations. This value is a very conservative estimate as gain reductions for these particular antennas are typically much higher in this direction.

- 13) The antenna mounting height centerline of the proposed antennas is 85 feet above ground level (AGL).
- 14) Emissions values for additional carriers were taken from the Connecticut Siting Council active database. Values in this database are provided by the individual carriers themselves.
- 15) All calculations were done with respect to uncontrolled / general population threshold limits.

T-Mobile Site Inventory and Power Data

Sector:	A	Sector:	B	Sector:	C
Antenna #:	1	Antenna #:	1	Antenna #:	1
Make / Model:	Ericsson AIR 6449	Make / Model:	Ericsson AIR 6449	Make / Model:	Ericsson AIR 6449
Frequency Bands:	2500 MHz / 2500 MHz	Frequency Bands:	2500 MHz / 2500 MHz	Frequency Bands:	2500 MHz / 2500 MHz
Gain:	22.05 dBd / 22.05 dBd	Gain:	22.05 dBd / 22.05 dBd	Gain:	22.05 dBd / 22.05 dBd
Height (AGL):	85 feet	Height (AGL):	85 feet	Height (AGL):	85 feet
Channel Count:	2	Channel Count:	2	Channel Count:	2
Total TX Power (W):	240 Watts	Total TX Power (W):	240 Watts	Total TX Power (W):	240 Watts
ERP (W):	38,477.89	ERP (W):	38,477.89	ERP (W):	38,477.89
Antenna A1 MPE %:	19.15%	Antenna B1 MPE %:	19.15%	Antenna C1 MPE %:	19.15%
Antenna #:	2	Antenna #:	2	Antenna #:	2
Make / Model:	Ericsson AIR 32	Make / Model:	Ericsson AIR 32	Make / Model:	Ericsson AIR 32
Frequency Bands:	1900 MHz / 1900 MHz / 2100 MHz	Frequency Bands:	1900 MHz / 1900 MHz / 2100 MHz	Frequency Bands:	1900 MHz / 1900 MHz / 2100 MHz
Gain:	15.35 dBd / 15.35 dBd / 15.85 dBd	Gain:	15.35 dBd / 15.35 dBd / 15.85 dBd	Gain:	15.35 dBd / 15.35 dBd / 15.85 dBd
Height (AGL):	85 feet	Height (AGL):	85 feet	Height (AGL):	85 feet
Channel Count:	8	Channel Count:	8	Channel Count:	8
Total TX Power (W):	360 Watts	Total TX Power (W):	360 Watts	Total TX Power (W):	360 Watts
ERP (W):	12,841.53	ERP (W):	12,841.53	ERP (W):	12,841.53
Antenna A2 MPE %:	6.39%	Antenna B2 MPE %:	6.39%	Antenna C2 MPE %:	6.39%
Antenna #:	3	Antenna #:	3	Antenna #:	3
Make / Model:	RFS APXVAARR24_43-U-NA20	Make / Model:	RFS APXVAARR24_43-U-NA20	Make / Model:	RFS APXVAARR24_43-U-NA20
Frequency Bands:	600 MHz / 600 MHz / 700 MHz / 1900 MHz / 2100 MHz	Frequency Bands:	600 MHz / 600 MHz / 700 MHz / 1900 MHz / 2100 MHz	Frequency Bands:	600 MHz / 600 MHz / 700 MHz / 1900 MHz / 2100 MHz
Gain:	12.95 dBd / 12.95 dBd / 13.35 dBd / 15.65 dBd / 16.35 dBd	Gain:	12.95 dBd / 12.95 dBd / 13.35 dBd / 15.65 dBd / 16.35 dBd	Gain:	12.95 dBd / 12.95 dBd / 13.35 dBd / 15.65 dBd / 16.35 dBd
Height (AGL):	85 feet	Height (AGL):	85 feet	Height (AGL):	85 feet
Channel Count:	9	Channel Count:	9	Channel Count:	9
Total TX Power (W):	380 Watts	Total TX Power (W):	380 Watts	Total TX Power (W):	380 Watts
ERP (W):	11,055.53	ERP (W):	11,055.53	ERP (W):	11,055.53
Antenna A3 MPE %:	8.30%	Antenna B3 MPE %:	8.30%	Antenna C3 MPE %:	8.30%

Site Composite MPE %	
Carrier	MPE %
T-Mobile (Max at Sector A):	33.84%
Metro PCS	2.41%
Clearwire	0.24%
Sprint	10.49%
AT&T	4.32%
Site Total MPE % :	51.30%

T-Mobile MPE % Per Sector	
T-Mobile Sector A Total:	33.84%
T-Mobile Sector B Total:	33.84%
T-Mobile Sector C Total:	33.84%
Site Total MPE % :	51.30%

T-Mobile Maximum MPE Power Values (Sector A)							
T-Mobile Frequency Band / Technology (Sector A)	# Channels	Watts ERP (Per Channel)	Height (feet)	Total Power Density ($\mu\text{W}/\text{cm}^2$)	Frequency (MHz)	Allowable MPE ($\mu\text{W}/\text{cm}^2$)	Calculated % MPE
T-Mobile 2500 MHz LTE	1	19238.94	85.0	95.73	2500 MHz LTE	1000	9.57%
T-Mobile 2500 MHz NR	1	19238.94	85.0	95.73	2500 MHz NR	1000	9.57%
T-Mobile 1900 MHz GSM	4	1028.30	85.0	20.47	1900 MHz GSM	1000	2.05%
T-Mobile 1900 MHz LTE	2	2056.61	85.0	20.47	1900 MHz LTE	1000	2.05%
T-Mobile 2100 MHz LTE	2	2307.55	85.0	22.96	2100 MHz LTE	1000	2.30%
T-Mobile 600 MHz LTE	2	591.73	85.0	5.89	600 MHz LTE	400	1.47%
T-Mobile 600 MHz NR	1	1577.94	85.0	7.85	600 MHz NR	400	1.96%
T-Mobile 700 MHz LTE	2	648.82	85.0	6.46	700 MHz LTE	467	1.38%
T-Mobile 1900 MHz LTE	2	2203.69	85.0	21.93	1900 MHz LTE	1000	2.19%
T-Mobile 2100 MHz UMTS	2	1294.56	85.0	12.88	2100 MHz UMTS	1000	1.29%
						Total:	33.84%

• NOTE: Totals may vary by approximately 0.01% due to summation of remainders in calculations.

Summary

All calculations performed for this analysis yielded results that were **within** the allowable limits for general population exposure to RF Emissions.

The anticipated maximum composite contributions from the T-Mobile facility as well as the site composite emissions value with regards to compliance with FCC's allowable limits for general population exposure to RF Emissions are shown here:

T-Mobile Sector	Power Density Value (%)
Sector A:	33.84%
Sector B:	33.84%
Sector C:	33.84%
T-Mobile Maximum MPE % (Sector A):	33.84%
Site Total:	51.30%
Site Compliance Status:	COMPLIANT

The anticipated composite MPE value for this site assuming all carriers present is **51.30%** of the allowable FCC established general population limit sampled at the ground level. This is based upon values listed in the Connecticut Siting Council database for existing carrier emissions.

FCC guidelines state that if a site is found to be out of compliance (over allowable thresholds), that carriers over a 5% contribution to the composite value will require measures to bring the site into compliance. For this facility, the composite values calculated were well within the allowable 100% threshold standard per the federal government.