



STATE OF CONNECTICUT

CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: siting.council@ct.gov

www.ct.gov/csc

VIA ELECTRONIC MAIL

March 1, 2022

Rodney A. Galton, P.E.
Ecos Energy
222 South 9th Street, Suite 1600
Minneapolis, MN 55402
Rodney.galton@ecosrenewable.com

RE: **PETITION NO. 1220** - Windham Solar LLC declaratory ruling that no Certificate of Environmental Compatibility and Public Need is required for the construction, maintenance and operation of three 2.0 Megawatt and one 1.0 Megawatt Solar Photovoltaic Electric Generating facilities located at 1219 and 1240 Voluntown Road, Griswold, Connecticut. **Request to Modify Development and Management Plan.**

Dear Mr. Galton:

The Connecticut Siting Council (Council) requests your responses to the enclosed questions no later than **March 15, 2022**. Please submit an original to the Council's office and an electronic copy to siting.council@ct.gov.

Any request for an extension of time to submit responses to interrogatories shall be submitted to the Council in writing pursuant to §16-50j-22a of the Regulations of Connecticut State Agencies.

Sincerely,

Melanie Bachman
Executive Director

MB/MP

c: The Honorable Dana Bennett, First Selectman, Town of Griswold
Mario Tristany, Jr., Town Planner, Town of Griswold

Petition No. 1220
Windham Solar LLC
1219 and 1240 Voluntown Road
Griswold, Connecticut

Development & Management (D&M) Plan Modification Interrogatories
March 1, 2022

1. Referencing the Connecticut Siting Council (Council) Petition No. 1220 Development and Management (D&M) Plan approval dated July 19, 2019, Condition Nos. 1 and 2 required the submission of the final electrical design plans/interconnection design for the western parcel and the final structural designs (for the racking systems) stamped by a Professional Engineer licensed in Connecticut (for both parcels). Please provide the required outstanding information.
2. Referencing the February 24, 2022 request to modify the approved D&M Plan to install a shed, please respond to the following:
 - a) Provide the height of the storage shed above grade.
 - b) Provide a “zoomed in” site plan depicting the shed location and including the shed dimensions and location of the electrical service connection.
 - c) Provide a photo of the proposed shed.
 - d) Would the design of the shed comply with applicable building codes, e.g. Connecticut State Building Code and/or any local building code? Explain.
 - e) How would the shed be fastened in place at the base to protect against high wind conditions e.g. a hurricane?
 - f) What would be stored inside the shed?
 - g) Would the shed be used in support of hosting sheep grazing at the solar facility? If so, please provide a sheep grazing management plan for the site.
 - h) What is the setback distance from the proposed shed to the edge of Voluntown Road, to the project fence line and to the solar panel rows?
 - i) The shed location was selected, in part, to facilitate the connection of electrical service. What would the electrical service be used for?