

---

**From:** Bachman, Melanie  
**Sent:** Monday, March 23, 2020 1:21 PM  
**To:** 'Shanley, Kathleen M'  
**Cc:** CSC-DL Siting Council  
**Subject:** RE: Incident at Manchester Substation (MX Position Bus)

Good afternoon, Ms. Shanley.

Thank you for the notification regarding the incident at Manchester Substation. With regard to extended work hours at this site, an extension of work hours past 7 PM is hereby approved. Please provide the summary described below at your convenience.

Thanks.

Melanie A. Bachman, Esq.  
Executive Director/Staff Attorney  
Connecticut Siting Council  
10 Franklin Square  
New Britain, CT 06051  
860-827-2951

**CONFIDENTIAL INFORMATION:** The information contained in this e-mail is confidential and protected from general disclosure. If the recipient or the reader of this e-mail is not the intended recipient, or person responsible to receive this e-mail, you are requested to delete this e-mail immediately and do not disseminate or distribute or copy. If you have received this e-mail by mistake, please notify us immediately by replying to the message so that we can take appropriate action immediately and see to it that this mistake is rectified.

**From:** Shanley, Kathleen M <kathleen.shanley@eversource.com>  
**Sent:** Monday, March 23, 2020 1:16 PM  
**To:** Bachman, Melanie <Melanie.Bachman@ct.gov>  
**Subject:** Incident at Manchester Substation (MX Position Bus)

Dear Ms. Bachman:

Please be advised that earlier today an incident occurred at Manchester Substation resulting in damage requiring the 115kV B Bus, 3A-3X (115/23-kV transformer) and 3A-6X (345/115-kV transformer) being out of service. Please see attached photo. There are no injuries associated with the incident. However, as a result of this incident, Eversource will need to work past the 7 pm deadline to undertake repairs. At this time, Eversource is unable to estimate how much additional time is required. I will follow up this notice with a more detailed summary of the incident and additional work hours needed to undertake repairs.

Please let me know if you have any questions or concerns.

Thank you,

Kate

Kathleen M. Shanley | Manager - Transmission Siting | [kathleen.shanley@eversource.com](mailto:kathleen.shanley@eversource.com) |  
Direct: (860) 728-4527