

FIFTEEN ROPE FERRY ROAD



WATERFORD, CT 06385-2886

June 17, 2020

In response to the questions put forth in the letter from Emily A. Gianquinto, EAG Law LLC the Fire Marshal states the following:

Responding to Item 1 – The Fire Marshal walked the site with Planning Department and Public Works Department. The installation of the solar array must be installed in accordance with the Connecticut State Fire Prevention Code (CSFPC 11.12.3, 11.12.3.2, 11.12.3.3). We will initiate, with the site developer, training to be held for the fire department to be able to handle any issues at the site.

Responding to Item 2 – Site access will be inspected throughout the project for compliance (CSFPC 11.12.3.1).

Linda Finnegan  
Office Coordinator

WATERFORD FIRE DEPARTMENT  
204 Boston Post Rd.  
Waterford, CT 06385  
860-440-0544