



STATE OF CONNECTICUT

CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051
Phone: (860) 827-2935 Fax: (860) 827-2950
E-Mail: siting.council@ct.gov
Web Site: www.ct.gov/csc

VIA ELECTRONIC MAIL

April 1, 2020

Justin Adams
Permitting Manager
Bloom Energy Corporation
4353 North First Street
San Jose, CA 95134

RE: **PETITION NO. 1387** – Bloom Energy Corporation declaratory ruling, pursuant to Connecticut General Statutes §4-176 and §16-50k, for the proposed construction, maintenance and operation of a grid-side 10-megawatt (MW) fuel cell facility and associated equipment to be located at Eversource Energy’s existing Judd Brook electric distribution substation, 160 Old Amston Road, Colchester, Connecticut.

Dear Mr. Adams:

The Connecticut Siting Council (Council) is in receipt of your correspondence of March 31, 2020 submitted in response to the conditions of the Council’s March 28, 2020 approval of the Development and Management Plan (D&M Plan) for the above-referenced matter.

The submission partially satisfies the Council’s D&M Plan conditions. With regard to Condition No. 1 of the Council’s March 28, 2020 approval, the submission satisfies the identification of the locations of the laydown area and material stockpile, but the submission does not satisfy the portion of Condition No. 1 that requires the submission of **revised** Drawing Nos. G1.1, C1.1 and C2.4 to depict the final erosion and sedimentation control measures consistent with the Wetland and Vernal Pool Protection Plan. Drawing No. G1.1 still indicates 10” Compost Filter Sock will be installed on the western limits of the project and Drawing No. C1.1 still indicates silt fence will be installed on the western limits of the project.

The Council recommends that Bloom Energy submit revised Drawing Nos. G1.1, C1.1 and C2.4 to depict the final erosion and sedimentation control measures consistent with the Wetland and Vernal Pool Protection Plan by April 8, 2020. If additional time is needed to gather the requested information, please submit a written request for an extension of time prior to April 8, 2020.

Please be advised that construction cannot commence prior to the submission of the revised drawings.

Thank you for your attention to this matter. Should you have any questions, please feel free to contact me at 860-827-2951.

Sincerely,

s/Melanie A. Bachman

Melanie A. Bachman
Executive Director

MB/MP

c: Paul Evan, Bloom Energy Corporation