



STATE OF CONNECTICUT  
*CONNECTICUT SITING COUNCIL*

Ten Franklin Square, New Britain, CT 06051  
Phone: (860) 827-2935 Fax: (860) 827-2950  
E-Mail: [siting.council@ct.gov](mailto:siting.council@ct.gov)  
Web Site: [www.ct.gov/csc](http://www.ct.gov/csc)

**VIA ELECTRONIC MAIL**

October 7, 2020

Kathleen Shanley  
Manager – Transmission Siting  
Eversource Energy  
56 Prospect Street  
Hartford, CT 06103

RE: **PETITION NO. 1428** - The Connecticut Light and Power Company d/b/a Eversource Energy petition for a declaratory ruling, pursuant to Connecticut General Statutes §4-176 and §16-50k, for the proposed installation of an omni-directional antenna on an existing approximately 50-foot wood pole and associated radio communications equipment located at Eversource-owned Branford 11J substation property, 272 East Main Street, Branford, Connecticut.

Dear Ms. Shanley:

The Connecticut Siting Council (Council) is in receipt of your request for an extension of time to respond to interrogatories for the above-referenced petition for a declaratory ruling dated October 6, 2020.

Pursuant to Section 16-50j-22a of the Regulations of Connecticut State Agencies, the Council hereby grants the request for an extension of time to October 8, 2020.

Sincerely,

*s/ Melanie A. Bachman*

Melanie Bachman  
Executive Director

MAB/CMW/emr

c: Service List, dated August 24, 2020

**From:** Lord, Andrew <andrew.lord@eversource.com>

**Sent:** Tuesday, October 6, 2020 3:59 PM

**To:** CSC-DL Siting Council <Siting.Council@ct.gov>

**Cc:** Bachman, Melanie <Melanie.Bachman@ct.gov>; Robidoux, Evan <Evan.Robidoux@ct.gov>; Shanley, Kathleen M <kathleen.shanley@eversource.com>; Brian Gaudet <BGaudet@allpointstech.com>

**Subject:** Petition No. 1428 - Response to Interrogatories

Good afternoon,

In regard to the Interrogatories for Petition No. 1428, the Petitioner is requesting an extension for the response to Interrogatory No. 1 until Thursday October 8th, 2020. We are working to verify additional information to ensure a complete and accurate response.

Please see the attachment for the response to Interrogatory No. 2. Please let me know if you have any questions.

Best regards,  
Andrew

Andrew Lord  
Project Siting Specialist  
56 Prospect Street  
Hartford, CT 06103  
860 608-3922

---

This electronic message contains information from Eversource Energy or its affiliates that may be confidential, proprietary or otherwise protected from disclosure. The information is intended to be used solely by the recipient(s) named. Any views or opinions expressed in this message are not necessarily those of Eversource Energy or its affiliates. Any disclosure, copying or distribution of this message or the taking of any action based on its contents, other than by the intended recipient for its intended purpose, is strictly prohibited. If you have received this e-mail in error, please notify the sender immediately and delete it from your system. Email transmission cannot be guaranteed to be error-free or secure or free from viruses, and Eversource Energy disclaims all liability for any resulting damage, errors, or omissions.



## STATE OF CONNECTICUT

### CONNECTICUT SITING COUNCIL

Ten Franklin Square, New Britain, CT 06051

Phone: (860) 827-2935 Fax: (860) 827-2950

E-Mail: [siting.council@ct.gov](mailto:siting.council@ct.gov)

Web Site: [portal.ct.gov/csc](http://portal.ct.gov/csc)

### VIA ELECTRONIC MAIL

September 22, 2020

Kathleen Shanley  
Manager – Transmission Siting  
Eversource Energy  
56 Prospect Street  
Hartford, CT 06103

**RE: PETITION NO. 1428** - The Connecticut Light and Power Company d/b/a Eversource Energy petition for a declaratory ruling, pursuant to Connecticut General Statutes §4-176 and §16-50k, for the proposed installation of an omni-directional antenna on an existing approximately 50-foot wood pole and associated radio communications equipment located at Eversource-owned Branford 11J substation property, 272 East Main Street, Branford, Connecticut.

Dear Ms. Shanley:

The Connecticut Siting Council (Council) requests your responses to the enclosed questions no later than October 6, 2020. To help expedite the Council's review, please file individual responses as soon as they are available. At this time, consistent with the Council's policy to prevent the spread of Coronavirus, please submit an electronic copy only to [siting.council@ct.gov](mailto:siting.council@ct.gov). However, please be advised that the Council may later request one or more hard copies for records retention purposes.

Any request for an extension of time to submit responses to interrogatories shall be submitted to the Council in writing pursuant to §16-50j-22a of the Regulations of Connecticut State Agencies.

Sincerely,

*s/ Melanie A. Bachman*

Melanie A. Bachman  
Executive Director

MB/CW/emr

**Petition No. 1428**  
**The Connecticut Light and Power Company d/b/a Eversource Energy**  
**272 East Main Street, Branford, Connecticut**

**Interrogatories – Set One**

1. Since the facility is located within the Federal Emergency Management Agency-designated 100-year flood zone, would any protective design measures for the radio shelter and/or generator be used? If so, indicate what measures would be utilized.

**Response is forthcoming.**

2. Referencing page 8 of the Petition, could the testing of the proposed backup generator be scheduled during daytime hours?

**Yes, the unit will be scheduled to be exercised for a 30-minute period, once per week, during daytime hours on a weekday.**

L:\siting\forms\dockets\intcvr.doc