



STATE OF CONNECTICUT

CONNECTICUT SITING COUNCIL

1 CENTRAL PARK PLAZA • NEW BRITAIN, CONN. 06051

PHONE: 827-2604

Petition No. 101 Field Review
Westport, Ct.
February 6, 1984

Mortimer Gelston, Dr. James Horsfall, and Robert Erling of the Connecticut Siting Council met Jerry Thompson of Northeast Utilities (NU) for a field review of Petition No. 101 which is associated with Petition No. 99, the proposed Department of Transportation (DOT) Sasco Creek Substation. Under this petition, NU would provide a 115 kV power supply to this substation in Westport. NU proposes to loop the existing 115 kV line that runs between CL&P's South End and United Illuminating's Ash Creek substations, into the proposed DOT substation.

The proposed structure consists of installing two 70' single circuit steel poles between two existing structures mounted on catenaries and stringing conductors from the new poles into the proposed substation. A temporary 115 kV tie between the two steel poles will be necessary; it will be removed when the permanent conductors are installed. Some right-of-way clearing of brush would be necessary to provide access to the proposed structures.

The proposed site is on the same property as that in Petition No. 99. Access to the work site would be off of Maple Lane, in conjunction with the DOT project.

Robert K. Erling
Siting Analyst

RKE :cp