



STATE OF CONNECTICUT

CONNECTICUT SITING COUNCIL

1 CENTRAL PARK PLAZA • NEW BRITAIN, CONN. 06051

PHONE: 827-2604

Petition No. 161
Field Review
September 24, 1986

Gloria Dibble Pond, William Smith, and Joel Rinebold of the Siting Council met with Bob Klanco, Dave Damer, and other representatives of the United Illuminating Company (UI) to review changes to UI's English Station power plant in New Haven, Ct.

The changes would consist of the installation and operation of two natural gas fired, 350 horsepower boilers to provide heating steam to the facility during the normal heating season. The boilers now used to provide heating steam are large, less efficient boilers originally designed to produce steam in larger quantities for power generation.

The installation of the proposed boilers would make less frequent use of the large existing boilers, and thus result in reduced fuel consumption, reduced manpower requirements, and reduced air emissions.

The change would not use additional land or require exterior construction other than for a relatively small exhaust stack to be located on the side of the existing building.

UI contends that the changes to the facility would have no substantial adverse environmental effect, and, therefore, that no certificate is required.

Respectfully submitted,

Joel M. Rinebold
Sr. Siting Analyst