Attachment D

## DEPARTMENT OF DEVELOPMENTAL SERVICES RENT SUBSIDY PROPERTY INSPECTION BASIC HEALTH AND SAFETY CHECKLIST

CONSUMER(S):		
Address:		
Provider:		
INSPECTOR: INSPECTION DATE:		
		TYPE OF RESIDENCE ROOM CONFIGURATION
	Sing	le family:
		3 family: ☐ Duplex: ☐ # of Floors:
	A	partment: Condo: # of Bedrooms:
		Other:  see comments # of Baths:
YES	No	All Locations Need
٦		A/C - D/C powered smoke detector.
	۵	Ground Fault Interrupt (GFI) outlet within 6' of running water in kitchen.
	٦	Ground Fault Interrupt (GFI) outlet within 6' of running water in bathroom.
ū	۵	Two means of egress at minimum.
ū	۵	Bottom of egress windows shall not be more that 44" above the floor.
۵	۵	Exterior doors do not operate with a key from the inside.
۵		Exterior doors do not require more than 1 or both hands engaged in a single unlocking motion.
		Bedroom & bathroom doors locks are equipped with a release device to unlock the door from the exterior.
ū	۵	Closet doors are operable from the inside.
		Electrical outlets/switches are covered.
Comments:		
Inspection Report Reviewed and Approved by:		
Signature of Executive Director Date		