

Facility DEC ID: 1282000553

**PERMIT**  
**Under the Environmental Conservation Law (ECL)**

**IDENTIFICATION INFORMATION**

Permit Type: Air State Facility

Permit ID: 1-2820-00553/00058

Effective Date:

Expiration Date:

Permit Issued To: NATIONAL GRID GENERATION LLC  
175 E OLD COUNTRY RD  
HICKSVILLE, NY 11801

Contact: CATHY WAXMAN  
NATIONAL GRID  
175 E OLD COUNTRY RD  
HICKSVILLE, NY 11801-4280  
(516) 545-2579

Facility: EF BARRETT POWER STATION  
1 MCCARTHY RD  
ISLAND PARK, NY 11558

Contact: Edyta Korczynska  
National Grid Generation LLC  
175 E Old Country Rd  
Hicksville, NY 11801  
(516) 545-5648

Description:

By acceptance of this permit, the permittee agrees that the permit is contingent upon strict compliance with the ECL, all applicable regulations, the General Conditions specified and any Special Conditions included as part of this permit.

Permit Administrator: KEVIN A KISPERT  
SUNY @ STONY BROOK  
50 CIRCLE RD  
STONY BROOK, NY 11790

Authorized Signature: \_\_\_\_\_ Date: \_\_\_\_ / \_\_\_\_ / \_\_\_\_

Facility DEC ID: 1282000553

**Notification of Other State Permittee Obligations****Item A: Permittee Accepts Legal Responsibility and Agrees to Indemnification**

The permittee expressly agrees to indemnify and hold harmless the Department of Environmental Conservation of the State of New York, its representatives, employees and agents ("DEC") for all claims, suits, actions, and damages, to the extent attributable to the permittee's acts or omissions in connection with the compliance permittee's undertaking of activities in connection with, or operation and maintenance of, the facility or facilities authorized by the permit whether in compliance or not in any compliance with the terms and conditions of the permit. This indemnification does not extend to any claims, suits, actions, or damages to the extent attributable to DEC's own negligent or intentional acts or omissions, or to any claims, suits, or actions naming the DEC and arising under article 78 of the New York Civil Practice Laws and Rules or any citizen suit or civil rights provision under federal or state laws.

**Item B: Permittee's Contractors to Comply with Permit**

The permittee is responsible for informing its independent contractors, employees, agents and assigns of their responsibility to comply with this permit, including all special conditions while acting as the permittee's agent with respect to the permitted activities, and such persons shall be subject to the same sanctions for violations of the Environmental Conservation Law as those prescribed for the permittee.

**Item C: Permittee Responsible for Obtaining Other Required Permits**

The permittee is responsible for obtaining any other permits, approvals, lands, easements and rights-of-way that may be required to carry out the activities that are authorized by this permit.

**Item D: No Right to Trespass or Interfere with Riparian Rights**

This permit does not convey to the permittee any right to trespass upon the lands or interfere with the riparian rights of others in order to perform the permitted work nor does it authorize the impairment of any rights, title, or interest in real or personal property held or vested in a person not a party to the permit.

Facility DEC ID: 1282000553

**PAGE LOCATION OF CONDITIONS**

**PAGE**

**DEC GENERAL CONDITIONS**

**General Provisions**

- |   |   |   |
|---|---|---|
| 4 | 1 | Facility Inspection by the Department                                     |
| 4 | 2 | Relationship of this Permit to Other Department Orders and Determinations |
| 4 | 3 | Applications for permit renewals, modifications and transfers             |
| 5 | 4 | Permit modifications, suspensions or revocations by the Department        |

**Facility Level**

- |   |   |  |
|---|---|--|
| 5 | 5 | Submission of application for permit modification or renewal - REGION 1 HEADQUARTERS |
|---|---|--|

Facility DEC ID: 1282000553

**DEC GENERAL CONDITIONS****\*\*\*\* General Provisions \*\*\*\*****GENERAL CONDITIONS - Apply to ALL Authorized Permits.****Condition 1: Facility Inspection by the Department****Applicable State Requirement: ECL 19-0305****Item 1.1:**

The permitted site or facility, including relevant records, is subject to inspection at reasonable hours and intervals by an authorized representative of the Department of Environmental Conservation (the Department) to determine whether the permittee is complying with this permit and the ECL. Such representative may order the work suspended pursuant to ECL 71-0301 and SAPA 401(3).

**Item 1.2:**

The permittee shall provide a person to accompany the Department's representative during an inspection to the permit area when requested by the Department.

**Item 1.3:**

A copy of this permit, including all referenced maps, drawings and special conditions, must be available for inspection by the Department at all times at the project site or facility. Failure to produce a copy of the permit upon request by a Department representative is a violation of this permit.

**Condition 2: Relationship of this Permit to Other Department Orders and Determinations****Applicable State Requirement: ECL 3-0301 (2) (m)****Item 2.1:**

Unless expressly provided for by the Department, issuance of this permit does not modify, supersede or rescind any order or determination previously issued by the Department or any of the terms, conditions or requirements contained in such order or determination.

**Condition 3: Applications for permit renewals, modifications and transfers****Applicable State Requirement: 6 NYCRR 621.11****Item 3.1:**

The permittee must submit a separate written application to the Department for renewal, modification or transfer of this permit. Such application must include any forms or supplemental information the Department requires. Any renewal, modification or transfer granted by the Department must be in writing.

**Item 3.2:**

The permittee must submit a renewal application at least 180 days before the expiration of permits for Title V and State Facility Permits.

**Item 3.3**

Permits are transferrable with the approval of the department unless specifically prohibited by the statute, regulation or another permit condition. Applications for permit transfer should be submitted prior to actual transfer of ownership.

Facility DEC ID: 1282000553

**Condition 4: Permit modifications, suspensions or revocations by the Department**  
**Applicable State Requirement: 6 NYCRR 621.13**

**Item 4.1:**

The Department reserves the right to exercise all available authority to modify, suspend, or revoke this permit in accordance with 6NYCRR Part 621. The grounds for modification, suspension or revocation include:

- a) materially false or inaccurate statements in the permit application or supporting papers;
- b) failure by the permittee to comply with any terms or conditions of the permit;
- c) exceeding the scope of the project as described in the permit application;
- d) newly discovered material information or a material change in environmental conditions, relevant technology or applicable law or regulations since the issuance of the existing permit;
- e) noncompliance with previously issued permit conditions, orders of the commissioner, any provisions of the Environmental Conservation Law or regulations of the Department related to the permitted activity.

**\*\*\*\* Facility Level \*\*\*\***

**Condition 5: Submission of application for permit modification or renewal - REGION 1 HEADQUARTERS**  
**Applicable State Requirement: 6 NYCRR 621.6 (a)**

**Item 5.1:**

Applications for permit modification or renewal are to be submitted to:  
 NYSDEC Regional Permit Administrator  
 Region 1 Headquarters  
 Division of Environmental Permits  
 Stony Brook University  
 50 Circle Road  
 Stony Brook, NY 11790-3409  
 (631) 444-0365

**Permit ID: 1-2820-00553/00058**

**Facility DEC ID: 1282000553**

**Permit Under the Environmental Conservation Law (ECL)**

**ARTICLE 19: AIR POLLUTION CONTROL - AIR STATE FACILITY PERMIT**

**IDENTIFICATION INFORMATION**

Permit Issued To: NATIONAL GRID GENERATION LLC  
175 E OLD COUNTRY RD  
HICKSVILLE, NY 11801

Facility: EF BARRETT POWER STATION  
1 MCCARTHY RD  
ISLAND PARK, NY 11558

Authorized Activity By Standard Industrial Classification Code:  
4911 - ELECTRIC SERVICES

Permit Effective Date:

Permit Expiration Date:

Permit ID: 1-2820-00553/00058

Facility DEC ID: 1282000553

**PAGE LOCATION OF CONDITIONS****PAGE****FEDERALLY ENFORCEABLE CONDITIONS****Facility Level**

- 5 1 6 NYCRR 200.6: Acceptable Ambient Air Quality
- 6 2 6 NYCRR 201-1.7: Recycling and Salvage
- 6 3 6 NYCRR 201-1.8: Prohibition of Reintroduction of Collected  
Contaminants to the air
- 6 4 6 NYCRR 201-3.2 (a): Exempt Sources - Proof of Eligibility
- 6 5 6 NYCRR 201-3.3 (a): Trivial Sources - Proof of Eligibility
- 7 6 40 CFR Part 68: Accidental release provisions.
- 7 7 6 NYCRR 201-7.1: Facility Permissible Emissions
- 7 \*8 6 NYCRR 201-7.1: Capping Monitoring Condition
- 9 9 6 NYCRR 211.2: Visible Emissions Limited
- 9 10 40CFR 63, Subpart DDDDD: Applicability
- 9 11 40CFR 63.7490(b), Subpart DDDDD: New source
- 9 12 40CFR 63.7500(e), Subpart DDDDD: Compliance Demonstration

**Emission Unit Level****EU=U--CNGH**

- 10 13 6 NYCRR 227-1.3 (a): Compliance Demonstration
- 10 14 6 NYCRR 231-11.2 (b): Compliance Demonstration
- 11 15 40CFR 63.7495(a), Subpart DDDDD: Compliance Demonstration

**STATE ONLY ENFORCEABLE CONDITIONS****Facility Level**

- 14 16 ECL 19-0301: Contaminant List
- 14 17 6 NYCRR 201-1.4: Malfunctions and start-up/shutdown activities
- 15 18 6 NYCRR Subpart 201-5: Emission Unit Definition
- 15 19 6 NYCRR Subpart 201-5: Compliance Demonstration
- 16 20 6 NYCRR 201-5.2 (c): Renewal deadlines for state facility permits
- 16 21 6 NYCRR 201-5.3 (c): Compliance Demonstration
- 17 22 6 NYCRR 211.1: Air pollution prohibited

**Emission Unit Level**

- 17 23 6 NYCRR Subpart 201-5: Emission Point Definition By Emission Unit
- 18 24 6 NYCRR Subpart 201-5: Process Definition By Emission Unit

NOTE: \* preceding the condition number indicates capping.

Permit ID: 1-2820-00553/00058

Facility DEC ID: 1282000553

# **FEDERALLY ENFORCEABLE CONDITIONS**

**\*\*\*\* Facility Level \*\*\*\***

## **NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS**

**This section contains terms and conditions which are federally enforceable. Permittees may also have other obligations under regulations of general applicability**

### **Item A: Sealing - 6 NYCRR 200.5**

The Commissioner may seal an air contamination source to prevent its operation if compliance with 6 NYCRR Chapter III is not met within the time provided by an order of the Commissioner issued in the case of the violation. Sealing means labeling or tagging a source to notify any person that operation of the source is prohibited, and also includes physical means of preventing the operation of an air contamination source without resulting in destruction of any equipment associated with such source, and includes, but is not limited to, bolting, chaining or wiring shut control panels, apertures or conduits associated with such source.

No person shall operate any air contamination source sealed by the Commissioner in accordance with this section unless a modification has been made which enables such source to comply with all requirements applicable to such modification.

Unless authorized by the Commissioner, no person shall remove or alter any seal affixed to any contamination source in accordance with this section.

### **Item B: Acceptable Ambient Air Quality - 6 NYCRR 200.6**

Notwithstanding the provisions of 6 NYCRR Chapter III, Subchapter A, no person shall allow or permit any air contamination source to emit air contaminants in quantities which alone or in combination with emissions from other air contamination sources would contravene any applicable ambient air quality standard and/or cause air pollution. In such cases where contravention occurs or may occur, the Commissioner shall specify the degree and/or method of emission control required.

### **Item C: Maintenance of Equipment - 6 NYCRR 200.7**

Any person who owns or operates an air contamination source which is equipped with an emission control device shall operate such device and keep it in a satisfactory state of maintenance and repair in accordance with ordinary and necessary practices, standards and procedures, inclusive of manufacturer's specifications, required to operate such device effectively.

### **Item D: Unpermitted Emission Sources - 6 NYCRR 201-1.2**

If an existing emission source was subject to the permitting requirements of 6 NYCRR Part 201 at the time of construction or



Permit ID: 1-2820-00553/00058

Facility DEC ID: 1282000553

modification, and the owner and/or operator failed to apply for a permit for such emission source then the following provisions apply:

(a) The owner and/or operator must apply for a permit for such emission source or register the facility in accordance with the provisions of Part 201.

(b) The emission source or facility is subject to all regulations that were applicable to it at the time of construction or modification and any subsequent requirements applicable to existing sources or facilities.

**Item E: Recycling and Salvage - 6 NYCRR 201-1.7**

Where practical, any person who owns or operates an air contamination source shall recycle or salvage air contaminants collected in an air cleaning device according to the requirements of 6 NYCRR.

**Item F: Prohibition of Reintroduction of Collected Contaminants to the Air - 6 NYCRR 201-1.8**

No person shall unnecessarily remove, handle, or cause to be handled, collected air contaminants from an air cleaning device for recycling, salvage or disposal in a manner that would reintroduce them to the outdoor atmosphere.

**Item G: Proof of Eligibility for Sources Defined as Exempt Activities - 6 NYCRR 201-3.2 (a)**

The owner and/or operator of an emission source or unit that is eligible to be exempt, may be required to certify that it operates within the specific criteria described in 6 NYCRR Subpart 201-3. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility which contains emission sources or units subject to 6 NYCRR Subpart 201-3, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations, or law.

**Item H: Proof of Eligibility for Sources Defined as Trivial Activities - 6 NYCRR 201-3.3 (a)**

The owner and/or operator of an emission source or unit that is listed as being trivial in 6 NYCRR Part 201 may be required to certify that it operates within the specific criteria described in 6 NYCRR Subpart 201-3. The owner or operator of any such emission source must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility which contains emission sources or units subject to 6 NYCRR Subpart 201-3, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution

Permit ID: 1-2820-00553/00058

Facility DEC ID: 1282000553

control requirements, regulations, or law.

**Item I: Required Emission Tests - 6 NYCRR 202-1.1**

An acceptable report of measured emissions shall be submitted, as may be required by the Commissioner, to ascertain compliance or noncompliance with any air pollution code, rule, or regulation. Failure to submit a report acceptable to the Commissioner within the time stated shall be sufficient reason for the Commissioner to suspend or deny an operating permit. Notification and acceptable procedures are specified in 6 NYCRR Subpart 202-1.

**Item J: Open Fires Prohibitions - 6 NYCRR 215.2**

Except as allowed by section 215.3 of 6 NYCRR Part 215, no person shall burn, cause, suffer, allow or permit the burning of any materials in an open fire.

**Item K: Permit Exclusion - ECL 19-0305**

The issuance of this permit by the Department and the receipt thereof by the Applicant does not and shall not be construed as barring, diminishing, adjudicating or in any way affecting any legal, administrative or equitable rights or claims, actions, suits, causes of action or demands whatsoever that the Department may have against the Applicant for violations based on facts and circumstances alleged to have occurred or existed prior to the effective date of this permit, including, but not limited to, any enforcement action authorized pursuant to the provisions of applicable federal law, the Environmental Conservation Law of the State of New York (ECL) and Chapter III of the Official Compilation of the Codes, Rules and Regulations of the State of New York (NYCRR). The issuance of this permit also shall not in any way affect pending or future enforcement actions under the Clean Air Act brought by the United States or any person.

**Item L: Federally Enforceable Requirements - 40 CFR 70.6 (b)**

All terms and conditions in this permit required by the Act or any applicable requirement, including any provisions designed to limit a facility's potential to emit, are enforceable by the Administrator and citizens under the Act. The Department has, in this permit, specifically designated any terms and conditions that are not required under the Act or under any of its applicable requirements as being enforceable under only state regulations.

**FEDERAL APPLICABLE REQUIREMENTS**

**The following conditions are federally enforceable.**

**Condition 1: Acceptable Ambient Air Quality  
Effective for entire length of Permit**

Permit ID: 1-2820-00553/00058

Facility DEC ID: 1282000553

**Applicable Federal Requirement:6 NYCRR 200.6****Item 1.1:**

Notwithstanding the provisions of 6 NYCRR Chapter III, Subchapter A, no person shall allow or permit any air contamination source to emit air contaminants in quantities which alone or in combination with emissions from other air contamination sources would contravene any applicable ambient air quality standard and/or cause air pollution. In such cases where contravention occurs or may occur, the Commissioner shall specify the degree and/or method of emission control required.

**Condition 2:     Recycling and Salvage  
                         Effective for entire length of Permit****Applicable Federal Requirement:6 NYCRR 201-1.7****Item 2.1:**

Where practical, the owner or operator of an air contamination source shall recycle or salvage air contaminants collected in an air cleaning device according to the requirements of the ECL.

**Condition 3:     Prohibition of Reintroduction of Collected Contaminants to the air  
                         Effective for entire length of Permit****Applicable Federal Requirement:6 NYCRR 201-1.8****Item 3.1:**

No person shall unnecessarily remove, handle or cause to be handled, collected air contaminants from an air cleaning device for recycling, salvage or disposal in a manner that would reintroduce them to the outdoor atmosphere.

**Condition 4:     Exempt Sources - Proof of Eligibility  
                         Effective for entire length of Permit****Applicable Federal Requirement:6 NYCRR 201-3.2 (a)****Item 4.1:**

The owner or operator of an emission source or activity that is listed as being exempt may be required to certify that it is operated within the specific criteria described in this Subpart. The owner or operator of any such emission source or activity must maintain all records necessary for demonstrating compliance with this Subpart on-site for a period of five years, and make them available to representatives of the department upon request.

**Condition 5:     Trivial Sources - Proof of Eligibility  
                         Effective for entire length of Permit****Applicable Federal Requirement:6 NYCRR 201-3.3 (a)****Item 5.1:**

The owner or operator of an emission source or activity that is listed as being trivial in this Section may be required to certify that it is operated within the specific criteria described in this Subpart. The owner or operator of any such emission source or activity must maintain all required records on-site for a period of five years and make them available to representatives of the department upon request.

Permit ID: 1-2820-00553/00058

Facility DEC ID: 1282000553

**Condition 6: Accidental release provisions.**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 40 CFR Part 68**

**Item 6.1:**

If a chemical is listed in Tables 1,2,3 or 4 of 40 CFR §68.130 is present in a process in quantities greater than the threshold quantity listed in Tables 1,2,3 or 4, the following requirements will apply:

- a) The owner or operator shall comply with the provisions of 40 CFR Part 68 and;
- b) The owner or operator shall submit at the time of permit issuance (if not previously submitted) one of the following, if such quantities are present:
  - 1) A compliance schedule for meeting the requirements of 40 CFR Part 68 by the date provided in 40 CFR §68.10(a) or,
  - 2) A certification statement that the source is in compliance with all requirements of 40 CFR Part 68, including the registration and submission of the Risk Management Plan. Information should be submitted to:

Risk Management Plan Reporting Center  
C/O CSC  
8400 Corporate Dr  
Carrollton, Md. 20785

**Condition 7: Facility Permissible Emissions**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 6 NYCRR 201-7.1**

**Item 7.1:**

The sum of emissions from the emission units specified in this permit shall not equal or exceed the following

Potential To Emit (PTE) rate for each regulated contaminant:

CAS No: 0NY210-00-0

PTE: 1.24 pounds per year

Name: OXIDES OF NITROGEN

**Condition 8: Capping Monitoring Condition**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 6 NYCRR 201-7.1**

**Item 8.1:**

Under the authority of 6 NYCRR Part 201-7, this condition contains an emission cap for the purpose of limiting emissions from the facility, emission unit or process to avoid being subject to the following applicable requirement(s) that the facility, emission unit or process would otherwise be subject to:

Permit ID: 1-2820-00553/00058

Facility DEC ID: 1282000553

6 NYCRR 201-6.1

**Item 8.2:**

Operation of this facility shall take place in accordance with the approved criteria, emission limits, terms, conditions and standards in this permit.

**Item 8.3:**

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

**Item 8.4:**

On an annual basis, unless otherwise specified below, beginning one year after the granting of an emissions cap, the responsible official shall provide a certification to the Department that the facility has operated all emission units within the limits imposed by the emission cap. This certification shall include a brief summary of the emissions subject to the cap for that time period and a comparison to the threshold levels that would require compliance with an applicable requirement.

**Item 8.5:**

The emission of pollutants that exceed the applicability thresholds for an applicable requirement, for which the facility has obtained an emissions cap, constitutes a violation of Part 201 and of the Act.

**Item 8.6:**

The Compliance Demonstration activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 0NY210-00-0      OXIDES OF NITROGEN

**Item 8.7:**

Compliance Demonstration shall include the following monitoring:

Capping: Yes

Monitoring Type: MONITORING OF PROCESS OR CONTROL DEVICE  
PARAMETERS AS SURROGATE

Monitoring Description:

The CNG Injection Station NO<sub>x</sub> emissions will be capped to 2480 lbs per year (1.24 tons per year). NO<sub>x</sub> emissions will be calculated as follows:  $G1(93) \times 10^{-6} = \text{Total Annual NO}_x \text{ (lbs)}$ .

$G1 = 12 \text{ month rolling total of SCF of natural gas in the four 4.0 MMBtu/hr heaters, in SCF/year}$

Parameter Monitored: OXIDES OF NITROGEN

Upper Permit Limit: 1.24 tons per year

Monitoring Frequency: MONTHLY

Averaging Method: ANNUAL MAXIMUM ROLLED MONTHLY

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Permit ID: 1-2820-00553/00058

Facility DEC ID: 1282000553

Subsequent reports are due every 6 calendar month(s).

**Condition 9: Visible Emissions Limited**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 6 NYCRR 211.2**

**Item 9.1:**

Except as permitted by a specific part of this Subchapter and for open fires for which a restricted burning permit has been issued, no person shall cause or allow any air contamination source to emit any material having an opacity equal to or greater than 20 percent (six minute average) except for one continuous six-minute period per hour of not more than 57 percent opacity.

**Condition 10: Applicability**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 40 CFR 63, Subpart DDDDD**

**Item 10.1:**

Facilities that are major sources of HAP with industrial, commercial, or institutional boilers and/or process heaters must comply with applicable portions of 40 CFR 63 DDDDD.

**Condition 11: New source**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 40 CFR 63.7490(b), Subpart DDDDD**

**Item 11.1:**

A boiler or process heater is new if the owner or operator commenced construction of the boiler or process heater after June 4, 2010.

**Condition 12: Compliance Demonstration**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 40 CFR 63.7500(e), Subpart DDDDD**

**Item 12.1:**

The Compliance Demonstration activity will be performed for the Facility.

**Item 12.2:**

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Boilers and process heaters in the units designed to burn gas 1 fuels subcategory with a heat input capacity of less than or equal to 5 million Btu per hour must complete a tune-up every 5 years as specified in 40 CFR 63.7540.

Permit ID: 1-2820-00553/00058

Facility DEC ID: 1282000553

Monitoring Frequency: Once every five years  
Reporting Requirements: SEMI-ANNUALLY (CALENDAR)  
Reports due 30 days after the reporting period.  
Subsequent reports are due every 6 calendar month(s).

**\*\*\*\* Emission Unit Level \*\*\*\***

**Condition 13: Compliance Demonstration**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 6 NYCRR 227-1.3 (a)**

**Item 13.1:**

The Compliance Demonstration activity will be performed for:

Emission Unit: U--CNGH

**Item 13.2:**

Compliance Demonstration shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL DEVICE  
PARAMETERS AS SURROGATE

Monitoring Description:

No person shall operate a stationary combustion installation which exhibits greater than 20 percent opacity (based on a six minute average), except for one 6 minute period per hour of not more than 27 percent opacity. The applicant will conduct a Method 9 test annually. A report of the results of the test will be submitted to the Department within 30 days of the completion of the Method 9 test. All records generated by the permittee will be maintained at the facility for a minimum of five years.

Parameter Monitored: OPACITY

Upper Permit Limit: 20 percent

Reference Test Method: Method 9

Monitoring Frequency: ANNUALLY

Averaging Method: 6-MINUTE AVERAGE (METHOD 9)

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

**Condition 14: Compliance Demonstration**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 6 NYCRR 231-11.2 (b)**

**Item 14.1:**

The Compliance Demonstration activity will be performed for:

Emission Unit: U--CNGH

Permit ID: 1-2820-00553/00058

Facility DEC ID: 1282000553

**Item 14.2:**

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

For a modification with a project emission potential that does not utilize the emissions exclusion allowed under section 231-4.1(b)(41)(i)(c) of this Part and which is less than 50 percent of the applicable significant project threshold in Table 3, Table 4 or Table 6 of Subpart 231-13 of this Part, or for a modification with a project emission potential which when added to emissions excluded in accordance with clause 231-4.1(b)(41)(i)(c) of this Part is less than 50 percent of the applicable significant project threshold in Table 3, Table 4 or Table 6 of Subpart 231-13 of this Part, the facility owner or operator, in addition to complying with any requirements under Part 201 of this Title, must maintain the following information for a minimum of five years:

- (1) A description of the modification.
- (2) An identification of each new or modified emission source(s) including the associated processes and emission unit.
- (3) The calculation of the project emission potential for each modified emission source(s) including supporting documentation.
- (4) The date the modification commenced operation.

These recordkeeping requirements apply to exempt and trivial activities but do not affect their exempt or trivial permitting status under Subpart 201-3 of this Title. The facility must submit these records to the Department, upon the Department's request.

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

**Condition 15: Compliance Demonstration**  
**Effective for entire length of Permit**

**Applicable Federal Requirement: 40CFR 63.7495(a), Subpart DDDDD**

**Item 15.1:**

The Compliance Demonstration activity will be performed for:

Emission Unit: U--CNGH

**Item 15.2:**

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

The owner or operator of a new or reconstructed boiler or process heater must comply with subpart DDDDD by April 1, 2013 or upon startup



**Permit ID: 1-2820-00553/00058**

**Facility DEC ID: 1282000553**

of the boiler or process heater, whichever is later.

Reporting Requirements: ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 12 calendar month(s).

Permit ID: 1-2820-00553/00058

Facility DEC ID: 1282000553

**STATE ONLY ENFORCEABLE CONDITIONS****\*\*\*\* Facility Level \*\*\*\*****NOTIFICATION OF GENERAL PERMITTEE OBLIGATIONS**

**This section contains terms and conditions which are not federally enforceable. Permittees may also have other obligations under regulations of general applicability**

**Item A: Emergency Defense - 6 NYCRR 201-1.5**

An emergency, as defined by subpart 201-2, constitutes an affirmative defense to penalties sought in an enforcement action brought by the Department for noncompliance with emissions limitations or permit conditions for all facilities in New York State.

(a) The affirmative defense of emergency shall be demonstrated through properly signed, contemporaneous operating logs, or other relevant evidence that:

(1) An emergency occurred and that the facility owner or operator can identify the cause(s) of the emergency;

(2) The equipment at the permitted facility causing the emergency was at the time being properly operated and maintained;

(3) During the period of the emergency the facility owner or operator took all reasonable steps to minimize levels of emissions that exceeded the emission standards, or other requirements in the permit; and

(4) The facility owner or operator notified the Department within two working days after the event occurred. This notice must contain a description of the emergency, any steps taken to mitigate emissions, and corrective actions taken.

(b) In any enforcement proceeding, the facility owner or operator seeking to establish the occurrence of an emergency has the burden of proof.

(c) This provision is in addition to any emergency or upset provision contained in any applicable requirement.

**Item B: Public Access to Recordkeeping for Facilities With State Facility Permits - 6 NYCRR 201-1.10 (a)**

Where facility owners and/or operators keep records pursuant to compliance with the requirements of 6 NYCRR Subpart 201-5.4, and/or the emission capping requirements of 6 NYCRR Subpart 201-7, the Department will make such records available to the public upon request in accordance with 6 NYCRR Part 616 - Public Access to Records. Facility owners and/or operators must submit the records required to comply with the request within sixty working days of written notification by the Department.

**Item C: General Provisions for State Enforceable Permit Terms and Condition -**

Permit ID: 1-2820-00553/00058

Facility DEC ID: 1282000553

**6 NYCRR Part 201-5**

Any person who owns and/or operates stationary sources shall operate and maintain all emission units and any required emission control devices in compliance with all applicable Parts of this Chapter and existing laws, and shall operate the facility in accordance with all criteria, emission limits, terms, conditions, and standards in this permit. Failure of such person to properly operate and maintain the effectiveness of such emission units and emission control devices may be sufficient reason for the Department to revoke or deny a permit.

The owner or operator of the permitted facility must maintain all required records on-site for a period of five years and make them available to representatives of the Department upon request. Department representatives must be granted access to any facility regulated by this Subpart, during normal operating hours, for the purpose of determining compliance with this and any other state and federal air pollution control requirements, regulations or law.

**STATE ONLY APPLICABLE REQUIREMENTS**

**The following conditions are state only enforceable.**

**Condition 16: Contaminant List**  
**Effective for entire length of Permit**

**Applicable State Requirement: ECL 19-0301**

**Item 16.1:**

Emissions of the following contaminants are subject to contaminant specific requirements in this permit (emission limits, control requirements or compliance monitoring conditions).

CAS No: 0NY210-00-0

Name: OXIDES OF NITROGEN

**Condition 17: Malfunctions and start-up/shutdown activities**  
**Effective for entire length of Permit**

**Applicable State Requirement: 6 NYCRR 201-1.4**

**Item 17.1:**

(a) The facility owner or operator shall take all necessary and appropriate actions to prevent the emission of air pollutants that result in contravention of any applicable emission standard during periods of start-up, shutdown, or malfunction.

(b) The facility owner or operator shall compile and maintain records of all equipment malfunctions, maintenance, or start-up/shutdown activities when they can be expected to result in an exceedance of any applicable emission standard, and shall submit a report of such activities to the department when requested to do so, or when so required by a condition of a permit issued for the corresponding air contamination source. Such reports shall state whether

Permit ID: 1-2820-00553/00058

Facility DEC ID: 1282000553

any violations occurred and, if so, whether they were unavoidable, include the time, frequency and duration of the maintenance and/or start-up/shutdown activities, and an estimate of the emission rates of any air contaminants released. Such records shall be maintained for a period of at least five years and made available for review to department representatives upon request. Facility owners or operators subject to continuous stack monitoring and quarterly reporting requirements need not submit additional reports for equipment maintenance or start-up/shutdown activities for the facility to the department.

(c) In the event that emissions of air contaminants in excess of any emission standard in this Subchapter occur due to a malfunction, the facility owner or operator shall compile and maintain records of the malfunction and notify the department as soon as possible during normal working hours, but not later than two working days after becoming aware that the malfunction occurred. When requested by the department, the facility owner or operator shall submit a written report to the department describing the malfunction, the corrective action taken, identification of air contaminants, and an estimate of the emission rates.

(d) The department may also require the owner or operator to include, in reports described under Subdivisions (b) and (c) of this Section, an estimate of the maximum ground level concentration of each air contaminant emitted and the effect of such emissions.

(e) A violation of any applicable emission standard resulting from start-up, shutdown, or malfunction conditions at a permitted or registered facility may not be subject to an enforcement action by the department and/or penalty if the department determines, in its sole discretion, that such a violation was unavoidable. The actions and recordkeeping and reporting requirements listed above must be adhered to in such circumstances.

**Condition 18: Emission Unit Definition**  
**Effective for entire length of Permit**

**Applicable State Requirement:6 NYCRR Subpart 201-5**

**Item 18.1:**

The facility is authorized to perform regulated processes under this permit for:

Emission Unit: U--CNGH

Emission Unit Description:

The CNG injection station includes the addition of two decompression skids that will include a total of four (4) 4.00 MMBTU/hr natural gas fired heaters with Eclipse ThermAir Burners.

Building(s): CNG

**Condition 19: Compliance Demonstration**  
**Effective for entire length of Permit**

**Applicable State Requirement:6 NYCRR Subpart 201-5**

**Item 19.1:**

The Compliance Demonstration activity will be performed for the Facility.

Regulated Contaminant(s):

CAS No: 0NY210-00-0 OXIDES OF NITROGEN

Permit ID: 1-2820-00553/00058

Facility DEC ID: 1282000553

**Item 19.2:**

Compliance Demonstration shall include the following monitoring:

Monitoring Type: MONITORING OF PROCESS OR CONTROL DEVICE  
PARAMETERS AS SURROGATE

Monitoring Description:

Annual volumetric natural gas flow rate of 6,667,400 scf/yr for each 4.00 MMBtu/hr heater will be monitored by using a gas flow meter. Monthly readings will be recorded from the gas flow meter. Records shall be kept in a log book, reported to the Department and must be kept for a minimum of five years.

Parameter Monitored: VOLUMETRIC FLOW RATE

Upper Permit Limit: 6667400 standard cubic feet per year

Monitoring Frequency: MONTHLY

Averaging Method: ANNUAL MAXIMUM ROLLED MONTHLY

Reporting Requirements: SEMI-ANNUALLY (CALENDAR)

Reports due 30 days after the reporting period.

Subsequent reports are due every 6 calendar month(s).

**Condition 20: Renewal deadlines for state facility permits**  
**Effective for entire length of Permit**

**Applicable State Requirement: 6 NYCRR 201-5.2 (c)**

**Item 20.1:**

The owner or operator of a facility having an issued state facility permit shall submit a complete application at least 180 days, but not more than eighteen months, prior to the date of permit expiration for permit renewal purposes.

**Condition 21: Compliance Demonstration**  
**Effective for entire length of Permit**

**Applicable State Requirement: 6 NYCRR 201-5.3 (c)**

**Item 21.1:**

The Compliance Demonstration activity will be performed for the Facility.

**Item 21.2:**

Compliance Demonstration shall include the following monitoring:

Monitoring Type: RECORD KEEPING/MAINTENANCE PROCEDURES

Monitoring Description:

Any reports or submissions required by this permit shall be submitted to the Regional Air Pollution Control Engineer (RAPCE) at the following address:

Division of Air Resources

Permit ID: 1-2820-00553/00058

Facility DEC ID: 1282000553

NYS Dept. of Environmental Conservation  
Region 1  
SUNY at Stony Brook  
Building 40  
Stony Brook, NY 11790-2356

Reporting Requirements: AS REQUIRED - SEE MONITORING DESCRIPTION

**Condition 22: Air pollution prohibited**  
**Effective for entire length of Permit**

**Applicable State Requirement: 6 NYCRR 211.1****Item 22.1:**

No person shall cause or allow emissions of air contaminants to the outdoor atmosphere of such quantity, characteristic or duration which are injurious to human, plant or animal life or to property, or which unreasonably interfere with the comfortable enjoyment of life or property. Notwithstanding the existence of specific air quality standards or emission limits, this prohibition applies, but is not limited to, any particulate, fume, gas, mist, odor, smoke, vapor, pollen, toxic or deleterious emission, either alone or in combination with others.

**\*\*\*\* Emission Unit Level \*\*\*\***

**Condition 23: Emission Point Definition By Emission Unit**  
**Effective for entire length of Permit**

**Applicable State Requirement: 6 NYCRR Subpart 201-5****Item 23.1:**

The following emission points are included in this permit for the cited Emission Unit:

Emission Unit: U--CNGH

Emission Point: CNGH1			
Height (ft.): 14	Diameter (in.): 14		
NYTMN (km.): 4496.8	NYTME (km.): 614.36	Building: CNG	
Emission Point: CNGH2			
Height (ft.): 14	Diameter (in.): 14		
NYTMN (km.): 4496.8	NYTME (km.): 614.36	Building: CNG	
Emission Point: CNGH3			
Height (ft.): 14	Diameter (in.): 14		
NYTMN (km.): 4496.8	NYTME (km.): 614.36	Building: CNG	
Emission Point: CNGH4			
Height (ft.): 14	Diameter (in.): 14		
NYTMN (km.): 4496.8	NYTME (km.): 614.36	Building: CNG	

Permit ID: 1-2820-00553/00058

Facility DEC ID: 1282000553

**Condition 24: Process Definition By Emission Unit**  
**Effective for entire length of Permit**

**Applicable State Requirement: 6 NYCRR Subpart 201-5**

**Item 24.1:**

This permit authorizes the following regulated processes for the cited Emission Unit:

Emission Unit: U--CNGH

Process: 001

Source Classification Code: 1-02-006-03

Process Description:

Four (4) 4.00 MMBtu/hr natural gas fired heaters with Eclipse  
ThermAir Burners associated with two (2) CNG injection skids.

Emission Source/Control: CNGH1 - Combustion

Emission Source/Control: CNGH2 - Combustion

Emission Source/Control: CNGH3 - Combustion

Emission Source/Control: CNGH4 - Combustion

**Permit ID: 1-2820-00553/00058**

**Facility DEC ID: 1282000553**



Summary of Compliance Requirements

\*\*\* THIS SUMMARY IS NOT ENFORCEABLE BUT IS MERELY INTENDED TO PROVIDE A CONCISE VIEW OF THE MONITORING REQUIREMENTS.

READERS ARE DIRECTED TO THE MAIN PERMIT FOR DETAILS REGARDING ENFORCEABLE CONDITIONS. \*\*\*

DEC ID 1282000553 Facility EF BARRETT POWER STATION

Location 1 MCCARTHY RD ISLAND PARK, NY 11558

Permit ID 1-2820-00553/00058 Application Recv'd 04/27/2020 Renewal No: 0

Permit Type ASF Status Draft

Compliance Assurance Monitoring				Activity Type
Monitored Parameter				Reporting Frequency
Cond	Regulated Contaminant	Lower Limit	Upper Limit	Monitoring Frequency
Num	Process Material	Units		Averaging Method
8	OXIDES OF NITROGEN		1.24	MONITORING OF PROCESS OR CONTROL DEVICE PARAMETERS AS SURROGATE
CAP	OXIDES OF NITROGEN	tons per year		SEMI-ANNUALLY (CALENDAR)
	****			
	THE CNG INJECTION STATION NOX EMISSIONS WILL BE CAPPED TO 2480 LBS PER YEAR (1.24 TONS PER YEAR). NOX EMISSIONS WILL BE CALCULATED AS FOLLOWS: $G1(93) \times 10^{-6} = \text{TOTAL ANNUAL NOX (LBS)}$ . G1= 12 MONTH ROLLING TOTAL OF SCF OF NATURAL GAS IN THE FOUR 4.0 MMBTU/HR HEATERS, IN SCF/YEAR			MONTHLY
				ANNUAL MAXIMUM ROLLED MONTHLY
12	****			RECORD KEEPING/MAINTENANCE PROCEDURES
	****			
	****			SEMI-ANNUALLY (CALENDAR)
	BOILERS AND PROCESS HEATERS IN THE UNITS DESIGNED TO BURN GAS 1 FUELS SUBCATEGORY WITH A HEAT INPUT CAPACITY OF LESS THAN OR EQUAL TO 5 MILLION BTU PER HOUR MUST COMPLETE A TUNE-UP EVERY 5 YEARS AS SPECIFIED IN 40 CFR 63.7540.			Once every five years
				****

Summary of Compliance Requirements

\*\*\* THIS SUMMARY IS NOT ENFORCEABLE BUT IS MERELY INTENDED TO PROVIDE A CONCISE VIEW OF THE MONITORING REQUIREMENTS.

READERS ARE DIRECTED TO THE MAIN PERMIT FOR DETAILS REGARDING ENFORCEABLE CONDITIONS. \*\*\*

DEC ID 1282000553 Facility EF BARRETT POWER STATION

Location 1 MCCARTHY RD ISLAND PARK, NY 11558

Permit ID 1-2820-00553/00058 Application Recv'd 04/27/2020 Renewal No: 0

Permit Type ASF Status Draft

Compliance Assurance Monitoring

Monitored Parameter				Reporting Frequency
Cond	Regulated Contaminant	Lower Limit	Upper Limit	Monitoring Frequency
Num	Process Material	Units		Averaging Method
Emission Unit: U--CNGH				
13	OPACITY		20	MONITORING OF PROCESS OR CONTROL DEVICE PARAMETERS AS SURROGATE
	****	percent		AS REQUIRED - SEE MONITORING DESCRIPTION
	****			ANNUALLY
	NO PERSON SHALL OPERATE A STATIONARY COMBUSTION INSTALLATION WHICH EXHIBITS GREATER THAN 20 PERCENT OPACITY (BASED ON A SIX MINUTE AVERAGE), EXCEPT FOR ONE 6 MINUTE PERIOD PER HOUR OF NOT MORE THAN 27 PERCENT OPACITY. THE APPLICANT WILL CONDUCT A METHOD 9 TEST ANNUALLY. A REPORT OF THE RESULTS OF THE TEST WILL BE SUBMITTED TO THE DEPARTMENT WITHIN 30 DAYS OF THE COMPLETION OF THE METHOD 9 TEST. ALL RECORDS GENERATED BY THE PERMITTEE WILL BE MAINTAINED AT THE FACILITY FOR A MINIMUM OF FIVE YEARS.			6-MINUTE AVERAGE (METHOD 9)

Summary of Compliance Requirements

\*\*\* THIS SUMMARY IS NOT ENFORCEABLE BUT IS MERELY INTENDED TO PROVIDE A CONCISE VIEW OF THE MONITORING REQUIREMENTS.

READERS ARE DIRECTED TO THE MAIN PERMIT FOR DETAILS REGARDING ENFORCEABLE CONDITIONS. \*\*\*

DEC ID 1282000553      Facility EF BARRETT POWER STATION

Location 1 MCCARTHY RD ISLAND PARK, NY 11558

Permit ID 1-2820-00553/00058      Application Recv'd 04/27/2020      Renewal No: 0

Permit Type ASF      Status Draft

Compliance Assurance Monitoring				Activity Type
Monitored Parameter				Reporting Frequency
Cond	Regulated Contaminant	Lower Limit	Upper Limit	Monitoring Frequency
Num	Process Material	Units		Averaging Method

Emission Unit: U--CNGH

14	<div>****</div> <div>****</div> <div>****</div> <div> FOR A MODIFICATION WITH A PROJECT EMISSION POTENTIAL THAT DOES NOT UTILIZE THE EMISSIONS EXCLUSION ALLOWED UNDER SECTION 231-4.1(B)(41)(I)(C) OF THIS PART AND WHICH IS LESS THAN 50 PERCENT OF THE APPLICABLE SIGNIFICANT PROJECT THRESHOLD IN TABLE 3, TABLE 4 OR TABLE 6 OF SUBPART 231-13 OF THIS PART, OR FOR A MODIFICATION WITH A PROJECT EMISSION POTENTIAL WHICH WHEN ADDED TO EMISSIONS EXCLUDED IN ACCORDANCE WITH CLAUSE 231-4.1(B)(41)(I)(C) OF THIS PART IS LESS THAN 50 PERCENT OF THE APPLICABLE SIGNIFICANT PROJECT THRESHOLD IN TABLE 3, TABLE 4 OR TABLE 6 OF SUBPART 231-13 OF THIS PART, THE FACILITY OWNER OR OPERATOR, IN ADDITION TO COMPLYING WITH ANY REQUIREMENTS UNDER PART 201 OF THIS TITLE, MUST MAINTAIN THE FOLLOWING INFORMATION FOR A MINIMUM OF FIVE YEARS:</div> <div>(1) A DESCRIPTION OF THE MODIFICATION.</div> <div>(2) AN IDENTIFICATION OF EACH NEW OR MODIFIED EMISSION SOURCE(S) INCLUDING THE ASSOCIATED PROCESSES AND EMISSION UNIT.</div> <div>(3) THE CALCULATION OF THE PROJECT EMISSION POTENTIAL FOR EACH MODIFIED EMISSION SOURCE(S) INCLUDING SUPPORTING DOCUMENTATION.</div> <div>(4) THE DATE THE MODIFICATION COMMENCED OPERATION.</div> <div>THESE RECORDKEEPING REQUIREMENTS APPLY TO EXEMPT AND TRIVIAL ACTIVITIES BUT DO NOT AFFECT THEIR EXEMPT OR TRIVIAL PERMITTING STATUS UNDER SUBPART 201-3 OF THIS TITLE. THE FACILITY MUST SUBMIT THESE RECORDS TO THE DEPARTMENT, UPON THE DEPARTMENT'S REQUEST.</div>	<div>RECORD KEEPING/MAINTENANCE PROCEDURES</div> <div>AS REQUIRED - SEE MONITORING DESCRIPTION</div> <div>****</div> <div>****</div>
----	--	--

Summary of Compliance Requirements

\*\*\* THIS SUMMARY IS NOT ENFORCEABLE BUT IS MERELY INTENDED TO PROVIDE A CONCISE VIEW OF THE MONITORING REQUIREMENTS.

READERS ARE DIRECTED TO THE MAIN PERMIT FOR DETAILS REGARDING ENFORCEABLE CONDITIONS. \*\*\*

DEC ID 1282000553 Facility EF BARRETT POWER STATION

Location 1 MCCARTHY RD ISLAND PARK, NY 11558

Permit ID 1-2820-00553/00058 Application Recv'd 04/27/2020 Renewal No: 0

Permit Type ASF Status Draft

Compliance Assurance Monitoring				Activity Type
Monitored Parameter				Reporting Frequency
Cond	Regulated Contaminant	Lower Limit	Upper Limit	Monitoring Frequency
Num	Process Material	Units		Averaging Method
Emission Unit: U--CNGH				
15	****			RECORD KEEPING/MAINTENANCE PROCEDURES
	****			
	****			ANNUALLY (CALENDAR)
	THE OWNER OR OPERATOR OF A NEW OR RECONSTRUCTED BOILER OR PROCESS HEATER MUST COMPLY WITH SUBPART DDDDD BY APRIL 1, 2013 OR UPON STARTUP OF THE BOILER OR PROCESS HEATER, WHICHEVER IS LATER.			****
				****
19	VOLUMETRIC FLOW RATE		6667400	MONITORING OF PROCESS OR CONTROL DEVICE PARAMETERS AS SIIRROGATF
	OXIDES OF NITROGEN	standard cubic feet per year		SEMI-ANNUALLY (CALENDAR)
	****			
	ANNUAL VOLUMETRIC NATURAL GAS FLOW RATE OF 6,667,400 SCF/YR FOR EACH 4.00 MMBTU/HR HEATER WILL BE MONITORED BY USING A GAS FLOW METER. MONTHLY READINGS WILL BE RECORDED FROM THE GAS FLOW METER. RECORDS SHALL BE KEPT IN A LOG BOOK, REPORTED TO THE DEPARTMENT AND MUST BE KEPT FOR A MINIMUM OF FIVE YEARS.			MONTHLY
				ANNUAL MAXIMUM ROLLED MONTHLY

Summary of Compliance Requirements

\*\*\* THIS SUMMARY IS NOT ENFORCEABLE BUT IS MERELY INTENDED TO PROVIDE A CONCISE VIEW OF THE MONITORING REQUIREMENTS.

READERS ARE DIRECTED TO THE MAIN PERMIT FOR DETAILS REGARDING ENFORCEABLE CONDITIONS. \*\*\*

DEC ID 1282000553 Facility EF BARRETT POWER STATION

Location 1 MCCARTHY RD ISLAND PARK, NY 11558

Permit ID 1-2820-00553/00058 Application Recv'd 04/27/2020 Renewal No: 0

Permit Type ASF Status Draft

Compliance Assurance Monitoring

Monitored Parameter				Reporting Frequency
Cond	Regulated Contaminant	Lower Limit	Upper Limit	Monitoring Frequency
Num	Process Material	Units		Averaging Method
21	****			RECORD KEEPING/MAINTENANCE PROCEDURES
	****			
	****			AS REQUIRED - SEE MONITORING DESCRIPTION
	ANY REPORTS OR SUBMISSIONS REQUIRED BY THIS PERMIT SHALL BE SUBMITTED TO THE REGIONAL AIR POLLUTION CONTROL ENGINEER (RAPCE) AT THE FOLLOWING ADDRESS:			****
	DIVISION OF AIR RESOURCES NYS DEPT. OF ENVIRONMENTAL CONSERVATION REGION 1 SUNY AT STONY BROOK BUILDING 40 STONY BROOK, NY 11790-2356			****

**Summary of Compliance Requirements**

**\*\*\* THIS SUMMARY IS NOT ENFORCEABLE BUT IS MERELY INTENDED TO PROVIDE A CONCISE VIEW OF FACILITY PERMISSIBLE EMISSIONS.  
READERS ARE DIRECTED TO THE MAIN PERMIT FOR DETAILS REGARDING ENFORCEABLE CONDITIONS. \*\*\***

**DEC ID 1282000553      Facility EF BARRETT POWER STATION**

**Location 1 MCCARTHY RD ISLAND PARK, NY 11558**

**Permit ID 1-2820-00553/00058    Application Recv'd 04/27/2020    Renewal No: 0**

**Permit Type ASF    Status Draft**

**Facility Permissible Emissions**

<b>0NY210-00-0    OXIDES OF NITROGEN</b>	<b>1.24 pounds per year</b>
--	-----------------------------