

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0210011	AQUARION-FALLS VILLAGE	C	488	L	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
AQUARION WATER CO OF CT-FALLS VILLAGE	Connections				125

Towns Served: CANAAN

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

Asbestos (1094)	3 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30		Complete
Total Coliform (3100)	2 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
Lead And Copper (PBCU)	5 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/27	6/1-9/30	
Physical Parameters (PPS)	2 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: **ENTRY POINT-WELLS #3 & #4** (WSF ID: 00701)

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL 3&4 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0210011	AQUARION-FALLS VILLAGE	C	488	L	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
AQUARION WATER CO OF CT-FALLS VILLAGE	Connections				125

Towns Served: CANAAN

Monitoring Requirements

Water System Facility: **ENTRY POINT-WELLS #3 & #4 (WSF ID: 00701)**

Nitrate And Nitrite (NOX)			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL 3&4 (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL 3&4 (3)	1/1/25 - 12/31/30		
Pesticides, Herbicides and PCBs-Phase II (SOC2)			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL 3&4 (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		
Pesticides, Herbicides and PCBs-Phase V (SOC5)			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL 3&4 (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		
Organic Chemicals (VOCS)			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL 3&4 (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Water System Facility: **ENTRY POINT-WELLS #5 & #6 (WSF ID: 00702)**

Net Gross Alpha (4000)			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL 5&6 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Uranium (4006)			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL 5&6 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Combined Radium-226/228 (4010)			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL 5&6 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Inorganic Chemicals (IOCS)			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL 5&6 (3)	1/1/23 - 12/31/25		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0210011	AQUARION-FALLS VILLAGE	C	488	L	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
AQUARION WATER CO OF CT-FALLS VILLAGE	Connections				125

Towns Served: CANAAN

Monitoring Requirements

Water System Facility: ENTRY POINT-WELLS #5 & #6 (WSF ID: 00702)

Inorganic Chemicals (IOCS)		1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		
Nitrate And Nitrite (NOX)			1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT-WELL 5&6 (3)	1/1/25 - 12/31/25			Complete
	1/1/26 - 12/31/26			
	1/1/27 - 12/31/27			
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)			1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT-WELL 5&6 (3)	1/1/23 - 12/31/25			Complete
	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			
Organic Chemicals (VOCS)			1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT-WELL 5&6 (3)	1/1/23 - 12/31/25			Complete
	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
MAIL/HAND DELIVER NOTICE TO CONSUMERS	12/31/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2026	
CERTIFY LEAD SL NOTIFICATION	7/1/2026	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
					Rule			
00600	DISTRIBUTION SYSTEM	00587	TORRINGTON SAV BANK	A	Y			Y
		00588	CANAAN TOWN HALL	A	Y			Y
		00588D	CANAAN TOWN HALL -	A	Y			
		00588U	CANAAN TOWN HALL -	A	Y			
		00591	FALLS VILLAGE ELDERL	A	Y			
		00592	FALLS VILLAGE INN	A	Y			Y
		00592D	FALLS VILLAGE INN -	A	Y			
		00592U	UPSTREAM FALLS VILLA	A	Y			
		05986	BEEBE HILL RD SS	A	Y			Y
		05987	RAILROAD ST SS	A	Y			Y
				4	GENERIC DISTRIBUTION	A	Y	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0210011	AQUARION-FALLS VILLAGE	C	488	L	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
AQUARION WATER CO OF CT-FALLS VILLAGE	Connections				125

Towns Served: CANAAN

Water System Facility and Sampling Point Inventory						
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier
					Asbestos	WQP 2 DBPR
	CWD001	TOWN HALL - LAV SINK	A	Y	2	
	CWD002	TORRINGTON SAV BANK	A	Y		
	CWD003	108 MAIN ST	A	Y		Y
	CWD003 - 10	GENERATED BY BATCH	A	Y		
	CWD004	KELLOGG SCHOOL	A	Y	2	
	CWD005	114 BEEBE HILL RD	A	Y		
	CWD005 - 11	GENERATED BY BATCH	A	Y		
	CWD006	40 BEEBE HILL RD	A	Y		
	CWD006 - 40	GENERATED BY BATCH	A	Y		
	CWD007	107 MAIN ST	A	Y		
	CWD007 - 10	GENERATED BY BATCH	A	Y		
	CWD008	FALLS VILLAGE INN	A	Y		
	CWD009	JACOBS GARAGE	A	Y		
	CWD009 - JA	GENERATED BY BATCH	A	Y		
	DOWNSTREAM	WITHIN 5 SERVICE CON	A			
	PB8964	PB8964 - 50 BEEBE HI	A	Y		
	PB8966	PB8966 - 114 BEEBE H	A	Y		
	PB8967	17 FACCHIN ST	A		3	
	PB8968	PB8968 - 21 FACCHIN	A	Y		
	PB8969	PB8969 - 22 FACCHIN	A	Y		
	PB8970	PB8970 - 32 MAIN ST	A	Y		
	PB8971	38 MAIN ST	A		3	
	PB8972	PB8972 - 93 MAIN ST	A	Y		
	PB8973	PB8973 - 104 MAIN ST	A	Y		
	PB8974	PB8974 - 19 PROSPECT	A	Y		
	PB8975	40 PROSPECT ST	A		3	
	PB8976	PB8976 - 55 PROSPECT	A	Y		
	PB8977	45 RAILROAD ST	A		3	
	PB8978	PB8978 - 92 RAILROAD	A	Y		
	UPSTREAM	WITHIN 5 SERVICE CON	A			
00701	ENTRY POINT-WELLS #3 & #4	3	ENTRY POINT-WELL 3&4	A		
00702	ENTRY POINT-WELLS #5 & #6	3	ENTRY POINT-WELL 5&6	A		
24	WELL 3	2	WELL 3	A		
25	WELL 4	2	WELL 4	A		
26	WELL 5	2	WELL 5	A		
27	WELL 6	2	WELL 6	A		
57517	ATMOSPHERIC STORAGE 1					
57519	ATMOSPHERIC STORAGE 2					

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0210011	AQUARION-FALLS VILLAGE	C	488	L	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
AQUARION WATER CO OF CT-FALLS VILLAGE	Connections				125

Towns Served: CANAAN

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total	Lead and Coliform	Copper	Stage	
				Status	Rule	Rule Tier		
57521	PUMP STATION							

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification:	Certification		
Operator Name	Operator Type	Certification(s)	Expiration
GAGNON, MATTHEW B.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS III	3/31/2027 3/31/2027
GEDDES, HOLLY	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2027

Contact Information

Name	Organization	Job Title		
Mr. Robert J. Ulrich	Aquarion Water Company of Ct	Vp-Supply & Utility		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
505 Huntington St.		Shelton	CT	06484
Business Phone	Extension	Fax	Mobile Phone	Email Address
203-926-4320		203-929-5297		203-395-3205 rulrich@aquarionwater.com

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0210091	PINE GROVE ASSOCIATION, INC.	C	248	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		60			Agricultural

Towns Served: CANAAN

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

Chlorine Residual (1012)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
Asbestos (1094)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30		
Total Haloacetic Acids (2456)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
UNIT 21 (CANPINE008)	1/1/25 - 12/31/25	7/1-7/31	Complete
	1/1/26 - 12/31/26	7/1-7/31	
	1/1/27 - 12/31/27	7/1-7/31	
Total Trihalomethanes (2950)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
FIELD TAP OPP # 4 (CANPINE010)	1/1/25 - 12/31/25	7/1-7/31	Complete
	1/1/26 - 12/31/26	7/1-7/31	
	1/1/27 - 12/31/27	7/1-7/31	
Total Coliform (3100)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
Lead And Copper (PBCU)	5 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/27	6/1-9/30	
Physical Parameters (PPS)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: **ENTRY POINT** (WSF ID: 00700)

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0210091	PINE GROVE ASSOCIATION, INC.	C	248	P	GW
Local Address (where applicable)	Service Connections	Residential 60	Commercial	Industrial	Combined

Towns Served: CANAAN

Monitoring Requirements

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Net Gross Alpha (4000)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Uranium (4006)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Combined Radium-226/228 (4010)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Organic Chemicals (VOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/27		

Monthly Water System Facility (WSF) Level Monitoring Requirements

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0210091	PINE GROVE ASSOCIATION, INC.	C	248	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		60			

Towns Served: CANAAN

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit		Samples Req/Month	
		Minimum:	0.2 MG/L	Daily	Monitoring
Chlorine	Entry Point RDC (EPRD)				Compliance Status:
Start Date:	7/1/2025	Compliance History:	Operating Limit	Monitoring	Compliance Status:
		Monitoring Period	Compliance Status:	Compliance Status:	
		8/1/2025 - 8/31/2025			
		9/1/2025 - 9/30/2025			
		10/1/2025 - 10/31/2025			
		11/1/2025 - 11/30/2025			
		12/1/2025 - 12/31/2025			

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2029	

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total		Lead and Coliform Rule		Copper Rule Tier		Asbestos WQP 2 DBPR		Stage
				Status	Coliform Rule	Copper Rule Tier	Asbestos WQP 2 DBPR	WQP 2 DBPR	WQP 2 DBPR	Asbestos WQP 2 DBPR	Stage	
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	I	Y							
		CANPINE001	UNIT 58	A	Y	3						
		CANPINE002	UNIT 36	A	Y	3						
		CANPINE003	UNIT 55	A	Y	3						
		CANPINE004	UNIT 42	A	Y	3						
		CANPINE005	UNIT 53	A	Y	3						
		CANPINE006	UNIT 6	A	Y	3						
		CANPINE007	UNIT 7	A	Y	3						
		CANPINE008	UNIT 21	A	Y	3					Y	
		CANPINE009	UNIT 9	A	Y	3						
		CANPINE010	FIELD TAP OPP # 4	A	Y	3					Y	
		CANPINE011	UNIT 11	A	Y	3						
		CANPINE012	UNIT 12	A	Y	3						
		CANPINE013	UNIT 13	A	Y	3						
		CANPINE014	UNIT 14	A	Y	3						
		CANPINE015	UNIT 15	A	Y	3						
		CANPINE016	UNIT 16	A	Y	3						
		CANPINE017	UNIT 17	A	Y	3						
		CANPINE018	UNIT 18	A	Y	3						
		CANPINE019	UNIT 19	A	Y	3						
		CANPINE020	UNIT 20	A	Y	3						
		CANPINE021	UNIT 8	A	Y	3						
		CANPINE022	UNIT 22	A	Y	3						
		CANPINE023	UNIT 23	A	Y	3						
		CANPINE024	UNIT 24	A	Y	3						

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0210091	PINE GROVE ASSOCIATION, INC.	C	248	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
	60				

Towns Served: CANAAN

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
					Y	3	Y	3
	CANPINE025	UNIT 25		A	Y	3		
	CANPINE026	UNIT 26		A	Y	3		
	CANPINE027	UNIT 27		A	Y	3		
	CANPINE028	UNIT 28		A	Y	3		
	CANPINE029	UNIT 29		A	Y	3		
	CANPINE030	UNIT 30		A	Y	3		
	CANPINE031	UNIT 31		A	Y	3		
	CANPINE032	UNIT 32		A	Y	3		
	CANPINE033	UNIT 33		A	Y	3		
	CANPINE034	UNIT 34		A	Y	3		
	CANPINE035	UNIT 35		A	Y	3		
	CANPINE036	UNIT 2		A	Y	3		
	CANPINE037	UNIT 37		A	Y	3		
	CANPINE038	UNIT 38		A	Y	3		
	CANPINE039	UNIT 39		A	Y	3		
	CANPINE040	UNIT 40		A	Y	3		
	CANPINE041	UNIT 41		A	Y	3		
	CANPINE042	UNIT 4		A	Y	3		
	CANPINE043	UNIT 43		A	Y	3		
	CANPINE044	UNIT 44		A	Y	3		
	CANPINE045	UNIT 45		A	Y	3		
	CANPINE046	UNIT 46		A	Y	3		
	CANPINE047	UNIT 47		A	Y	3		
	CANPINE048	UNIT 48		A	Y	3		
	CANPINE049	UNIT 49		A	Y	3		
	CANPINE050	UNIT 50		A	Y	3		
	CANPINE051	UNIT 51		A	Y	3		
	CANPINE052	UNIT 52		A	Y	3		
	CANPINE053	UNIT 5		A	Y	3		
	CANPINE054	UNIT 54		A	Y	3		
	CANPINE055	UNIT 3		A	Y	3		
	CANPINE056	UNIT 56		A	Y	3		
	CANPINE057	UNIT 57		A	Y	3		
	CANPINE058	UNIT 1		A	Y	3		
	CANPINE059	UNIT 59		A	Y	3		
	CANPINE060	UNIT 60		A	Y	3		
	CANPINE10	CANE PINE 010		A	Y			
	DOWNSTREAM	WITHIN 5 SERVICE CON		A	Y			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0210091	PINE GROVE ASSOCIATION, INC.	C	248	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
	60				

Towns Served: CANAAN

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule	Asbestos	Stage WQP 2 DBPR
	UPSTREAM	WITHIN 5 SERVICE CON		A		Y		
00700	ENTRY POINT	3	ENTRY POINT	A				
29	WELL 1	2	WELL 1	A				
36236	TREATMENT PLANT							
55404	ATM STORAGE TANK							

Certified Operator Information

Water System Facility: TREATMENT PLANT (WSF ID: 36236)

Facility Classification:	CLASS 1 TREATMENT PLANT	Certification Expiration
Operator Name	Operator Type	Certification(s)
HELMING, TRAVIS	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III DISTRIBUTION SYSTEM OPERATOR - CLASS III
		9/30/2028 9/30/2028

Contact Information

Name	Organization	Job Title
Ms. Nancy Utter	Pine Grove Assn., Inc.	President
Mailing Address Line One	Mailing Address Line Two	City
35 Alton Street		State
		Zip Code
Business Phone	Extension	
781-777-1997		Email Address
		nancyu57@aol.com

Contact Role(s): **Administrative Contact, Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.