

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0250024	CHESHIRE PUBLIC PARK WELL (LOCK 12)	NC	27	L	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
487 NORTH BROOKSVALE ROAD					3

Towns Served: CHESHIRE

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	4/1/26 - 6/30/26		

Physical Parameters (PPS)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	4/1/26 - 6/30/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule	Asbestos Rule Tier	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		B	HOUSE (BUILDING)	A	Y			
		D	DRINKING FOUNTAIN	A	Y			
	DOWNSTREAM	WITHIN 5 SERVICE CON		A	Y			
		M	RESTROOM (MEN)	A	Y			
	UPSTREAM	WITHIN 5 SERVICE CON		A	Y			
		W	RESTROOM (WOMEN)	A	Y			
00700	ENTRY POINT	3	ENTRY POINT	A				
22778	WELL	2	WELL	A				

Contact Information

Name	Organization			Job Title		
Mr. Daniel Bombero	Town of Cheshire			Publicworks Director		
Mailing Address Line One	Mailing Address Line Two		City	State	Zip Code	
Cheshire Town Hall	84 South Main Street		Cheshire	CT	06410	
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-271-6650	6657	203-271-6659		475-341-5428	rharris@cheshirect.org	
Contact Role(s):	Administrative Contact, Legal Contact					

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0250024	CHESHIRE PUBLIC PARK WELL (LOCK 12)	NC	27	L	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
487 NORTH BROOKSVALE ROAD	Connections				3

Towns Served: CHESHIRE

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0250054	MIXVILLE PARK	NC	25	L	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
NOTCH ROAD			1		

Towns Served: CHESHIRE

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	4/1/26 - 6/30/26		

Physical Parameters (PPS)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	4/1/26 - 6/30/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform Status	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y		
		B	JOHN G MARTIN BLDG	A	Y		
		D	DRINKING FOUNTAIN	A	Y		
	DOWNSTREAM	WITHIN 5 SERVICE CON		A			
		M	RESTROOM (MEN)	A	Y		
	UPSTREAM	WITHIN 5 SERVICE CON		A			
		W	RESTROOM (WOMEN)	A	Y		
00700	ENTRY POINT	3	ENTRY POINT	A			
23041	WELL #1	2	WELL #1	A			

Contact Information

Name	Organization	Job Title
Mr. Daniel Bombero	Town of Cheshire	Publicworks Director
Mailing Address Line One	Mailing Address Line Two	City
Cheshire Town Hall	84 South Main Street	State
Business Phone	Extension	Zip Code
203-271-6650	6657	06410
Fax	Mobile Phone	Email Address
203-271-6659		475-341-5428 rharris@cheshirect.org
Contact Role(s):	Administrative Contact, Legal Contact	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0250054	MIXVILLE PARK	NC	25	L	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
NOTCH ROAD			1		

Towns Served: CHESHIRE

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0259054	MAPLE OAK FARM AND MARKET	NC	62	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
1681 WATERBURY ROAD					1

Towns Served: CHESHIRE

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100) 1 routine (RT) per quarter			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Physical Parameters (PPS) 1 routine (RT) per quarter			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX) 1 routine (RT) per year			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
RESPOND TO SANITARY SURVEY	5/11/2024	

Public Notification Requirements

Violation/Situation	Compliance Period	Notice Tier	Public Notification		PN Certification	
			Required	Performed	Due to DPH	Received
Nitrate And Nitrite M&R Violation	1/1/22 - 12/31/23	3	4/27/2023		5/7/2023	
Physical Parameters M&R Violation	7/1/22 - 9/30/22	3	6/9/2023		6/19/2023	
Physical Parameters M&R Violation	10/1/22 - 12/31/22	3	6/7/2024		6/17/2024	
Physical Parameters M&R Violation	1/1/23 - 3/31/23	3	6/7/2024		6/17/2024	
E. Coli	7/1/24 -	3	11/15/2025		11/25/2025	
Total Coliform M&R Violation	10/1/24 - 12/31/24	3	2/14/2026		2/24/2026	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform		Lead and Copper Rule		Asbestos		Stage WQP 2 DBPR
				Status	Rule	Tier	Asbestos			
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y					
		DOWNSTREAM	WITHIN 5 SERVICE CON	A	Y					
		UPSTREAM	WITHIN 5 SERVICE CON	A	Y					
00700	ENTRY POINT	3	ENTRY POINT	A						
62526	WELL 1	2	WELL 1	A						

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0259054	MAPLE OAK FARM AND MARKET	NC	62	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
1681 WATERBURY ROAD					1

Towns Served: CHESHIRE

Contact Information

Name	Organization	Job Title		
Mr. Matthew Switajewski				
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
1143 Summit Road		Cheshire	CT	06410
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone
203-506-3263				Email Address summithillgrowers@gmail.com

Contact Role(s): **Administrative Contact, Owner**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule