

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0280014	COLCHESTER BIBLE BAPTIST CHURCH	NC	26	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
34 CHESTNUT HILL ROAD			1		

Towns Served: COLCHESTER

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100) 1 routine (RT) per quarter			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Physical Parameters (PPS) 1 routine (RT) per quarter			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX) 1 routine (RT) per year			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform Status	Lead and Copper Rule	Asbestos Rule Tier	WQP 2 DBPR Stage
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A			
		UPSTREAM	WITHIN 5 SERVICE CON	A			
00700	ENTRY POINT	3	ENTRY POINT	A			
20523	WELL	2	WELL	A			

Contact Information

Name	Organization	Job Title
Mr. Mark Love	Colchester Bible Baptist Ch	Pastor
Mailing Address Line One	Mailing Address Line Two	City
38 Chestnut Hill Road		State
Business Phone	Extension	Zip Code
860-537-1050		Colchester
		CT
		06415
Emergency Phone	Mobile Phone	Email Address
		PASTOR@COLCHESTERBIBLE.ORG

Contact Role(s): Administrative Contact, Legal Contact

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name				Classification	Population	Owner Type	Primary Source
CT0280014	COLCHESTER BIBLE BAPTIST CHURCH				NC	26	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
34 CHESTNUT HILL ROAD				1				
Towns Served: COLCHESTER								
Name			Organization			Job Title		
Colchester Bible Baptist Church								
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code	
34 Chestnut Hill Rd					Colchester	CT	06415	
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			

Contact Role(s): **Owner**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0280024	STATE POLICE FLEET MAINTENANCE	NC	25	S	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
MILL HILL ROAD			1		

Towns Served: COLCHESTER

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

Total Coliform (3100)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/25 - 7/31/25		
Total Coliform (3100)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
Total Coliform (3100)	3 repeat (RP) per period		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	8/7/25 - 8/12/25		
	8/7/25 - 8/12/25		
	8/7/25 - 8/12/25		
Total Coliform (3100)	3 temporary routine (TR) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		
Physical Parameters (PPS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/25 - 8/31/25		
Physical Parameters (PPS)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0280024	STATE POLICE FLEET MAINTENANCE	NC	25	S	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
MILL HILL ROAD			1		

Towns Served: COLCHESTER

Monitoring Requirements

Water System Facility: TREATMENT PLANT (WSF ID: 00700)

Nitrate And Nitrite (NOX)				1 routine (RT) per year
Sampling Point (Sampling Point ID)		Monitoring Period	Collection Period	Compliance Status
TREATMENT PLANT EP (3)		1/1/25 - 12/31/25		Complete
		1/1/26 - 12/31/26		Complete
		1/1/27 - 12/31/27		

Water System Facility: WELL 1A (WSF ID: 58246)

E. Coli (3014)				1 triggered (TG) per period
Sampling Point (Sampling Point ID)		Monitoring Period	Collection Period	Compliance Status
WELL 1A (2)		8/6/25 - 8/12/25		Complete
		8/6/25 - 8/12/25		
		8/6/25 - 8/12/25		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: TREATMENT PLANT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit		Samples Req/Month	
		Minimum:	7.0 PH		4
pH	Entry Point pH Monitoring (PHRD)				
Start Date: 4/1/2013		Monitoring Period		Compliance Status:	Monitoring
		8/1/2025 - 8/31/2025			Compliance Status:
		9/1/2025 - 9/30/2025			
		10/1/2025 - 10/31/2025			
		11/1/2025 - 11/30/2025			
		12/1/2025 - 12/31/2025			

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT		3/1/2026

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total		Lead and Coliform			Stage
				Status	Rule	Rule Tier	Asbestos	WQP 2 DBPR	
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y				
		DOWNSTREAM	WITHIN 5 SERVICE CON	A					
		UPSTREAM	WITHIN 5 SERVICE CON	A					
00700	TREATMENT PLANT	3	TREATMENT PLANT EP	A					
58246	WELL 1A	2	WELL 1A	A					
58249	ATMOSPHERIC TANK								

Certified Operator Information

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0280024	STATE POLICE FLEET MAINTENANCE	NC	25	S	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
MILL HILL ROAD			1		

Towns Served: COLCHESTER

Certified Operator Information

Water System Facility: TREATMENT PLANT (WSF ID: 00700)

Facility Classification:

Operator Name	Operator Type	Certification(s)	Certification Expiration
NIGRO, DAVID	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	3/31/2028

Contact Information

Name	Organization	Job Title		
Mr. James Rovella	Despp	Commissioner		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
Despp	1111 Country Club Road	Middletown	CT	06457
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone
860-258-5800				james.rovella@ct.gov

Contact Role(s): Legal Contact

Name	Organization	Job Title		
Mr. Willis G. Ballard Iv	Des & Pp	Facilities Director		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
1111 Country Club Road		Middletown	CT	06457
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone
860-685-8325		860-685-8354		860-234-1581 willis.ballard@ct.gov

Contact Role(s): Administrative Contact

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0280044	DAY POND S.P./BEACHWELL	NC	83	S	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
DAY POND ROAD		1			

Towns Served: COLCHESTER

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	4/1/26 - 6/30/26		
Physical Parameters (PPS)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	4/1/26 - 6/30/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/25 - 12/31/25	4/1-9/30	Complete
	1/1/26 - 12/31/26	4/1-9/30	
	1/1/27 - 12/31/27	4/1-9/30	

Public Notification Requirements

Violation/Situation	Compliance Period	Notice Tier	Public Notification	PN Certification	
			Required	Performed	Due to DPH
Distribution Turbidity MCL Violation	4/1/12 - 6/30/12	2	9/7/2012		9/17/2012
Physical Parameters M&R Violation	7/1/14 - 9/30/14	3	11/21/2015		12/1/2015

Water System Facility and Sampling Point Inventory

Water System Facility ID	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule	Asbestos	Stage WQP 2 DBPR
				Rule	Rule Tier	Received	
00600 DISTRIBUTION SYSTEM	101	EXTERIOR FAUCET	A	Y			
	102	WOMEN'S BATHROOM	A	Y			
	103	MEN'S BATHROOM	A	Y			
	4	DISTRIBUTION SYSTEM	A	Y			
	DOWNSTREAM	WITHIN 5 SERVICE CON	A				
	UPSTREAM	WITHIN 5 SERVICE CON	A				
00700 ENTRY POINT	3	ENTRY POINT	A				
20525 WELL	2	WELL	A				

Contact Information

Name	Organization	Job Title
Mr. David Cooley	Deep-Engineering Unit	Supv Civil Engineer
Mailing Address Line One	Mailing Address Line Two	City
163 Great Hill Road		State
		Zip Code
Business Phone	Extension	Fax
860-342-2215		860-344-2560
Mobile Phone		Emergency Phone
860-205-7552		860-424-3333
Email Address		
		david.cooley@ct.gov

Contact Role(s): Legal Contact, Owner

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name				Classification	Population	Owner Type	Primary Source
CT0280044	DAY POND S.P./BEACHWELL				NC	83	S	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
DAY POND ROAD			1					
Towns Served: COLCHESTER								
Name			Organization			Job Title		
Ms. Andrea M. Lane			State of CT Deep					
Mailing Address Line One		Mailing Address Line Two			City		State	Zip Code
163 Great Hill Road					Portland		CT	06480
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-977-9739				860-424-3333	andrea.lane@ct.gov			

Contact Role(s): **Administrative Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0280084	WESTCHESTER CONGREGATIONAL CHURCH	NC	25	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
ROUTE 149 & CEMETARY ROAD	Connections		1		

Towns Served: COLCHESTER

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	4/1/26 - 6/30/26		
Total Coliform (3100)	3 repeat (RP) per period		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	12/12/25 - 12/17/25		Complete
Total Coliform (3100)	3 temporary routine (TR) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/26 - 1/31/26		
Physical Parameters (PPS)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Water System Facility: WELL (WSF ID: 20529)

E. Coli (3014)	1 triggered (TG) per period		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL (2)	12/11/25 - 12/17/25		Complete

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
RESPOND TO SANITARY SURVEY	12/16/2020	
L1 ASSESSMENT (MULTIPLE TC+)	1/16/2026	
RESPOND TO SANITARY SURVEY	2/7/2026	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform Status	Lead and Copper Rule Status	Asbestos Rule Tier	WQP 2 DBPR Stage
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A			
		UPSTREAM	WITHIN 5 SERVICE CON	A			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0280084	WESTCHESTER CONGREGATIONAL CHURCH	NC	25	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
ROUTE 149 & CEMETARY ROAD	Connections		1		

Towns Served: COLCHESTER

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule	Asbestos Rule Tier	Stage WQP 2	DBPR
00700	ENTRY POINT	3	ENTRY POINT	A					
20529	WELL	2	WELL	A					
56863	TREATMENT PLANT								

Contact Information

Name	Organization	Job Title
Mr. Karl Ostberg	Westchester Cong Church	Minister
Mailing Address Line One	Mailing Address Line Two	City State Zip Code
95 Cemetery Road		Colchester CT 06415
Business Phone	Extension	Fax
860-267-0480		
Mobile Phone		Emergency Phone
		860-267-0480
Email Address		
Contact Role(s): Legal Contact		
Name	Organization	Job Title
Ms. Melissa H Engel	Westchester Cong. Church	Maintenance
Mailing Address Line One	Mailing Address Line Two	City State Zip Code
98 Cemetery Rd		Colchester CT 06415
Business Phone	Extension	Fax
860-490-0968		
Mobile Phone		Emergency Phone
		tissahale@aol.com
Email Address		

Contact Role(s): Administrative Contact

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0280104	PAPA-ZS & SONS PIZZA	NC	39	P	GW
Local Address (where applicable)	713 MIDDLETOWN RD	Service Connections	Residential	Commercial	Industrial
			1		Combined Agricultural

Towns Served: COLCHESTER

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

1 routine (RT) per quarter			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

1 routine (RT) per quarter			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

1 routine (RT) per year			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Water System Facility: WELL (WSF ID: 20531)

1 routine (RT) per quarter			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL (2)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule	Asbestos Rule Tier	Stage WQP 2	DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y				
		DOWNSTREAM	WITHIN 5 SERVICE CON	A					
		UPSTREAM	WITHIN 5 SERVICE CON	A					
00700	ENTRY POINT	3	ENTRY POINT	A					
20531	WELL	2	WELL	A					
58329	TREATMENT PLANT								

Contact Information

Name	Organization	Job Title
Mr. Zisis N. Alveras	Papa-Zs & Sons Pizza	
Mailing Address Line One	Mailing Address Line Two	City State Zip Code

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0280104	PAPA-ZS & SONS PIZZA	NC	39	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
713 MIDDLETOWN RD			1		

Towns Served: COLCHESTER

20 Hartford Rd			Salem	CT	06420
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
860-267-1518					info@papazsrestaurant.com

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0280114	STRIP MALL ON MIDDLETOWN ROAD	NC	25	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
738 MIDDLETOWN ROAD			1		

Towns Served: COLCHESTER

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
Physical Parameters (PPS)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Public Notification Requirements

Violation/Situation	Compliance Period	Notice Tier	Public Notification Required	Public Notification Performed	PN Certification Due to DPH	PN Certification Received
Physical Parameters M&R Violation	1/1/19 - 3/31/19	3	5/27/2020		6/6/2020	
Total Coliform M&R Violation	1/1/19 - 3/31/19	3	5/27/2020		6/6/2020	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform Status	Lead and Copper Rule Status	Asbestos Rule Tier	WQP 2 Stage	DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
20532	WELL	2	WELL	A				

Contact Information

Name	Organization				Job Title		
Mr. Michael Malinosky	Quik Stop Convenience Store				Owner		
Mailing Address Line One	Mailing Address Line Two			City		State	Zip Code
268 Sunflower Court				Marco Island		FL	34145
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
239-394-7363		239-394-7363			75Benz@comcast.net		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0280114	STRIP MALL ON MIDDLETOWN ROAD			NC	25	P	GW
Local Address (where applicable)		Service	Residential	Commercial	Industrial	Combined	Agricultural
738 MIDDLETOWN ROAD		Connections		1			
Towns Served: COLCHESTER							
Contact Role(s): Administrative Contact, Legal Contact, Owner							
Please note the following:							
<ol style="list-style-type: none"> 1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample. 2. If a Collection Period is specified, all water quality samples must be collected during the specified period. 3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this 							
<i>If you have any questions, please contact the Drinking Water Section at (860) 509-7333.</i> http://www.ct.gov/dph/publicdrinkingwater							

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0280124	TWO BROTHERS WINE & SPIRIT	NC	37	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
711 MIDDLETOWN ROAD			1		

Towns Served: COLCHESTER

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Physical Parameters (PPS)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Water System Facility: WELL (WSF ID: 20533)

E. Coli (3014)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL (2)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule	Asbestos Rule Tier	Stage WQP 2	DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y				
		DOWNSTREAM	WITHIN 5 SERVICE CON	A					
		UPSTREAM	WITHIN 5 SERVICE CON	A					
00700	ENTRY POINT	3	ENTRY POINT	A					
20533	WELL	2	WELL	A					
56285	TREATMENT PLANT								

Contact Information

Name	Organization	Job Title
Mr. Ray Beckus	Allstate Agent	
Mailing Address Line One	Mailing Address Line Two	City State Zip Code

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0280124	TWO BROTHERS WINE & SPIRIT	NC	37	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
711 MIDDLETOWN ROAD			1		

Towns Served: COLCHESTER

711 Middletown Road		Colchester	CT	06415
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone

Contact Role(s): **Owner**

Name	Organization	Job Title
Mr. Zisis Alevras		Owner
Mailing Address Line One	Mailing Address Line Two	City
711 Middletown Rd.		Colchester
Business Phone	Extension	Fax
		Mobile Phone
		Emergency Phone
		Email Address

Contact Role(s): **Legal Contact, Owner**

Name	Organization	Job Title
Mr. Alex Alevras	Two Brothers Wine And Sprit	
Mailing Address Line One	Mailing Address Line Two	City
713 Middletown Road		Colchester
Business Phone	Extension	Fax
860-267-4014		Mobile Phone
		Emergency Phone
		Email Address
		860-267-2478
		alexalevras@sbcglobal.net

Contact Role(s): **Legal Contact, Owner**

Name	Organization	Job Title
Mr. Evan J Cossette	Water Boy, LLC	Chief Operator
Mailing Address Line One	Mailing Address Line Two	City
Water Boy, LLC	70 Comstock Trail	East Hampton
Business Phone	Extension	Fax
203-314-9343		Mobile Phone
		Emergency Phone
		Email Address
		waterboylc@icloud.com

Contact Role(s): **Administrative Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0280144	FRESCA BAR AND GRILL	NC	25	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
232 NEW LONDON ROAD			1		

Towns Served: COLCHESTER

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

1 routine (RT) per quarter			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

1 routine (RT) per quarter			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

1 routine (RT) per year			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Water System Facility: WELL (WSF ID: 20535)

1 routine (RT) per quarter			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL (2)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule	Asbestos Rule Tier	Stage WQP 2	DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y				
		DOWNSTREAM	WITHIN 5 SERVICE CON	A					
		UPSTREAM	WITHIN 5 SERVICE CON	A					
00700	ENTRY POINT	3	ENTRY POINT	A					
20535	WELL	2	WELL	A					
57419	TREATMENT PLANT								

Contact Information

Name	Organization	Job Title
Mr. Chun-Oi (Jim) Chan	Hung Wong Li, LLC	Owner
Mailing Address Line One	Mailing Address Line Two	City State Zip Code

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0280144	FRESCA BAR AND GRILL	NC	25	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
232 NEW LONDON ROAD			1		

Towns Served: COLCHESTER

2 Seratin Terrace					East Hampton	CT	06424
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-267-8822				860-205-9008			

Contact Role(s): **Legal Contact, Owner**

Name	Organization	Job Title		
Ms. Jennifer Marozzi	Fresca Bar And Grill	Owner / Manager		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
Fresca Bar And Grill	232 New London Rd	Colchester	CT	06415
Business Phone	Extension	Mobile Phone	Emergency Phone	Email Address
860-531-9234		860-918-1302		jennifer.marozzi@yahoo.com

Contact Role(s): **Administrative Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0280164	SALMON RIVER STATE PARK	NC	25	S	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
GULF ROAD			1		

Towns Served: COLCHESTER

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)		1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)		Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points		7/1/25 - 9/30/25		Complete
		10/1/25 - 12/31/25		Complete
		1/1/26 - 3/31/26		
		4/1/26 - 6/30/26		

Physical Parameters (PPS)		1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)		Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points		7/1/25 - 9/30/25		Complete
		10/1/25 - 12/31/25		Complete
		1/1/26 - 3/31/26		
		4/1/26 - 6/30/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)		1 routine (RT) per year		
Sampling Point (Sampling Point ID)		Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)		1/1/25 - 12/31/25		Complete
		1/1/26 - 12/31/26		
		1/1/27 - 12/31/27		

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform Status	Lead and Copper Rule	Asbestos Rule Tier	WQP 2	DBPR	Stage
00600	DISTRIBUTION SYSTEM	101	SPIGOT	A	Y				
		4	DISTRIBUTION SYSTEM	A	Y				
		DOWNSTREAM	WITHIN 5 SERVICE CON	A					
		UPSTREAM	WITHIN 5 SERVICE CON	A					
00700	ENTRY POINT	3	ENTRY POINT	A					
22902	WELL #1	2	WELL #1	A					

Contact Information

Name	Organization	Job Title
Mr. David Cooley	Deep-Engineering Unit	Supv Civil Engineer
Mailing Address Line One	Mailing Address Line Two	City
163 Great Hill Road		State
		Zip Code
Business Phone	Extension	Fax
860-342-2215		860-344-2560
		Mobile Phone
		Emergency Phone
		Email Address
		860-205-7552
		860-424-3333
		david.cooley@ct.gov

Contact Role(s): Legal Contact, Owner

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name				Classification	Population	Owner Type	Primary Source
CT0280164	SALMON RIVER STATE PARK				NC	25	S	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
GULF ROAD				1				
Towns Served: COLCHESTER								
Name			Organization			Job Title		
Ms. Andrea M. Lane			State of CT Deep					
Mailing Address Line One		Mailing Address Line Two			City		State	Zip Code
163 Great Hill Road					Portland		CT	06480
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-977-9739				860-424-3333	andrea.lane@ct.gov			

Contact Role(s): **Administrative Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0280194	MARIAS PIZZA PALACE RESTAURANT	NC	25	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
744 MIDDLETOWN ROAD			1		

Towns Served: COLCHESTER

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
Physical Parameters (PPS)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2026	

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform Status	Lead and Copper Rule Status	Asbestos Rule Tier	WQP 2 DBPR Stage
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION	A			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A			
		UPSTREAM	WITHIN 5 SERVICE CON	A			
00700	ENTRY POINT	3	ENTRY POINT	A			
49127	WELL 1	2	WELL 1	A			
58241	TREATMENT PLANT						

Contact Information

Name	Organization			Job Title		
Ms. Maria Sourvalis	Maria's Pizza Palace					
Mailing Address Line One	Mailing Address Line Two			City	State	Zip Code
744 Middletown Rd				Colchester	CT	06415
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-267-8722				860-267-8722		

Contact Role(s): Legal Contact, Owner

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name				Classification	Population	Owner Type	Primary Source
CT0280194	MARIAS PIZZA PALACE RESTAURANT				NC	25	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
744 MIDDLETOWN ROAD				1				
Towns Served: COLCHESTER								
Name			Organization			Job Title		
Ms. Athanasoula Sourvalis			Maria's Pizza Palace			Property Owner		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code	
744 Middletown Rd					Colchester	CT	06415	
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-267-8722			860-638-9788		nasoula78@yahoo.com			

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0280214	SCOTTIES FROZEN CUSTARD	NC	35	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
327 NEW LONDON ROAD			1		

Towns Served: COLCHESTER

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	4/1/26 - 6/30/26		
Physical Parameters (PPS)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	4/1/26 - 6/30/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Water System Facility: DUG WELL 1 (WSF ID: 49138)

E. Coli (3014)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 1 (2)	7/1/25 - 9/30/25		Complete
	4/1/26 - 6/30/26		

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule	Asbestos Rule Tier	Stage WQP 2	DBPR
					Stage				
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION	A					
		DOWNSTREAM	WITHIN 5 SERVICE CON	A					
		UPSTREAM	WITHIN 5 SERVICE CON	A					
00700	ENTRY POINT	3	ENTRY POINT	A					
49138	DUG WELL 1	2	WELL 1	A					
61312	TREATMENT PLANT								

Contact Information

Name	Organization	Job Title
Mr. Michael Haggerty	Scotties Frozen Custard	Owner
Mailing Address Line One	Mailing Address Line Two	City
62 Slocum Terrace		State
Business Phone	Extension	Zip Code
860-235-0860		Groton
		CT
		06340
Email Address		
		michaelhaggerty@sbcglobal.net
Contact Role(s):	Owner	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name				Classification	Population	Owner Type	Primary Source
CT0280214	SCOTTIES FROZEN CUSTARD				NC	35	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
327 NEW LONDON ROAD				1				
Towns Served: COLCHESTER								
Name		Organization			Job Title			
Mr. Hysen Kodra								
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code	
327 New London Road					Colchester	CT	06415	
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-567-1265					kodra@digisist.com			

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0286024	PRIAM VINEYARDS	NC	28	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
11 SHAILOR HILL RD	Connections		1		

Towns Served: COLCHESTER

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
Total Coliform (3100)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
Physical Parameters (PPS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
Physical Parameters (PPS)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT		3/1/2025

Water System Facility and Sampling Point Inventory						
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A		
		DOWNSTREAM	PV-DA	A	Y	
		UPSTREAM	PV-UA	A	Y	
00700	ENTRY POINT	3	ENTRY POINT	A		
60227	WELL 1	2	WELL 1	A		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0286024	PRIAM VINEYARDS	NC	28	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
11 SHAILOR HILL RD			1		

Towns Served: COLCHESTER

Contact Information

Name	Organization	Job Title		
Mr. Ryan Winiarski	Winiarski Family Vineyards	Owner		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
11 Shailor Hill Road		Colchester	CT	06415
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone
860-778-0677				Email Address ryan@priamvineyards.com

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0286014	752 MIDDLETOWN ROAD - COLCHESTER	NC	25	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
752 MIDDLETOWN ROAD - COLCHESTER	Connections		1		

Towns Served: COLCHESTER

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

Total Coliform (3100) 1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Physical Parameters (PPS) 1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: **ENTRY POINT** (WSF ID: 00700)

Nitrate And Nitrite (NOX) 1 routine (RT) per year			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Organic Chemicals (VOCS) 1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: **WELL 1** (WSF ID: 60529)

Organic Chemicals (VOCS) 1 routine (RT) per quarter			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 1 (2)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility and Sampling Point Inventory						
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Status	Lead and Coliform Rule	Copper Rule Tier
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A		
		DOWNSTREAM	DISTRIBUTION SYSTEM	A		
		UPSTREAM	DISTRIBUTION SYSTEM	A		
00700	ENTRY POINT	3	ENTRY POINT	A		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0286014	752 MIDDLETOWN ROAD - COLCHESTER	NC	25	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
752 MIDDLETOWN ROAD - COLCHESTER			1		

Towns Served: COLCHESTER

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total	Lead and Coliform	Copper Rule	Asbestos Rule Tier	Stage WQP 2	DBPR
60529	WELL 1	2	WELL 1	A						
60758	TREATMENT PLANT									
62235	IN BETWEEN GAC TREATMENT FILTERS									

Contact Information

Name	Organization	Job Title			
Mr. Evan J Cossette	Water Boy, LLC	Chief Operator			
Mailing Address Line One	Mailing Address Line Two	City State Zip Code			
Water Boy, LLC	70 Comstock Trail	East Hampton CT 06424			
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
203-314-9343					waterboyllc@icloud.com

Contact Role(s): **Administrative Contact**

Name	Organization	Job Title			
Mr. William Hincks	The Juniper Group, LLC	Member			
Mailing Address Line One	Mailing Address Line Two	City State Zip Code			
752 Middletown Rd	Unit C	Colchester CT 06415			
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
860-365-0565	101	860-271-8113		860-680-9696	whincks@moebius-tech.com

Contact Role(s): **Legal Contact, Owner**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0286034	HOP CULTURE FARMS & BREW CO.	NC	25	P	GW
Local Address (where applicable)	144 CATO CORNER ROAD	Service Connections	Residential	Commercial	Industrial
			1	Combined	Agricultural

Towns Served: COLCHESTER

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

1 routine (RT) per quarter			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

1 routine (RT) per quarter			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

1 routine (RT) per year			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: TREATMENT PLANT (WSFID: 61691)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	4
Start Date: 1/1/2020		Compliance History:	Operating Limit
		Monitoring Period	Monitoring
		Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2026	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform Status	Lead and Copper Rule Status	Asbestos Rule Tier	WQP 2 DBPR Stage
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A	Y		
		UPSTREAM	WITIN 5 SEVICE CONNE	A	Y		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0286034	HOP CULTURE FARMS & BREW CO.	NC	25	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
144 CATO CORNER ROAD			1		

Towns Served: COLCHESTER

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule	Asbestos Rule Tier	Stage WQP 2	DBPR
00700	ENTRY POINT	3	ENTRY POINT	A					
61689	WELL 1	2	WELL 1	A					
61691	TREATMENT PLANT								

Contact Information

Name	Organization	Job Title
Mr. Sam Wilson	Hop Culture Farms & Brew Co.	
Mailing Address Line One	Mailing Address Line Two	City
Hop Culture Farms & Brew Co.	292 Prospect Hill Road	Colchester
Business Phone	Extension	Fax
		Mobile Phone
		Emergency Phone
		Email Address
		sam@hopculturefarms.com

Contact Role(s): **Administrative Contact, Owner**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0286044	9 LOOMIS ROAD, LLC	NC	25	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: COLCHESTER

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Physical Parameters (PPS)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform Status	Lead and Copper Rule	Asbestos Rule Tier	WQP 2	DBPR Stage
00600	DISTRIBUTION SYSTEM	4	GENERAL	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A	Y			
		UPSTREAM	WITHIN 5 SERVICE CON	A	Y			
00700	ENTRY POINT	3	ENTRY POINT	A				
61978	WELL	2	WELL	A				
61980	TREATMENT PLANT							

Contact Information

Name	Organization				Job Title		
Mr. George Veneziano	9 Loomis Road LLC				Member		
Mailing Address Line One	Mailing Address Line Two			City	State	Zip Code	
PO Box 847				Colchester	CT	06415	
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-537-0734					george@venezianocompanies.com		
Contact Role(s):	Administrative Contact, Owner						

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0286044	9 LOOMIS ROAD, LLC	NC	25	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: COLCHESTER

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule