

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0240192	NICKERSON PARK CAMPGROUND	NC	30	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
1036 PHOENIXVILLE ROAD (RT 198)	Connections	37			

Towns Served: EASTFORD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	4/1/26 - 6/30/26		

Physical Parameters (PPS)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	4/1/26 - 6/30/26		

Water System Facility: ENTRY POINT - WELL 2 (WSF ID: 00700)

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - WELL 2 (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Water System Facility: ENTRY POINT - WELL 1 (WSF ID: 00701)

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - WELL 1 (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Public Notification Requirements

Violation/Situation	Compliance Period	Notice Tier	Public Notification Required	Public Notification Performed	PN Certification Due to DPH	PN Certification Received
Total Coliform M&R Violation	7/1/25 - 9/30/25	3	1/21/2027		1/31/2027	
Physical Parameters M&R Violation	7/1/25 - 9/30/25	3	1/21/2027		1/31/2027	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper	Stage	
					Rule	Rule Tier		Asbestos
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT - WELL 2	3	EP - WELL 2	A				
00701	ENTRY POINT - WELL 1	3	EP - WELL 1	A				
20060	WELL 2	2	WELL	A				
58528	WELL 1	2	WELL 1	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0240192	NICKERSON PARK CAMPGROUND	NC	30	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
1036 PHOENIXVILLE ROAD (RT 198)	Connections	37			Agricultural

Towns Served: EASTFORD

Contact Information

Name	Organization	Job Title		
Mr. Chris Nickerson				
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
1036 Phoenixville Road-Route 198		Chaplin	CT	06235
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone
860-455-0007				Email Address chris@nickersonpark.com

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0390064	CHARLIE BROWN CAMPGROUND	NC	75	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
98 CHAPLIN ROAD			1		

Towns Served: EASTFORD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	4/1/26 - 6/30/26		

Physical Parameters (PPS)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	4/1/26 - 6/30/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/25 - 12/31/25	4/1-9/30	Complete
	1/1/26 - 12/31/26	4/1-9/30	
	1/1/27 - 12/31/27	4/1-9/30	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform Status	Lead and Copper Rule Status	Asbestos Rule Tier	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A			
		UPSTREAM	WITHIN 5 SERVICE CON	A			
00700	ENTRY POINT	3	ENTRY POINT	A			
20702	WELL	2	WELL	A			

Contact Information

Name	Organization	Job Title
Mr. Steven A. St. John	Charlie Brown Campground	Owner, President
Mailing Address Line One	Mailing Address Line Two	City
98 Chaplin Road (Route 198)		State
Business Phone	Extension	Zip Code
860-974-0142	860-974-0759	Eastford
Emergency Phone	Email Address	CT
	ssaint51@hotmail.com	06242

Contact Role(s): Administrative Contact, Legal Contact, Owner

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0390084	EASTFORD BAPTIST CHURCH	NC	25	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
133 UNION ROAD			1		

Towns Served: EASTFORD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Physical Parameters (PPS)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform Status	Lead and Copper Rule	Asbestos Rule Tier	WQP 2	DBPR Stage
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
20704	WELL	2	WELL	A				
59527	TREATMENT PLANT							

Contact Information

Name	Organization			Job Title		
Pastor Timothy Howard Jr.	Eastford Baptist Church			Pastor		
Mailing Address Line One	Mailing Address Line Two			City	State	Zip Code
135 Union Road				Eastford	CT	06242
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-974-1414					pastortimothyhoward@gmail.com	
Contact Role(s):	Legal Contact					

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name				Classification	Population	Owner Type	Primary Source
CT0390084	EASTFORD BAPTIST CHURCH				NC	25	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
133 UNION ROAD				1				
Towns Served: EASTFORD								
Name			Organization			Job Title		
Mr. John H Buell			Eastford Baptist Church			Trustee		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code	
107 Crystal Pond Rd					Eastford	CT	06242	
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-974-3291					Jhbuell@charter.net			

Contact Role(s): **Administrative Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0390214	PEPPERTREE CAMPING	NC	34	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
146 CHAPLIN ROAD		1	77		

Towns Served: EASTFORD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	4/1/26 - 6/30/26		

Physical Parameters (PPS)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	4/1/26 - 6/30/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/25 - 12/31/25	4/1-9/30	Complete
	1/1/26 - 12/31/26	4/1-9/30	
	1/1/27 - 12/31/27	4/1-9/30	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform Status	Lead and Copper Rule Status	Asbestos Rule Tier	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A			
		UPSTREAM	WITHIN 5 SERVICE CON	A			
00700	ENTRY POINT	3	ENTRY POINT	A			
20717	WELL	2	WELL	A			

Contact Information

Name	Organization	Job Title
Mr. Phil Cotnoir	Ctac Properties, LLC	Owner
Mailing Address Line One	Mailing Address Line Two	City
146 Chaplin Road		State
Business Phone	Extension	Zip Code
860-974-1439		Eastford
Email Address		CT
		06042
peppertreecamping@comcast.net		

Contact Role(s): Administrative Contact, Legal Contact, Owner

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0390254	CRYSTAL POND PARK	NC	25	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
4 WEEKS ROAD			1		

Towns Served: EASTFORD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	4/1/26 - 6/30/26		
Physical Parameters (PPS)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	4/1/26 - 6/30/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/25 - 12/31/25	4/1-9/30	Complete
	1/1/26 - 12/31/26	4/1-9/30	
	1/1/27 - 12/31/27	4/1-9/30	

Public Notification Requirements

Violation/Situation	Compliance Period	Notice Tier	Public Notification Required	PN Certification Due to DPH	Received
Total Coliform M&R Violation	4/1/24 - 4/30/24	3	6/6/2025	6/16/2025	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform Status	Lead and Copper Rule Status	Asbestos Rule Tier	WQP 2 DBPR Stage
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y		
		DOWNTSTREAM	WITHIN 5 SERVICE CON	A			
		UPSTREAM	WITHIN 5 SERVICE CON	A			
00700	ENTRY POINT	3	ENTRY POINT	A			
23014	WELL	2	WELL	A			

Contact Information

Name	Organization	Job Title
Mr. John Cimochowski	Crystal Pond Park Commission	Commission Member
Mailing Address Line One	Mailing Address Line Two	City
C/O Woodstock Treasurer	415 Rte 169	State
Business Phone	Extension	Zip Code
	Fax	Woodstock
	Mobile Phone	CT
	Emergency Phone	06281
	860-617-3488	johncimochowski@gmail.com

Contact Role(s): Administrative Contact, Legal Contact

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0390254	CRYSTAL POND PARK	NC	25	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
4 WEEKS ROAD			1		

Towns Served: EASTFORD

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0399034	CHARLIE BROWN CAMPGROUND-REC HALL	NC	75	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
98 CHAPLIN ROAD, RTE 198	Connections		15		

Towns Served: EASTFORD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	4/1/26 - 6/30/26		
Physical Parameters (PPS)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	4/1/26 - 6/30/26		

Water System Facility: ENTRY POINT - REC HALL (WSF ID: 00700)

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT-REC HALL (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Public Notification Requirements

Violation/Situation	Compliance Period	Notice Tier	Public Notification Required	Public Notification Performed	PN Certification Due to DPH	PN Certification Received
Total Coliform M&R Violation	10/1/21 - 12/31/21	3	3/29/2023		4/8/2023	
Physical Parameters M&R Violation	10/1/21 - 12/31/21	3	3/29/2023		4/8/2023	
REVISED TOTAL COLIFORM RULE (RTCR)	4/19/25 - 5/22/25	3	12/9/2026		12/19/2026	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform Status	Lead and Copper Rule Status	Asbestos Rule Tier	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION	A			
		DOWNTSTREAM	WITHIN 5 SERVICE CON	A			
		UPSTREAM	WITHIN 5 SERVICE CON	A			
00700	ENTRY POINT - REC HALL	3	ENTRY POINT-REC HALL	A			
52521	WELL 2	2	WELL 2	A			

Contact Information

Name	Organization			Job Title		
Mr. Steven A. St. John	Charlie Brown Campground			Owner, President		
Mailing Address Line One	Mailing Address Line Two			City	State	Zip Code
98 Chaplin Road (Route 198)				Eastford	CT	06242
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-974-0142		860-974-0759		860-974-0142	ssaint51@hotmail.com	
Contact Role(s):	Administrative Contact, Legal Contact, Owner					

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0399034	CHARLIE BROWN CAMPGROUND-REC HALL			NC	75	P	GW
Local Address (where applicable)		Service	Residential	Commercial	Industrial	Combined	Agricultural
98 CHAPLIN ROAD, RTE 198		Connections		15			
Towns Served: EASTFORD							
Please note the following:							
<ol style="list-style-type: none"> 1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample. 2. If a Collection Period is specified, all water quality samples must be collected during the specified period. 3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this 							
<i>If you have any questions, please contact the Drinking Water Section at (860) 509-7333.</i> http://www.ct.gov/dph/publicdrinkingwater							

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0399044	EASTFORD BAPTIST CHURCH- ACTIVITY CENTER	NC	25	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
133 UNION ROAD	Connections				1

Towns Served: EASTFORD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)		1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)		Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points		7/1/25 - 9/30/25		Complete
		10/1/25 - 12/31/25		Complete
		1/1/26 - 3/31/26		
		4/1/26 - 6/30/26		
Physical Parameters (PPS)		1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)		Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points		7/1/25 - 9/30/25		Complete
		10/1/25 - 12/31/25		Complete
		1/1/26 - 3/31/26		
		4/1/26 - 6/30/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)		1 routine (RT) per year		
Sampling Point (Sampling Point ID)		Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)		1/1/25 - 12/31/25		Complete
		1/1/26 - 12/31/26		
		1/1/27 - 12/31/27		

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform Status	Lead and Copper Rule Status	Asbestos Rule Tier	WQP 2 Stage DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A			
		UPSTREAM	WITHIN 5 SERVICE CON	A			
00700	ENTRY POINT	3	ENTRY POINT	A			
56636	WELL	2	WELL	A			

Contact Information

Name	Organization	Job Title
Mr. John H Buell	Eastford Baptist Church	Trustee
Mailing Address Line One	Mailing Address Line Two	City
107 Crystal Pond Rd		State
Business Phone	Extension	Zip Code
860-974-3291		

Contact Role(s): Administrative Contact, Legal Contact

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0399044	EASTFORD BAPTIST CHURCH- ACTIVITY CENTER	NC	25	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
133 UNION ROAD	Connections				1

Towns Served: EASTFORD

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0399064	DOLLAR GENERAL - EASTFORD	NC	25	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
230 EASTFORD RD			1		

Towns Served: EASTFORD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
Physical Parameters (PPS)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform Status	Lead and Copper Rule	Asbestos Rule Tier	WQP 2 DBPR Stage
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION	A	Y		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A			
		UPSTREAM	WITHIN 5 SERVICE CON	A			
00700	ENTRY POINT	3	ENTRY POINT	A			
61945	WELL 1	2	WELL 1	A			

Contact Information

Name	Organization	Job Title
Mr. Delbert Walmsley	Dg York, LLC	
Mailing Address Line One	Mailing Address Line Two	City
2103 Fawn Meadow Ln		Richmond
Business Phone	Extension	State
832-727-3040		Zip Code
		77406
Email Address		
		del@luinc.com

Contact Role(s): Administrative Contact, Legal Contact, Owner

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0399064	DOLLAR GENERAL - EASTFORD	NC	25	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
230 EASTFORD RD			1		

Towns Served: EASTFORD

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0390274	ALWAYS MOORE, LLC	NC	25	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
134 UNION ROAD			1		

Towns Served: EASTFORD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100) 1 routine (RT) per quarter			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Physical Parameters (PPS) 1 routine (RT) per quarter			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX) 1 routine (RT) per year			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform		Lead and Copper Rule Tier	Asbestos	WQP 2 DBPR Stage
				Status	Rule			
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		BSINK	BATHROOM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		DSINK	DISH SINK	A	Y			
		FSINK	FOOD SINK	A	Y			
		HSINK	HAND SINK	A	Y			
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
63289	WELL 1	2	WELL 1	A				

Contact Information

Name	Organization			Job Title		
Mr. Ted Moore	Always More, LLC			Owner		
Mailing Address Line One	Mailing Address Line Two			City	State	Zip Code
134 Union Road				Eastford	CT	06242
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-315-7570				203-577-9632	alwaysmoore134@gmail.com	

Contact Role(s): Administrative Contact, Legal Contact, Owner

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0390274	ALWAYS MOORE, LLC	NC	25	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
134 UNION ROAD			1		

Towns Served: EASTFORD

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule