

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0390102	WHITCRAFT LLC	NTNC	272	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
77 COUNTY ROAD				2	

Towns Served: EASTFORD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

Asbestos (1094)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
Total Alkalinity (1927)	2 routine (RT) per six months		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 12/31/25		Complete
	1/1/26 - 6/30/26		
	7/1/26 - 12/31/26		
Total Coliform (3100)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		Complete
	4/1/26 - 6/30/26		
Lead And Copper (PBCU)	10 routine (RT) per six months		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 12/31/25		Complete
	1/1/26 - 6/30/26		
	7/1/26 - 12/31/26		
Physical Parameters (PPS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		Complete
	4/1/26 - 6/30/26		

Water System Facility: **ENTRY POINT - WELLS 3 & 5** (WSF ID: 00700)

Chloride (1017)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 3 & 5 (3)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		Complete
	4/1/26 - 6/30/26		
Nickel (1036)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 3 & 5 (3)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		Complete
	4/1/26 - 6/30/26		
Nitrate (1040)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0390102	WHITCRAFT LLC	NTNC	272	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
77 COUNTY ROAD					2

Towns Served: EASTFORD

Monitoring Requirements

Water System Facility: ENTRY POINT - WELLS 3 & 5 (WSF ID: 00700)

Nitrate (1040)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 3 & 5 (3)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		Complete
	4/1/26 - 6/30/26		
Nitrite (1041)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 3 & 5 (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 3 & 5 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	1 (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 3 & 5 (3)	1/1/23 - 12/31/25	1/1/12/31	Waiver
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 3 & 5 (3)	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 3 & 5 (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT - WELLS 3 & 5 (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Maximum: 7.9 PH	Daily
Start Date: 1/1/2025		Compliance History:	
		Monitoring Period	Operating Limit
			Monitoring
			Compliance Status:
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0390102	WHITCRAFT LLC	NTNC	272	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
77 COUNTY ROAD					2

Towns Served: EASTFORD

Water System Facility: ENTRY POINT - WELLS 3 & 5 (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit		Samples Req/Month	
		Minimum:	7.3 PH	Daily	Monitoring
pH	Entry Point pH Monitoring (PHRD)				Compliance Status:
Start Date:	1/1/2025	Monitoring Period	Operating Limit	Monitoring	Compliance Status:
		8/1/2025 - 8/31/2025	Y		
		9/1/2025 - 9/30/2025	Y		
		10/1/2025 - 10/31/2025	Y		
		11/1/2025 - 11/30/2025	Y		
		12/1/2025 - 12/31/2025	Y		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2026	

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total		Lead and Copper Rule		Stage WQP 2 DBPR
				Status	Coliform Rule	Rule Tier	Asbestos	
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		OM2200	OFFC BTH SINK	I	Y	N	Y	Y
		OM2201	TRANS WASH SINK	I	Y	N		
		OM2202	MAINT WASH SINK	I	Y	N		
		OM2203	LADIES LAV	I	Y	N		
		OM2204	BRACK WASH SINK	I	Y	N		
		OM2205	CAF LOWER	I	Y	N		
		OM2206	CAF UPPER	I	Y	N		Y
		OM2207	MENS LOWER	I	Y	N		
		OM2208	BREAK RM UPPER	I	Y	N		
		OM2209	LADIES LOWER	I	Y	N		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
		WC1	B2 CAFÉ 2	A	Y	N	Y	Y
		WC10	B6 TROUGH 1 LH	A	Y	N	Y	Y
		WC11	B6 TROUGH 2	A	Y	N	Y	Y
		WC12	B6 TROUGH 3	A	Y	N	Y	Y
		WC13	B6 TROUGH 4	A	Y	N	Y	Y
		WC14	B6 TROUGH 5 RH	A		N	Y	Y
		WC15	B6 CAFÉ 3	A	Y	N	Y	Y
		WC16	B6 CONF 5 LH	A	Y	N	Y	Y
		WC17	B6 CONF 5 RH	A	Y	N	Y	Y
		WC18	B6 MENS UP RH	A	Y	N	Y	Y
		WC19	B6 MENS UP LH	A	Y	N	Y	Y
		WC2	B2 TROUGH 1 LH	A	Y	N	Y	Y

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0390102	WHITCRAFT LLC	NTNC	272	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
77 COUNTY ROAD					2

Towns Served: EASTFORD

Water System Facility and Sampling Point Inventory							
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos WQP 2 DBPR
					Stage	Stage	Stage
		WC20	B6 MENS UP RH	A	Y	N	Y
		WC21	B6 LADYS DOWN 1 LH	A	Y	N	Y
		WC22	B6 LADYS DOWN 2	A	Y	N	Y
		WC23	B6 LADYS DOWN 3 RH	A	Y	N	Y
		WC24	B6 LADYS UP 1 LH	A	Y	N	Y
		WC25	B6 LADYS UP 2	A	Y	N	Y
		WC26	B6 LADYS UP 3 RH	A	Y	N	Y
		WC3	B2 TROUGH 2	A	Y	N	Y
		WC4	B2 TROUGH 3	A	Y	N	Y
		WC5	B2 TROUGH 4	A	Y	N	Y
		WC6	B2 TROUGH 5 RH	A	Y	N	Y
		WC7	B2 LADIES	A	Y	N	Y
		WC8	B3 LADIES	A	Y	N	Y
		WC9	B3 CAFÉ 1	A	Y	N	Y
00700	ENTRY POINT - WELLS 3 & 5	3	EP - WELLS 3 & 5	A			
10185	WELL #3	2	WELL 3	A			
52346	ATMOSPHERIC TANK						
58288	TREATMENT PLANT						
61311	WELL #5	2	WELL #5	A			

Certified Operator Information

Water System Facility: **TREATMENT PLANT (WSF ID: 58288)**

Facility Classification: CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
NIGRO, JR., VICTOR N.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2027 6/30/2026
NIGRO, SCOTT A.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2028 6/30/2026
NIGRO, DAVID	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	3/31/2028

Contact Information

Name	Organization	Job Title
Mrs. Jacqueline Gallo	Whitcraft Corp	General Manager
Mailing Address Line One	Mailing Address Line Two	City
76 County Road		State
		Zip Code
Business Phone	Extension	Fax
860-630-4383		Mobile Phone
		Emergency Phone
		Email Address
		860-268-5572
		Jgallo@whitcraftgroup.com

Contact Role(s): **Legal Contact**

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0390102	WHITCRAFT LLC	NTNC	272	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
77 COUNTY ROAD				2	

Towns Served: EASTFORD

Name	Organization	Job Title		
Ms. Shelley Wilcox	Whitcraft Eastford	General Manager		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
76 County Road		Eastford	CT	06242
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone
860-630-4383				swilcox@whitcraftgroup.com

Contact Role(s): **Legal Contact**

Name	Organization	Job Title		
Mr. Mark Turner	Whitcraft LLC	Ehs & Maint. Mgr		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
76 County Rd		Eastford	CT	06242
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone
860-630-4470				860-576-6340 mtturner@pursuitaero.com

Contact Role(s): **Administrative Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0390212	EASTFORD ELEMENTARY SCHOOL	NTNC	225	L	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
12 WESTFORD ROAD	Connections	2			

Towns Served: EASTFORD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

Asbestos (1094)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
Total Coliform (3100)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25 Complete		
	10/1/25 - 12/31/25 Complete		
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
Lead And Copper (PBCU)	10 routine (RT) per six months		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/25 - 12/31/25 Complete		
	1/1/26 - 6/30/26		
	7/1/26 - 12/31/26		
Physical Parameters (PPS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25 Complete		
	10/1/25 - 12/31/25 Complete		
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: **ENTRY POINT** (WSF ID: 00700)

Di(2-Ethylhexyl) - Phthalate (2039)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
ENTRY POINT (3)	1/1/25 - 12/31/25 Complete		
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25 Complete		
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
ENTRY POINT (3)	1/1/25 - 12/31/25 Complete		
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25 Complete		
	1/1/26 - 12/31/28		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0390212	EASTFORD ELEMENTARY SCHOOL	NTNC	225	L	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
12 WESTFORD ROAD	Connections	2			

Towns Served: EASTFORD

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per three years		
Sampling Point (Sampling Point ID)		Monitoring Period	Collection Period	Compliance Status
		1/1/29 - 12/31/31		
Organic Chemicals (VOCS)			1 routine (RT) per year	
Sampling Point (Sampling Point ID)		Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)		1/1/25 - 12/31/25	Complete	
		1/1/26 - 12/31/26		
		1/1/27 - 12/31/27		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT		3/1/2025

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total	Lead and Coliform	Copper	Asbestos	WQP 2	DBPR	Stage
					Coliform Rule	Rule Tier					
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y						
		DOWNSTREAM	WITHIN 5 SERVICE CON	A							
		UPSTREAM	WITHIN 5 SERVICE CON	A							
		WS112	CAFE LUNCH ROOM	A	Y	1		Y			
		WS1-6	WATER COOLER RM116	A	Y	N					
		WS4-1	KINDERGARTEN RM 107	A	Y	N					
		WS4-10	RESOURCE ROOM B17	A	Y	N					
		WS4-11	PRESCHOOL RM B16	A	Y	N					
		WS4-2	KITCHEN WASH ROOM	A	Y	1					
		WS4-3	STAFF LOUNGE RM 120	A	Y	N					
00700	ENTRY POINT	WS4-4	GIRLS M.S. BATHROOM	A	Y	N					
		WS4-5	MATH ROOM RM 117	A	Y	N					
		WS4-7	STAFF BATHRM RM B20	A	Y	N					
		WS4-8	ELA ROOM RM 116	A	Y	N					
		WS4-9	KITCHEN DISH SINK	A	Y	N					
28636	ENTRY POINT	3	ENTRY POINT	A							
48725	TREATMENT PLANT	2	WELL	A							
60242	WELL #2	2	WELL #2	A							
62631	1,100 GALLON ATM STORAGE TANK										

Certified Operator Information

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0390212	EASTFORD ELEMENTARY SCHOOL	NTNC	225	L	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
12 WESTFORD ROAD		2			

Towns Served: EASTFORD

Certified Operator Information

Water System Facility: TREATMENT PLANT (WSF ID: 48725)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LAFRAMBOISE, PAUL F.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2027 9/30/2027

Contact Information

Name	Organization	Job Title		
Ms. Donna Leake				
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
12 Westford Road	P.O. Box 158	Eastford	CT	06242
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone
860-974-1130		860-974-0837		dleake@eastfordct.org

Contact Role(s): Administrative Contact, Legal Contact

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.