

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0420011	AQUARION-EAST HAMPTON	C	189	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
49 LAKE ROAD (TREATMENT PLANT)	Connections	48			

Towns Served: EAST HAMPTON

**Monitoring Requirements**

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

<b>Chlorine Residual (1012)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
LAKE DRIVE DIST TAP (05915)	1/1/21 - 12/31/29		
<b>Total Coliform (3100)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
<b>Disinfectant Byproducts - TTHM &amp; HAAs (DBP)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
LAKE DRIVE DIST TAP (05915)	1/1/25 - 12/31/25	8/1-8/31	Complete
	1/1/26 - 12/31/26	8/1-8/31	
	1/1/27 - 12/31/27	8/1-8/31	
<b>Lead And Copper (PBCU)</b>	<b>5 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/27	6/1-9/30	
<b>Physical Parameters (PPS)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0420011	AQUARION-EAST HAMPTON	C	189	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
49 LAKE ROAD (TREATMENT PLANT)	Connections	48			

Towns Served: EAST HAMPTON

**Monitoring Requirements**

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

Physical Parameters (PPS)	1 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: **ENTRY POINT** (WSF ID: 00700)

Net Gross Alpha (4000)	1 routine (RT) per six years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/20 - 12/31/25		Complete
	1/1/26 - 12/31/31		
Uranium (4006)	1 routine (RT) per six years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/20 - 12/31/25		Complete
	1/1/26 - 12/31/31		

Combined Radium-226/228 (4010)	1 routine (RT) per six years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/20 - 12/31/25		Complete
	1/1/26 - 12/31/31		

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

Organic Chemicals (VOCS)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0420011	AQUARION-EAST HAMPTON	C	189	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
49 LAKE ROAD (TREATMENT PLANT)	Connections	48			

Towns Served: EAST HAMPTON

### Monitoring Requirements

Water System Facility: WELL 3 (WSF ID: 1725)

E. Coli (3014)		1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
WELL 3 (2)	7/1/25 - 9/30/25		Complete	
	10/1/25 - 12/31/25		Complete	
	1/1/26 - 3/31/26			
	4/1/26 - 6/30/26			

Water System Facility: WELL 1 (WSF ID: 439)

E. Coli (3014)		1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
WELL 1 (2)	7/1/25 - 9/30/25		Complete	
	10/1/25 - 12/31/25		Complete	
	1/1/26 - 3/31/26			
	4/1/26 - 6/30/26			

### Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 11/1/2008		<b>Compliance History:</b>	
		<b>Monitoring Period</b>	<b>Operating Limit</b>
		8/1/2025 - 8/31/2025	<b>Monitoring</b>
		9/1/2025 - 9/30/2025	<b>Compliance Status:</b>
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
<b>Start Date:</b> 1/1/2004		<b>Compliance History:</b>	
		<b>Monitoring Period</b>	<b>Operating Limit</b>
		8/1/2025 - 8/31/2025	<b>Monitoring</b>
		9/1/2025 - 9/30/2025	<b>Compliance Status:</b>
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Maximum: 10 MG/L	2
<b>Start Date:</b> 1/1/2004		<b>Compliance History:</b>	
		<b>Monitoring Period</b>	<b>Operating Limit</b>
		8/1/2025 - 8/31/2025	<b>Monitoring</b>
		9/1/2025 - 9/30/2025	<b>Compliance Status:</b>

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0420011	AQUARION-EAST HAMPTON	C	189	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
49 LAKE ROAD (TREATMENT PLANT)	Connections	48			

Towns Served: EAST HAMPTON

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Maximum: 10 MG/L	2
Start Date: 1/1/2004		Compliance History: Monitoring Period	Operating Limit Monitoring Compliance Status: Compliance Status:
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
MAIL/HAND DELIVER NOTICE TO CONSUMERS	12/31/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2026	
CERTIFY LEAD SL NOTIFICATION	7/1/2026	

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
					Rule	Rule Tier	Asbestos	Stage WQP 2 DBPR
00500	EAST HAMPTON WELLFIELD	00500	EAST HAMPTON WELLS	A				
00600	DISTRIBUTION SYSTEM	05914	22 LAKEWOOD DR SS -	A	Y			
		05915	LAKE DRIVE DIST TAP	A	Y		Y	Y
		05915D	EAST HAMPTON DIST TA	A	Y			
		05915U	EAST HAMPTON DIST TA	A	Y			
		4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		PB6214	12 LAKEWOOD E HAMTN	A		1		
		PB6215	23 LAKEWOOD RD	A		3		
		PB6216	6 HALE RD	A		3		
		PB6217	13 HALE E HAMPTON	A		1		
		PB6218	7 BOULDER RD	A		3		
		PB6219	77 LAKE RD	A		3		
		PB6224	13 LAKEWOOD E HAMTN	A		1		
		PB6321	4 HALE RD	A	Y	3		
		PB6322	36 LAKEWOOD RD	A		3		
		PB8370	29 LAKEWOOD RD	A		1		
		PB8495	5 HALE RD	A		3		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
1725	WELL 3	2	WELL 3	A				
36275	TREATMENT PLANT							
439	WELL 1	2	WELL 1	A				
49650	ATMOSPHERIC TANK							

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0420011	AQUARION-EAST HAMPTON	C	189	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
49 LAKE ROAD (TREATMENT PLANT)	Connections	48			

Towns Served: EAST HAMPTON

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total	Lead and Coliform	Copper	Stage	
				Status	Rule	Rule Tier		
49654	PUMP STATION							

## Certified Operator Information

Water System Facility: TREATMENT PLANT (WSF ID: 36275)

Facility Classification:	CLASS 1 TREATMENT PLANT			Certification Expiration
	Operator Name	Operator Type	Certification(s)	
CHARNETSKI, MICHAEL R.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR - CLASS III		6/30/2027 6/30/2026
GARDNER, DAVID C.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV		6/30/2028
SORENSEN, KEVIN T.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV		6/30/2028
ROGERS, JUSTUS	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS II		9/30/2027 9/30/2026

## Contact Information

Name	Organization	Job Title
Mr. John P. Walsh	Aquarion Water Company	Vice President
Mailing Address Line One	Mailing Address Line Two	City State Zip Code
835 Main Street	Mail Stop 700	Bridgeport CT 06604
Business Phone	Extension	Fax Mobile Phone Emergency Phone Email Address
203-337-5852		203-337-5938 781-413-6175 jwalsh@aquarionwater.com

Contact Role(s): Legal Contact

Name	Organization	Job Title
Mr. Robert J. Ulrich	Aquarion Water Company of Ct	Vp-Supply & Utility
Mailing Address Line One	Mailing Address Line Two	City State Zip Code
505 Huntington St.		Shelton CT 06484
Business Phone	Extension	Fax Mobile Phone Emergency Phone Email Address
203-926-4320		203-929-5297 203-395-3205 rulrich@aquarionwater.com

Contact Role(s): Administrative Contact

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

**If you have any questions, please contact the Drinking Water Section at (860) 509-7333.**

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0420021	EDGEMERE CONDOMINIUM ASSN., INC.	C	540	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		180			

Towns Served: EAST HAMPTON

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30		
<b>Total Coliform (3100)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
<b>Lead And Copper (PBCU)</b>	<b>10 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/27	6/1-9/30	
	1/1/28 - 12/31/30	6/1-9/30	
<b>Physical Parameters (PPS)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: **ENTRY POINT** (WSF ID: 00700)

<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0420021	EDGEMERE CONDOMINIUM ASSN., INC.	C	540	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: EAST HAMPTON

## Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/29 - 12/31/31		
<b>Uranium (4006)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
<b>Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

## Monthly Water System Facility (WSF) Level Monitoring Requirements

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0420021	EDGEMERE CONDOMINIUM ASSN., INC.	C	540	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: EAST HAMPTON

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 3/1/2008		Compliance History: Monitoring Period	Operating Limit Monitoring Compliance Status: Compliance Status:
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT FISCAL AND ASSET MANAGEMENT CERT	1/1/2021	
CROSS CONNECTION SURVEY REPORT	3/1/2025	

### Public Notification Requirements

Violation/Situation	Compliance Period	Notice Tier	Public Notification		PN Certification	
			Required	Performed	Due to DPH	Received
E. Coli	4/10/19 - 6/27/19	3	5/6/2020		5/16/2020	
Total Coliform M&R Violation	5/1/19 - 5/31/19	3	8/11/2020		8/21/2020	
Nitrate M&R Violation	4/1/19 - 6/30/19	3	8/11/2020		8/21/2020	
Physical Parameters M&R Violation	5/1/19 - 5/31/19	3	8/11/2020		8/21/2020	

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total		Lead and Coliform Rule		Copper Rule Tier		Asbestos WQP 2 DBPR		Stage
				Status	Rule	Y	N	Y	N	Y	N	
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y							WQP 2 DBPR
		DOWNSTREAM	WITHIN 5 SERVICE CON	A								
		EDCON002	UNIT 61	A		Y		N				
		EDCON003	UNIT 92	A		Y		N				
		EDCON004	UNIT 97	A		Y		N				
		EDCON005	BUILDING #2 TAP	A		Y		N				
		EDCON006	UNIT 56	A		Y		N				
		EDCON007	UNIT 43	A		Y		N				
		EDCON008	UNIT 12	A		Y		N				
		EDCON009	UNIT 15C	A		Y		N				
		EDCON010	UNIT 11C	A		Y		N				
		EDCON011	UNIT 4B	A		Y		N				
		UPSTREAM	WITHIN 5 SERVICE CON	A								
00700	ENTRY POINT	3	ENTRY POINT	A								
36276	TREATMENT PLANT - WELL #1											
445	WELL 1	2	WELL 1	A								

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0420021	EDGEMERE CONDOMINIUM ASSN., INC.	C	540	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		180			

Towns Served: EAST HAMPTON

<b>Water System Facility and Sampling Point Inventory</b>							
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule	Lead and Copper Rule Tier
					WQP 2	Asbestos	DBPR
446	WELL 2	2	WELL 2	A			
51094	ATMOSPHERIC STORAGE						
51096	HYDROPNEUMATIC STORAGE						
54393	BOOSTER PUMPING FACILITIES						

## Certified Operator Information

Water System Facility: TREATMENT PLANT - WELL #1 (WSF ID: 36276)

Facility Classification:	CLASS 1 TREATMENT PLANT	Certification Expiration
Operator Name	Operator Type	Certification(s)
KING, THAD D.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I
		WATER TREATMENT PLANT OPERATOR - CLASS II

## Contact Information

Name	Organization	Job Title
Ms. Nancy S. Geysen	Edgemere Condo Association	President
Mailing Address Line One	Mailing Address Line Two	City
P.O. Box 3	85 North Main Street, Unit 15C	State
Business Phone	Extension	Zip Code
860-267-2591		
Mobile Phone	Emergency Phone	Email Address
	860-267-2591	

Contact Role(s): Legal Contact, Owner

Name	Organization	Job Title
Mr. Paul Oliva	Edgemere Condo Assn.	Manager
Mailing Address Line One	Mailing Address Line Two	City
85 North Main St	Unit 1B	State
Business Phone	Extension	Zip Code
860-267-2591	860-267-2591	
Mobile Phone	Emergency Phone	Email Address
	860-280-6767	pauloliva118@gmail.com

Contact Role(s): Administrative Contact

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0420031	BELLWOOD COURT	C	31	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
BELLWOOD COURT, EAST HAMPTON	Connections	30			

Towns Served: EAST HAMPTON

### Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30		
<b>Total Coliform (3100)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
<b>Lead And Copper (PBCU)</b>	<b>5 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/27	6/1-9/30	
<b>Physical Parameters (PPS)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
<b>Radionuclides - Gross Alpha, Combined Radium &amp; Uranium (RADA)</b>	<b>1 routine (RT) per six years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/28		
<b>Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)</b>	<b>1 (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25	1/1-12/31	Waiver
<b>Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0420031	BELLWOOD COURT	C	31	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
BELLWOOD COURT, EAST HAMPTON	Connections	30			

Towns Served: EAST HAMPTON

**Monitoring Requirements**

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Organic Chemicals (VOCS)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

**Monthly Water System Facility (WSF) Level Monitoring Requirements**

Water System Facility: **ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit		Samples Req/Month	
		Compliance History:	Operating Limit	Monitoring	Compliance Status:
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH			4
<b>Start Date:</b> 7/1/2003		<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Monitoring</b>	<b>Compliance Status:</b>
		8/1/2025 - 8/31/2025			
		9/1/2025 - 9/30/2025			
		10/1/2025 - 10/31/2025			
		11/1/2025 - 11/30/2025			
		12/1/2025 - 12/31/2025			

**Other Compliance Schedules**

Compliance Schedule Activity	Due Date	Achieved Date
RESPOND TO SANITARY SURVEY	10/9/2022	
CROSS CONNECTION EXEMPTION	3/1/2026	

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total		Lead and Coliform		Copper Rule Tier		Asbestos WQP 2 DBPR		Stage
				Status	Rule	Y	2	Y	Y	Y	Y	
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y							
		DOWNSTREAM	WITHIN 5 SERVICE CON	A								
		GWS001	COMMUNITY BLDG	A	Y	2						
		GWS002	APT 5	A	Y	2						
		GWS003	APT 15	A	Y	2						
		GWS004	APT 16	A	Y	2						
		GWS005	APT 20	A	Y	2						
		GWS006	APT 25	A	Y	2						
		GWS007	APT 29	A	Y	2						
		UPSTREAM	WITHIN 5 SERVICE CON	A								
00700	ENTRY POINT	3	ENTRY POINT	A								
437	WELL 1	2	WELL 1	A								
585	TREATMENT PLANT WELL #1											
61982	ATMOSPHERIC TANKS											
61984	PUMP STATION											

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0420031	BELLWOOD COURT	C	31	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
BELLWOOD COURT, EAST HAMPTON	Connections	30			

Towns Served: EAST HAMPTON

## Certified Operator Information

Water System Facility: **TREATMENT PLANT WELL #1 (WSF ID: 585)**

**Facility Classification:** CLASS 1 TREATMENT PLANT

**Certification**

**Expiration**

Operator Name	Operator Type	Certification(s)	
LAFRAMBOISE, PAUL F.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2027
		WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2027

## Contact Information

Name	Organization	Job Title
<b>Bellwood Court</b>		

Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
Emergency Contact		Emergency Contact	CT	06000

Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
860-267-0544					

Contact Role(s):	Owner	Organization	Job Title
<b>East Hampton Housing Authority</b>			

Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
Chatham Acres	Governor Bill O'Neal Drive	East Hampton	CT	06424
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone
860-267-8498				ehamptonhousing@sbcgloba.net

Contact Role(s):	Owner	Organization	Job Title
<b>Mr. David Schumacher</b>		East Hampton Housing	Executive Director
Mailing Address Line One	Mailing Address Line Two	City	State
Gov. Bill O'Neill Drive		East Hampton	CT

Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
860-267-8498				203-437-1511	dave@easthamptonctha.gov

Contact Role(s): **Administrative Contact, Legal Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

**If you have any questions, please contact the Drinking Water Section at (860) 509-7333.**

**<http://www.ct.gov/dph/publicdrinkingwater>**

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0420071	CHATHAM APARTMENTS	C	40	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
41 EAST HIGH STREET		29			

Towns Served: EAST HAMPTON

### Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

<b>Chlorine Residual (1012)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30		
<b>Total Haloacetic Acids (2456)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
LOUNGE SINK (CWS001)	1/1/25 - 12/31/25	9/1-9/30	Complete
	1/1/26 - 12/31/26	9/1-9/30	
	1/1/27 - 12/31/27	9/1-9/30	
<b>Total Trihalomethanes (2950)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
APARTMENT 39 (CWS032)	1/1/25 - 12/31/25	9/1-9/30	Complete
	1/1/26 - 12/31/26	9/1-9/30	
	1/1/27 - 12/31/27	9/1-9/30	
<b>Total Coliform (3100)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
<b>Lead And Copper (PBCU)</b>	<b>5 routine (RT) per six months</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 12/31/25		Complete
	1/1/26 - 6/30/26		
	7/1/26 - 12/31/26		
<b>Physical Parameters (PPS)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
Water System Facility: ENTRY POINT (WSF ID: 00700)			
<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/27		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0420071	CHATHAM APARTMENTS	C	40	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
41 EAST HIGH STREET	29				

Towns Served: EAST HAMPTON

## Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)				1 routine (RT) per year
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete	
	1/1/26 - 12/31/26			
	1/1/27 - 12/31/27			
Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)				1 routine (RT) per six years
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)	1/1/20 - 12/31/25		Complete	
	1/1/26 - 12/31/31			
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)				1 routine (RT) per three years
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete	
	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			
Organic Chemicals (VOCS)				1 routine (RT) per year
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete	
	1/1/26 - 12/31/26			
	1/1/27 - 12/31/27			

## Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.5 MG/L	Daily
Start Date:	1/1/2015	Compliance History:	Monitoring
		Monitoring Period	Compliance Status:
		8/1/2025 - 8/31/2025	Y
		9/1/2025 - 9/30/2025	Y
		10/1/2025 - 10/31/2025	Y
		11/1/2025 - 11/30/2025	Y
		12/1/2025 - 12/31/2025	Y

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SWTS 2: DWS REVIEW & APPROVAL OF SOWT		
CCTS 5: PWS OCCT INSTALLATION		
CCTS 2: DWS REVIEW & APPROVAL OF OCCT		
CROSS CONNECTION EXEMPTION	3/1/2026	

## Water System Facility and Sampling Point Inventory

Water System	Water System Facility	Sampling Point	Sampling Point	Total Coliform	Lead and Copper	Stage
--------------	-----------------------	----------------	----------------	----------------	-----------------	-------

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
<b>CT0420071</b>		<b>CHATHAM APARTMENTS</b>		C	40	P	GW	
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
41 EAST HIGH STREET			29					
Towns Served: EAST HAMPTON								
Facility ID	ID	Description		Status	Rule	Rule Tier	Asbestos WQP 2 DBPR	
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
	CWS001	LOUNGE SINK		A	Y	2	Y	
	CWS002	BSMNT UTILITY SINK		A	Y	2	Y	
	CWS003	PUBLIC RESTROOM		A	Y	2	Y	
	CWS004	APARTMENT 1		A	Y	2	Y	
	CWS005	APARTMENT 2		A	Y	2	Y	
	CWS006	APARTMENT 3		A	Y	2	Y	
	CWS007	APARTMENT 4		A	Y	2	Y	
	CWS008	APARTMENT 5		A	Y	2	Y	
	CWS009	APARTMENT 6		A	Y	2	Y	
	CWS010	APARTMENT 7		A	Y	2	Y	
	CWS011	APARTMENT 8		A	Y	2	Y	
	CWS012	APARTMENT 9		A	Y	2	Y	
	CWS013	APARTMENT 10		A	Y	2	Y	
	CWS014	APARTMENT 11		A	Y	2	Y	
	CWS015	APARTMENT 21		A	Y	2	Y	
	CWS016	APARTMENT 22		A	Y	2	Y	
	CWS017	APARTMENT 23		A	Y	2	Y	
	CWS018	APARTMENT 24		A	Y	2	Y	
	CWS019	APARTMENT 25		A	Y	2	Y	
	CWS020	APARTMENT 26		A	Y	2	Y	
	CWS021	APARTMENT 27		A	Y	2	Y	
	CWS022	APARTMENT 28		A	Y	2	Y	
	CWS023	APARTMENT 29		A	Y	2	Y	
	CWS024	APARTMENT 31		A	Y	2	Y	
	CWS025	APARTMENT 32		A	Y	2	Y	
	CWS026	APARTMENT 33		A	Y	2	Y	
	CWS027	APARTMENT 34		A	Y	2	Y	
	CWS028	APARTMENT 35		A	Y	2	Y	
	CWS029	APARTMENT 36		A	Y	2	Y	
	CWS030	APARTMENT 37		A	Y	2	Y	
	CWS031	APARTMENT 38		A	Y	2	Y	
	CWS032	APARTMENT 39		A	Y	2	Y	
	DOWNSTREAM	WITHIN 5 SERVICE CON		A				
	UPSTREAM	WITHIN 5 SERVICE CON		A				
00700	ENTRY POINT	3	ENTRY POINT	A				
1493	WELL 1	2	WELL 1	A				
548	TREATMENT PLANT							
59014	ATMOSPHERIC TANKS							
59016	PUMP STATION							

**NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.**

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0420071	CHATHAM APARTMENTS	C	40	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
41 EAST HIGH STREET	29				

Towns Served: EAST HAMPTON

## Certified Operator Information

Water System Facility: TREATMENT PLANT (WSF ID: 548)

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
FILANDA, MICHAEL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2028
SUSCO, VINCENT	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2024
BOULE, MICHAEL	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2026

## Contact Information

Name	Organization	Job Title		
Ms. Margaret Gledhill	41 East High St LLC	Property Manager		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
705 N Mountain Rd		Newington	CT	06111
Business Phone	Extension	Fax	Mobile Phone	Email Address
860-358-0788			860-377-8912	margaret@alta-properties.com

Contact Role(s): **Administrative Contact, Legal Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0421001	WESTSIDE MANOR	C	30	P	GW
Local Address (where applicable)	Service Connections	Residential 1	Commercial	Industrial	Combined

Towns Served: EAST HAMPTON

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

<b>Chlorine Residual (1012)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31		
<b>Total Haloacetic Acids (2456)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
KITCHEN (L15)	1/1/25 - 12/31/25	7/1-7/31	Complete
	1/1/26 - 12/31/26	7/1-7/31	
	1/1/27 - 12/31/27	7/1-7/31	
<b>Total Trihalomethanes (2950)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ROOM 7 (L112)	1/1/25 - 12/31/25	7/1-7/31	Complete
	1/1/26 - 12/31/26	7/1-7/31	
	1/1/27 - 12/31/27	7/1-7/31	
<b>Total Coliform (3100)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
<b>Lead And Copper (PBCU)</b>	<b>5 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/27	6/1-9/30	
<b>Physical Parameters (PPS)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0421001	WESTSIDE MANOR	C	30	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: EAST HAMPTON

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

Physical Parameters (PPS)	1 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: **ENTRY POINT** (WSF ID: 00700)

Chloride (1017)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Net Gross Alpha (4000)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

Uranium (4006)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

Combined Radium-226/228 (4010)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0421001	WESTSIDE MANOR	C	30	P	GW
Local Address (where applicable)	Service Connections	Residential 1	Commercial	Industrial	Combined

Towns Served: EAST HAMPTON

## Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		
Organic Chemicals (VOCS)			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

Water System Facility: WELL 1 (WSF ID: 436)

E. Coli (3014)			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 1 (2)	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

## Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 12/1/2017	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		
	11/1/2025 - 11/30/2025		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0421001	WESTSIDE MANOR	C	30	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: EAST HAMPTON

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 12/1/2017		Compliance History: Monitoring Period	Operating Limit Monitoring Compliance Status: Compliance Status:
		12/1/2025 - 12/31/2025	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	8
Start Date: 7/1/2003		Compliance History: Monitoring Period	Operating Limit Monitoring Compliance Status: Compliance Status:
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT FISCAL AND ASSET MANAGEMENT CERT	1/1/2021	
RESPOND TO SANITARY SURVEY	10/17/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2027	

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total	Lead and Coliform	Copper	Asbestos Rule Tier	WQP 2 DBPR Stage
					Coliform Rule	Copper Rule Tier			
00600	DISTRIBUTION SYSTEM	3	ENTRY POINT	A	Y				
		4	GENERIC DISTRIBUTION	A	Y				
		B11	OFFICE	A	Y	1			
		B21	LAUNDRY	A	Y	1			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A					
		L11	EW BATHROOM	A	Y	3			
		L110	NURSES STATION	A	Y	1			
		L111	WEST WING BATHROOM	A	Y	1			
		L112	ROOM 7	A	Y	1			Y
		L12	ROOM 19	A	Y	3			
		L13	ROOM 17&18	A	Y	3			
		L14	DR FOUNTAIN	A	Y	1			
		L15	KITCHEN	A	Y	3			
		L16	JANITORS CLOSET	I	Y	1			
		L17	T WING BATHROOM 1	A	Y	1			
		L18	T WING BATHROOM 2	A	Y	1			
		L19	T WING BATHROOM 3	A	Y	1			
		L21	FULL BATH	A	Y	3			

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0421001	WESTSIDE MANOR	C	30	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		1			

Towns Served: EAST HAMPTON

Water System Facility and Sampling Point Inventory						
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform Status	Lead and Copper Rule Tier	Asbestos WQP 2 DBPR Stage
		L22	HALF BATH	A	Y	3
		UPSTREAM	WITHIN 5 SERVICE CON	A		
00700	ENTRY POINT	3	ENTRY POINT	A		
36279	TREATMENT PLANT					
436	WELL 1	2	WELL 1	A		
51360	ATMOSPHERIC STORAGE					
61462	TRANSFER PUMPS					

## Certified Operator Information

Water System Facility: TREATMENT PLANT (WSF ID: 36279)

Facility Classification:		Certification Expiration
Operator Name	Operator Type	Certification(s)
JACKSON IV, SHELBY P	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III
		WATER TREATMENT PLANT OPERATOR - CLASS IV

## Contact Information

Name	Organization	Job Title
Ms. Neeta Dhanraj	Westside Manor	Administrator
Mailing Address Line One	Mailing Address Line Two	City
9 West High St.	P.O. Box 279	State
Business Phone	Extension	Zip Code
860-267-4401	860-267-7966	East Hampton
		CT
		06424
Emergency Phone	Mobile Phone	Email Address
		860-816-2173
		dhanrajneeta@gmail.com

Contact Role(s): Administrative Contact, Legal Contact, Owner

### Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0421011	COBALT LODGE HEALTHCARE & REHAB CENTER	C	130	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
29 MIDDLE HADDAM RD	Connections	1			

Towns Served: EAST HAMPTON

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30		
<b>Total Coliform (3100)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
<b>Disinfectant Byproducts - TTHM &amp; HAA5 (DBP)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
HOPPER ROOM 2 (COBALT 1)	1/1/25 - 12/31/25		
	8/1/25 - 8/31		
	1/1/26 - 12/31/26		
	8/1/26 - 8/31		
	1/1/27 - 12/31/27		
	8/1/27 - 8/31		
<b>Lead And Copper (PBCU)</b>	<b>5 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/26		
	6/1/9-30		
	1/1/27 - 12/31/29		
	6/1/9-30		
<b>Physical Parameters (PPS)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0421011	COBALT LODGE HEALTHCARE & REHAB CENTER	C	130	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
29 MIDDLE HADDAM RD	Connections	1			

Towns Served: EAST HAMPTON

**Monitoring Requirements**

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Uranium (4006)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
<b>Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/27		
Water System Facility: <b>WELL 2 (WSF ID: 1726)</b>			
<b>E. Coli (3014)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 2 (2)	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0421011	COBALT LODGE HEALTHCARE & REHAB CENTER	C	130	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
29 MIDDLE HADDAM RD	Connections	1			

Towns Served: EAST HAMPTON

### Monitoring Requirements

Water System Facility: WELL 2 (WSF ID: 1726)

E. Coli (3014)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
		1/1/26 - 1/31/26		
		2/1/26 - 2/28/26		
		3/1/26 - 3/31/26		
		4/1/26 - 4/30/26		
		5/1/26 - 5/31/26		
		6/1/26 - 6/30/26		
		7/1/26 - 7/31/26		

### Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 11/1/2020	Compliance History: Monitoring Period	Operating Limit	Monitoring Compliance Status: Compliance Status:
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		
	11/1/2025 - 11/30/2025		
	12/1/2025 - 12/31/2025		

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT		3/1/2025

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total	Lead and Coliform	Copper	Stage
					Rule	Rule Tier	Asbestos	
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		COBALT 1	HOPPER ROOM 2	A	Y		N	
		COBALT 2	RIGHT SHOWER ROOM	A	Y		N	
		COBALT 3	WING 2 NURSE'S BATH	A	Y		N	
		COBALT 4	DIETARY BATHROOM	A	Y		N	
		COBALT 5	WING 2 TUB ROOM	A	Y		N	
		COBALT 6	WING 2 MEN'S ROOM	A	Y		N	
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
1726	WELL 2	2	WELL 2	A				
55043	ATMOSPHERIC TANK							

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0421011	COBALT LODGE HEALTHCARE & REHAB CENTER	C	130	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
29 MIDDLE HADDAM RD	Connections	1			

Towns Served: EAST HAMPTON

**Water System Facility and Sampling Point Inventory**

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total	Lead and Coliform	Copper	Stage	
				Status	Rule	Rule Tier		
61961	TREATMENT PLANT							

**Certified Operator Information**

Water System Facility: TREATMENT PLANT (WSF ID: 61961)

Facility Classification:	CLASS 1 TREATMENT PLANT			Certification Expiration
	Operator Name	Operator Type	Certification(s)	
COSSETTE, EVAN J		CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2027
			DISTRIBUTION SYSTEM OPERATOR IN TRAINING	6/30/2027
			DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2027

**Contact Information**

Name	Organization	Job Title		
Mr. Todd P. Zgorski	Z, Inc.	President/Treasurer		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
29 Middle Haddam Road	P.O. Box 246	Cobalt	CT	06414-0246
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone
860-267-9034	12	860-267-8617		860-301-6011
				cobalthealthcare@gmail.com

Contact Role(s): **Administrative Contact, Legal Contact**

Name	Organization	Job Title		
Cobalt Lodge Healthcare & Rehab Center				
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
Emergency Contact		Emergency Contact	CT	06000
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone
860-739-6163				

Contact Role(s): **Owner**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

**If you have any questions, please contact the Drinking Water Section at (860) 509-7333.**

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0424011	CHATHAM ACRES ELDERLY HOUSING	C	50	L	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
1 GOVERNOR BILL O'NEILL DR	Connections	41			

Towns Served: EAST HAMPTON

### Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30		
<b>Total Coliform (3100)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
<b>Lead And Copper (PBCU)</b>	<b>5 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/27	6/1-9/30	
<b>Physical Parameters (PPS)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/27		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
<b>Radionuclides - Gross Alpha, Combined Radium &amp; Uranium (RADA)</b>	<b>1 routine (RT) per six years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/28		
<b>Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)</b>	<b>1 (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25	1/1-12/31	Waiver
<b>Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0424011	CHATHAM ACRES ELDERLY HOUSING	C	50	L	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
1 GOVERNOR BILL O'NEILL DR	41				

Towns Served: EAST HAMPTON

### Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Organic Chemicals (VOCS)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
RESPOND TO SANITARY SURVEY	10/9/2022	
CROSS CONNECTION EXEMPTION	3/1/2025	

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	WQP 2	DBPR	Stage
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y					
		DOWNSTREAM	WITHIN 5 SERVICE CON	A						
		SP15	CENTER	A	Y					
		SP16	APT B-5	A	Y					
		SWS001	COMMUNITY BLDG	A	Y	2		Y	Y	
		SWS002	APT A-6	A	Y	2				
		SWS003	APT B-2	A	Y	2				
		SWS004	APT C-6	A	Y	2				
		SWS005	APT D-5	A	Y	2				
		SWS006	APT E-1	A	Y	2				
		UPSTREAM	WITHIN 5 SERVICE CON	A						
00700	ENTRY POINT	3	ENTRY POINT	A						
376	TREATMENT PLANT WELL 1									
438	WELL 1	2	WELL 1	A						
50678	ATMOSPHERIC STORAGE									
50680	HYDRONEUMATIC STORAGE									

### Certified Operator Information

Water System Facility: TREATMENT PLANT WELL 1 (WSF ID: 376)

Facility Classification:	CLASS 1 TREATMENT PLANT	Certification Expiration	
Operator Name	Operator Type	Certification(s)	Certification Expiration
LAFRAMBOISE, PAUL F.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	9/30/2027
		WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2027

### Contact Information

Name	Organization	Job Title
Mr. David Schumacher	East Hampton Housing	Executive Director
Mailing Address Line One	Mailing Address Line Two	City
Gov. Bill O'Neill Drive		State Zip Code
		CT 06421

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0424011	CHATHAM ACRES ELDERLY HOUSING	C	50	L	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
1 GOVERNOR BILL O'NEILL DR	41				

Towns Served: EAST HAMPTON

GOV. BILL O'NEILL DRIVE	East Hampton	C1	00424
Business Phone	Extension	Fax	Mobile Phone

860-267-8498      203-437-1511      dave@easthamptonctha.gov

Contact Role(s): **Administrative Contact, Legal Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0427011	MALLARD COVE CONDOMINIUM ASSN.	C	177	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
MALLARD COVE RD (OFF 66)	Connections	59			

Towns Served: EAST HAMPTON

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

<b>Chlorine Residual (1012)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30		
<b>Total Haloacetic Acids (2456)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
UNIT 30 (MC3)	1/1/25 - 12/31/25	7/1-7/31	
	1/1/26 - 12/31/26	7/1-7/31	
	1/1/27 - 12/31/27	7/1-7/31	
<b>Total Trihalomethanes (2950)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
UNIT 55 (MC5)	1/1/25 - 12/31/25	7/1-7/31	
	1/1/26 - 12/31/26	7/1-7/31	
	1/1/27 - 12/31/27	7/1-7/31	
<b>Total Coliform (3100)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
<b>Lead And Copper (PBCU)</b>	<b>10 routine (RT) per six months</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 12/31/25		Complete
	1/1/26 - 6/30/26		
	7/1/26 - 12/31/26		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0427011	MALLARD COVE CONDOMINIUM ASSN.	C	177	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
MALLARD COVE RD (OFF 66)	Connections	59			

Towns Served: EAST HAMPTON

**Monitoring Requirements**

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

Physical Parameters (PPS)	1 routine (RT) per month
<i>Sampling Point (Sampling Point ID)</i>	
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25
	9/1/25 - 9/30/25
	10/1/25 - 10/31/25
	11/1/25 - 11/30/25
	12/1/25 - 12/31/25
	1/1/26 - 1/31/26
	2/1/26 - 2/28/26
	3/1/26 - 3/31/26
	4/1/26 - 4/30/26
	5/1/26 - 5/31/26
	6/1/26 - 6/30/26
	7/1/26 - 7/31/26

Water System Facility: **ENTRY POINT** (WSF ID: 00700)

Inorganic Chemicals (IOCS)	1 routine (RT) per three years
<i>Sampling Point (Sampling Point ID)</i>	
ENTRY POINT (3)	1/1/25 - 12/31/27

Nitrate And Nitrite (NOX)	1 routine (RT) per year
<i>Sampling Point (Sampling Point ID)</i>	
ENTRY POINT (3)	1/1/25 - 12/31/25
	1/1/26 - 12/31/26
	1/1/27 - 12/31/27

Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)	1 routine (RT) per quarter
<i>Sampling Point (Sampling Point ID)</i>	
ENTRY POINT (3)	7/1/25 - 9/30/25
	10/1/25 - 12/31/25
	1/1/26 - 3/31/26
	4/1/26 - 6/30/26

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	1 routine (RT) per quarter
<i>Sampling Point (Sampling Point ID)</i>	
ENTRY POINT (3)	7/1/25 - 9/30/25
	10/1/25 - 12/31/25
	1/1/26 - 3/31/26
	4/1/26 - 6/30/26

Organic Chemicals (VOCS)	1 routine (RT) per quarter
<i>Sampling Point (Sampling Point ID)</i>	
ENTRY POINT (3)	7/1/25 - 9/30/25
	10/1/25 - 12/31/25
	1/1/26 - 3/31/26

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0427011	MALLARD COVE CONDOMINIUM ASSN.	C	177	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
MALLARD COVE RD (OFF 66)	Connections	59			

Towns Served: EAST HAMPTON

## Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Organic Chemicals (VOCS)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	4/1/26 - 6/30/26		

Water System Facility: WELL 3 (WSF ID: 451)

E. Coli (3014)	1 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 3 (2)	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: WELL 4 (WSF ID: 63306)

E. Coli (3014)	1 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 4 (2)	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

## Monthly Water System Facility (WSF) Level Monitoring Requirements

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0427011	MALLARD COVE CONDOMINIUM ASSN.	C	177	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
MALLARD COVE RD (OFF 66)	Connections	59			

Towns Served: EAST HAMPTON

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily	
<b>Start Date:</b> 1/1/2004		<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.7 PH	Daily	
<b>Start Date:</b> 7/1/2003		<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2026	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	3/31/2026	

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total		Lead and Coliform Rule	Copper Rule Tier	Asbestos	WQP 2 DBPR	Stage
				Status	Coliform Rule					
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y					
		DOWNSTREAM	WITHIN 5 SERVICE CON	A						
		M11	UNIT 4	A		2				
		M12	UNIT 20	A		2				
		M13	UNIT 37	A		2				
		M14	UNIT 47	A		2				
		MC1	UNIT 10	A	Y	2				
		MC10	UNIT 53	A	Y	2				Y
		MC2	UNIT 23	A	Y					
		MC3	UNIT 30	A	Y	2				Y
		MC4	UNIT 34	A	Y	2				Y
		MC5	UNIT 55	A	Y	2				Y
		MC6	ATMOSPHERIC TANK	P						
		MC7	WELL #1 DIRECT	P						
		MC8	WELL #2 DIRECT	P						

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0427011	MALLARD COVE CONDOMINIUM ASSN.	C	177	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
MALLARD COVE RD (OFF 66)	59				

Towns Served: EAST HAMPTON

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total	Lead and Coliform	Copper	Asbestos	WQP 2	DBPR	Stage
					Rule	Rule Tier					
		MC9	UNIT 52	A	Y	2					Y
		UPSTREAM	WITHIN 5 SERVICE CON	A							
00700	ENTRY POINT	3	ENTRY POINT	A							
36698	TREATMENT PLANT										
451	WELL 3	2	WELL 3	A							
59204	BOOSTER STATION										
63306	WELL 4	2	WELL 4	A							
ST01	ATMOSPHERIC TANK										

## Certified Operator Information

Water System Facility: TREATMENT PLANT (WSF ID: 36698)

**Facility Classification:** CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
KING, THAD D.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2028 12/31/2028

## Contact Information

Name	Organization	Job Title
Ms. Rita Jensen	Mallard Cove Condominium Assn	Treasurer
Mailing Address Line One	Mailing Address Line Two	City State Zip Code
61 Mallard Cove		East Hampton CT 06424
Business Phone	Extension	Fax
860-539-2809		
		Mobile Phone
		Emergency Phone
		Email Address
		ehmallardcove@gmail.com

Contact Role(s): **Administrative Contact**

Name	Organization	Job Title
Mr. Gregory Davis	Mallard Cove Condominium Assn	Interim President
Mailing Address Line One	Mailing Address Line Two	City State Zip Code
61 Mallard Cove		East Hampton CT 06424
Business Phone	Extension	Fax
860-682-3580		
		Mobile Phone
		Emergency Phone
		Email Address
		ehmallardcove@gmail.com

Contact Role(s): **Legal Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

**If you have any questions, please contact the Drinking Water Section at (860) 509-7333.**

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0427021	CTWC - WESTCHESTER EAST	C	153	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		103			

Towns Served: EAST HAMPTON

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30		
<b>Total Haloacetic Acids (2456)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
SAMPLING STATION (53251)	1/1/25 - 12/31/25	8/1-8/31	Complete
	1/1/26 - 12/31/26	8/1-8/31	
	1/1/27 - 12/31/27	8/1-8/31	
<b>Total Trihalomethanes (2950)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
6 WATERVIEW CIRCLE (WE30)	1/1/25 - 12/31/25	8/1-8/31	Complete
	1/1/26 - 12/31/26	8/1-8/31	
	1/1/27 - 12/31/27	8/1-8/31	
<b>Total Coliform (3100)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		Complete
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
<b>Lead And Copper (PBCU)</b>	<b>10 routine (RT) per six months</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 12/31/25		Complete
	1/1/26 - 6/30/26		
	7/1/26 - 12/31/26		
<b>Physical Parameters (PPS)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		Complete

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0427021	CTWC - WESTCHESTER EAST	C	153	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: EAST HAMPTON

**Monitoring Requirements**

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Physical Parameters (PPS)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	1 routine (RT) per month
		2/1/26 - 2/28/26			
		3/1/26 - 3/31/26			
		4/1/26 - 4/30/26			
		5/1/26 - 5/31/26			
		6/1/26 - 6/30/26			
		7/1/26 - 7/31/26			

Water System Facility: **ENTRY POINT #3 (WSF ID: 00702)**

Net Gross Alpha (4000)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	1 routine (RT) per three years
	ENTRY POINT #3 (3)	1/1/23 - 12/31/25			Complete
		1/1/26 - 12/31/28			
		1/1/29 - 12/31/31			
Uranium (4006)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	1 routine (RT) per three years
	ENTRY POINT #3 (3)	1/1/23 - 12/31/25			Complete
		1/1/26 - 12/31/28			
		1/1/29 - 12/31/31			

Combined Radium-226/228 (4010)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	1 routine (RT) per three years
	ENTRY POINT #3 (3)	1/1/23 - 12/31/25			Complete
		1/1/26 - 12/31/28			
		1/1/29 - 12/31/31			

Inorganic Chemicals (IOCS)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	1 routine (RT) per year
	ENTRY POINT #3 (3)	1/1/25 - 12/31/25			Complete
		1/1/26 - 12/31/26			
		1/1/27 - 12/31/27			

Nitrate And Nitrite (NOX)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	1 routine (RT) per year
	ENTRY POINT #3 (3)	1/1/25 - 12/31/25			Complete
		1/1/26 - 12/31/26			
		1/1/27 - 12/31/27			

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	1 routine (RT) per three years
	ENTRY POINT #3 (3)	1/1/23 - 12/31/25			Complete
		1/1/26 - 12/31/28			
		1/1/29 - 12/31/31			

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0427021	CTWC - WESTCHESTER EAST	C	153	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: EAST HAMPTON

**Monitoring Requirements**

Water System Facility: **ENTRY POINT #3 (WSF ID: 00702)**

Organic Chemicals (VOCS)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT #3 (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

**Monthly Water System Facility (WSF) Level Monitoring Requirements**

Water System Facility: **ENTRY POINT #3 (WSFID: 00702)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.25 MG/L	Continuous
Start Date:		Compliance History:	Monitoring
8/1/2021		Monitoring Period	Compliance Status:
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025	Y	
	10/1/2025 - 10/31/2025	Y	
	11/1/2025 - 11/30/2025	Y	
	12/1/2025 - 12/31/2025	Y	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.2 MG/L	2
Start Date:		Compliance History:	Monitoring
2/1/2022		Monitoring Period	Compliance Status:
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025	Y	
	10/1/2025 - 10/31/2025	Y	
	11/1/2025 - 11/30/2025	Y	
	12/1/2025 - 12/31/2025	Y	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date:		Compliance History:	Monitoring
11/1/2014		Monitoring Period	Compliance Status:
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025	Y	
	10/1/2025 - 10/31/2025	Y	
	11/1/2025 - 11/30/2025	Y	
	12/1/2025 - 12/31/2025	Y	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 1.0 MG/L	2
Start Date:		Compliance History:	Monitoring
2/1/2022		Monitoring Period	Compliance Status:
	8/1/2025 - 8/31/2025	Y	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0427021	CTWC - WESTCHESTER EAST	C	153	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: EAST HAMPTON

Water System Facility: ENTRY POINT #3 (WSFID: 00702)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 1.0 MG/L	2
Start Date: 2/1/2022		Compliance History: Monitoring Period	Operating Limit Compliance Status: Monitoring Compliance Status:
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
MAIL/HAND DELIVER NOTICE TO CONSUMERS	12/31/2025	
CERTIFY LEAD SL NOTIFICATION	7/1/2026	
CROSS CONNECTION SURVEY REPORT	3/1/2030	

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total	Lead and	Stage
					Coliform	Copper Rule Tier	
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y		
		53250	DISTRIBUTION SYSTEM	A	Y		
		53251	SAMPLING STATION	A	Y		Y
		53251 C	TWC - WESTCHESTER E	A	Y		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A			
		UPSTREAM	WITHIN 5 SERVICE CON	A			
		WE1	WELL ZONE #1	A	Y		
		WE11	DISTRIBUTION SYSTEM	A	Y		
		WE12	4 MOUNTAINVIEW RD	A	Y	3	
		WE13	10 MOUNTAINVIEW RD	A	Y	3	
		WE14	14 MOUNTAINVIEW RD	A	Y	3	
		WE15	23 MOUNTAINVIEW RD	A		3	
		WE16	27 MOUNTAINVIEW RD	A	Y	3	
		WE17	33 MOUNTAINVIEW RD	A	Y	3	
		WE18	40 MOUNTAINVIEW RD	A	Y	3	
		WE19	59 MOUNTAINVIEW RD	A	Y	3	
		WE2	WELL ZONE #2	A	Y		
		WE20	70 MOUNTAINVIEW RD	A	Y	3	
		WE21	91 MOUNTAINVIEW RD	A	Y	3	
		WE22	102 MOUNTAINVIEW RD	A	Y	3	
		WE23	108 MOUNTAINVIEW RD	A	Y	3	
		WE24	109 MOUNTAINVIEW RD	A	Y	3	
		WE25	5 HILLTOP RD	A	Y	3	
		WE26	11 HILLTOP RD	A	Y	3	

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT0427021</b>	<b>CTWC - WESTCHESTER EAST</b>	C	153	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
	103				

Towns Served: EAST HAMPTON

<b>Water System Facility and Sampling Point Inventory</b>									
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	WQP 2	DBPR Stage
	WE27	17 HILLTOP RD		A	Y	3			
	WE28	21 HILLTOP RD		A	Y	3			
	WE29	34 HILLTOP RD		A	Y	3			
	WE3	56 MOUNTAIN VIEW		A	Y				
	WE30	6 WATerview CIRCLE		A	Y	3			
	WE31	15 WATerview CIRCLE		A	Y	3			
	WE32	16 WATerview CIRCLE		A	Y	3			
	WE33	21 WATerview CIRCLE		A	Y	3			
	WE34	22 WATerview CIRCLE		A	Y	3			
	WE35	25 WATerview CIRCLE		A	Y	3			
	WE36	26 WATerview CIRCLE		A	Y	3			
	WE37	28 WATerview CIRCLE		A	Y	3			
	WE38	38 WATerview CIRCLE		A	Y	3			
	WE39	40 WATerview CIRCLE		A	Y	3			
	WE4	SHOP		A	Y				
	WE40	42 WATerview CIRCLE		A	Y	3			
	WE41	8 CLARK HILL RD		A	Y	N			
	WE42	20 HILLTOP ROAD		A	Y	N			
	WE43	24 HILLTOP ROD		A	Y	N			
	WE44	25 HILLTOP RD		A	Y	N			
	WE45	31 HILLTOP RD		A	Y	N			
	WE46	18 MOUNTAINVIEW RD		A	Y	N			
	WE47	24 MOUNTAINVIEW RD		A	Y	N			
	WE48	28 MOUNTAINVIEW RD		A	Y	N			
	WE49	30 MOUNTAINVIEW RD		A	Y	N			
	WE5	45 WATerview RD		A	Y				
	WE50	50 MOUNTAINVIEW RD		A	Y	N			
	WE51	55 MOUNTAINVIEW RD		A	Y	N			
	WE52	61 MOUNTAINVIEW RD		A	Y	N			
	WE53	66 MOUNTAINVIEW RD		A	Y	N			
	WE54	69 MOUNTAINVIEW RD		A	Y	N			
	WE55	76 MOUNTAINVIEW RD		A	Y	N			
	WE56	80 MOUNTAINVIEW RD		A	Y	N			
	WE57	84 MOUNTAINVIEW RD		A	Y	N			
	WE58	85 MOUNTAINVIEW RD		A	Y	N			
	WE59	97 MOUNTAINVIEW RD		A	Y	3			
	WE6	37 WATerview CIRCLE		A	Y				
	WE60	98 MOUNTAIN VIEW RD		A	Y	N			

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0427021	CTWC - WESTCHESTER EAST	C	153	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
	103				

Towns Served: EAST HAMPTON

<b>Water System Facility and Sampling Point Inventory</b>									
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total	Lead and Coliform	Lead and Copper Rule Tier	Asbestos	WQP 2	DBPR Stage
				Status	Rule				
	WE61	101 MOUNTAIN VIEW RD	A	Y	N				
	WE62	112 MOUNTAINVIEW RD	A	Y	3				
	WE63	1 WATerview CIR	A	Y	N				
	WE64	5 WATerview CIR	A	Y	N				
	WE65	7 WATerview CIR	A	Y	N				
	WE66	10 WATerview CIR	A	Y	N				
	WE67	32 WATerview CIR	A	Y	N				
	WE68	44 WATerview CIR	A		N				
	WE69	50 WATerview CIR	A		N				
	WE7	WE7-23 MOUNTAIN VIEW	A	Y					
	WE8	WE8-40 MOUNTAIN VIEW	A	Y					
	WE9	DISTRIBUTION SYSTEM	A	Y					
00702	ENTRY POINT #3	3	ENTRY POINT #3	A					
441	WELL 2	2	WELL 2	A					
442	WELL 1	2	WELL 1	A					
443	WELL 4	2	WELL 4	A					
459	WELL 6	2	WELL 6	A					
61376	TREATMENT PLANT								
61379	VFD PUMP STATION								
61383	ATMOSPHERIC STORAGE								
63157	IN BETWEEN PFAS FILTER	5	IN BETWEEN PFAS FILT	A					

## Certified Operator Information

Water System Facility: **TREATMENT PLANT (WSF ID: 61376)**

Facility Classification: CLASS 2 TREATMENT PLANT			Certification Expiration
Operator Name	Operator Type	Certification(s)	
KORNATZ, CHRISTOPHER	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2028
		WATER TREATMENT PLANT OPERATOR - CLASS III	3/31/2027
HINES, DAVE	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2027

## Contact Information

Name		Organization		Job Title		
<b>Mr. Craig J. Patla</b>		Connecticut Water Company		Vp, Service Delivery		
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
93 West Main Street				Clinton	CT	06413
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-664-6140				800-391-1924	craig.patla@ctwater.com	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0427021	CTWC - WESTCHESTER EAST	C	153	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
	103				Agricultural

Towns Served: EAST HAMPTON

Contact Role(s): Legal Contact, Owner

Name	Organization	Job Title		
Mr. Gerald McDermott	The Connecticut Water Company	Manager, Service Del		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
93 West Main Street		Clinton	CT	06413
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone
860-664-6125				Email Address ctwcdphadmin@ctwater.com

Contact Role(s): Administrative Contact

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0428031	CTWC - SPICE HILL DIVISION	C	712	P	GW
Local Address (where applicable)	Service Connections	Residential 178	Commercial	Industrial	Combined Agricultural

Towns Served: EAST HAMPTON

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

<b>Chlorine Residual (1012)</b>	<b>1 routine (RT) per month</b>		
<b>Sampling Point (Sampling Point ID)</b>	<b>Monitoring Period</b>	<b>Collection Period</b>	<b>Compliance Status</b>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		Complete
<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<b>Sampling Point (Sampling Point ID)</b>	<b>Monitoring Period</b>	<b>Collection Period</b>	<b>Compliance Status</b>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31		
<b>Total Coliform (3100)</b>	<b>1 routine (RT) per month</b>		
<b>Sampling Point (Sampling Point ID)</b>	<b>Monitoring Period</b>	<b>Collection Period</b>	<b>Compliance Status</b>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		Complete
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
<b>Disinfectant Byproducts - TTHM &amp; HAA5 (DBP)</b>	<b>1 routine (RT) per year</b>		
<b>Sampling Point (Sampling Point ID)</b>	<b>Monitoring Period</b>	<b>Collection Period</b>	<b>Compliance Status</b>
SAMPLING STATION (SP5000)	1/1/25 - 12/31/25	8/1-8/30	Complete
	1/1/26 - 12/31/26	8/1-8/30	
	1/1/27 - 12/31/27	8/1-8/30	
<b>Lead And Copper (PBCU)</b>	<b>10 routine (RT) per year</b>		
<b>Sampling Point (Sampling Point ID)</b>	<b>Monitoring Period</b>	<b>Collection Period</b>	<b>Compliance Status</b>
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/25	6/1-9/30	Complete
	1/1/26 - 12/31/26	6/1-9/30	
	1/1/27 - 12/31/27	6/1-9/30	
<b>Physical Parameters (PPS)</b>	<b>1 routine (RT) per month</b>		
<b>Sampling Point (Sampling Point ID)</b>	<b>Monitoring Period</b>	<b>Collection Period</b>	<b>Compliance Status</b>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0428031	CTWC - SPICE HILL DIVISION	C	712	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: EAST HAMPTON

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

Physical Parameters (PPS)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
		11/1/25 - 11/30/25		Complete
		12/1/25 - 12/31/25		Complete
		1/1/26 - 1/31/26		Complete
		2/1/26 - 2/28/26		
		3/1/26 - 3/31/26		
		4/1/26 - 4/30/26		
		5/1/26 - 5/31/26		
		6/1/26 - 6/30/26		
		7/1/26 - 7/31/26		

Water System Facility: **ENTRY POINT** (WSF ID: 00700)

Net Gross Alpha (4000)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		

Uranium (4006)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		

Combined Radium-226/228 (4010)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		

Inorganic Chemicals (IOCS)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		

Nitrate And Nitrite (NOX)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
		1/1/26 - 12/31/26		
		1/1/27 - 12/31/27		

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	ENTRY POINT (3)	1/1/23 - 12/31/25		Complete

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0428031	CTWC - SPICE HILL DIVISION	C	712	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		178			

Towns Served: EAST HAMPTON

### Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Organic Chemicals (VOCS)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

### Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7 PH	Daily
Start Date:	10/1/2010	Compliance History:	Monitoring
Monitoring Period	Operating Limit	Compliance Status:	Compliance Status:
8/1/2025 - 8/31/2025			
9/1/2025 - 9/30/2025			
10/1/2025 - 10/31/2025			
11/1/2025 - 11/30/2025			
12/1/2025 - 12/31/2025			

Water System Facility: SPICE HILL PUMP HOUSE (WSFID: TP001)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Continuous
Start Date:	11/1/2015	Compliance History:	Monitoring
Monitoring Period	Operating Limit	Compliance Status:	Compliance Status:
8/1/2025 - 8/31/2025		Y	
9/1/2025 - 9/30/2025		Y	
10/1/2025 - 10/31/2025		Y	
11/1/2025 - 11/30/2025		Y	
12/1/2025 - 12/31/2025		Y	

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2028	

### Water System Facility and Sampling Point Inventory

Water System Facility Facility ID	Sampling Point ID	Sampling Point Description	Total	Lead and Coliform	Copper	Stage
			Status	Rule	Rule Tier	
00600 DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM DOWNSTREAM WITHIN 5 SERVICE CON	A	Y		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0428031	CTWC - SPICE HILL DIVISION	C	712	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
	178				Agricultural

Towns Served: EAST HAMPTON

Water System Facility and Sampling Point Inventory								
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos WQP 2 DBPR	Stage
		SP5000	SAMPLING STATION		A	Y		Y
		SPIC001	28 SPICE HILL	A	Y	N		Y
		SPIC002	41 SPICE HILL	A	Y	N		
		SPIC003	47 SPICE HILL	A	Y	N		
		SPIC004	50 SPICE HILL	A	Y	N		
		SPIC005	62 SPICE HILL	A	Y	N		
		SPIC006	8 SPICE HILL	A	Y	N		
		SPIC007	91 TARRAGON	A	Y			
		SPIC008	DISTRIBUTION SYSTEM	A	Y			
		SPIC009	DISTRIBUTION SYSTEM	A	Y			
		SPIC010	DISTRIBUTION SYSTEM	A	Y			
		SPIC011	17 SPICE HILL DR	A	Y	N		
		SPIC012	19 SPICE HILL DR	A	Y	N		
		SPIC013	2 SPICE HILL DR	A	Y	N		
		SPIC014	21 SPICE HILL DR	A	Y	N		
		SPIC015	23 SPICE HILL DR	A	Y	N		
		SPIC016	24 SPICE HILL DR	A	Y	N		
		SPIC017	25 SPICE HILL DR	A	Y	N		
		SPIC018	26 SPICE HILL DR	A	Y	N		
		SPIC019	27 SPICE HILL DR	A	Y	N		
		SPIC020	29 SPICE HILL DR	A	Y	N		
		SPIC021	3 SPICE HILL DR	A	Y	N		
		SPIC022	31 SPICE HILL DR	A	Y	N		
		SPIC023	33 SPICE HILL DR	A	Y	N		
		SPIC024	34 SPICE HILL DR	A	Y	N		
		SPIC025	35 SPICE HILL DR	A	Y	N		
		SPIC026	36 SPICE HILL DR	A	Y	N		
		SPIC027	38 SPICE HILL DR	A	Y	N		
		SPIC028	4 SPICE HILL DR	A	Y	N		
		SPIC029	40 SPICE HILL DR	A	Y	N		
		SPIC030	42 SPICE HILL DR	A	Y	N		
		SPIC031	45 SPICE HILL DR	A	Y	N		
		SPIC032	46 SPICE HILL DR	A	Y	N		
		SPIC033	48 SPICE HILL DR	A	Y	N		
		SPIC034	5 SPICE HILL DR	A	Y	N		
		SPIC035	6 SPICE HILL DR	A	Y	N		
		SPIC036	7 SPICE HILL DR	A	Y	N		
		SPIC037	9 SPICE HILL DR	A	Y	N		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0428031	CTWC - SPICE HILL DIVISION	C	712	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		178			Agricultural

Towns Served: EAST HAMPTON

<b>Water System Facility and Sampling Point Inventory</b>								
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos WQP 2 DBPR	Stage
	SPIC038	1 SPICE HILL DR		A	Y	N		
	SPIC039	10 SPICE HILL DR		A	Y	N		
	SPIC040	11 SPICE HILL DR		A	Y	N		
	SPIC041	12 SPICE HILL DR		A	Y	N		
	SPIC042	13 SPICE HILL DR		A	Y	N		
	SPIC043	14 SPICE HILL DR		A	Y	N		
	SPIC044	15 SPICE HILL DR		A	Y	N		
	SPIC045	16 SPICE HILL DR		A	Y	N		
	SPIC046	18 SPICE HILL DR		A	Y	N		
	SPIC047	20 SPICE HILL DR		A	Y	N		
	SPIC048	22 SPICE HILL DR		A	Y	N		
	SPIC049	30 SPICE HILL DR		A	Y	N		
	SPIC050	32 SPICE HILL DR		A	Y	N		
	SPIC051	37 SPICE HILL DR		A	Y	N		
	SPIC052	39 SPICE HILL DR		A	Y	N		
	SPIC053	43 SPICE HILL DR		A	Y	N		
	SPIC054	44 SPICE HILL DR		A	Y	N		
	SPIC055	57 SPICE HILL DR		A	Y	N		
	SPIC056	58 SPICE HILL DR		A	Y	N		
	SPIC057	59 SPICE HILL DR		A	Y	N		
	SPIC058	63 SPICE HILL DR		A	Y	N		
	SPIC059	95 TARRAGON DR		A	Y	N		
	UPSTREAM	WITHIN 5 SERVICE CON		A				
00700	ENTRY POINT	3	ENTRY POINT	A				
447	WELL 8	2	WELL 8	A				
448	WELL 6	2	WELL 6	A				
451	WELL 1	2	WELL 1	A				
452	WELL 2	2	WELL 2	A				
453	WELL 5	2	WELL 5	A				
52128	WELL 11	2	WELL 11	A				
52130	WELL 12	2	WELL 12	A				
52132	WELL 15	2	WELL 15	A				
52703	ATMOSPHERIC STORAGE							
52705	PRESSURE TANK							
52707	PUMP STATION							
52909	WELL 14	2	WELL 14	A				
56642	WELL 17	2	WELL 17	A				
TP001	SPICE HILL PUMP HOUSE							

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0428031	CTWC - SPICE HILL DIVISION	C	712	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		178			Agricultural

Towns Served: EAST HAMPTON

<b>Water System Facility and Sampling Point Inventory</b>							
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform Status	Lead and Copper Rule	Asbestos Rule Tier	Stage WQP 2 DBPR

## Certified Operator Information

Water System Facility: SPICE HILL PUMP HOUSE (WSF ID: TP001)

Facility Classification:	CLASS 1 TREATMENT PLANT			Certification Expiration
<b>Operator Name</b>	<b>Operator Type</b>	<b>Certification(s)</b>		
KORNATZ, CHRISTOPHER	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III		6/30/2028
		WATER TREATMENT PLANT OPERATOR - CLASS III		3/31/2027
HINES, DAVE	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II		9/30/2027

## Contact Information

Name	Organization	Job Title		
Mr. Craig J. Patla	Connecticut Water Company	Vp, Service Delivery		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
93 West Main Street		Clinton	CT	06413
Business Phone	Extension	Fax	Mobile Phone	Email Address
860-664-6140				800-391-1924 craig.patla@ctwater.com

Contact Role(s): Legal Contact, Owner

Name	Organization	Job Title		
Mr. Gerald McDermott	The Connecticut Water Company	Manager, Service Del		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
93 West Main Street		Clinton	CT	06413
Business Phone	Extension	Fax	Mobile Phone	Email Address
860-664-6125				ctwcdphadmin@ctwater.com

Contact Role(s): Administrative Contact

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

**NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0429011	CTWC - BAKER HILL DIVISION	C	203	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: EAST HAMPTON

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

<b>Chlorine Residual (1012)</b>	<b>2 routine (RT) per quarter</b>		
<b>Sampling Point (Sampling Point ID)</b>	<b>Monitoring Period</b> <b>Collection Period</b> <b>Compliance Status</b>		
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<b>Sampling Point (Sampling Point ID)</b>	<b>Monitoring Period</b> <b>Collection Period</b> <b>Compliance Status</b>		
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31		
<b>Total Haloacetic Acids (2456)</b>	<b>1 routine (RT) per year</b>		
<b>Sampling Point (Sampling Point ID)</b>	<b>Monitoring Period</b> <b>Collection Period</b> <b>Compliance Status</b>		
LAUREL R. NHOLLOW HYDRANT (LR002)	1/1/25 - 12/31/25	8/1-8/31	Complete
	1/1/26 - 12/31/26	8/1-8/31	
	1/1/27 - 12/31/27	8/1-8/31	
<b>Total Trihalomethanes (2950)</b>	<b>1 routine (RT) per year</b>		
<b>Sampling Point (Sampling Point ID)</b>	<b>Monitoring Period</b> <b>Collection Period</b> <b>Compliance Status</b>		
LAUREL RIDGE EAST HYDRANT (LR003)	1/1/25 - 12/31/25	8/1-8/31	Complete
	1/1/26 - 12/31/26	8/1-8/31	
	1/1/27 - 12/31/27	8/1-8/31	
<b>Total Coliform (3100)</b>	<b>2 routine (RT) per quarter</b>		
<b>Sampling Point (Sampling Point ID)</b>	<b>Monitoring Period</b> <b>Collection Period</b> <b>Compliance Status</b>		
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
<b>Lead And Copper (PBCU)</b>	<b>10 routine (RT) per six months</b>		
<b>Sampling Point (Sampling Point ID)</b>	<b>Monitoring Period</b> <b>Collection Period</b> <b>Compliance Status</b>		
Select from Inventory of Active Sampling Points	7/1/25 - 12/31/25		Complete
	1/1/26 - 6/30/26		
	7/1/26 - 12/31/26		
<b>Physical Parameters (PPS)</b>	<b>2 routine (RT) per quarter</b>		
<b>Sampling Point (Sampling Point ID)</b>	<b>Monitoring Period</b> <b>Collection Period</b> <b>Compliance Status</b>		
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: **ENTRY POINT - BAKER HILL** (WSF ID: 00700)

<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per three years</b>		
<b>Sampling Point (Sampling Point ID)</b>	<b>Monitoring Period</b> <b>Collection Period</b> <b>Compliance Status</b>		
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0429011	CTWC - BAKER HILL DIVISION	C	203	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		157			

Towns Served: EAST HAMPTON

### Monitoring Requirements

Water System Facility: ENTRY POINT - BAKER HILL (WSF ID: 00700)

<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/29 - 12/31/31		
<b>Uranium (4006)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Gross Beta Particle Activity (4100)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Man-Made Beta Particle &amp; Photon Emitters (4101)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Tritium (4102)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Strontium-90 (4174)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/26		Complete
	1/1/27 - 12/31/29		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0429011	CTWC - BAKER HILL DIVISION	C	203	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: EAST HAMPTON

**Monitoring Requirements**

Water System Facility: ENTRY POINT - BAKER HILL (WSF ID: 00700)

<b>Nitrate And Nitrite (NOX)</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
<b>Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Organic Chemicals (VOCS)</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

Water System Facility: ENTRY POINT - LAUREL RIDGE (WSF ID: 00701)

<b>Gross Beta Particle Activity (4100)</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-LAUREL (3)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
<b>Man-Made Beta Particle &amp; Photon Emitters (4101)</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-LAUREL (3)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
<b>Tritium (4102)</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-LAUREL (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
<b>Strontium-90 (4174)</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-LAUREL (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
<b>Inorganic Chemicals (IOCS)</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-LAUREL (3)	1/1/23 - 12/31/25		Complete

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0429011	CTWC - BAKER HILL DIVISION	C	203	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		157			

Towns Served: EAST HAMPTON

**Monitoring Requirements**

Water System Facility: ENTRY POINT - LAUREL RIDGE (WSF ID: 00701)

<b>Inorganic Chemicals (IOCS)</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Nitrate And Nitrite (NOX)</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-LAUREL (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
<b>Radionuclides - Gross Alpha, Combined Radium &amp; Uranium (RADA)</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-LAUREL (3)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
<b>Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-LAUREL (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Organic Chemicals (VOCS)</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-LAUREL (3)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
Water System Facility: LAUREL RIDGE WELL 1 (WSF ID: 53205)			
<b>E. Coli (3014)</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
LAUREL WELL 1 (2)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
Water System Facility: LAUREL RIDGE WELL 2 (WSF ID: 53207)			
<b>E. Coli (3014)</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
LAUREL WELL 2 (2)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0429011	CTWC - BAKER HILL DIVISION	C	203	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: EAST HAMPTON

## Monitoring Requirements

Water System Facility: LAUREL RIDGE WELL 2 (WSF ID: 53207)

E. Coli (3014)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
		4/1/26 - 6/30/26		

Water System Facility: LAUREL RIDGE WELL 3 (WSF ID: 53209)

E. Coli (3014)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	LAUREL WELL 3 (2)	7/1/25 - 9/30/25		Out of Service
		10/1/25 - 12/31/25		
		1/1/26 - 3/31/26		
		4/1/26 - 6/30/26		

Water System Facility: EDGEWATER WELL #3 (WSF ID: 61518)

E. Coli (3014)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	EDGEWATER WELL #3 (2)	7/1/25 - 9/30/25		Complete
		10/1/25 - 12/31/25		Complete
		1/1/26 - 3/31/26		
		4/1/26 - 6/30/26		

Water System Facility: EDGEWATER WELL #4 (WSF ID: 61520)

E. Coli (3014)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	EDGEWATER WELL #4 (2)	7/1/25 - 9/30/25		Complete
		10/1/25 - 12/31/25		Complete
		1/1/26 - 3/31/26		
		4/1/26 - 6/30/26		

## Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT - LAUREL RIDGE (WSFID: 00701)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date:	Compliance History:	Operating Limit	Monitoring
5/1/2007	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		
	11/1/2025 - 11/30/2025		
	12/1/2025 - 12/31/2025		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0429011	CTWC - BAKER HILL DIVISION	C	203	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: EAST HAMPTON

Water System Facility: ENTRY POINT - LAUREL RIDGE (WSFID: 00701)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily	
<b>Start Date:</b> 11/1/2010		<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: .3 MG/L	2	
<b>Start Date:</b> 10/1/2010		<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		

**Other Compliance Schedules**

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2030	

**Water System Facility and Sampling Point Inventory**

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
					Rule	Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		BAK001	101 LAKE VISTA DR	A	Y		N	
		BAK002	102 LAKE VISTA DR	A	Y		N	
		BAK003	104 LAKE VISTA DR	A	Y		N	
		BAK004	105 LAKE VISTA DR	A	Y		N	
		BAK005	106 LAKE VISTA DR	A	Y		N	
		BAK006	201 LAKE VISTA DR	A	Y		N	
		BAK007	103 LAKE VISTA DR	A	Y		N	
		BAK008	107 LAKE VISTA DR	A	Y		N	
		BAK009	202 LAKE VISTA DR	A			N	
		BAK010	203 LAKE VISTA DR	A	Y		N	
		BAK011	204 LAKE VISTA DR	A	Y		N	
		BAK012	205 LAKE VISTA DR	A	Y		N	
		BAK013	206 LAKE VISTA DR	A	Y		N	
		BAK014	301 LAKE VISTA DR	A	Y		N	
		BAK015	302 LAKE VISTA DR	A	Y		N	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT0429011</b>	<b>CTWC - BAKER HILL DIVISION</b>	C	203	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
	157				Agricultural

Towns Served: EAST HAMPTON

<b>Water System Facility and Sampling Point Inventory</b>									
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	WQP 2	DBPR Stage
	BAK016	303 LAKE VISTA DR		A		N			
	BAK017	304 LAKE VISTA DR		A	Y	N			
	BAK018	305 LAKE VISTA DR		A	Y	N			
	BAK019	306 LAKE VISTA DR		A	Y	3			
	BAK020	307 LAKE VISTA DR		A	Y	N			
	BAK021	308 LAKE VISTA DR		A	Y	N			
	BAK022	401 LAKE VISTA DR		A	Y	N			
	BAK023	402 LAKE VISTA DR		A	Y	N			
	BAK024	403 LAKE VISTA DR		A	Y	N			
	BAK025	405 LAKE VISTA DR		A	Y	N			
	BAK026	406 LAKE VISTA DR		A	Y	N			
	BAK027	407 LAKE VISTA DR		A	Y	N			
	BAK028	501 LAKE VISTA DR		A	Y	N			
	BAK029	503 LAKE VISTA DR		A	Y	N			
	BAK030	601 LAKE VISTA DR		A	Y	N			
	BAK031	602 LAKE VISTA DR		A	Y	N			
	BAK032	603 LAKE VISTA DR		A	Y	N			
	BAK033	DISTRIBUTION SYSTEM		A	Y	N			
	BAK034	605 LAKE VISTA DR		A	Y	N			
	BAK035	607 LAKE VISTA DR		A	Y	N			
	BAK036	608 LAKE VISTA DR		A	Y	N			
	BAK037	701 LAKE VISTA DR		A	Y	N			
	BAK038	702 LAKE VISTA DR		A		N			
	BAK039	703 LAKE VISTA DR		A	Y	N			
	BAK040	704 LAKE VISTA DR		A		N			
	BAK041	705 LAKE VISTA DR		A	Y	N			
	BAK042	706 LAKE VISTA DR		A	Y	N			
	BAK043	707 LAKE VISTA DR		A		N			
	BAK044	708 LAKE VISTA DR		A	Y	N			
	BAK045	709 LAKE VISTA DR		A	Y	N			
	BAK046	710 LAKE VISTA DR		A	Y	N			
	BAK047	711 LAKE VISTA DR		A	Y	N			
	BAK048	712 LAKE VISTA DR		A	Y	N			
	BAK049	801 LAKE VISTA DR		A	Y	N			
	BAK050	803 LAKE VISTA DR		A	Y	N			
	BAK051	804 LAKE VISTA DR		A	Y	N			
	BAK052	805 LAKE VISTA DR		A	Y	N			
	BAK053	806 LAKE VISTA DR		A	Y	N			

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT0429011</b>	<b>CTWC - BAKER HILL DIVISION</b>	C	203	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
	157				

Towns Served: EAST HAMPTON

<b>Water System Facility and Sampling Point Inventory</b>									
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	WQP 2	DBPR Stage
	BAK054	807 LAKE VISTA DR		A	Y	N			
	BAK055	808 LAKE VISTA DR		A	Y	N			
	BAK056	809 LAKE VISTA DR		A	Y	N			
	BAK057	810 LAKE VISTA DR		A	Y	N			
	BAK058	811 LAKE VISTA DR		A	Y	N			
	DOWNSTREAM	WITHIN 5 SERVICE CON		A					
	LR002	LAUREL R. NHOLLOW HY		A					Y
	LR003	LAUREL RIDGE EAST HY		A					Y
	LR004	DISTRIBUTION SYSTEM		A	Y				
	LR005	DISTRIBUTION SYSTEM		A	Y				
	LR006	18 LAUREL RIDGE		A	Y	N			
	LR007	21 LAUREL RIDGE		A	Y	N			
	LR008	22 LAUREL RIDGE		A	Y	N			
	LR009	23 LAUREL RIDGE		A	Y	N			
	LR010	24 LAUREL RIDGE		A	Y	N			
	LR011	26 LAUREL RIDGE		A	Y	N			
	LR012	37 LAUREL RIDGE		A	Y	N			
	LR013	58 LAUREL RIDGE		A	Y	N			
	LR014	59 LAUREL RIDGE		A	Y	N			
	LR015	65 LAUREL RIDGE		A					
	LR016	67 LAUREL RIDGE		A	Y	N			
	LR017	80 LAUREL RIDGE		A					
	LR018	81 LAUREL RIDGE		A	Y	N			
	LR019	82 LAUREL RIDGE		A	Y	N			
	LR020	84 LAUREL RIDGE		A	Y	N			
	LR021	85 LAUREL RIDGE		A	Y	N			
	LR022	87 LAUREL RIDGE		A	Y	N			
	LR023	88 LAUREL RIDGE		A	Y	N			
	LR024	89 LAUREL RIDGE		A	Y	N			
	LR025	91 LAUREL RIDGE		A	Y	N			
	LR026	92 LAUREL RIDGE		A	Y	N			
	LR027	94 LAUREL RIDGE		A	Y	N			
	LR028	95 LAUREL RIDGE		A	Y	N			
	LR029	96 LAUREL RIDGE		A	Y	N			
	LR030	97 LAUREL RIDGE		A	Y	N			
	LR031	100 LAUREL RIDGE		A	Y	N			
	LR032	104 LAUREL RIDGE		A	Y	N			
	LR033	105 LAUREL RIDGE		A	Y	N			

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT0429011</b>	<b>CTWC - BAKER HILL DIVISION</b>	C	203	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
	157				Agricultural

Towns Served: EAST HAMPTON

<b>Water System Facility and Sampling Point Inventory</b>									
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	WQP 2	DBPR Stage
	LR034	106 LAUREL RIDGE	A	Y	N				
	LR035	108 LAUREL RIDGE	A	Y	N				
	LR036	112 LAUREL RIDGE	A	Y	N				
	LR037	114 LAUREL RIDGE	A	Y	N				
	LR038	116 LAUREL RIDGE	A	Y	N				
	LR039	120 LAUREL RIDGE	A	Y	N				
	LR040	122 LAUREL RIDGE	A	Y	N				
	LR041	124 LAUREL RIDGE	A	Y	N				
	LR042	1 NORTH HOLLOW	A	Y	N				
	LR043	3 NORTH HOLLOW	A	Y	N				
	LR044	5 NORTH HOLLOW	A		N				
	LR045	6 NORTH HOLLOW	A	Y	N				
	LR046	7 NORTH HOLLOW	A	Y	N				
	LR047	9 NORTH HOLLOW	A	Y	N				
	LR048	10 NORTH HOLLOW	A	Y	N				
	LR049	12 NORTH HOLLOW	A	Y	N				
	LR050	13 NORTH HOLLOW	A	Y	N				
	LR051	15 NORTH HOLLOW	A	Y	N				
	LR052	16 NORTH HOLLOW	A	Y	N				
	LR053	19 NORTH HOLLOW	A	Y	N				
	LR054	20 NORTH HOLLOW	A	Y	N				
	LR055	22 NORTH HOLLOW	A	Y	N				
	LR056	23 NORTH HOLLOW	A	Y	N				
	LR057	24 NORTH HOLLOW	A	Y	N				
	LR058	1 NORTH RIDGE	A	Y	N				
	LR059	2 NORTH RIDGE	A	Y	N				
	LR060	4 NORTH RIDGE	A	Y	N				
	LR061	5 NORTH RIDGE	A	Y	N				
	LR062	6 NORTH RIDGE	A	Y	N				
	LR063	7 NORTH RIDGE	A	Y	N				
	LR064	8 NORTH RIDGE	A	Y	N				
	LR065	10 NORTH RIDGE	A	Y	N				
	LR066	12 NORTH RIDGE	A	Y	N				
	LR067	14 NORTH RIDGE	A	Y	N				
	LR068	15 NORTH RIDGE	A	Y	N				
	LR069	16 NORTH RIDGE	A	Y	N				
	LR070	17 NORTH RIDGE	A	Y	N				
	LR071	18 NORTH RIDGE	A	Y	N				

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0429011	CTWC - BAKER HILL DIVISION	C	203	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		157			Agricultural

Towns Served: EAST HAMPTON

<b>Water System Facility and Sampling Point Inventory</b>							
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total	Lead and Coliform		Stage
				Status	Rule	Copper Rule Tier	
		LR072	19 NORTH RIDGE	A	Y	N	
		LR073	20 NORTH RIDGE	A	Y	N	
		LR074	1 SOUTH HOLLOW	A	Y	N	
		LR075	4 SOUTH HOLLOW	A	Y	N	
		LR076	5 SOUTH HOLLOW	A	Y	N	
		LR077	8 SOUTH HOLLOW	A	Y	N	
		LR078	9 SOUTH HOLLOW	A	Y	N	
		LR079	10 SOUTH HOLLOW	A	Y	N	
		LR080	11 SOUTH HOLLOW	A	Y	N	
		LR081	12 SOUTH HOLLOW	A	Y	N	
		LR082	13 SOUTH HOLLOW	A	Y	N	
		LR083	14 SOUTH HOLLOW	A	Y	N	
		LR084	15 SOUTH HOLLOW	A	Y	N	
		LR085	16 SOUTH HOLLOW	A	Y	N	
		LR086	4 SOUTH RIDGE	A	Y	N	
		LR087	6 SOUTH RIDGE	A	Y	N	
		LR088	8 SOUTH RIDGE	A	Y	N	
		LR089	9 SOUTH RIDGE	A	Y	N	
		LR090	11 SOUTH RIDGE	A	Y	N	
		LR091	12 SOUTH RIDGE	A	Y	N	
		LR092	13 SOUTH RIDGE	A	Y	N	
		LR093	14 SOUTH RIDGE	A	Y	N	
		LR094	55 LAUREL RIDGE	A	Y		
		UPSTREAM	WITHIN 5 SERVICE CON	A			
00700	ENTRY POINT - BAKER HILL	3	ENTRY POINT	A			
00701	ENTRY POINT - LAUREL RIDGE	3	ENTRY POINT-LAUREL	A			
1740	BAKER HILL WELL 4	2	WELL 4	A			
468	BAKER HILL WELL 1	2	WELL 1	A			
470	BAKER HILL WELL 3	2	WELL 3	A			
52609	BAKER HILL ATMOSPHERIC TANK						
52611	BAKER HILL PRESSURE TANK						
52613	BAKER HILL PUMP STATION						
53205	LAUREL RIDGE WELL 1	2	LAUREL WELL 1	A			
53207	LAUREL RIDGE WELL 2	2	LAUREL WELL 2	A			
53209	LAUREL RIDGE WELL 3	2	LAUREL WELL 3	A			
53212	LAUREL RIDGE TP						
53214	LAUREL RIDGE ATM TANK						
53216	LAUREL RIDGE PRESSURE TANK						

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0429011	CTWC - BAKER HILL DIVISION	C	203	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
	157				Agricultural

Towns Served: EAST HAMPTON

<b>Water System Facility and Sampling Point Inventory</b>					
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform Status	Lead and Copper Rule Tier
				Stage 2 WQP	Asbestos DBPR
53218	LAUREL RIDGE PUMP STATION				
545	BAKER HILL TP				
61518	EDGEWATER WELL #3	2	EDGEWATER WELL #3	A	
61520	EDGEWATER WELL #4	2	EDGEWATER WELL #4	A	
62963	EDGEWATER WELL #2A	2	EDGEWATER WELL #2A	A	
62965	EDGEWATER WELL #6	2	EDGEWATER WELL #6	A	
62968	EDGEWATER WELL #5	2	EDGEWATER WELL #5	A	
62970	EDGEWATER WELL #8	2	EDGEWATER WELL #8	A	
62972	EDGEWATER WELL #9	2	EDGEWATER WELL #9	A	

## Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: DISTRIBUTION SYSTEM				Certification Expiration
Operator Name	Operator Type	Certification(s)		Certification Expiration
HART, WILLIAM G.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II		6/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS III		12/31/2026
BUHLER, BRANT D.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II		12/31/2028
		DISTRIBUTION SYSTEM OPERATOR - CLASS III		6/30/2028

Water System Facility: **BAKER HILL TP (WSF ID: 545)**

Facility Classification: CLASS 2 TREATMENT PLANT				Certification Expiration
Operator Name	Operator Type	Certification(s)		Certification Expiration
KORNATZ, CHRISTOPHER	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III		6/30/2028
		WATER TREATMENT PLANT OPERATOR - CLASS III		3/31/2027
HINES, DAVE	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II		9/30/2027

Water System Facility: **LAUREL RIDGE TP (WSF ID: 53212)**

Facility Classification: CLASS 2 TREATMENT PLANT				Certification Expiration
Operator Name	Operator Type	Certification(s)		Certification Expiration
KORNATZ, CHRISTOPHER	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III		6/30/2028
		WATER TREATMENT PLANT OPERATOR - CLASS III		3/31/2027
HINES, DAVE	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II		9/30/2027

## Contact Information

Name		Organization		Job Title		
<b>Mr. Craig J. Patla</b>		Connecticut Water Company		Vp, Service Delivery		
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
93 West Main Street				Clinton	CT	06413
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-664-6140				800-391-1924	craig.patla@ctwater.com	

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0429011	CTWC - BAKER HILL DIVISION	C	203	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		157			Agricultural

Towns Served: EAST HAMPTON

Contact Role(s): Legal Contact, Owner

Name	Organization	Job Title		
Mr. Gerald McDermott	The Connecticut Water Company	Manager, Service Del		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
93 West Main Street		Clinton	CT	06413
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone
860-664-6125				Email Address ctwcdphadmin@ctwater.com

Contact Role(s): Administrative Contact

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0429031	EAST HAMPTON WPCA - VILLAGE CENTER	C	366	L	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		9	22		

Towns Served: EAST HAMPTON

**Monitoring Requirements**

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

<b>Chlorine Residual (1012)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30		
<b>Total Haloacetic Acids (2456)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
94 MAIN STREET (VC0003)	1/1/25 - 12/31/25	7/1-7/31	Complete
	1/1/26 - 12/31/26	7/1-7/31	
	1/1/27 - 12/31/27	7/1-7/31	
<b>Total Trihalomethanes (2950)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EPOCH ARTS (VC007)	1/1/25 - 12/31/25	7/1-7/31	Complete
	1/1/26 - 12/31/26	7/1-7/31	
	1/1/27 - 12/31/27	7/1-7/31	
<b>Total Coliform (3100)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
<b>Lead And Copper (PBCU)</b>	<b>5 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/27	6/1-9/30	
<b>Physical Parameters (PPS)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
Water System Facility: <b>ENTRY POINT</b> (WSF ID: 00700)			
<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Uranium (4006)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0429031	EAST HAMPTON WPCA - VILLAGE CENTER	C	366	L	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: EAST HAMPTON

### Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

<b>Uranium (4006)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/27		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
<b>Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
Water System Facility: WELL 2 (WSF ID: 1491)			
<b>E. Coli (3014)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 2 (2)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
Water System Facility: WELL 1 (WSF ID: 1492)			
<b>E. Coli (3014)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0429031	EAST HAMPTON WPCA - VILLAGE CENTER	C	366	L	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: EAST HAMPTON

## Monitoring Requirements

Water System Facility: WELL 1 (WSF ID: 1492)

E. Coli (3014)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	WELL 1 (2)	7/1/25 - 9/30/25		Out of Service
		10/1/25 - 12/31/25		
		1/1/26 - 3/31/26		
		4/1/26 - 6/30/26		

## Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 1/3/2003	Compliance History: Monitoring Period	Operating Limit	Monitoring Compliance Status:
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		
	11/1/2025 - 11/30/2025		
	12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	4
Start Date: 3/1/2003	Compliance History: Monitoring Period	Operating Limit	Monitoring Compliance Status:
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		
	11/1/2025 - 11/30/2025		
	12/1/2025 - 12/31/2025		

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2026	

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule	Asbestos	Stage WQP 2 DBPR
					Rule Tier			
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
		VC0003	94 MAIN STREET	A	Y	1		
		VC001	93 MAIN STREET	A		1		
		VC002A	95 MAIN STREET	A		1		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0429031	EAST HAMPTON WPCA - VILLAGE CENTER	C	366	L	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		9	22		

Towns Served: EAST HAMPTON

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
					Y	Y	Y	Y
	VC003	6 SUMMIT STREET		A		1		
	VC006	81 MAIN STREET		A		1		
	VC007	EPOCH ARTS		A		1		
	VC008	82 MAIN STREET		A	Y	1		
	VC009	11 SKINNER ST		A	Y	1		
	VC010	87 MAIN STREET		A	Y	1		
	VC032A	70 MAIN STREET		A		1		
	VCCS	CENTER SCHOOL		A	Y	1		
	VCTB	TREATMENT BUILDING		A				
00700	ENTRY POINT	3	ENTRY POINT	A				
1491	WELL 2	2	WELL 2	A				
1492	WELL 1	2	WELL 1	A				
374	VILLAGE CENTER PUMPHOUSE							
50560	ATMOSPHERIC STORAGE TANK							
52473	PUMP STATION							

## Certified Operator Information

Water System Facility: VILLAGE CENTER PUMPHOUSE (WSF ID: 374)

Facility Classification:		Certification Expiration
CLASS 2 TREATMENT PLANT		
Operator Name	Operator Type	Certification(s)
COSSETTE, EVAN J	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR IN TRAINING DISTRIBUTION SYSTEM OPERATOR - CLASS II
ARMSTRONG, KYLE	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I WATER TREATMENT PLANT OPERATOR - CLASS II
CERRETA, PAUL M	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II WATER TREATMENT PLANT OPERATOR - CLASS II
		12/31/2028 9/30/2027

## Contact Information

Name	Organization	Job Title
Mr. Anthony M. Desimone	Town of East Hampton	Public Utilities Adm
Mailing Address Line One	Mailing Address Line Two	City
20 Gildersleeve Drive		State
Business Phone	Extension	Zip Code
860-267-2536	860-267-9913	aDeSimone@easthamptonct.gov
Contact Role(s):	Administrative Contact, Legal Contact, Owner	

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0429031	EAST HAMPTON WPCA - VILLAGE CENTER	C	366	L	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		9	22		Agricultural

Towns Served: EAST HAMPTON

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

*<http://www.ct.gov/dph/publicdrinkingwater>*

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0429121	EAST HAMPTON WPCA - ROYAL OAKS SYSTEM	C	328	L	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: EAST HAMPTON

### Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

<b>Chlorine Residual (1012)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		
<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
<b>Total Haloacetic Acids (2456)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
29 ROYAL OAKS AVE (RO010)	1/1/25 - 12/31/25   7/1-7/31		
	1/1/26 - 12/31/26   7/1-7/31		
	1/1/27 - 12/31/27   7/1-7/31		
<b>Total Trihalomethanes (2950)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
MEMORIAL SCHOOL (ROMS)	1/1/25 - 12/31/25   7/1-7/31		
	1/1/26 - 12/31/26   7/1-7/31		
	1/1/27 - 12/31/27   7/1-7/31		
<b>Total Coliform (3100)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
<b>Lead And Copper (PBCU)</b>	<b>5 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/25   6/1-9/30		
	1/1/26 - 12/31/26   6/1-9/30		
	1/1/27 - 12/31/27   6/1-9/30		
<b>Physical Parameters (PPS)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
Water System Facility: ROYAL OAKS ENTRY POINT (WSF ID: 00700)			
<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
EP - ROYAL OAKS (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0429121	EAST HAMPTON WPCA - ROYAL OAKS SYSTEM	C	328	L	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: EAST HAMPTON

### Monitoring Requirements

Water System Facility: ROYAL OAKS ENTRY POINT (WSF ID: 00700)

<b>Uranium (4006)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - ROYAL OAKS (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - ROYAL OAKS (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - ROYAL OAKS (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - ROYAL OAKS (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
<b>Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - ROYAL OAKS (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - ROYAL OAKS (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
Water System Facility: MEMORIAL SCHOOL ENTRY POINT (WSF ID: 00701)			
<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-MEMORIAL SCHOOL (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Uranium (4006)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-MEMORIAL SCHOOL (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0429121	EAST HAMPTON WPCA - ROYAL OAKS SYSTEM	C	328	L	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: EAST HAMPTON

### Monitoring Requirements

Water System Facility: MEMORIAL SCHOOL ENTRY POINT (WSF ID: 00701)

<b>Uranium (4006)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/29 - 12/31/31		
<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-MEMORIAL SCHOOL (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-MEMORIAL SCHOOL (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-MEMORIAL SCHOOL (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
<b>Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-MEMORIAL SCHOOL (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP-MEMORIAL SCHOOL (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
Water System Facility: WELL 1 (WSF ID: 51385)			
<b>E. Coli (3014)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 1 (2)	7/1/25 - 9/30/25		Out of Service
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
Water System Facility: WELL 3 (WSF ID: 51387)			
<b>E. Coli (3014)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 3 (2)	7/1/25 - 9/30/25		Complete

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0429121	EAST HAMPTON WPCA - ROYAL OAKS SYSTEM	C	328	L	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: EAST HAMPTON

### Monitoring Requirements

Water System Facility: WELL 3 (WSF ID: 51387)

E. Coli (3014)				1 routine (RT) per quarter
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
	10/1/25 - 12/31/25			
	1/1/26 - 3/31/26			
	4/1/26 - 6/30/26			

Water System Facility: WELL 4 (WSF ID: 51389)

E. Coli (3014)				1 routine (RT) per quarter
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
WELL 4 (2)	7/1/25 - 9/30/25		Complete	
	10/1/25 - 12/31/25			
	1/1/26 - 3/31/26			
	4/1/26 - 6/30/26			

### Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ROYAL OAKS ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 2/1/2006	Compliance History: Monitoring Period	Operating Limit	Monitoring Compliance Status:
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		
	11/1/2025 - 11/30/2025		
	12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date: 3/1/2009	Compliance History: Monitoring Period	Operating Limit	Monitoring Compliance Status:
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		
	11/1/2025 - 11/30/2025		
	12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Maximum: 9.0 PH	Daily
Start Date: 3/1/2009	Compliance History: Monitoring Period	Operating Limit	Monitoring Compliance Status:
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0429121	EAST HAMPTON WPCA - ROYAL OAKS SYSTEM	C	328	L	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: EAST HAMPTON

Water System Facility: ROYAL OAKS ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Maximum: 9.0 PH	Daily
Start Date:	3/1/2009	Compliance History: Monitoring Period	Operating Limit Monitoring Compliance Status: Compliance Status:
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

Water System Facility: MEMORIAL SCHOOL ENTRY POINT (WSFID: 00701)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 PH	Daily
Start Date:	1/1/2006	Compliance History: Monitoring Period	Operating Limit Monitoring Compliance Status: Compliance Status:
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Maximum: 9.0 PH	Daily
Start Date:	1/1/2006	Compliance History: Monitoring Period	Operating Limit Monitoring Compliance Status: Compliance Status:
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2026	

### Public Notification Requirements

Violation/Situation	Compliance Period	Notice Tier	Public Notification		PN Certification	
			Required	Performed	Due to DPH	Received
E. Coli M&R Violation	4/1/25 - 6/30/25	3	11/5/2026		11/15/2026	
E. Coli M&R Violation	4/1/25 - 6/30/25	3	11/5/2026		11/15/2026	
Chlorine M&R Violation	4/1/25 - 6/30/25	3	11/5/2026		11/15/2026	
Total Coliform M&R Violation	4/1/25 - 6/30/25	3	11/5/2026		11/15/2026	
Physical Parameters M&R Violation	4/1/25 - 6/30/25	3	11/5/2026		11/15/2026	

### Water System Facility and Sampling Point Inventory

Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform Status	Lead and Copper Rule	Asbestos Rule Tier	Stage 2 WQP	DBP
Facility ID							
00600 DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0429121	EAST HAMPTON WPCA - ROYAL OAKS SYSTEM	C	328	L	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
	82				

Towns Served: EAST HAMPTON

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	WQP 2	DBPR	Stage
		DOWNSTREAM	WITHIN 5 SERVICE CON	A						
		ROMS2	MEMORIAL SCHOOL	A	Y					
		RO001	14 ROYAL OAKS AVE	I						
		RO002	8 JOSEPH COURT	I						
		RO003	36 ROYAL OAKS AVE	I						
		RO004	55 ROYAL OAKS AVE	I						
		RO006	36 SMITH STREET	I						
		RO007	8 NICHOLAS COURT	A			N			
		RO009	6 JOSEPH COURT	I						
		RO010	29 ROYAL OAKS AVE	A			N			Y
		RO012	47 ROYAL OAKS AVE	A			N			
		RO014	5 NICHOLAS COURT	A			1			
		RO015	15 JULIA TERRACE	A			N			
		RO016	62 ROYAL OAKS AVE	A	Y		N			
		RO017	18 ROYAL OAKS AVE	A			N			
		RO023	23 MATHIEU LANE	A	Y		N			
		RO035	35 MATHIEU LANE	A	Y		N			
		RO071	71 ROYAL OAKS AVENUE	A			N			
		ROMS	MEMORIAL SCHOOL	A	Y	1				Y
		ROMS1	MEM SCHOOL KITCHEN	A	Y	1				
		ROMS2	MEM SCHOOL LOUNGE	A	Y	1				
		UPSTREAM	WITHIN 5 SERVICE CON	A						
00700	ROYAL OAKS ENTRY POINT	3	EP - ROYAL OAKS	A						
00701	MEMORIAL SCHOOL ENTRY POINT	3	EP-MEMORIAL SCHOOL	A						
1013	MEMORIAL SCHOOL TREATMENT STATION									
10204	MEMORIAL SCHOOL WELL	2	MEMORIAL SCH WELL	A						
51385	WELL 1	2	WELL 1	A						
51387	WELL 3	2	WELL 3	A						
51389	WELL 4	2	WELL 4	A						
51395	ROYAL OAKS TREATMENT PLANT									
51397	ATMOSPHERIC TANK 1									
51399	ATMOSPHERIC TANK 2									
51403	ROYAL OAKS PUMP STATION									

## Certified Operator Information

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0429121	EAST HAMPTON WPCA - ROYAL OAKS SYSTEM	C	328	L	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
	82				

Towns Served: EAST HAMPTON

## Certified Operator Information

Water System Facility: ROYAL OAKS TREATMENT PLANT (WSF ID: 51395)

**Facility Classification:** CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
COSSETTE, EVAN J	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR IN TRAINING DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2027 6/30/2027 9/30/2027
ARMSTRONG, KYLE	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2028 9/30/2028
CERRETA, PAUL M	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2028 9/30/2027

Water System Facility: MEMORIAL SCHOOL TREATMENT STATION (WSF ID: 1013)

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
COSSETTE, EVAN J	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV DISTRIBUTION SYSTEM OPERATOR IN TRAINING DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2027 6/30/2027 9/30/2027
ARMSTRONG, KYLE	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2028 9/30/2028
CERRETA, PAUL M	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2028 9/30/2027

## Contact Information

Name	Organization	Job Title		
Mr. Anthony M. Desimone	Town of East Hampton	Public Utilities Adm		
Mailing Address Line One 20 Gildersleeve Drive	Mailing Address Line Two	City East Hampton	State CT	Zip Code 06424
Business Phone 860-267-2536	Extension 860-267-9913	Fax	Mobile Phone	Emergency Phone Email Address aDeSimone@easthamptonct.gov

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.