

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0470052	EAST WINDSOR COMMONS, LLC	NTNC	30	P	GW
Local Address (where applicable)	150 NORTH ROAD	Service Connections	Residential 4	Commercial	Industrial
				Combined	Agricultural

Towns Served: EAST WINDSOR

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Asbestos (1094)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
Total Coliform (3100)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		Complete
	4/1/26 - 6/30/26		
Lead And Copper (PBCU)	5 routine (RT) per six months		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/26 - 6/30/26		
	7/1/26 - 12/31/26		
Lead And Copper (PBCU)	5 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/25	6/1-9/30	
Physical Parameters (PPS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		Complete
	4/1/26 - 6/30/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		Complete
	1/1/27 - 12/31/27		
Pesticides, Herbicides and PCBs-Phase II (SOC2)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		
Pesticides, Herbicides and PCBs-Phase V (SOC5)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0470052	EAST WINDSOR COMMONS, LLC	NTNC	30	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
150 NORTH ROAD	Connections	4			

Towns Served: EAST WINDSOR

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Organic Chemicals (VOCS)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2026	

Public Notification Requirements

Violation/Situation	Compliance Period	Notice Tier	Public Notification		PN Certification	
			Required	Performed	Due to DPH	Received
Total Coliform M&R Violation	4/1/25 - 6/30/25	3	10/9/2026		10/19/2026	
Physical Parameters M&R Violation	4/1/25 - 6/30/25	3	10/9/2026		10/19/2026	
Lead and Copper M&R Violation	10/1/25 -	3	12/30/2026		1/9/2027	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total		Lead and Copper		Stage
				Status	Coliform Rule	Rule Tier	Asbestos	
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		BP005	DENTIST KITCHENETTE	A	Y	2	Y	Y
		BP010	DENTIST REST 1	A	Y	2	Y	Y
		BP015	DENTIST REST 2	A	Y	2	Y	Y
		BP020	MEDICAL KITCHENETTE	A	Y	2	Y	Y
		BP025	MEDICAL BATHROOM	A	Y	2	Y	Y
		BP030	LEFT HAIR SALOON	A	Y	2	Y	Y
		BP035	VEGGIE FRUIT BATH	A	Y	2	Y	Y
		BP040	RIGHT HAIR SALOON	A	Y	2	Y	Y
		BP045	UNIT 1	A	Y	2	Y	Y
		BP050	UNIT 2	A	Y	2	Y	Y
		BP070	GAS STATION	A	Y	2	Y	Y
		BP075	BAKERY	A	Y	2	Y	Y
		BP080	RESTAURANT	A	Y	2	Y	Y
		BP085	CRAFTECH HOBBIES	A	Y	2	Y	Y
		BP090	CAROL SEAN HAIR	A	Y	2	Y	Y
		BP095	GOLD LEAF TATTOO	A	Y	2	Y	Y
		BP100	UNIT 6	A	Y	2	Y	Y
		BP105	142 EAST NORTH ROAD	A	Y	2	Y	Y
		BP110	AUTO GARAGE	A	Y	2	Y	Y
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0470052	EAST WINDSOR COMMONS, LLC	NTNC	30	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
150 NORTH ROAD		4			

Towns Served: EAST WINDSOR

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total	Lead and Coliform	Copper Rule	Asbestos Rule Tier	Stage WQP 2	DBPR
	UPSTREAM	WITHIN 5 SERVICE CON	A							
00700	ENTRY POINT	3	ENTRY POINT	A						
59018	WELL 2	2	WELL 2	A						
59028	HYDROSTATIC TANK									

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification:	SMALL WATER SYSTEM	Certification	Expiration
Operator Name	Operator Type	Certification(s)	
NIGRO, JR., VICTOR N.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2026
NIGRO, SCOTT A.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2028
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2026

Contact Information

Name	Organization	Job Title
East Windsor Commons, LLC		
Mailing Address Line One	Mailing Address Line Two	City
148 North Road		State
Business Phone	Extension	Zip Code
		East Windsor
		CT
		06088
Email Address		

Contact Role(s): Owner

Name	Organization	Job Title
Mr. Bilal Ali		
Mailing Address Line One	Mailing Address Line Two	City
148 North Road		State
Business Phone	Extension	Zip Code
860-992-5201		East Windsor
		CT
		06088
Email Address		
		alibilal72@yahoo.com

Contact Role(s): Administrative Contact, Legal Contact

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0473023	SOFIA'S PLAZAS II/III	NTNC	40	P	GW
Local Address (where applicable)	122 PROSPECT HILL ROAD	Service Connections	Residential	Commercial	Industrial
			1		Combined Agricultural

Towns Served: EAST WINDSOR

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

Asbestos (1094)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
Total Coliform (3100)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
Lead And Copper (PBCU)	5 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/25	6/1-9/30	Complete
	1/1/26 - 12/31/26	6/1-9/30	
	1/1/27 - 12/31/27	6/1-9/30	
Physical Parameters (PPS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: **ENTRY POINT** (WSF ID: 00700)

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
Pesticides, Herbicides and PCBs-Phase II (SOC2)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Pesticides, Herbicides and PCBs-Phase V (SOC5)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0473023	SOFIA'S PLAZAS II/III	NTNC	40	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
122 PROSPECT HILL ROAD	Connections		1		

Towns Served: EAST WINDSOR

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Pesticides, Herbicides and PCBs-Phase V (SOC5)		1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
		1/1/29 - 12/31/31		
Organic Chemicals (VOCS)			1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete	
	1/1/26 - 12/31/26			
	1/1/27 - 12/31/27			

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
COMPLETE INITIAL LSL INVENTORY	10/16/2024	
CROSS CONNECTION SURVEY REPORT	3/1/2026	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total	Lead and	Stage
					Coliform Rule	Copper Rule Tier	
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y	1	
		DOWNSTREAM	WITHIN 5 SERVICE CON	A			
		SP1	UNIT 1 - PLAZA II	A	Y	1	
		SP2	UNIT 2 - PLAZA II	A	Y	1	
		SP3	UNIT 7 - PLAZA II	A	Y	1	
		SP4	COT-BLDGIII	A	Y	1	
		SP5	MO-BLDGIII	A	Y	1	
00700	ENTRY POINT	UPSTREAM	WITHIN 5 SERVICE CON	A			
		3	ENTRY POINT	A			
10857	WELL #1	2	WELL #1	A			

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification:	SMALL WATER SYSTEM	Certification Expiration
Operator Name	Operator Type	Certification(s)
TARTSINIS, DESPINA C.	CHIEF OPERATOR	SMALL WATER SYSTEM OPERATOR CONDITIONAL
		6/30/2026

Contact Information

Name	Organization	Job Title
Ms. Despina C. Tartsinis	Sofia's Plazas	
Mailing Address Line One	Mailing Address Line Two	City
122 Prospect Hill Road	C/O Management Office	State
Business Phone	Fax	Zip Code
860-623-1095		East Windsor
		CT
		06088
Emergency Phone	Email Address	
860-559-3748	sofiasplazas@gmail.com	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification		Population	Owner Type	Primary Source
CT0473023	SOFIA'S PLAZAS II/III	NTNC		40	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
122 PROSPECT HILL ROAD			1			

Towns Served: EAST WINDSOR

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0470042	GROSZYK FARM WORKER HOUSING	NTNC	46	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
100 WAPPING ROAD					1

Towns Served: EAST WINDSOR

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

Asbestos (1094)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/33		
Total Coliform (3100)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25 Complete		
	10/1/25 - 12/31/25 Complete		
	4/1/26 - 6/30/26		
Lead And Copper (PBCU)	5 routine (RT) per six months		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/25 - 12/31/25 7/1-11/30 Complete		
	1/1/26 - 6/30/26 5/1-6/30		
	7/1/26 - 12/31/26 7/1-11/30		
Physical Parameters (PPS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25 Complete		
	10/1/25 - 12/31/25 10/1-11/30 Complete		
	4/1/26 - 6/30/26 5/1-6/30		

Water System Facility: **ENTRY POINT** (WSF ID: 00700)

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
ENTRY POINT (3)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25	10/1-11/30	Complete
	4/1/26 - 6/30/26	5/1-6/30	
Organic Chemicals (VOCS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
ENTRY POINT (3)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25	10/1-11/30	Complete
	4/1/26 - 6/30/26	5/1-6/30	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0470042	GROSZYK FARM WORKER HOUSING	NTNC	46	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
100 WAPPING ROAD					1

Towns Served: EAST WINDSOR

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule	Asbestos	Stage WQP 2 DBPR
					Rule Tier	WQD	DBPR	
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A				
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		GF1	KITCHEN SINK	A	Y	N		
		GF2	MENS BATH	A	Y	N		
		GF3	HAND SINK	A	Y	N		
		GF4	KITCHEN SLOP	A	Y	N		
		GF5	BATHROOM SLOP	A	Y	N		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
63090	WELL 1	2	WELL 1	A				

Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification:	DISTRIBUTION SYSTEM			Certification Expiration
Operator Name	Operator Type	Certification(s)		
NIGRO, JR., VICTOR N.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II		6/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS III		6/30/2026
NIGRO, SCOTT A.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I		6/30/2028
		WATER TREATMENT PLANT OPERATOR - CLASS II		6/30/2026

Contact Information

Name	Organization	Job Title		
Mr. Dana Groszyk	Groszyk Farm	Owner		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
60 Weymouth Road		Enfield	CT	06082
Business Phone	Extension	Fax	Mobile Phone	Email Address
				groszykfarms@sbcglobal.net

Contact Role(s): Administrative Contact, Owner

Name	Organization	Job Title		
Mr. Andre Groszyk	Groszyk Farm	Owner		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
100 Wapping Road		Broadbrook	CT	06016
Business Phone	Extension	Fax	Mobile Phone	Email Address
860-490-3684				groszykfarms@sbcglobal.net

Contact Role(s): Legal Contact

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0470042	GROSZYK FARM WORKER HOUSING			NTNC	46	P	GW
Local Address (where applicable)		Service	Residential	Commercial	Industrial	Combined	Agricultural
100 WAPPING ROAD		Connections				1	

Towns Served: EAST WINDSOR

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule