

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0680011	AQUARION-KENT	C	817	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural

Towns Served: KENT

**Monitoring Requirements**

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

<b>Chlorine Residual (1012)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
<b>Chlorine Residual (1012)</b>	<b>4 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	9/1/25 - 9/30/25		Complete
<b>Asbestos (1094)</b>	<b>2 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30		
<b>Total Haloacetic Acids (2456)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
59 NORTH MAIN ST. SS (02816)	1/1/25 - 12/31/25	9/8-9/14	Complete
	1/1/26 - 12/31/26	9/8-9/14	
	1/1/27 - 12/31/27	9/8-9/14	
<b>Total Trihalomethanes (2950)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
PATCO ROUTE 7 (02813)	1/1/25 - 12/31/25	9/8-9/14	Complete
	1/1/26 - 12/31/26	9/8-9/14	
	1/1/27 - 12/31/27	9/8-9/14	
<b>Total Coliform (3100)</b>	<b>3 repeat (RP) per period</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	9/17/25 - 9/22/25		Complete
<b>Total Coliform (3100)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0680011	AQUARION-KENT	C	817	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: KENT

**Monitoring Requirements**

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

<b>Total Coliform (3100)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
<b>Lead And Copper (PBCU)</b>	<b>10 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/27	6/1-9/30	
<b>Physical Parameters (PPS)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: **WELL #2 TP ENTRY POINT** (WSF ID: 00700)

<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL #2 TP (3)	1/1/17 - 12/31/25		Complete
<b>Uranium (4006)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL #2 TP (3)	1/1/17 - 12/31/25		Complete
<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL #2 TP (3)	1/1/17 - 12/31/25		Complete
<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL #2 TP (3)	1/1/25 - 12/31/27		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0680011	AQUARION-KENT	C	817	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: KENT

### Monitoring Requirements

Water System Facility: WELL #2 TP ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)				1 routine (RT) per year
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
EP - WELL #2 TP (3)	1/1/25 - 12/31/25		Complete	
	1/1/26 - 12/31/26			
	1/1/27 - 12/31/27			
Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)				1 routine (RT) per six years
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
EP - WELL #2 TP (3)	1/1/26 - 12/31/31			
Pesticides, Herbicides and PCBs-Phase II (SOC2)				1 routine (RT) per three years
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
EP - WELL #2 TP (3)	1/1/25 - 12/31/27			
Pesticides, Herbicides and PCBs-Phase V (SOC5)				1 routine (RT) per three years
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
EP - WELL #2 TP (3)	1/1/25 - 12/31/27			
Organic Chemicals (VOCS)				1 routine (RT) per year
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
EP - WELL #2 TP (3)	1/1/25 - 12/31/25		Complete	
	1/1/26 - 12/31/26			
	1/1/27 - 12/31/27			

Water System Facility: WELL #3 TP ENTRY POINT (WSF ID: 00701)

Inorganic Chemicals (IOCS)				1 routine (RT) per three years
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
EP - WELL #3 TP (3)	1/1/25 - 12/31/27			
Nitrate And Nitrite (NOX)				1 routine (RT) per year
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
EP - WELL #3 TP (3)	1/1/25 - 12/31/25		Complete	
	1/1/26 - 12/31/26			
	1/1/27 - 12/31/27			
Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)				1 routine (RT) per six years
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
EP - WELL #3 TP (3)	1/1/20 - 12/31/25		Complete	
	1/1/26 - 12/31/31			
Pesticides, Herbicides and PCBs-Phase II (SOC2)				1 routine (RT) per three years
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
EP - WELL #3 TP (3)	1/1/23 - 12/31/25		Complete	
	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			
Pesticides, Herbicides and PCBs-Phase V (SOC5)				1 routine (RT) per three years
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
EP - WELL #3 TP (3)	1/1/23 - 12/31/25		Complete	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0680011	AQUARION-KENT	C	817	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural

Towns Served: KENT

## Monitoring Requirements

Water System Facility: WELL #3 TP ENTRY POINT (WSF ID: 00701)

Pesticides, Herbicides and PCBs-Phase V (SOC5)		1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			
Organic Chemicals (VOCS)			1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
EP - WELL #3 TP (3)	1/1/25 - 12/31/25			Complete
	1/1/26 - 12/31/26			
	1/1/27 - 12/31/27			

Water System Facility: WELL #2 (WSF ID: 990)

E. Coli (3014)		1 triggered (TG) per period		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
WELL #2 (2)	9/16/25 - 9/22/25			Complete
E. Coli (3014)			1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
WELL #2 (2)	7/1/25 - 9/30/25			Complete
	10/1/25 - 12/31/25			Complete
	1/1/26 - 3/31/26			
	4/1/26 - 6/30/26			

Water System Facility: WELL #3 (WSF ID: 991)

E. Coli (3014)		1 triggered (TG) per period		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
WELL #3 (2)	9/16/25 - 9/22/25			Complete
E. Coli (3014)			1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
WELL #3 (2)	7/1/25 - 9/30/25			Complete
	10/1/25 - 12/31/25			Complete
	1/1/26 - 3/31/26			
	4/1/26 - 6/30/26			

## Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: WELL #2 TP ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2003	Compliance History: 8/1/2025 - 8/31/2025	Operating Limit	Monitoring
	Monitoring Period 9/1/2025 - 9/30/2025	Compliance Status:	Compliance Status:
	10/1/2025 - 10/31/2025		
	11/1/2025 - 11/30/2025		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0680011	AQUARION-KENT	C	817	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural

Towns Served: KENT

### Water System Facility: WELL #2 TP ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2003		Compliance History: Monitoring Period	Operating Limit Monitoring Compliance Status: Compliance Status:
12/1/2025 - 12/31/2025			

### Water System Facility: WELL #3 TP ENTRY POINT (WSFID: 00701)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2003		Compliance History: Monitoring Period	Operating Limit Monitoring Compliance Status: Compliance Status:
8/1/2025 - 8/31/2025			
9/1/2025 - 9/30/2025			
10/1/2025 - 10/31/2025			
11/1/2025 - 11/30/2025			
12/1/2025 - 12/31/2025			

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2025	
MAIL/HAND DELIVER NOTICE TO CONSUMERS	12/31/2025	
CERTIFY LEAD SL NOTIFICATION		7/1/2026

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
					Rule			
00600	DISTRIBUTION SYSTEM	02804	KENT TANKS SS	A	Y			
		02812	KENT FABRICS RT 7	A	Y			
		02813	PATCO ROUTE 7	A	Y			Y
		02815	KENT TANK SS	A	Y			
		02816	59 NORTH MAIN ST. SS	A				Y
		02816D	59 N MAIN ST SS - KE	A	Y			
		02816U	59 N MAIN ST SS - KE	A	Y			
		4	DISTRIBUTION SYSTEM	A	Y			
	DOWNSTREAM	WITHIN 5 SERVICE CON		A				
		PB5701	46 N MAIN ST. P.O. B	A		3		
		PB5704	92 N MAIN ST	A		3		
		PB5706	10 S MAIN KENT	A		3		
		PB5707	41 ELIZABETH STREET	A		3		
		PB5708	9 MAPLE ST EXT KENT	A		3		
		PB5709	43 MAPLE ST EXT KENT	A		3		
		PB5710	30 ELIZBETH KENT	A		3		
		PB5836	80 NO. MAIN ST. UNIT	A		N		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0680011	AQUARION-KENT	C	817	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
					360

Towns Served: KENT

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
					Rule			
		PB5966	4 BLUFF KENT	A		3		
		PB5967	6 BLUFF ST	A		3		
		PB5968	8 BLUFF KENT	A		3		
		PB5969	1 BRIDGE ST	A		3		
		PB5971	52 ELIZABETH ST	A		3		
		PB5972	14 JUDD AVE	A		3		
		PB5973	8 JUDD AVE	A		3		
		PB6347	19 MAPLE ST	A	Y	3		
		PB6348	27 ELIZABETH STREET	A	Y	3		
		PB6349	27 LANE STREET	A	Y	3		
		PB7042	23 LANE STREET	A		3		
		PB7043	8 ELIZABETH STREET	A		3		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	WELL #2 TP ENTRY POINT	3	EP - WELL #2 TP	A				
00701	WELL #3 TP ENTRY POINT	3	EP - WELL #3 TP	A				
1609	WELL #3 TREATMENT PLANT							
510	WELL #2 TREATMENT PLANT							
56640	CONCRETE ATMOSPHERIC STORAGE TANK							
990	WELL #2	2	WELL #2	A				
991	WELL #3	2	WELL #3	A				

## Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification:	DISTRIBUTION SYSTEM			Certification Expiration
Operator Name	Operator Type	Certification(s)		
PASSECK, PETER	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III		9/30/2028
		WATER TREATMENT PLANT OPERATOR - CLASS IV		6/30/2027
LAGO, ANTHONY V.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III		6/30/2028
		DISTRIBUTION SYSTEM OPERATOR - CLASS III		6/30/2028

Water System Facility: **WELL #2 TREATMENT PLANT (WSF ID: 510)**

Facility Classification:	CLASS 1 TREATMENT PLANT			Certification Expiration
Operator Name	Operator Type	Certification(s)		
COYLE, BRIAN	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III		12/31/2028
		DISTRIBUTION SYSTEM OPERATOR - CLASS III		6/30/2027
PASSECK, PETER	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV		6/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS III		9/30/2028
LAGO, ANTHONY V.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III		6/30/2028

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0680011	AQUARION-KENT	C	817	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
				360	

Towns Served: KENT

## Certified Operator Information

Water System Facility: WELL #2 TREATMENT PLANT (WSF ID: 510)

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2028
OSBORN, BRADLEY E.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2026
		WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2026
		WATER TREATMENT PLANT OPERATOR IN TRAINING	9/30/2026

Water System Facility: WELL #3 TREATMENT PLANT (WSF ID: 1609)

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
COYLE, BRIAN	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2027
		WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2028
PASSECK, PETER	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2028
LAGO, ANTHONY V.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2028
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2028
OSBORN, BRADLEY E.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	9/30/2026
		WATER TREATMENT PLANT OPERATOR IN TRAINING	9/30/2026
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2026

## Contact Information

Name	Organization	Job Title		
Mr. John P. Walsh	Aquarion Water Company	Vice President		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
835 Main Street	Mail Stop 700	Bridgeport	CT	06604
Business Phone	Extension	Fax	Mobile Phone	Email Address
203-337-5852		203-337-5938		781-413-6175 jwalsh@aquarionwater.com

Contact Role(s): Legal Contact

Name	Organization	Job Title		
Mr. Robert J. Ulrich	Aquarion Water Company of Ct	Vp-Supply & Utility		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
505 Huntington St.		Shelton	CT	06484
Business Phone	Extension	Fax	Mobile Phone	Email Address
203-926-4320		203-929-5297		203-395-3205 rulrich@aquarionwater.com

Contact Role(s): Administrative Contact

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT0680011</b>	<b>AQUARION-KENT</b>	<b>C</b>	<b>817</b>	<b>P</b>	<b>GW</b>
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural

Towns Served: KENT

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

*<http://www.ct.gov/dph/publicdrinkingwater>*

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0680021	KENT SCHOOL CORP (VALLEY CAMPUS)	C	722	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: KENT

## Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31		
<b>Total Coliform (3100)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
<b>Lead And Copper (PBCU)</b>	<b>10 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Physical Parameters (PPS)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		
	9/1/25 - 9/30/25		
	10/1/25 - 10/31/25		
	11/1/25 - 11/30/25		
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: **ENTRY POINT** (WSF ID: 00700)

<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0680021	KENT SCHOOL CORP (VALLEY CAMPUS)	C	722	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: KENT

## Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Uranium (4006)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
<b>Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/26		Complete
	1/1/27 - 12/31/29		

## Monthly Water System Facility (WSF) Level Monitoring Requirements

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0680021	KENT SCHOOL CORP (VALLEY CAMPUS)	C	722	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: KENT

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit		Samples Req/Month	
		Minimum:	6.4 PH	Daily	Monitoring
pH	Entry Point pH Monitoring (PHRD)				Compliance Status:
Start Date:	1/1/2003	Monitoring Period	Operating Limit	Monitoring	Compliance Status:
		8/1/2025 - 8/31/2025			
		9/1/2025 - 9/30/2025			
		10/1/2025 - 10/31/2025			
		11/1/2025 - 11/30/2025			
		12/1/2025 - 12/31/2025			

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT FISCAL AND ASSET MANAGEMENT CERT	1/1/2021	
RESPOND TO SANITARY SURVEY	2/4/2026	
CROSS CONNECTION SURVEY REPORT	3/1/2026	

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform		Lead and Copper Rule Tier		Asbestos	WQP 2 DBPR	Stage
				Status	Rule	Rule Tier	Asbestos			
00600	DISTRIBUTION SYSTEM	001	DINING HALL	A	Y		N			
		002	FIELD DORM MENS	A			N			
		003	CASE DORM STAFF BTH	A			N			
		004	ADMIN BLD MENS RM	A			N			
		005	S.H. KITCHEN 4 FL	A			N			
		006	M.D. 1ST SLOP	A			N			
		007	M.D.S. 1ST SLOP	A			N			
		008	N.D. 1ST SLOP	A			N			
		009	SCI LST MENS RM	A			N			
		010	FOLEY MENS ROOM	A			N			
00700	ENTRY POINT	4	GENERIC DISTRIBUTION	A		Y				
		DOWNSTREAM	WITHIN 5 SERVICE CON	A						
		UPSTREAM	WITHIN 5 SERVICE CON	A						
00700	ENTRY POINT	3	ENTRY POINT	A						
392	KENT SCHOOL TREATMENT PLANT									
45859	ATMOSPHERIC TANK 1									
45861	ATMOSPHERIC TANK 2									
45863	HYDROPNEUMATIC TANK									
992	WELL 2	2	WELL 2	A						
993	WELL 1	2	WELL 1	A						

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0680021	KENT SCHOOL CORP (VALLEY CAMPUS)	C	722	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		22	8		

Towns Served: KENT

## Certified Operator Information

Water System Facility: KENT SCHOOL TREATMENT PLANT (WSF ID: 392)

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
TOMLINSON, JONATHAN	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	9/30/2026
KNIFFEN, PETER	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	9/30/2026

## Contact Information

Name	Organization	Job Title		
Mr. Jonathan Tomlinson	Kent School Corporation	Chf Water Sys Opr		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
PO Box 2006		Kent	CT	06757
Business Phone	Extension	Fax	Mobile Phone	Email Address
860-927-6124				860-671-1477 tomlinson@kent-school.edu

Contact Role(s): **Administrative Contact**

Name	Organization	Job Title		
Mr. John Bergin	Kent School Corp.	Facilities Director		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
PO Box 2006		Kent	CT	06757
Business Phone	Extension	Fax	Mobile Phone	Email Address
860-927-6119				845-309-1574 berginj@kent-school.edu

Contact Role(s): **Legal Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

**If you have any questions, please contact the Drinking Water Section at (860) 509-7333.**

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0680031	THE MARVELWOOD SCHOOL	C	220	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
476 SKIFF MOUNTAIN RD	Connections	8	4		

Towns Served: KENT

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

<b>Chlorine Residual (1012)</b>	<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete	
	9/1/25 - 9/30/25		Complete	
	10/1/25 - 10/31/25		Complete	
	11/1/25 - 11/30/25		Complete	
	12/1/25 - 12/31/25		Complete	
<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31			
<b>Total Coliform (3100)</b>	<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete	
	9/1/25 - 9/30/25		Complete	
	10/1/25 - 10/31/25		Complete	
	11/1/25 - 11/30/25		Complete	
	12/1/25 - 12/31/25		Complete	
	1/1/26 - 1/31/26			
	2/1/26 - 2/28/26			
	3/1/26 - 3/31/26			
	4/1/26 - 4/30/26			
	5/1/26 - 5/31/26			
	6/1/26 - 6/30/26			
	7/1/26 - 7/31/26			
<b>Disinfectant Byproducts - TTHM &amp; HAA5 (DBP)</b>	<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
SCHOOL HOUSE BATH (MS007)	1/1/25 - 12/31/25	8/1-8/31	Complete	
	1/1/26 - 12/31/26	8/1-8/31		
	1/1/27 - 12/31/27	8/1-8/31		
<b>Lead And Copper (PBCU)</b>	<b>5 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/26	6/1-9/30		
	1/1/27 - 12/31/29	6/1-9/30		
<b>Physical Parameters (PPS)</b>	<b>1 routine (RT) per month</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete	
	9/1/25 - 9/30/25		Complete	
	10/1/25 - 10/31/25		Complete	
	11/1/25 - 11/30/25		Complete	
	12/1/25 - 12/31/25		Complete	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0680031	THE MARVELWOOD SCHOOL	C	220	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
476 SKIFF MOUNTAIN RD	Connections	8	4		Agricultural

Towns Served: KENT

**Monitoring Requirements**

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Physical Parameters (PPS)	1 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Net Gross Alpha (4000)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

Uranium (4006)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

Combined Radium-226/228 (4010)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	1 (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25	1/1/12/31	Waiver
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0680031	THE MARVELWOOD SCHOOL	C	220	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
476 SKIFF MOUNTAIN RD	Connections	8	4		

Towns Served: KENT

## Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			
Organic Chemicals (VOCS)			1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)	1/1/25 - 12/31/25			Complete
	1/1/26 - 12/31/26			
	1/1/27 - 12/31/27			

Water System Facility: WELL 4 (WSF ID: 129)

E. Coli (3014)		1 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
WELL 4 (2)	8/1/25 - 8/31/25			Complete
	9/1/25 - 9/30/25			Complete
	10/1/25 - 10/31/25			Complete
	11/1/25 - 11/30/25			Complete
	12/1/25 - 12/31/25			Complete
	1/1/26 - 1/31/26			Complete
	2/1/26 - 2/28/26			
	3/1/26 - 3/31/26			
	4/1/26 - 4/30/26			
	5/1/26 - 5/31/26			
	6/1/26 - 6/30/26			
	7/1/26 - 7/31/26			

Water System Facility: WELL 5 (WSF ID: 130)

E. Coli (3014)		1 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
WELL 5 (2)	8/1/25 - 8/31/25			Complete
	9/1/25 - 9/30/25			Complete
	10/1/25 - 10/31/25			Complete
	11/1/25 - 11/30/25			Complete
	12/1/25 - 12/31/25			Complete
	1/1/26 - 1/31/26			Complete
	2/1/26 - 2/28/26			
	3/1/26 - 3/31/26			
	4/1/26 - 4/30/26			
	5/1/26 - 5/31/26			
	6/1/26 - 6/30/26			
	7/1/26 - 7/31/26			

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0680031	THE MARVELWOOD SCHOOL	C	220	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
476 SKIFF MOUNTAIN RD	Connections	8	4		

Towns Served: KENT

### Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 1/1/2003		<b>Compliance History:</b>	<b>Monitoring</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2026	

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
					Rule			
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		MS002	SUMMIT DORM	A	Y	N		
		MS003	STERLING DORM	A	Y	N		
		MS004	LAKE DORM	A	Y	N		
		MS005	STAR DORM	A	Y	N		
		MS006	DINING HALL BATHROOM	A	Y	N		
		MS007	SCHOOL HOUSE BATH	A	Y	N	Y	Y
		MS008	GYM GIRLS BATH 1	A	Y	N		
		MS009	KITCHEN HANDWASH SIN	A	Y	N		
		MS010	KITCHEN PREP SINK 1	A	Y	N		
		MS011	KITCHEN PREP SINK 2	A	Y	N		
		MS012	BUSINESS/MED BUILDIN	A	Y	N		
		MS013	SCHOOL HOUSE F BATH	A	Y	N		
		MS014	SCHOOL HOUSE M BATH	A	Y	N		
		MS015	GYM GIRLS BATH 2	A	Y	N		
		MS016	GYM GIRLS LOCKER ROO	A	Y	N		
		MS017	PAC CTR BATH	A	Y	N		
		MS018	FACULTY HOUSE KITCH	A	Y	N		
		MS019	MAINTENANCE SINK	A	Y	N		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
		MS001	PUMP HOUSE	I				

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0680031	THE MARVELWOOD SCHOOL	C	220	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
476 SKIFF MOUNTAIN RD		8	4		

Towns Served: KENT

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule	Asbestos	Stage WQP 2 DBPR
					Rule Tier	WQD	DBPR	
129	WELL 4	2	WELL 4	A				
130	WELL 5	2	WELL 5	A				
51455	CONCRETE ATMOSPHERIC TANK							
566	WELL 4 & 5 TREATMENT STATION							
59004	PUMP STATION							

## Certified Operator Information

Water System Facility: WELL 4 & 5 TREATMENT STATION (WSF ID: 566)

Facility Classification:	CLASS 1 TREATMENT PLANT			Certification Expiration
Operator Name	Operator Type	Certification(s)		
BLACK, RON W.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2026	
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2026	
CROWNSHAW, MICHAEL L	ASSIGNED OPERATOR	SMALL WATER SYSTEM OPERATOR	3/31/2028	

## Contact Information

Name	Organization	Job Title		
Mr. David Fiorillo	Marvelwood School	Business Manager		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
476 Skiff Mountain Road		Kent	CT	06757
Business Phone	Extension	Fax	Mobile Phone	Email Address
860-927-0047		860-927-2012		david.fiorillo@marvelwood.org

Contact Role(s): Administrative Contact, Legal Contact, Owner

### Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0680082	SOUTH KENT SCHOOL	C	228	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
40 BULLS BRIDGE RD				36	

Towns Served: KENT

**Monitoring Requirements**

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

<b>Chlorine Residual (1012)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30		
<b>Total Haloacetic Acids (2456)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
GARF.UPST.DORM BATH (SKS004)	1/1/25 - 12/31/25	9/1-9/30	Complete
	1/1/26 - 12/31/26	9/1-9/30	
	1/1/27 - 12/31/27	9/1-9/30	
<b>Total Trihalomethanes (2950)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
FACULTY HOUSE #1 KITCHEN (SKS011)	1/1/25 - 12/31/25	9/1-9/30	Complete
	1/1/26 - 12/31/26	9/1-9/30	
	1/1/27 - 12/31/27	9/1-9/30	
<b>Total Coliform (3100)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
<b>Lead And Copper (PBCU)</b>	<b>5 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/26	6/1-9/30	Complete
	1/1/26 - 12/31/28	6/1-9/30	
	1/1/29 - 12/31/31	6/1-9/30	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0680082	SOUTH KENT SCHOOL	C	228	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
40 BULLS BRIDGE RD					36

Towns Served: KENT

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

Physical Parameters (PPS)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points		8/1/25 - 8/31/25		Complete
		9/1/25 - 9/30/25		Complete
		10/1/25 - 10/31/25		Complete
		11/1/25 - 11/30/25		Complete
		12/1/25 - 12/31/25		Complete
		1/1/26 - 1/31/26		
		2/1/26 - 2/28/26		
		3/1/26 - 3/31/26		
		4/1/26 - 4/30/26		
		5/1/26 - 5/31/26		
		6/1/26 - 6/30/26		
		7/1/26 - 7/31/26		

Water System Facility: **ENTRY POINT** (WSF ID: 00700)

Net Gross Alpha (4000)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)		1/1/23 - 12/31/25		Complete
		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		

  

Uranium (4006)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)		1/1/23 - 12/31/25		Complete
		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		

Combined Radium-226/228 (4010)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)		1/1/23 - 12/31/25		Complete
		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		

Inorganic Chemicals (IOCS)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)		1/1/23 - 12/31/25		Complete
		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		

Nitrate And Nitrite (NOX)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)		1/1/25 - 12/31/25		Complete
		1/1/26 - 12/31/26		
		1/1/27 - 12/31/27		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0680082	SOUTH KENT SCHOOL	C	228	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
40 BULLS BRIDGE RD					36

Towns Served: KENT

## Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Pesticides, Herbicides and PCBs-Phase II (SOC2)		1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)	1/1/24 - 12/31/26			
	1/1/27 - 12/31/29			
Pesticides, Herbicides and PCBs-Phase V (SOC5)			1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)	1/1/24 - 12/31/26			
	1/1/27 - 12/31/29			
Organic Chemicals (VOCS)			1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete	
	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			

## Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit		Samples Req/Month	
		Minimum:	0.45 MG/L	Continuous	
Chlorine	Entry Point RDC (EPRD)				
Start Date: 12/1/2014		Compliance History:	Operating Limit	Monitoring	
		Monitoring Period	Compliance Status:	Compliance Status:	
		8/1/2025 - 8/31/2025	Y		
		9/1/2025 - 9/30/2025	Y		
		10/1/2025 - 10/31/2025	Y		
		11/1/2025 - 11/30/2025	Y		
		12/1/2025 - 12/31/2025	Y		

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT FISCAL AND ASSET MANAGEMENT CERT	1/1/2021	
CROSS CONNECTION SURVEY REPORT	3/1/2026	

Water System Facility and Sampling Point Inventory						
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y	
		DOWNSTREAM	WITHIN 5 SERVICE CON	A		
		SKS001	MN.BLD.SM KITCH.SINK	A	Y	
		SKS002	MN.BLD.DISH WASH SK.	A	Y	
		SKS003	MN.BLD.BASEM.BATH S.	A	Y	
		SKS004	GARF.UPST.DORM BATH	A	Y	2
		SKS005	BRINGH.Lobby MENS R.	A	Y	Y

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0680082	SOUTH KENT SCHOOL	C	228	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
40 BULLS BRIDGE RD					36

Towns Served: KENT

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
					Y	2	N	Y
	SKS006	MCCOUN ART RM.SINK	A	Y	2			
	SKS007	2ND FL.MAINT.SH.SINK	A	Y				
	SKS008	BARTL.DORM BATH SINK	A		2			
	SKS009	GILDER HOUSE	A		2			
	SKS010	WOODWD.D.3RD.FL.BAT H	A		2			
	SKS011	FACULTY HOUSE #1 KIT	A					
	UPSTREAM	WITHIN 5 SERVICE CON	A					
00700	ENTRY POINT	3	ENTRY POINT	A				
37258	ATMOSPHERIC TANK							
502	WELL #1 TREATMENT PLANT							
995	WELL #1	2	WELL #1	A				

## Certified Operator Information

Water System Facility: WELL #1 TREATMENT PLANT (WSF ID: 502)

Facility Classification:	CLASS 1 TREATMENT PLANT	Certification Expiration
Operator Name	Operator Type	Certification(s)

CARLSON, BRUCE	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	6/30/2028
----------------	----------------	--	-----------

## Contact Information

Name	Organization	Job Title
South Kent School Corporation		
Mailing Address Line One	Mailing Address Line Two	City State Zip Code
40 Bulls Bridge Rd		South Kent CT 06785

Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address

Contact Role(s):	Owner	Organization	Job Title
Name	Mr. Brian Sullivan	South Kent School	Head of School
Mailing Address Line One	Mailing Address Line Two	City	State Zip Code
40 Bulls Bridge Rd		South Kent	CT 06785
Business Phone	Extension	Fax	Mobile Phone
860-927-3539	209		

Contact Role(s):	Legal Contact	Sullivanb@southkentschool.org

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT0680082</b>	<b>SOUTH KENT SCHOOL</b>	C	228	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
40 BULLS BRIDGE RD				36	

Towns Served: KENT

Name		Organization			Job Title		
<b>Ms. Luz McCarthy</b>		South Kent School			Cfo_Business Office		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
40 Bulls Bridge Rd					South Kent	CT	06785
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-927-3539	215			860-795-6889	mccarthy@southkentschool.org		

Contact Role(s): **Legal Contact**

Name		Organization			Job Title		
<b>Mr. Jeff Galusha</b>		South Kent School			Plant Manager		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
40 Bulls Bridge Rd					South Kent	CT	06785
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-927-3539	233		860-248-0548		galushaj@southkentschool.org		

Contact Role(s): **Administrative Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

**If you have any questions, please contact the Drinking Water Section at (860) 509-7333.**

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0681061	KENT SCHOOL (MAINTENANCE WELL)	C	30	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: KENT

### Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31		
<b>Total Coliform (3100)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
<b>Lead And Copper (PBCU)</b>	<b>5 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/25	6/1-9/30	Complete
	1/1/26 - 12/31/28	6/1-9/30	
	1/1/29 - 12/31/31	6/1-9/30	
<b>Physical Parameters (PPS)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0681061	KENT SCHOOL (MAINTENANCE WELL)	C	30	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: KENT

### Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Uranium (4006)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
<b>Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT FISCAL AND ASSET MANAGEMENT CERT	1/1/2021	
RESPOND TO SANITARY SURVEY	2/4/2026	
CROSS CONNECTION SURVEY REPORT	3/1/2030	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0681061	KENT SCHOOL (MAINTENANCE WELL)	C	30	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		9	2		

Towns Served: KENT

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total	Lead and Coliform	Copper	Asbestos	WQP 2	Stage DBPR
					Rule	Rule Tier				
00600	DISTRIBUTION SYSTEM	001	KITCHENET	A	Y	N				
		002	MENS ROOM	A		N				
		003	WOMENS ROOM	A		N				
		004	SLOP SINK	A		N				
		005	TOMS SHOP	A		N				
		4	GENERIC DISTRIBUTION	A	Y					
	DOWNSTREAM	WITHIN 5 SERVICE CON		A						
	UPSTREAM	WITHIN 5 SERVICE CON		A						
00700	ENTRY POINT	3	ENTRY POINT	A						
1674	WELL 3	2	WELL 3	A						

## Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

Facility Classification:	SMALL WATER SYSTEM		Certification Expiration
Operator Name	Operator Type	Certification(s)	Certification Expiration
TOMLINSON, JONATHAN	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	9/30/2026
KNIFFEN, PETER	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	9/30/2026

## Contact Information

Name	Organization	Job Title
Mr. Jonathan Tomlinson	Kent School Corporation	Chf Water Sys Opr
Mailing Address Line One	Mailing Address Line Two	City
PO Box 2006		State
Business Phone	Extension	Zip Code
860-927-6124		
Mobile Phone	Emergency Phone	Email Address
	860-671-1477	tomlinsonj@kent-school.edu

Contact Role(s): **Administrative Contact**

Name	Organization	Job Title
Mr. John Bergin	Kent School Corp.	Facilities Director
Mailing Address Line One	Mailing Address Line Two	City
PO Box 2006		State
Business Phone	Extension	Zip Code
860-927-6119		
Mobile Phone	Emergency Phone	Email Address
	845-309-1574	berginj@kent-school.edu

Contact Role(s): **Legal Contact**

Please note the following:					
1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.					
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.					
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this					

**If you have any questions, please contact the Drinking Water Section at (860) 509-7333.**

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0688011	BROOKWOODS II	C	120	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
433 KENT CORNWALL RD	Connections	30			

Towns Served: KENT

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30		
<b>Total Coliform (3100)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
<b>Lead And Copper (PBCU)</b>	<b>5 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/25	6/1-9/30	Complete
	1/1/26 - 12/31/28	6/1-9/30	
	1/1/29 - 12/31/31	6/1-9/30	
<b>Physical Parameters (PPS)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: **ENTRY POINT** (WSF ID: 00700)

<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0688011	BROOKWOODS II	C	120	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
433 KENT CORNWALL RD	Connections	30			

Towns Served: KENT

## Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Uranium (4006)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
<b>Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION EXEMPTION		3/1/2029

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0688011	BROOKWOODS II	C	120	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
433 KENT CORNWALL RD	Connections	30			

Towns Served: KENT

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
					Y	1	1	1
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		BRO-1	HOUSE 30-SINK	A	Y			
		BRO-2	DISTRIBUTION SAMPLE	A		1		
		BRO-3	HOUSE 3-SINK	A		1		
		BRO-4	HOUSE 12-SINK	A		1		
		BRO-5	HOUSE 16-SINK	A		1		
		BRO-6	HOUSE 20-SINK	A		1		
		BRO-7	HOUSE 23-SINK	A		1		
00700	ENTRY POINT	DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
1672	WELL 1	3	ENTRY POINT	A				
1673	WELL 2	2	WELL 1	A				
44913	ATMOSPHERIC TANK	2	WELL 2	A				

## Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

**Facility Classification:** SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
TOMASCAK, THOMAS S.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I WATER TREATMENT PLANT OPERATOR - CLASS I	12/31/2027 6/30/2028

## Contact Information

Name	Organization	Job Title
Mr. Stephen P. Allison	Brookwoods II Association	Administrator
Mailing Address Line One	Mailing Address Line Two	City
433 Kent Cornwall Rd	Unit #20	State
Business Phone	Extension	Zip Code
203-770-2458		
Mobile Phone	Emergency Phone	Email Address
	203-417-2126	water.contact.brookwoods@gmail.com

Contact Role(s): **Administrative Contact, Legal Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

**If you have any questions, please contact the Drinking Water Section at (860) 509-7333.**

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

**NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.**