

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830011	MIDDLETOWN WATER DEPARTMENT	C	41,019	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		10,469			532

Towns Served: CROMWELL, MIDDLEFIELD, MIDDLETOWN

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

Chlorine Residual (1012)	50 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
Asbestos (1094)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/21 - 12/31/29		
Total Coliform (3100)	50 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
Disinfectant Byproducts - TTHM & HAAs (DBP)	4 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
MID - WESTFIELD FIRE (70023)	7/1/25 - 9/30/25	7/1-7/31	Complete
	10/1/25 - 12/31/25	10/1-10/31	Complete
	1/1/26 - 3/31/26	1/1-1/31	
	4/1/26 - 6/30/26	4/1-4/30	
MID - AEROSPACE TECH (70025)	7/1/25 - 9/30/25	7/1-7/31	Complete
	10/1/25 - 12/31/25	10/1-10/31	Complete
	1/1/26 - 3/31/26	1/1-1/31	
	4/1/26 - 6/30/26	4/1-4/30	
MID - TOWER ROAD SS (70027)	7/1/25 - 9/30/25	7/1-7/31	Complete
	10/1/25 - 12/31/25	10/1-10/31	Complete
	1/1/26 - 3/31/26	1/1-1/31	
	4/1/26 - 6/30/26	4/1-4/30	
909 MIDDLE STREET (70122)	7/1/25 - 9/30/25	7/1-7/31	Complete
	10/1/25 - 12/31/25	10/1-10/31	Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830011	MIDDLETOWN WATER DEPARTMENT	C	41,019	L	SW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
	Connections	10,469			532

Towns Served: CROMWELL, MIDDLEFIELD, MIDDLETOWN

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Disinfectant Byproducts - TTHM & HAA5 (DBP)			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	1/1/26 - 3/31/26	1/1-1/31	
	4/1/26 - 6/30/26	4/1-4/30	
Lead And Copper (PBCU)			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/27	6/1-9/30	
Physical Parameters (PPS)			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: CHARLES B. BACON WATER TREATMENT PLANT (WSF ID: 161)

Total Organic Carbon (2920)			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP -CHARLES B. BACON (70201)	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
Net Gross Alpha (4000)			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP -CHARLES B. BACON (70201)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0830011	MIDDLETOWN WATER DEPARTMENT			C	41,019	L	SW
Local Address (where applicable)		Service	Residential	Commercial	Industrial	Combined	Agricultural
		Connections	10,469			532	

Towns Served: CROMWELL, MIDDLEFIELD, MIDDLETON

Monitoring Requirements

Water System Facility: CHARLES B. BACON WATER TREATMENT PLANT (WSF ID: 161)

Net Gross Alpha (4000)		1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
		1/1/29 - 12/31/31		
Uranium (4006)			1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP -CHARLES B. BACON (70201)		1/1/23 - 12/31/25		Complete
		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		
Combined Radium-226/228 (4010)			1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP -CHARLES B. BACON (70201)		1/1/23 - 12/31/25		Complete
		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		
Gross Beta Particle Activity (4100)			1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP -CHARLES B. BACON (70201)		1/1/23 - 12/31/25		Complete
		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		
Man-Made Beta Particle & Photon Emitters (4101)			1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP -CHARLES B. BACON (70201)		1/1/23 - 12/31/25		Complete
		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		
Tritium (4102)			1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP -CHARLES B. BACON (70201)		1/1/23 - 12/31/25		Complete
		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		
Strontium-90 (4174)			1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP -CHARLES B. BACON (70201)		1/1/23 - 12/31/25		Complete
		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		
Inorganic Chemicals (IOCS)			1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP -CHARLES B. BACON (70201)		1/1/25 - 12/31/25		Complete
		1/1/26 - 12/31/26		
		1/1/27 - 12/31/27		
Nitrate And Nitrite (NOX)			1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>		<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830011	MIDDLETOWN WATER DEPARTMENT	C	41,019	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		10,469			532

Towns Served: CROMWELL, MIDDLEFIELD, MIDDLETOWN

Monitoring Requirements

Water System Facility: CHARLES B. BACON WATER TREATMENT PLANT (WSF ID: 161)

1 routine (RT) per year			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP -CHARLES B. BACON (70201)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
2 routine (RT) per three years			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP -CHARLES B. BACON (70201)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
1 routine (RT) per year			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP -CHARLES B. BACON (70201)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Water System Facility: JOHN S. ROTH WATER TREATMENT PLANT (WSF ID: 162)

1 routine (RT) per three years			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - JOHN S. ROTH TP (70202)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
1 routine (RT) per three years			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - JOHN S. ROTH TP (70202)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
1 routine (RT) per three years			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - JOHN S. ROTH TP (70202)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
1 routine (RT) per three years			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - JOHN S. ROTH TP (70202)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
1 routine (RT) per year			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - JOHN S. ROTH TP (70202)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830011	MIDDLETOWN WATER DEPARTMENT	C	41,019	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		10,469			532

Towns Served: CROMWELL, MIDDLEFIELD, MIDDLETOWN

Monitoring Requirements

Water System Facility: JOHN S. ROTH WATER TREATMENT PLANT (WSF ID: 162)

Nitrate And Nitrite (NOX)		1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
		1/1/27 - 12/31/27		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)			2 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
EP - JOHN S. ROTH TP (70202)		1/1/23 - 12/31/25		
		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		
Organic Chemicals (VOCS)			1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
EP - JOHN S. ROTH TP (70202)		1/1/25 - 12/31/25		
		1/1/26 - 12/31/26		
		1/1/27 - 12/31/27		

Water System Facility: MOUNT HIGBY RESERVOIR #1 (WSF ID: 2148)

Total Alkalinity (1927)		1 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
MOUNT HIGBY RES (70301)	8/1/25 - 8/31/25		Complete	
	9/1/25 - 9/30/25		Complete	
	10/1/25 - 10/31/25		Complete	
	11/1/25 - 11/30/25		Complete	
	12/1/25 - 12/31/25		Complete	
	1/1/26 - 1/31/26			
	2/1/26 - 2/28/26			
	3/1/26 - 3/31/26			
	4/1/26 - 4/30/26			
	5/1/26 - 5/31/26			
	6/1/26 - 6/30/26			
	7/1/26 - 7/31/26			
Total Organic Carbon (2920)		1 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
MOUNT HIGBY RES (70301)	8/1/25 - 8/31/25		Complete	
	9/1/25 - 9/30/25		Complete	
	10/1/25 - 10/31/25		Complete	
	11/1/25 - 11/30/25		Complete	
	12/1/25 - 12/31/25		Complete	
	1/1/26 - 1/31/26			
	2/1/26 - 2/28/26			
	3/1/26 - 3/31/26			
	4/1/26 - 4/30/26			
	5/1/26 - 5/31/26			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830011	MIDDLETOWN WATER DEPARTMENT	C	41,019	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		10,469			532

Towns Served: CROMWELL, MIDDLEFIELD, MIDDLETOWN

Monitoring Requirements

Water System Facility: MOUNT HIGBY RESERVOIR #1 (WSF ID: 2148)

Total Organic Carbon (2920)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
Total Coliform (3100)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
MOUNT HIGBY RES (70301)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
Surface Water Inorganic Chemicals (RIOC)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
MOUNT HIGBY RES (70301)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
Surface Water Color and Turbidity (RPPS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
MOUNT HIGBY RES (70301)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
Surface Water Pesticides (RSOC)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
MOUNT HIGBY RES (70301)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: CHARLES B. BACON WATER TREATMENT PLANT (WSFID: 161)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2002			
	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025	Y	
	10/1/2025 - 10/31/2025	Y	
	11/1/2025 - 11/30/2025	Y	
	12/1/2025 - 12/31/2025	Y	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830011	MIDDLETOWN WATER DEPARTMENT	C	41,019	L	SW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
	Connections	10,469			532

Towns Served: CROMWELL, MIDDLEFIELD, MIDDLETOWN

Water System Facility: **CHARLES B. BACON WATER TREATMENT PLANT (WSFID: 161)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily	
Start Date: 1/1/2023		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily	
Start Date: 1/1/2023		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025	Y	
		9/1/2025 - 9/30/2025	Y	
		10/1/2025 - 10/31/2025	Y	
		11/1/2025 - 11/30/2025	Y	
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.8 PH	Daily	
Start Date: 10/1/2005		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.3 MG/L	2	
Start Date: 10/1/2005		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186	
Start Date: 1/1/2002		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025	Y	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830011	MIDDLETOWN WATER DEPARTMENT	C	41,019	L	SW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
	Connections	10,469			532

Towns Served: CROMWELL, MIDDLEFIELD, MIDDLETOWN

Water System Facility: **CHARLES B. BACON WATER TREATMENT PLANT (WSFID: 161)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
Start Date: 1/1/2002		Compliance History:	
		Monitoring Period	Operating Limit
		9/1/2025 - 9/30/2025	Y
		10/1/2025 - 10/31/2025	Y
		11/1/2025 - 11/30/2025	Y
		12/1/2025 - 12/31/2025	Y
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
Start Date: 1/1/2002		Compliance History:	
		Monitoring Period	Operating Limit
		8/1/2025 - 8/31/2025	Y
		9/1/2025 - 9/30/2025	Y
		10/1/2025 - 10/31/2025	Y
		11/1/2025 - 11/30/2025	Y
		12/1/2025 - 12/31/2025	Y

Water System Facility: **JOHN S. ROTH WATER TREATMENT PLANT (WSFID: 162)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.45 MG/L	Continuous
Start Date: 6/1/2010		Compliance History:	
		Monitoring Period	Operating Limit
		8/1/2025 - 8/31/2025	Y
		9/1/2025 - 9/30/2025	Y
		10/1/2025 - 10/31/2025	Y
		11/1/2025 - 11/30/2025	Y
		12/1/2025 - 12/31/2025	Y
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 1/1/2023		Compliance History:	
		Monitoring Period	Operating Limit
		8/1/2025 - 8/31/2025	Y
		9/1/2025 - 9/30/2025	Y
		10/1/2025 - 10/31/2025	Y
		11/1/2025 - 11/30/2025	Y
		12/1/2025 - 12/31/2025	Y

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 1/1/2023		Compliance History:	
		Monitoring Period	Operating Limit
		8/1/2025 - 8/31/2025	Y

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830011	MIDDLETOWN WATER DEPARTMENT	C	41,019	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		10,469			532

Towns Served: CROMWELL, MIDDLEFIELD, MIDDLETOWN

Water System Facility: JOHN S. ROTH WATER TREATMENT PLANT (WSFID: 162)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 1/1/2023		Compliance History:	
		Monitoring Period	Operating Limit
		9/1/2025 - 9/30/2025	Y
		10/1/2025 - 10/31/2025	Y
		11/1/2025 - 11/30/2025	Y
		12/1/2025 - 12/31/2025	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.8 PH	Daily
Start Date: 10/1/2005		Compliance History:	
		Monitoring Period	Operating Limit
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.3 MG/L	2
Start Date: 10/1/2005		Compliance History:	
		Monitoring Period	Operating Limit
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
MAIL/HAND DELIVER NOTICE TO CONSUMERS	12/31/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2026	
CERTIFY LEAD SL NOTIFICATION	7/1/2026	

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total		Lead and Coliform		Stage
				Status	Rule	Copper Rule Tier	Asbestos	
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			Y
		70023	MID - WESTFIELD FIRE	A	Y			
		70023A	WSTFLD UPSTREAM	A	Y			
		70023B	WSTFLD DNSTREAM	A	Y			
		70025	MID - AEROSPACE TECH	A	Y			
		70025A	AEROSP UPSTREAM	A	Y			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830011	MIDDLETOWN WATER DEPARTMENT	C	41,019	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		10,469			532

Towns Served: CROMWELL, MIDDLEFIELD, MIDDLETOWN

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
					Y	Y	Y	Y
	70025B	AEROSP DNSTREAM	A	Y				
	70027	MID - TOWER ROAD SS	A	Y				
	70027A	TOWER RD UPSTREAM	A	Y				
	70027B	TOWER RD DNSTREAM	A	Y				
	70101	10 WESLYAN HILL	A	Y				
	70101A	WELSLAN UPSTREAM	A	Y				
	70101B	WELSLAN DNSTREAM	A	Y				
	70102	299 WADSWORTH	A	Y				
	70102A	299 WADSWORTH UPST	A	Y				
	70102B	299 WADSWORTH DNST	A	Y				
	70103	70 MAYNARD ST.	A	Y				
	70103A	70 MAYNARD UPSTREAM	A	Y				
	70103B	70 MAYNARD DNSTREAM	A	Y				
	70104	99 SPRUCE ST.	A	Y				
	70104A	99 SPRUCE UPSTREAM	A	Y				
	70104B	99 SPRUCE DNSTREAM	A	Y				
	70105	KAPLAN ST.	A	Y				
	70105A	KAPLIN UPSTREAM	A	Y				
	70105B	KAPLIN DNSTREAM	A	Y				
	70106	207 WESTFIELD ST	A	Y				
	70106A	207 WSTFLD UPSTREAM	A	Y				
	70106B	207 WSTFLD DNSTREAM	A	Y				
	70107	222 MAIN ST.	A	Y				
	70107A	222 MAIN UPSTREAM	A	Y				
	70107B	222 MAIN DNSTREAM	A	Y				
	70108	533 MAIN ST.	A	Y				
	70108A	533 MAIN UPSTREAM	A	Y				
	70108B	533 MAIN DNSTREAM	A	Y				
	70109	169 CROSS ST.	A	Y				
	70109A	169 CROSS UPSTERAM	A	Y				
	70109B	169 CROSS DNSTERAM	A	Y				
	70110	100 RIVER RD.	A	Y				
	70111	222 COUNTRY CLUB	I	Y				
	70112	245 DEKOVEN DR.	A	Y				
	70112A	245 DEKOVEN UPSTREAM	A	Y				
	70112B	245 DEKOVEN DNSTREAM	A	Y				
	70114	245 MAIN, CROMWE	A	Y				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830011	MIDDLETOWN WATER DEPARTMENT	C	41,019	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
		10,469			532

Towns Served: CROMWELL, MIDDLEFIELD, MIDDLETOWN

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
					Y	Y	Y	Y
		70114A	245 MAIN CW UPSTREAM	A	Y			
		70114B	245 MAIN CW DNSTREAM	A	Y			
		70115	15 IND. PARK PLAC	A	Y			
		70115A	MID - GENERAL LOCATI	A	Y			
		70115A ADJ	MID - GENERAL LOCATI	A	Y			
		70115B	MID - GENERAL LOCATI	A	Y			
		70115B ADJ	MID - GENERAL LOCATI	A	Y			
		70116	919 MIDDLE ST.	I	Y			Y
		70117	218 SMITH	I	Y			Y
		70118	60 DANIELS	A	Y			
		70118A	60 DANIELS UPSTREAM	A	Y			
		70118B	60 DANIELS DNSTREAM	A	Y			
		70119	445 RANDOLH	A	Y			
		70119A	MID- 445 RANDOLPH AD	A	Y			
		70119B	MID- 445 RANDOLPH AD	A	Y			
		70120	217 SMITH STREET	A	Y			Y
		70120A	217 SMITH UPSTREAM	A	Y			
		70120B	217 SMITH DNSTREAM	A	Y			
		70122	909 MIDDLE STREET	A	Y			Y
		70122A	909 MIDDLE UPSTREAM	A	Y			
		70122B	909 MIDDLE DNSTREAM	A	Y			
		70123	300 COUNTRY CLUB RD	A	Y			
		70123A	300 CC RD UPSTREAM	A	Y			
		70123B	300 CC RD DNSTREAM	A	Y			
		70124	34 EAST MAIN ST	A	Y			
		70124A	34 E MAIN UPSTREAM	A	Y			
		70124B	34 E MAIN DNSTREAM	A	Y			
		70125	34 EAST MAIN ST	A	Y			
		ADDITIONAL1	390 RIDGE RD.	A	Y			
		ADDITIONAL2	370 HUNTING HILL AVE	A	Y			
		ADDITIONAL3	311 HUNTING HILL AVE	A	Y			
		ADDITIONAL4	66 SPRING ST.	A	Y			
		ADDITIONAL5	1 WILDERMANS WAY	A	Y			
		CL001	66 VALLEY DR.	A		1		
		CL0013	-FEE MID PB/CU CL013	I	Y			
		CL002	107 RIDGE RD.	A		3		
		CL003	122 WESTWOOD LN	A		1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830011	MIDDLETOWN WATER DEPARTMENT	C	41,019	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
		10,469			532

Towns Served: CROMWELL, MIDDLEFIELD, MIDDLETOWN

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
	CL004	17 COLES		A		1		
	CL005	46 TAVERN CIRCLE		A		1		
	CL006	256 BRUSH HILL		A		1		
	CL007	45 SNOW RIDGE		A		3		
	CL008	27 VALLEY DR.		A		1		
	CL009	311 LONG LANE		A		1		
	CL010	30 ANDERSON RD.		A		3		
	CL011	22 PHEDON PARKWAY		A		3		
	CL012	250 HUNTING HILL		A		3		
	CL013	288 PROUT HILL RD		A		1		
	CL014	9 MCCORMICK LN.		A		1		
	CL015	151 WESTWOOD LN		A		1		
	CL016	260 MERIDEN RD.		A		3		
	CL017	100 HIGH VIEW TER		A		3		
	CL018	112 MCCORMICK		A		3		
	CL019	500 HUNTING HILL		A		3		
	CL020	650 RIDGE RD.		A		3		
	CL021	10 LITTLE RIVER		A		3		
	CL022	207 CIMARRON RD.		A		1		
	CL023	95 BAILEY RD		A		3		
	CL024	43 HUNTING HILL AVE		A		3		
	CL025	8 HEMLOCK PL		A		3		
	CL026	11 LITTLE RIVER		A		3		
	CL027	70 BIRCHWOOD DR		A		3		
	CL028	85 SISK ST.		A		3		
	CL029	266 PROUT HILL RD		A		3		
	CL030	230 RIDGEWOOD RD		A		3		
	CL031	66 VALLEY DR.		A		1		
	CL032	107 RIDGE RD.		A		3		
	CL033	122 WESTWOOD LN		A		1		
	CL034	17 COLES		A		1		
	CL035	46 TAVERN CIRCLE		A		1		
	CL036	256 BRUSH HILL		A		1		
	CL037	45 SNOW RIDGE		A		3		
	CL038	27 VALLEY DR.		A		1		
	CL039	311 LONG LANE		A		1		
	CL040	30 ANDERSON RD.		A		3		
	CL041	22 PHEDON PARKWAY		A		3		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830011	MIDDLETOWN WATER DEPARTMENT	C	41,019	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
		10,469			532

Towns Served: CROMWELL, MIDDLEFIELD, MIDDLETOWN

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
	CL042	250 HUNTING HILL		A		3		
	CL043	288 PROUT HILL RD		A		1		
	CL044	9 MCCORMICK LN.		A		1		
	CL045	151 WESTWOOD LN		A		1		
	CL046	260 MERIDEN RD.		A		3		
	CL047	100 HIGH VIEW TER		A		3		
	CL048	112 MCCORMICK		A		3		
	CL049	500 HUNTING HILL		A		3		
	CL050	650 RIDGE RD.		A		3		
	CL051	10 LITTLE RIVER		A		3		
	CL052	207 CIMARRON RD.		A		1		
	CL053	95 BAILEY RD		A		3		
	CL054	43 HUNTING HILL AVE		A		3		
	CL055	8 HEMLOCK PL		A		3		
	CL056	11 LITTLE RIVER		A		3		
	CL057	70 BIRCHWOOD DR		A		3		
	CL058	85 SISK ST.		A		3		
	CL059	266 PROUT HILL RD		A		3		
	CL060	230 RIDGEWOOD RD		A		3		
	CL061	11 MAPLE PL.		A				
	CL062	94 CHESTNUT ST		A				
	CL063	177 RIDGE RD.		A				
	CL064	24 SHELLEY DR.		A				
	CL065	45 GOWINN RD.		A				
	CL066	67 MARGARITE RD		A				
	CL067	65 MURRAY ST.		A				
	CL068	36 DEWEY ST.		A				
	CL069	11 CRESCENT DR.		A				
	CL070	36 SCENIC VIEW DR		A				
	CL071	1 RED BLUE RD.		A				
	CL072	26 HOTCHKISS RD.		A				
	CL073	10 STONYCREST ST.		A				
	CL074	5 FITH AVE.		A				
	CL075	3 MCKENZIE CIRCLE		A				
	CL076	30 SILVER ST.		A				
	CL077	49 LEE ST.		A				
	CL078	101 OLD MILL RD.		A				
	CL079	65 BARBARA RD.		A				

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830011	MIDDLETOWN WATER DEPARTMENT	C	41,019	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
		10,469			532

Towns Served: CROMWELL, MIDDLEFIELD, MIDDLETOWN

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
	CL080	265 BARBARA RD.		A				
	CL081	75 WESTMONT DR		A				
	CL082	68 MILITARY RD.		A				
	CL083	95 SOUTH FRONT ST		A				
	CL084	55 DOROTHY DR.		A				
	CL085	390 PINE ST.		A				
	CL086	188 FOWLER AVE		A				
	CL087	38 MEADOWOOD DR		A				
	CL088	34 PLUMB RD.		A				
	CL089	20 NORTH VIEW DR		A				
	CL090	3 OAK RIDGE DR.		A				
	DOWNSTREAM	WITHIN 5 SERVICE CON		A				
	MLC001	497 MILLBROOK RD		A		1		
	MLC002	367 WESTFIELD ST		A		1		
	MLC003	21 ROUND HILL RD		A		1		
	MLC004	60 KNOX BLVD		A		1		
	MLC005	85 GOODMAN DR		A		1		
	MLC006	165 HIGHMEADOW LANE		A		1		
	MLC007	103 GOODMAN DR		A		1		
	MLC008	23 MINER ST		A		1		
	MLC009	150 KNOX BLVD		A		1		
	MLC010	349 CAMP ST		A		1		
	MLC011	897 EAST ST		A		1		
	MLC012	111 DORTHY DR		A		1		
	MLC013	157 TIMBER RIDGE RD		A		1		
	MLC014	38 BRECHLIN DR		A		1		
	MLC015	121 KNBOX BLVD		A		1		
	MLC016	264 GEORGE STREET		A		1		
	MLC017	114 HAWKS NEST CIRCL		A		1		
	MLC018	151 CIMARRON RD		A		1		
	MLC019	198 CIMARRON RD		A		1		
	MLC020	103 HERITAGE BLVD		A		1		
	MLC021	160 CIMARRON RD		A		1		
	MLC022	60 MINER BROOK DR		A		1		
	MLC023	188 TIMBER RIDGE RD		A		1		
	MLC024	559 EAST ST		A		1		
	MLC025	92 CIMARRON RD		A		1		
	MLC026	31 GOODMAN DR		A		1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830011	MIDDLETOWN WATER DEPARTMENT	C	41,019	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
		10,469			532

Towns Served: CROMWELL, MIDDLEFIELD, MIDDLETOWN

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
	MLC027	352 POPLAR RD		A		1		
	MLC028	160 HAWS NEST CIRCLE		A		1		
	MLC029	90 KNOX BLVD		A		1		
	MLC030	3 BLUEHILL RD		A		1		
	MLC031	270 TIMBER RIDGE RD		A		1		
	MLC032	286 GEORGE ST		A		1		
	MLC033	677 PINE ST		A		1		
	MLC034	18 LINDSEY RD		A		1		
	MLC035	77 HIGHMEADOW LANE		A		1		
	MLC036	315 EAST RIDGE RD		A		1		
	MLC037	90 HAWKS NEST CIRCLE		A		1		
	MLC038	321 EAST RIDGE RD		A		1		
	MLC039	238 TIMBER RIDGE RD		A		1		
	MLC040	25 KNOX BLVD		A		1		
	MLC041	510 BUTTERNUT ST		A		1		
	MLC042	4 BLUE ACRES RD		A		1		
	MLC043	6 BLUE ACRES RD		A		1		
	MLC044	567 RIDGEWOOD RD		A		1		
	MLC045	44 CHIMNEY HILL		A		1		
	MLC046	25 CHIMNEY HILL		A		1		
	MLC047	6 HAWKS NEST CIRCLE		A		1		
	MLC048	49 CHIMNEY HILL		A		1		
	MLC049	241 BLUE RD		A		1		
	MLC050	70 SPRING BROOK DR.		A		1		
	MLC051	244 MIDDLEFIELD ST		A		1		
	MLC052	619 RANDOLPH RD		A		1		
	MLC053	23 HAWKS NEST CIRCLE		A		1		
	MLC054	208 HIGHMEADOW LN		A		1		
	MLC055	417 BALLFALL RD		A		1		
	MLC056	198 POPLAR RD		A		1		
	MLC057	2 SAND HILL RD		A		1		
	MLC058	85 KNOX BLVD		A		1		
	MLC059	30 LORELEI CIRCLE		A		1		
	MLC060	76 LINDSEY RD		A		1		
	MLC061	270 TIMBER RIDGE RD		A		1		
	MLC062	248 TIMBER RIDGE RD		A		1		
	MLC063	53 HENDLEY ST		A		1		
	MLC064	227 TIMBER RIDGE RD		A		1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830011	MIDDLETOWN WATER DEPARTMENT	C	41,019	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
		10,469			532

Towns Served: CROMWELL, MIDDLEFIELD, MIDDLETON

Water System Facility and Sampling Point Inventory							
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos WQP 2 DBPR Stage
	MLC065	675 PINE ST		A		1	
	MLC066	45 LEDGEBROOK LANE		A		1	
	MLC067	53 HAWKS NEST CIRCLE		A		1	
	MLC068	310 TIMBER RIDGE RD		A		1	
	MLC069	223 JULIA TERR		A		1	
	MLC070	188 CIMARRON RD		A		1	
	MLC071	451 BARTHOLOMEW RD		A		1	
	MLC072	275 BLUE RD		A		1	
	MLC073	490 BALLFALL RD		A		1	
	MLC074	11 HERITAGE BLVD		A		1	
	MLC075	315 TIMBER RIDGE RD		A		1	
	MLC076	55 MCGRATH DR		A		1	
	MLC077	110 HILLSIDE AVE		A		1	
	MLC078	3 BLUE ACRE RD		A		1	
	MLC079	138 RESERVIOR RD		A		1	
	MLC080	124 HIGHMEADOW LANE		A		1	
	MLC081	144 CIMARRON RD		A		1	
	MLC082	208 TIMBER RIDGE RD		A		1	
	MLC083	66 LINDSEY RD		A		1	
	MLC084	70 HIGHMEADOW LANE		A		1	
	MLC085	1 BLUE ACRE RD		A		1	
	MLC086	322 POPLAR RD		A		1	
	MLC087	65 HERITAGE BLVD		A		1	
	MLC088	282 BLUE RD		A		1	
	MLC089	49 LORELEI CIR		A		1	
	MLC090	178 TIMBER RIDGE RD		A		1	
	MLC091	128 NEW FIELD ST.		A		N	
	MLC092	56 RAPALLO AVE		A		N	
	MLC093	122-130 NEWFIELD ST		A		N	
	MLC094	113-115 GROVE ST		A		N	
	MLC095	29 STACK ST		A		N	
	MLC096	275 RIDGE RD		A		N	
	MLC097	124 NEWFIELD ST		A		N	
	MLC098	130 NEWFIELD ST		A		N	
	UPSTREAM	WITHIN 5 SERVICE CON		A			
00700	CHARLES B. BACON WTP ENTRY POINT	3	EP-CHARLES B. BACON	A			
00701	JOHN S. ROTH WTP ENTRY POINT	3	EP- JOHN S. ROTH WTP	A			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830011	MIDDLETOWN WATER DEPARTMENT	C	41,019	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		10,469			532

Towns Served: CROMWELL, MIDDLEFIELD, MIDDLETOWN

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule	Asbestos	Stage WQP 2 DBPR
1217	JOHN S ROTH WELL #1	2	JOHN S ROTH WELL #1	A				
1218	JOHN S ROTH WELL #2A	2	JOHN S ROTH WELL #2A	A				
1219	JOHN S ROTH WELL #3	2	JOHN S ROTH WELL #3	A				
1220	JOHN S ROTH WELL #4A	2	JOHN S ROTH WELL #4A	A				
1221	JOHN S ROTH WELL #5	2	JOHN S ROTH WELL #5	A				
1222	JOHN S ROTH WELL #6	2	JOHN S ROTH WELL #6	A				
1223	JOHN S ROTH WELL #7	2	JOHN S ROTH WELL #7	A				
1224	JOHN S ROTH WELL #8	2	JOHN S ROTH WELL #8	A				
1225	JOHN S ROTH WELL #9	2	JOHN S ROTH WELL #9	A				
1226	JOHN S ROTH WELL #10	2	JOHN S ROTH WELL #10	A				
161	CHARLES B. BACON WATER TREATMENT PLANT	70201	EP -CHARLES B. BACON	A				
162	JOHN S. ROTH WATER TREATMENT PLANT	70202	EP - JOHN S. ROTH TP	A				
2148	MOUNT HIGBY RESERVOIR #1	70301	MOUNT HIGBY RES	A				
2149	JOHN S ROTH WELLFIELD COMBINED	70302	INF - JOHN S ROTH TP	A				
2155	ADDER RESERVOIR	1	ADDER RESERVOIR	A				
49146	LONG HILL TANK							
49148	LONG HILL PUMP STATION							
49150	WHITE ROAD STORAGE TANK							
49152	POPLAR ROAD PUMP STATION							
49154	RANDOLPH ROAD BOOSTER PUMP STATION							
49158	LAUREL BROOK PUMP STATION							
51946	CHARLES B. BACON CLEARWELL							
51948	JOHN ROTH CLEARWELL							
51950	MOUNT HIGHBY PUMP STATION							
51952	JOHN ROTH PUMP STATION							
52349	MOUNT HIGBY RESERVOIR #2	1	MH RESERVOIR #2	A				
52351	MOUNT HIGBY RESERVOIR #3	1	MH RESERVOIR #3	A				
52353	CHARLES B. BACON WTP INTAKE							
55711	WASHINGTON STREET PUMP STATION							
62543	CHERRY HILL STORAGE TANK							
62545	LONG HILL PUMP STATION							

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830011	MIDDLETOWN WATER DEPARTMENT	C	41,019	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		10,469			532

Towns Served: CROMWELL, MIDDLEFIELD, MIDDLETON

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: CLASS 2 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
DARLEY, DEVIN J.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	3/31/2026
TREVISAN, MICHAEL D.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	3/31/2026
GIULIANO, JUSTIN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2026

Water System Facility: **CHARLES B. BACON WATER TREATMENT PLANT (WSF ID: 161)**

Facility Classification: CLASS 4 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
RADOMSKI, FRANK	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2026
RADZIEWICZ, JAMES	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2028
		DISTRIBUTION SYSTEM OPERATOR IN TRAINING	6/30/2028
MICCIULLA, SEBASTIANO	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2028
TALAMONA, MICHAEL J.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2028
		DISTRIBUTION SYSTEM OPERATOR IN TRAINING	6/30/2026

Water System Facility: **JOHN S. ROTH WATER TREATMENT PLANT (WSF ID: 162)**

Facility Classification: CLASS 4 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
RADOMSKI, FRANK	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2026
RADZIEWICZ, JAMES	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2028
		DISTRIBUTION SYSTEM OPERATOR IN TRAINING	6/30/2028
MICCIULLA, SEBASTIANO	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2028
TALAMONA, MICHAEL J.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2028
		DISTRIBUTION SYSTEM OPERATOR IN TRAINING	6/30/2026

Contact Information

Name		Organization		Job Title		
Mr. Joseph Fazzino		Middletown Water And Sewer		Acting Director		
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
82 Berlin St				Middletown	CT	06457
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-638-3500		860-343-8091		860-250-0943	joe.fazzino@MiddletownCT.gov	

Contact Role(s): **Administrative Contact, Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830021	CONNECTICUT VALLEY HOSPITAL	C	2,928	S	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
SILVER STREET	70				

Towns Served: MIDDLETOWN

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Chlorine Residual (1012)	3 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		Complete
Asbestos (1094)	1 routine (RT) per nine years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/21 - 12/31/29		Complete
Total Haloacetic Acids (2456)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WHITING FORENSIC (CVH08WF)	7/1/25 - 9/30/25	8/1-8/31	Complete
	10/1/25 - 12/31/25	11/1-11/30	Complete
	1/1/26 - 3/31/26	2/1-2/28	
	4/1/26 - 6/30/26	5/1-5/31	
Total Trihalomethanes (2950)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
RIVERVIEW KITCHEN (CVH20RS)	7/1/25 - 9/30/25	8/1-8/31	Complete
	10/1/25 - 12/31/25	11/1-11/30	Complete
	1/1/26 - 3/31/26	2/1-2/28	
	4/1/26 - 6/30/26	5/1-5/31	
Total Coliform (3100)	3 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		Complete
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
Lead And Copper (PBCU)	10 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/27	6/1-9/30	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830021	CONNECTICUT VALLEY HOSPITAL	C	2,928	S	SW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
SILVER STREET	Connections	70			

Towns Served: MIDDLETOWN

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

Physical Parameters (PPS)	3 routine (RT) per month
<i>Sampling Point (Sampling Point ID)</i>	
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25
	9/1/25 - 9/30/25
	10/1/25 - 10/31/25
	11/1/25 - 11/30/25
	12/1/25 - 12/31/25
	1/1/26 - 1/31/26
	2/1/26 - 2/28/26
	3/1/26 - 3/31/26
	4/1/26 - 4/30/26
	5/1/26 - 5/31/26
	6/1/26 - 6/30/26
	7/1/26 - 7/31/26

Water System Facility: **CVH WTP ENTRY POINT** (WSF ID: 00700)

Dibromochloropropane (DBCP) (2931)	1 routine (RT) per quarter
<i>Sampling Point (Sampling Point ID)</i>	
CVH WTP ENTRY POINT (3)	7/1/25 - 9/30/25
	10/1/25 - 12/31/25
	1/1/26 - 3/31/26
	4/1/26 - 6/30/26
Net Gross Alpha (4000)	1 routine (RT) per nine years
<i>Sampling Point (Sampling Point ID)</i>	
CVH WTP ENTRY POINT (3)	1/1/17 - 12/31/25
	1/1/26 - 12/31/34

Uranium (4006)	1 routine (RT) per nine years
<i>Sampling Point (Sampling Point ID)</i>	
CVH WTP ENTRY POINT (3)	1/1/17 - 12/31/25
	1/1/26 - 12/31/34

Combined Radium-226/228 (4010)	1 routine (RT) per nine years
<i>Sampling Point (Sampling Point ID)</i>	
CVH WTP ENTRY POINT (3)	1/1/17 - 12/31/25
	1/1/26 - 12/31/34

Inorganic Chemicals (IOCS)	1 routine (RT) per year
<i>Sampling Point (Sampling Point ID)</i>	
CVH WTP ENTRY POINT (3)	1/1/25 - 12/31/25
	1/1/26 - 12/31/26
	1/1/27 - 12/31/27

Nitrate And Nitrite (NOX)	1 routine (RT) per year
<i>Sampling Point (Sampling Point ID)</i>	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830021	CONNECTICUT VALLEY HOSPITAL	C	2,928	S	SW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
SILVER STREET	Connections	70			

Towns Served: MIDDLETOWN

Monitoring Requirements

Water System Facility: CVH WTP ENTRY POINT (WSF ID: 00700)

1 routine (RT) per year			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
CVH WTP ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
1 routine (RT) per three years			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
CVH WTP ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
1 routine (RT) per three years			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
CVH WTP ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
1 routine (RT) per year			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
CVH WTP ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Water System Facility: CVH WATER TREATMENT PLANT (WSF ID: 164)

1 routine (RT) per month			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
CFE - CVH TP (5)	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		Complete
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: CVH RESERVOIRS #3 & #4 (WSF ID: 2062)

1 routine (RT) per month			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
RESERVOIR (1)	8/1/25 - 8/31/25		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830021	CONNECTICUT VALLEY HOSPITAL	C	2,928	S	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
SILVER STREET	70				

Towns Served: MIDDLETOWN

Monitoring Requirements

Water System Facility: CVH RESERVOIRS #3 & #4 (WSF ID: 2062)

Total Alkalinity (1927)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		Complete
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
Total Organic Carbon (2920)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RESERVOIR (1)	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		Complete
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
Total Coliform (3100)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RESERVOIR (1)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
Surface Water Inorganic Chemicals (RIOC)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RESERVOIR (1)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
Surface Water Color and Turbidity (RPPS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830021	CONNECTICUT VALLEY HOSPITAL	C	2,928	S	SW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
SILVER STREET	Connections	70			

Towns Served: MIDDLETOWN

Monitoring Requirements

Water System Facility: CVH RESERVOIRS #3 & #4 (WSF ID: 2062)

Surface Water Color and Turbidity (RPPS)		1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)		Monitoring Period	Collection Period	Compliance Status
RESERVOIR (1)		7/1/25 - 9/30/25		Complete
		10/1/25 - 12/31/25		Complete
		1/1/26 - 3/31/26		
		4/1/26 - 6/30/26		

Surface Water Pesticides (RSOC)		1 routine (RT) per year		
Sampling Point (Sampling Point ID)		Monitoring Period	Collection Period	Compliance Status
RESERVOIR (1)		1/1/25 - 12/31/25		Complete
		1/1/26 - 12/31/26		
		1/1/27 - 12/31/27		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: CVH WTP ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 7/1/2003		Compliance History:	Operating Limit
		Monitoring Period	Monitoring
		8/1/2025 - 8/31/2025	Compliance Status:
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 1/1/2023		Compliance History:	Operating Limit
		Monitoring Period	Monitoring
		8/1/2025 - 8/31/2025	Compliance Status:
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 1/1/2023		Compliance History:	Operating Limit
		Monitoring Period	Monitoring
		8/1/2025 - 8/31/2025	Compliance Status:
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830021	CONNECTICUT VALLEY HOSPITAL	C	2,928	S	SW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
SILVER STREET	Connections	70			

Towns Served: MIDDLETOWN

Water System Facility: CVH WTP ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 1/1/2023		Compliance History:	Operating Limit
		Monitoring Period	Monitoring
		12/1/2025 - 12/31/2025	Compliance Status:
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.8 PH	Daily
Start Date: 7/1/2003		Compliance History:	Operating Limit
		Monitoring Period	Monitoring
		8/1/2025 - 8/31/2025	Compliance Status:
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.3 MG/L	2
Start Date: 7/1/2003		Compliance History:	Operating Limit
		Monitoring Period	Monitoring
		8/1/2025 - 8/31/2025	Compliance Status:
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

Water System Facility: CVH WATER TREATMENT PLANT (WSFID: 164)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2002		Compliance History:	Operating Limit
		Monitoring Period	Monitoring
		8/1/2025 - 8/31/2025	Compliance Status:
		9/1/2025 - 9/30/2025	Y
		10/1/2025 - 10/31/2025	Y
		11/1/2025 - 11/30/2025	Y
		12/1/2025 - 12/31/2025	Y
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
Start Date: 1/1/2002		Compliance History:	Operating Limit
		Monitoring Period	Monitoring
		8/1/2025 - 8/31/2025	Compliance Status:
		9/1/2025 - 9/30/2025	Y
		10/1/2025 - 10/31/2025	Y
		11/1/2025 - 11/30/2025	Y

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830021	CONNECTICUT VALLEY HOSPITAL	C	2,928	S	SW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
SILVER STREET	Connections	70			

Towns Served: MIDDLETOWN

Water System Facility: CVH WATER TREATMENT PLANT (WSFID: 164)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
Start Date:	1/1/2002	Compliance History: Monitoring Period	Operating Limit Monitoring Compliance Status: Compliance Status:
		12/1/2025 - 12/31/2025	Y
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
Start Date:	1/1/2002	Compliance History: Monitoring Period	Operating Limit Monitoring Compliance Status: Compliance Status:
		8/1/2025 - 8/31/2025	Y
		9/1/2025 - 9/30/2025	Y
		10/1/2025 - 10/31/2025	Y
		11/1/2025 - 11/30/2025	Y
		12/1/2025 - 12/31/2025	Y

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2026	

Water System Facility and Sampling Point Inventory							
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y		
		CVH01BH	BATTELL HALL	A	Y	N	
		CVH02RV	RIVERVIEW BLDG#8	A	Y		
		CVH03MH	MERRITT HALL	A	Y	N	
		CVH04JS	CJTS	A			
		CVH05RH	RUSSELL HALL	A		N	
		CVH06EC	EDDY CENTER	A		N	
		CVH07CG	COTTAGE #7	I			
		CVH08WF	WHITING FORENSIC	A		N	Y
		CVH09DC	CHILD DAY CARE	I			Y
		CVH10DH	DUTCHER HALL	A		N	
		CVH11SH	SHEW HALL	A		N	
		CVH12CB	COTTER BUILDING	A		N	
		CVH13SP	SHEPHERD HOME	I			
		CVH14SC	SUPT. COTTAGE	A		N	
		CVH15GO	GROUNDS OFFICE	A		N	
		CVH16ON	COTTAGE #16	A		N	
		CVH17WH	WOODWARD HALL	A		N	
		CVH18DT	DUTTON HOME	A		N	
		CVH19QW	RIVERVIEW BLDG#4	A		N	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0830021	CONNECTICUT VALLEY HOSPITAL	C	2,928	S	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
SILVER STREET	70				

Towns Served: MIDDLETOWN

Water System Facility and Sampling Point Inventory							
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos WQP 2 DBPR
					Stage	Stage	Stage
		CVH20RS	RIVERVIEW KITCHEN	A		N	Y
		CVH21MA	COTTAGE #31	A		N	
		CVH22BE	COTTAGE #32	A		N	
		DOWNSTREAM	WITHIN 5 SERVICE CON	A			
		UPSTREAM	WITHIN 5 SERVICE CON	A			
00700	CVH WTP ENTRY POINT	3	CVH WTP ENTRY POINT	A			
164	CVH WATER TREATMENT PLANT	5	CFE - CVH TP	A			
2061	CVH RESERVOIR #2	1	RESERVOIR	A			
2062	CVH RESERVOIRS #3 & #4	1	RESERVOIR	A			
2063	CVH RESERVOIR #5	1	RESERVOIR	A			
2064	CVH RESERVOIR #6	1	RESERVOIR	A			
30044	CVH RESERVOIRS #3 & #4						
49793	CVH TREATMENT PLANT STORAGE TANK						

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: CLASS 1 DISTRIBUTION SYSTEM			Certification Expiration
Operator Name	Operator Type	Certification(s)	Certification Expiration
MROZOWSKI, JOSEPH	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2026 6/30/2028
BROWN, RICHARD M.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2026

Water System Facility: **CVH WATER TREATMENT PLANT (WSF ID: 164)**

Facility Classification: CLASS 3 TREATMENT PLANT			Certification Expiration
Operator Name	Operator Type	Certification(s)	Certification Expiration
MROZOWSKI, JOSEPH	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2026 6/30/2028
BROWN, RICHARD M.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2026

Contact Information

Name	Organization	Job Title
Ms. Lakisha Hyatt	Connecticut Valley Hospital	Ceo
Mailing Address Line One	Mailing Address Line Two	City
1000 Silver Street	Page Hall - 3Rd Floor	State
Business Phone	Mobile Phone	Zip Code
860-262-6110	Emergency Phone	
	860-418-7000	lakisha.hyatt@ct.gov

Contact Role(s): **Administrative Contact, Legal Contact**

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name				Classification	Population	Owner Type	Primary Source
CT0830021	CONNECTICUT VALLEY HOSPITAL				C	2,928	S	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
SILVER STREET			70					
Towns Served: MIDDLETOWN								
Name			Organization			Job Title		
Ms. Nancy Navarretta			Dmhas			Acting Commissioner		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code	
410 Capitol Avenue		PO Box 341431			Hartford	CT	06134	
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-418-6952				860-418-7000	nancy.navarretta@ct.gov			

Contact Role(s): **Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule