

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0880011	CTWC - NAUGATUCK REGION-CENTRAL SYSTEM	C	22,735	P	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					10,281

Towns Served: BEACON FALLS, NAUGATUCK, PROSPECT, WATERBURY

**Monitoring Requirements**

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

<b>Chlorine Residual (1012)</b>	<b>25 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
<b>Chlorine Residual (1012)</b>	<b>30 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/21 - 12/31/29		
<b>Total Coliform (3100)</b>	<b>25 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
<b>Disinfectant Byproducts - TTHM &amp; HAA5 (DBP)</b>	<b>4 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
NAUGATUCK POLICE DEPT (2061)	7/1/25 - 9/30/25	8/1-8/31	Complete
	10/1/25 - 12/31/25	11/1-11/30	Complete
	1/1/26 - 3/31/26	2/1-2/28	
	4/1/26 - 6/30/26	5/1-5/31	
2714 SOUTH MAIN (2150)	7/1/25 - 9/30/25	8/1-8/31	Complete
	10/1/25 - 12/31/25	11/1-11/30	Complete
	1/1/26 - 3/31/26	2/1-2/28	
	4/1/26 - 6/30/26	5/1-5/31	
65 TUCKER HILL RD (2156)	7/1/25 - 9/30/25	8/1-8/31	Complete
	10/1/25 - 12/31/25	11/1-11/30	Complete
	1/1/26 - 3/31/26	2/1-2/28	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT0880011</b>	<b>CTWC - NAUGATUCK REGION-CENTRAL SYSTEM</b>	C	22,735	P	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

**Towns Served:** BEACON FALLS, NAUGATUCK, PROSPECT, WATERBURY

## Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

## Disinfectant Byproducts - TTHM & HAA5 (DBP)

## 4 routine (RT) per quarter

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	4/1/26 - 6/30/26	5/1-5/31	
MIDDLEBURY EDGE (2158)	7/1/25 - 9/30/25	8/1-8/31	Complete
	10/1/25 - 12/31/25	11/1-11/30	Complete
	1/1/26 - 3/31/26	2/1-2/28	
	4/1/26 - 6/30/26	5/1-5/31	

## Lead And Copper (PBCU)

### **30 routine (RT) per three years**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/27	6/1-9/30	

## Physical Parameters (PPS)

**25 routine (RT) per month**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: STEWART WTP ENTRY POINT (WSF ID: 00700)

## Net Gross Alpha (4000)

### **1 routine (RT) per three years**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
STEWART ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

## Uranium (4006)

### 1 routine (BT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
STEWART ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

Combined Radium-226/228 (4010)

## 1 routine (RT) per three years

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
STEWART ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

**NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0880011	CTWC - NAUGATUCK REGION-CENTRAL SYSTEM	C	22,735	P	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
					10,281

Towns Served: BEACON FALLS, NAUGATUCK, PROSPECT, WATERBURY

### Monitoring Requirements

Water System Facility: STEWART WTP ENTRY POINT (WSF ID: 00700)

Inorganic Chemicals (IOCS)				1 routine (RT) per year
Sampling Point (Sampling Point ID)		Monitoring Period	Collection Period	Compliance Status
STEWART ENTRY POINT (3)		1/1/25 - 12/31/25		Complete
		1/1/26 - 12/31/26		
		1/1/27 - 12/31/27		
Nitrate And Nitrite (NOX)				1 routine (RT) per year
Sampling Point (Sampling Point ID)		Monitoring Period	Collection Period	Compliance Status
STEWART ENTRY POINT (3)		1/1/25 - 12/31/25		Complete
		1/1/26 - 12/31/26		
		1/1/27 - 12/31/27		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)				2 routine (RT) per three years
Sampling Point (Sampling Point ID)		Monitoring Period	Collection Period	Compliance Status
STEWART ENTRY POINT (3)		1/1/23 - 12/31/25		Complete
		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		
Organic Chemicals (VOCS)				1 routine (RT) per year
Sampling Point (Sampling Point ID)		Monitoring Period	Collection Period	Compliance Status
STEWART ENTRY POINT (3)		1/1/25 - 12/31/25		Complete
		1/1/26 - 12/31/26		
		1/1/27 - 12/31/27		
Water System Facility: INDIAN FIELD WELLFIELD ENTRY POINT (WSF ID: 00701)				
Net Gross Alpha (4000)				1 routine (RT) per three years
Sampling Point (Sampling Point ID)		Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)		1/1/23 - 12/31/25		Out of Service
		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		
Uranium (4006)				1 routine (RT) per three years
Sampling Point (Sampling Point ID)		Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)		1/1/23 - 12/31/25		Out of Service
		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		
Combined Radium-226/228 (4010)				1 routine (RT) per three years
Sampling Point (Sampling Point ID)		Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)		1/1/23 - 12/31/25		Out of Service
		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		
Inorganic Chemicals (IOCS)				1 routine (RT) per three years
Sampling Point (Sampling Point ID)		Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)		1/1/24 - 12/31/26		
		1/1/27 - 12/31/29		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0880011	CTWC - NAUGATUCK REGION-CENTRAL SYSTEM	C	22,735	P	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural

Towns Served: BEACON FALLS, NAUGATUCK, PROSPECT, WATERBURY

**Monitoring Requirements**

Water System Facility: INDIAN FIELD WELLFIELD ENTRY POINT (WSF ID: 00701)

<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/25		Out of Service
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
<b>Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)</b>	<b>2 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Out of Service
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/27		

Water System Facility: MARKS BROOK WELLFIELD ENTRY POINT (WSF ID: 00702)

<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	7/1/25 - 9/30/25		Out of Service
	10/1/25 - 12/31/25		Out of Service
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
<b>Uranium (4006)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	7/1/25 - 9/30/25		Out of Service
	10/1/25 - 12/31/25		Out of Service
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	7/1/25 - 9/30/25		Out of Service
	10/1/25 - 12/31/25		Out of Service
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/27		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/25		Out of Service
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0880011	CTWC - NAUGATUCK REGION-CENTRAL SYSTEM	C	22,735	P	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural

Towns Served: BEACON FALLS, NAUGATUCK, PROSPECT, WATERBURY

## Monitoring Requirements

Water System Facility: MARKS BROOK WELLFIELD ENTRY POINT (WSF ID: 00702)

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		2 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)	1/1/23 - 12/31/25			Out of Service
	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			

Organic Chemicals (VOCS)		1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)	1/1/25 - 12/31/27			

Water System Facility: INDIAN FIELDS WELL #1 (WSF ID: 1344)

E. Coli (3014)		1 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
INDIAN FIELDS WELL #1 (2)	8/1/25 - 8/31/25			Out of Service
	9/1/25 - 9/30/25			Out of Service
	10/1/25 - 10/31/25			Out of Service
	11/1/25 - 11/30/25			Out of Service
	12/1/25 - 12/31/25			Out of Service
	1/1/26 - 1/31/26			
	2/1/26 - 2/28/26			
	3/1/26 - 3/31/26			
	4/1/26 - 4/30/26			
	5/1/26 - 5/31/26			
	6/1/26 - 6/30/26			
	7/1/26 - 7/31/26			

Water System Facility: INDIAN FIELDS WELL #2 (WSF ID: 1345)

E. Coli (3014)		1 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
INDIAN FIELDS WELL #2 (2)	8/1/25 - 8/31/25			Out of Service
	9/1/25 - 9/30/25			Out of Service
	10/1/25 - 10/31/25			Out of Service
	11/1/25 - 11/30/25			Out of Service
	12/1/25 - 12/31/25			Out of Service
	1/1/26 - 1/31/26			
	2/1/26 - 2/28/26			
	3/1/26 - 3/31/26			
	4/1/26 - 4/30/26			
	5/1/26 - 5/31/26			
	6/1/26 - 6/30/26			
	7/1/26 - 7/31/26			

Water System Facility: MARKS BROOK WELL #1 (WSF ID: 1372)

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT0880011</b>	<b>CTWC - NAUGATUCK REGION-CENTRAL SYSTEM</b>	<b>C</b>	<b>22,735</b>	<b>P</b>	<b>SW</b>
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural

Towns Served: BEACON FALLS, NAUGATUCK, PROSPECT, WATERBURY

**Monitoring Requirements**

Water System Facility: **MARKS BROOK WELL #1 (WSF ID: 1372)**

<b>1 routine (RT) per month</b>			
<b>Sampling Point (Sampling Point ID)</b>	<b>Monitoring Period</b>	<b>Collection Period</b>	<b>Compliance Status</b>
MARKS BROOK WELL #1 (2)	8/1/25 - 8/31/25		Out of Service
	9/1/25 - 9/30/25		Out of Service
	10/1/25 - 10/31/25		Out of Service
	11/1/25 - 11/30/25		Out of Service
	12/1/25 - 12/31/25		Out of Service
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: **MARKS BROOK WELL #2 (WSF ID: 1373)**

<b>1 routine (RT) per month</b>			
<b>Sampling Point (Sampling Point ID)</b>	<b>Monitoring Period</b>	<b>Collection Period</b>	<b>Compliance Status</b>
MARKS BROOK WELL #2 (2)	8/1/25 - 8/31/25		Out of Service
	9/1/25 - 9/30/25		Out of Service
	10/1/25 - 10/31/25		Out of Service
	11/1/25 - 11/30/25		Out of Service
	12/1/25 - 12/31/25		Out of Service
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: **STEWART WATER TREATMENT PLANT (WSF ID: 172)**

<b>1 routine (RT) per month</b>			
<b>Sampling Point (Sampling Point ID)</b>	<b>Monitoring Period</b>	<b>Collection Period</b>	<b>Compliance Status</b>
EP - STEWART TP (5)	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		Complete
	2/1/26 - 2/28/26		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0880011	CTWC - NAUGATUCK REGION-CENTRAL SYSTEM	C	22,735	P	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural

Towns Served: BEACON FALLS, NAUGATUCK, PROSPECT, WATERBURY

**Monitoring Requirements**

Water System Facility: STEWART WATER TREATMENT PLANT (WSF ID: 172)

Total Organic Carbon (2920)	1 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: STRATSVILLE RESERVOIR (WSF ID: 2095)

Total Alkalinity (1927)	1 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
STRAITSVILLE RESERVOIR (1)	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		Complete
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Total Organic Carbon (2920)	1 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
STRAITSVILLE RESERVOIR (1)	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		Complete
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Total Coliform (3100)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
STRAITSVILLE RESERVOIR (1)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0880011	CTWC - NAUGATUCK REGION-CENTRAL SYSTEM	C	22,735	P	SW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
	Connections				10,281

Towns Served: BEACON FALLS, NAUGATUCK, PROSPECT, WATERBURY

### Monitoring Requirements

Water System Facility: STRAITSVILLE RESERVOIR (WSF ID: 2095)

1 routine (RT) per quarter			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
1 routine (RT) per year			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
STRAITSVILLE RESERVOIR (1)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
1 routine (RT) per quarter			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
STRAITSVILLE RESERVOIR (1)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
1 routine (RT) per year			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
STRAITSVILLE RESERVOIR (1)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

### Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: STEWART WTP ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	<spaces> ( )	Minimum: 0.55 MG/L	Daily
<b>Start Date:</b> 1/1/2023		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Monitoring</b>
			<b>Compliance Status:</b>
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
<b>Start Date:</b> 1/1/2023		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Monitoring</b>
			<b>Compliance Status:</b>
		8/1/2025 - 8/31/2025	Y
		9/1/2025 - 9/30/2025	Y
		10/1/2025 - 10/31/2025	Y
		11/1/2025 - 11/30/2025	Y

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT0880011</b>	<b>CTWC - NAUGATUCK REGION-CENTRAL SYSTEM</b>	C	22,735	P	SW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
	Connections				10,281

Towns Served: BEACON FALLS, NAUGATUCK, PROSPECT, WATERBURY

Water System Facility: STEWART WTP ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
<b>Start Date:</b> 1/1/2023		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Monitoring</b>
		12/1/2025 - 12/31/2025	<b>Compliance Status:</b> Y
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.8 PH	Daily
<b>Start Date:</b> 7/1/2003		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Monitoring</b>
		8/1/2025 - 8/31/2025	<b>Compliance Status:</b>
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.3 MG/L	2
<b>Start Date:</b> 7/1/2003		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Monitoring</b>
		8/1/2025 - 8/31/2025	<b>Compliance Status:</b>
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

Water System Facility: INDIAN FIELD WELLFIELD ENTRY POINT (WSFID: 00701)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 1/1/2002		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Monitoring</b>
		8/1/2025 - 8/31/2025	<b>Compliance Status:</b>
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
<b>Start Date:</b> 1/1/2023		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Monitoring</b>
	Offline	8/1/2025 - 8/31/2025	<b>Compliance Status:</b> n/a Y
	Offline	9/1/2025 - 9/30/2025	
	Offline	10/1/2025 - 10/31/2025	
	Offline	11/1/2025 - 11/30/2025	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0880011	CTWC - NAUGATUCK REGION-CENTRAL SYSTEM	C	22,735	P	SW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
	Connections				10,281

Towns Served: BEACON FALLS, NAUGATUCK, PROSPECT, WATERBURY

**Water System Facility: INDIAN FIELD WELLFIELD ENTRY POINT (WSFID: 00701)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
<b>Start Date:</b> 1/1/2023		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Monitoring</b>
		12/1/2025 - 12/31/2025	<b>Compliance Status:</b>
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.8 PH	Daily
<b>Start Date:</b> 7/1/2003		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Monitoring</b>
		8/1/2025 - 8/31/2025	<b>Compliance Status:</b>
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

**Water System Facility: MARKS BROOK WELLFIELD ENTRY POINT (WSFID: 00702)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 1/1/2002		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Monitoring</b>
		8/1/2025 - 8/31/2025	<b>Compliance Status:</b>
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	<spaces> ( )	Minimum: 0.55 MG/L	Daily
<b>Start Date:</b> 1/1/2023		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Monitoring</b>
		8/1/2025 - 8/31/2025	<b>Compliance Status:</b>
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
<b>Start Date:</b> 1/1/2023		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Monitoring</b>
	Offline	8/1/2025 - 8/31/2025	n/a
	Offline	9/1/2025 - 9/30/2025	n/a
	Offline	10/1/2025 - 10/31/2025	n/a
	Offline	11/1/2025 - 11/30/2025	n/a

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT0880011</b>	<b>CTWC - NAUGATUCK REGION-CENTRAL SYSTEM</b>	<b>C</b>	22,735	<b>P</b>	<b>SW</b>
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
	Connections				10,281

Towns Served: BEACON FALLS, NAUGATUCK, PROSPECT, WATERBURY

**Water System Facility: MARKS BROOK WELLFIELD ENTRY POINT (WSFID: 00702)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
<b>Start Date:</b> 1/1/2023		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Monitoring</b>
			<b>Compliance Status:</b>
		12/1/2025 - 12/31/2025	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.8 PH	Daily
<b>Start Date:</b> 7/1/2003		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Monitoring</b>
			<b>Compliance Status:</b>
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.3 MG/L	2
<b>Start Date:</b> 7/1/2003		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Monitoring</b>
			<b>Compliance Status:</b>
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

**Water System Facility: STEWART WATER TREATMENT PLANT (WSFID: 172)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 1/1/2002		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Monitoring</b>
			<b>Compliance Status:</b>
		8/1/2025 - 8/31/2025	Y
		9/1/2025 - 9/30/2025	Y
		10/1/2025 - 10/31/2025	Y
		11/1/2025 - 11/30/2025	Y
		12/1/2025 - 12/31/2025	Y
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
<b>Start Date:</b> 1/1/2002		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Monitoring</b>
			<b>Compliance Status:</b>
		8/1/2025 - 8/31/2025	Y
		9/1/2025 - 9/30/2025	Y
		10/1/2025 - 10/31/2025	Y
		11/1/2025 - 11/30/2025	Y

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0880011	CTWC - NAUGATUCK REGION-CENTRAL SYSTEM	C	22,735	P	SW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
	Connections				10,281

Towns Served: BEACON FALLS, NAUGATUCK, PROSPECT, WATERBURY

Water System Facility: STEWART WATER TREATMENT PLANT (WSFID: 172)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
Start Date: 1/1/2002		Compliance History: Monitoring Period	Operating Limit Monitoring Compliance Status: Compliance Status:
		12/1/2025 - 12/31/2025	Y
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
Start Date: 1/1/2002		Compliance History: Monitoring Period	Operating Limit Monitoring Compliance Status: Compliance Status:
		8/1/2025 - 8/31/2025	Y
		9/1/2025 - 9/30/2025	Y
		10/1/2025 - 10/31/2025	Y
		11/1/2025 - 11/30/2025	Y
		12/1/2025 - 12/31/2025	Y

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
MAIL/HAND DELIVER NOTICE TO CONSUMERS	12/31/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2026	
CERTIFY LEAD SL NOTIFICATION	7/1/2026	

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total	Lead and	Stage
					Coliform Rule	Copper Rule Tier	
00500	STEWART WTP BLENDED INFLUENT	1A	STEWART WTP BLENDED	A			
00600	DISTRIBUTION SYSTEM	2042	PROSPECT TANK	A	Y		
		2050	60 GABRIEL DRIVE	A	Y		
		2050-OLD	18 MAY STREET	I	Y		
		2051	1354 NEW HAVEN RD	A	Y		
		2052	2714 SOUTH MAIN	A	Y		
		2052OLD	2636 S MAIN ST	I	Y		
		2052X	2636 SOUTH MAIN STRE	I	Y		
		2053	41 MAPLE ST	A	Y		
		2054	159 QUINN ST	I	Y		
		2055	250 MEADOW ST	A	Y		
		2056	HORIZON HOMES	A			
		2057	253 PROSPECT ST	A	Y		
		2058	MESHADDOCK PUMP STA	A			
		2059	85 SPRING ROAD	A	Y		
		2059-OLD	MAPLE HILL PUMP STA	I	Y		
		2060	165 TAWNY THRUSH RD	A	Y		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT0880011</b>	<b>CTWC - NAUGATUCK REGION-CENTRAL SYSTEM</b>	C	22,735	P	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					10,281

Towns Served: BEACON FALLS, NAUGATUCK, PROSPECT, WATERBURY

**Water System Facility and Sampling Point Inventory**

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	Stage WQP 2	DBPR
					Y	Y	Y	Y	Y
	2061	NAUGATUCK POLICE DEP	A						
	20801	165 BEACON HILL COMM	A						
	20802	33 COUNTRY HILL RD	A						
	20803	173 BEACON HILL COMM	A						
	20804	176 BEACON HILL COMM	A						
	20805	60 CAMBRIDGE CT	A						
	20806	270 ANDREW AVE	A						
	20807	69 CAMBRIDGE CT	A						
	20808	205 ANDREW AVE	A						
	20809	25 COUNTRY HILL RD	A						
	20810	163 BEACON HILL COMM	A						
	20811	148 BEACON HILL COMM	A						
	20812	169 BEACON HILL COMM	A						
	20813	164 BEACON HILL COMM	A						
	20814	144 BEACON HILL COMM	A						
	20815	167 BEACON HILL COMM	A						
	20816	170 BEACON HILL COMM	A						
	20817	268 ANDREW AVE	A						
	20818	73 COUNTRY HILL RD	A						
	20819	91 COUNTRY HILL RD	A						
	20820	261 ANDREW AVE	A						
	20821	85 COUNTRY HILL RD	A						
	20822	67 COUNTRY HILL RD	A						
	20823	89 COUNTRY HILL RD	A						
	20824	29 CARRIAGE DR	A						
	20825	67 CARRIAGE DR	A						
	20826	66 CARRIAGE DR	A						
	20827	69 CARRIAGE DR	A						
	20828	14 CARRIAGE DR	A						
	20829	61 CARRIAGE DR	A						
	20830	10 CARRIAGE DR	A						
	20831	17 CARRIAGE DR	A						
	20832	21 AETNA ST	A	Y					
	20833	54 CLIFF ST	A	Y					
	20834	8 TUDOR LN	A	Y					
	20835	3 TUDOR LN	A	Y					
	20836	12 TUDOR LN	A	Y					
	20837	13 TUDOR LN	A	Y					

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT0880011</b>	<b>CTWC - NAUGATUCK REGION-CENTRAL SYSTEM</b>	<b>C</b>	<b>22,735</b>	<b>P</b>	<b>SW</b>
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					10,281

Towns Served: BEACON FALLS, NAUGATUCK, PROSPECT, WATERBURY

<b>Water System Facility and Sampling Point Inventory</b>									
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	WQP 2	DBPR Stage
	20838	14 TUDOR LN		A	Y	1			
	20839	15 TUDOR LN		A	Y	1			
	20840	16 TUDOR LN		A	Y	1			
	20841	18 TUDOR LN		A		1			
	20842	10 TUDOR LN		A	Y	1			
	20843	23 TUDOR LN		A	Y	1			
	20844	25 TUDOR LN		A	Y	1			
	20845	27 TUDOR LN		A	Y	1			
	20846	29 TUDOR LN		A	Y	1			
	20847	33 TUDOR LN		A	Y	1			
	20848	30 TUDOR LN		A	Y	1			
	20849	32 TUDOR LN		A	Y	1			
	20850	24 TUDOR LN		A	Y	1			
	20851	28 TUDOR LN		A	Y	1			
	20852	59 CARRIAGE DR		A	Y	1			
	20853	16 VINCENT PL		A	Y	1			
	20854	14 VINCENT PL		A	Y	1			
	20855	36 CELENTANO DR		A	Y	1			
	20856	34 CELENTANO DR		A	Y	1			
	20857	38 CELENTANO DR		A	Y	1			
	20858	28 CELENTANO DR		A	Y	1			
	20859	101 CELENTANO DR		A	Y	1			
	20860	99 CELENTANO DR		A	Y	1			
	20861	105 CELENTANO DR		A	Y	1			
	20862	107 CELENTANO DR		A	Y	1			
	20863	109 CELENTANO DR		A	Y	1			
	20864	113 CELENTANO DR		A	Y	1			
	20865	115 CELENTANO DR		A	Y	1			
	20866	119 CELENTANO DR		A	Y	1			
	20867	121 CELENTANO DR		A	Y	1			
	20868	40 CELENTANO DR		A	Y	1			
	20869	375 ALLERTON FARMS		A	Y	1			
	20870	379 ALLERTON FARMS		A	Y	1			
	20871	387 ALLERTON FARMS		A	Y	1			
	20872	10 VINCENT PL		A		1			
	20873	12 VINCENT PL		A	Y	1			
	20874	6 VINCENT PL		A	Y	1			
	20875	8 VINCENT PL		A	Y	1			

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT0880011</b>	<b>CTWC - NAUGATUCK REGION-CENTRAL SYSTEM</b>	<b>C</b>	<b>22,735</b>	<b>P</b>	<b>SW</b>
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					10,281

Towns Served: BEACON FALLS, NAUGATUCK, PROSPECT, WATERBURY

**Water System Facility and Sampling Point Inventory**

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
					Rule			
		20876	203 OSBORN RD	A	Y	1		
		20877	5 VINCENT PL	A	Y	1		
		20878	19 PUTTING GREEN LN	A	Y	1		
		20879	22 PUTTING GREEN LN	A	Y	1		
		20880	27 PUTTING GREEN LN	A	Y	1		
		20881	32 PUTTING GREEN LN	A	Y	1		
		20882	67 PUTTING GREEN LN	A	Y	1		
		20883	185 BLUEBIRD DR	A	Y	1		
		20884	162 BLUEBIRD DR	A	Y	1		
		20885	252 BLUEBIRD DR	A	Y	1		
		20886	248 BLUEBIRD DR	A	Y	1		
		20887	240 BLUEBIRD DR	A	Y	1		
		20888	229 BLUEBIRD DR	A	Y	1		
		20889	225 BLUEBIRD DR	A	Y	1		
		20890	217 BLUEBIRD DR	A	Y	1		
		20891	221 BLUEBIRD DR	A	Y	1		
		20892	209 BLUEBIRD DR	A	Y	1		
		20893	213 BLUEBIRD DR	A	Y	1		
		20894	194 BLUEBIRD DR	A	Y	1		
		20895	198 BLUEBIRD DR	A	Y	1		
		20896	202 BLUEBIRD DR	A	Y	1		
		20897	205 BLUEBIRD DR	A	Y	1		
		20898	209 BLUEBIRD DR	A	Y	1		
		20899	224 BLUEBIRD DR	A	Y	1		
		20900	190 BLUEBIRD DR	A	Y	1		
		20901	197 BLUEBIRD DR	A	Y	1		
		20902	232 BLUEBIRD DR	A	Y	1		
		20903	236 BLUEBIRD DR	A	Y	1		
		20904	237 BLUEBIRD DR	A	Y	1		
		20905	101 BLUEBIRD DR	A	Y	1		
		20906	112 BLUEBIRD DR	A	Y	1		
		20907	118 BLUEBIRD DR	A	Y	1		
		20908	125 BLUEBIRD DR	A	Y	1		
		20909	126 BLUEBIRD DR	A	Y	1		
		20910	131 BLUEBIRD DR	A	Y	1		
		20911	137 BLUEBIRD DR	A	Y	1		
		20912	138 BLUEBIRD DR	A	Y	1		
		20913	69 RUBBER AVE	A	Y			

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT0880011</b>	<b>CTWC - NAUGATUCK REGION-CENTRAL SYSTEM</b>	<b>C</b>	<b>22,735</b>	<b>P</b>	<b>SW</b>
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					10,281

Towns Served: BEACON FALLS, NAUGATUCK, PROSPECT, WATERBURY

<b>Water System Facility and Sampling Point Inventory</b>									
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	WQP 2	DBPR Stage
	20914	35 AETNA ST		A	Y	1			
	20915	115 AETNA ST		A	Y	1			
	20916	170 AETNA ST		A	Y	1			
	20917	179 AETNA ST		A	Y	1			
	20918	17 BEECHER ST		A	Y	1			
	20919	19 BRENNAN ST		A	Y	1			
	20920	8 BURRITT PL		A	Y	1			
	20921	167 CHERRY ST		A	Y	1			
	20922	215 CHERRY ST		A	Y	1			
	20923	143 CHERRY #3 ST		A	Y	1			
	20924	524 CHURCH ST		A	Y	1			
	20925	16 CLIFF ST		A	Y	1			
	20926	100 CLIFF ST		A	Y	1			
	20927	37 COEN ST		A	Y	1			
	20928	39 COEN ST		A		1			
	20929	44 COEN ST		A	Y	1			
	20930	55 DUNN AVE		A	Y	1			
	20931	20 FAIRCHILD ST		A	Y	1			
	20932	181 GORMAN ST		A	Y	1			
	20933	682 HIGH ST		A	Y	1			
	20934	148 HIGHLAND AVE		A	Y	1			
	20935	386 HILLSIDE AVE		A	Y	1			
	20936	524 HILLSIDE AVE		A	Y	1			
	20937	561 HILLSIDE AVE		A	Y	1			
	20938	32 HOADLEY ST		A	Y	1			
	20939	47 MAY ST		A	Y	1			
	20940	84 MELBOURNE ST		A	Y	1			
	20941	101 MELBOURNE ST		A	Y	1			
	20942	303 MILLVILLE AVE		A	Y	1			
	20943	583 N CHURCH ST		A	Y	1			
	20944	17 N HOADLEY ST		A	Y	1			
	20945	84 N HOADLEY ST		A	Y	1			
	20946	2 PARK AVE		A	Y	1			
	20947	16 PARK AVE		A	Y	1			
	20948	35 PARK AVE		A	Y	1			
	20949	63 PARK AVE		A	Y	1			
	20950	24 PLEASANT AVE		A	Y	1			
	20951	99 RADNOR AVE		A	Y	1			

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT0880011</b>	<b>CTWC - NAUGATUCK REGION-CENTRAL SYSTEM</b>	<b>C</b>	<b>22,735</b>	<b>P</b>	<b>SW</b>
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					10,281

Towns Served: BEACON FALLS, NAUGATUCK, PROSPECT, WATERBURY

<b>Water System Facility and Sampling Point Inventory</b>									
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	WQP 2	DBPR Stage
		20952	53 SCOTT ST	A	Y	1			
		20953	69 SPENCER ST	A	Y	1			
		20954	142 SPRING ST	A	Y	1			
		20955	25 STANLEY ST	A	Y	1			
		20956	21 WALNUT TER	A	Y	1			
		20957	25 WALNUT TER	A	Y	1			
		20958	111 WALNUT ST	A	Y	1			
		20959	2 STANLEY ST	A	Y	1			
		2096	NEW MAINS	A	Y				
		20960	12 WOOD ST	A	Y	2			
		20961	5 AETNA PL	A	Y	2			
		20962	25 AETNA PL	A	Y	2			
		20963	12 AETNA ST	A	Y	2			
		20964	169 AETNA ST	A	Y	2			
		20965	191 AETNA ST	A	Y	2			
		20966	68 ANDERSON ST	A	Y	2			
		20967	28 BRADLEY ST	A	Y	2			
		20968	263 CHERRY ST	A	Y	2			
		20969	12 CLIFF ST	A		2			
		20970	27 CLIFF ST	A	Y	2			
		20971	10 COEN ST	A	Y	2			
		20972	16 COEN ST	A		2			
		20973	21 COEN ST	A	Y	2			
		20974	28 COEN ST	A	Y	2			
		20975	34 COEN ST	A	Y	2			
		20976	43 COEN ST	A	Y	2			
		20977	50 COEN ST	A	Y	2			
		20978	40 FERN ST	A	Y	2			
		20979	76-78 GOODYEAR AVE	A	Y	2			
		20980	110 GORMAN ST	A	Y	2			
		20981	150 GORMAN ST	A	Y	2			
		20982	167 GORMAN ST	A	Y	2			
		20983	32 GREENWOOD ST	A	Y	2			
		20984	121 HILL ST	A	Y	2			
		20985	20 HOADLEY ST	A	Y	2			
		20986	226 MAPLE ST	A	Y	2			
		20987	90 OAK ST	A	Y	2			
		20988	93-95 OAK ST	A	Y	2			

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT0880011</b>	<b>CTWC - NAUGATUCK REGION-CENTRAL SYSTEM</b>	<b>C</b>	<b>22,735</b>	<b>P</b>	<b>SW</b>
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					10,281

Towns Served: BEACON FALLS, NAUGATUCK, PROSPECT, WATERBURY

<b>Water System Facility and Sampling Point Inventory</b>									
Water System Facility	Facility ID	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	WQP 2	Stage DBPR
					Y	2			
	20989	99 OAK ST		A	Y	2			
	20990	108 OAK ST		A	Y	2			
	20991	51 PARK AVE		A	Y	2			
	20992	60 SCOTT ST		A	Y	2			
	20993	5 STANLEY ST		A	Y	2			
	20994	128 WALNUT ST		A	Y	2			
	20995	138 WALNUT ST		A	Y	2			
	20996	127 WALNUT 2ND ST		A	Y	2			
	20997	170 WARD ST		A	Y	2			
	20998	11 WOOD ST		A	Y	2			
	20999	15 WOOD ST		A	Y	2			
	21000	59 LORANN DR		A	Y				
	21001	11 PHOENIX AVE		A	Y				
	21002	36 SUMMIT ROAD		A	Y				
	21003	100 HILLTOP RD		A	Y				
	21004	123 MAY STREET		A	Y				
	21005	93 WARREN AVE		A	Y				
	2150	2714 SOUTH MAIN		A	Y				Y
	2150X	930 STRAITS TPKE		I	Y	3			Y
	2156	65 TUCKER HILL RD		A	Y				Y
	2157	BLUEBERRY KNOLL		A	Y				
	2158	MIDDLEBURY EDGE		A					Y
	2165	PD 200 SOUTHFORD ROA		A	Y				
	2170	25-37 FAIRCHILD ST		A					Y
	2171	OSBORN RD PS		A	Y				
	2172	HILLSIDE AVE PS		A	Y				
	2173	KELLY RD PS		A	Y				
	4	GENERIC DISTRIBUTION		A	Y				
	DOWNSTREAM	WITHIN 5 SERVICE CON		A					
	UPSTREAM	WITHIN 5 SERVICE CON		A					
00700	STEWART WTP ENTRY POINT	3	STEWART ENTRY POINT	A					
00701	INDIAN FIELD WELLFIELD ENTRY POINT	3	ENTRY POINT	A					
00702	MARKS BROOK WELLFIELD ENTRY POINT	3	ENTRY POINT	A					
1344	INDIAN FIELDS WELL #1	2	INDIAN FIELDS WELL #	A					
1345	INDIAN FIELDS WELL #2	2	INDIAN FIELDS WELL #	A					
1372	MARKS BROOK WELL #1	2	MARKS BROOK WELL #1	A					

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0880011	CTWC - NAUGATUCK REGION-CENTRAL SYSTEM	C	22,735	P	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					10,281

Towns Served: BEACON FALLS, NAUGATUCK, PROSPECT, WATERBURY

<b>Water System Facility and Sampling Point Inventory</b>							
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos WQP 2 DBPR Stage
1373	MARKS BROOK WELL #2	2	MARKS BROOK WELL #2	A			
171	MARKS BROOK TREATMENT STATION	5	IESWTR - ENTRY POINT	A			
172	STEWART WATER TREATMENT PLANT	5	EP - STEWART TP	A			
174	INDIAN FIELDS TREATMENT STATION	5	IESWTR - ENTRY POINT	A			
2091	LONG HILL RESERVOIR	1	LONG HILL RESERVOIR	A			
2092	TWITCHELL RESERVOIR	1	RESERVOIR	A			
2093	BEACON VALLEY BROOK DIVERSION	1	RESERVOIR	A			
2094	MOODY RESERVOIR	1	RESERVOIR	A			
2095	STRAITSVILLE RESERVOIR	1	STRAITSVILLE RESERVO	A			
2096	MULBERRY RESERVOIR	1	MULBERRY RESERVOIR	A			
2097	HOPKINS DIVERSION	1	RESERVOIR	A			
2098	UPPER CANDEE RESERVOIR	1	UPPER CANDEE RESERVO	A			
2099	LOWER CANDEE RESERVOIR	1	RESERVOIR	A			
2100	MESHADDOCK BROOK DIVERSION	1	RESERVOIR	A			
30047	MULBERRY RESERVOIR						
30048	TWITCHELL RESERVOIR						
30049	LOWER CANDEE RESERVOIR						
30050	STRAITSVILLE RESERVOIR						
49033	SHADDUCK ROAD BOOSTER PUMP STATION						
49035	FERNDALE TANK						
49333	PROSPECT TANK						
50969	KELLY ROAD PUMP STATION						
50971	HYDROSTATIC TANKS - KELLY RD						
51785	FAWN MEADOW STORAGE TANKS						
52090	LOWER ROAD TANK						
52092	GREAT HILL RD TANK						
52094	CLARK TANK						
52096	HUNTERS MOUNTAIN RD TANK						
52098	MAPLE HILL TANK						
52100	MULBERRY #1 TANK						

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0880011	CTWC - NAUGATUCK REGION-CENTRAL SYSTEM	C	22,735	P	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					10,281

Towns Served: BEACON FALLS, NAUGATUCK, PROSPECT, WATERBURY

<b>Water System Facility and Sampling Point Inventory</b>							
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Lead and Copper Rule Tier Asbestos WQP 2 DBPR Stage
52102	MULBERRY #2 TANK						
52104	MESHADDOCK TANK						
52106	STEWART CLEARWELL						
52108	MESHADDOCK PUMP STATION						
52110	HILLSIDE PUMP STATION						
52112	FIRST INDUSTRIAL PARK PUMP STATION						
52114	SECOND INDUSTRIAL PARK PUMP STATION						
52116	OSBORN RD PUMP STATION						
52118	MAPLE HILL PUMP STATION						
52120	SHARON AVE PUMP STATION						
52122	HUNTERS MTN RD PUMP STATION						
52124	PROSPECT PUMP STATION						
52126	STEWART PUMP STATION						
56999	CLARK ROAD PUMP STATION						
59390	TUCKER HILL PUMP STATION						
61450	INTERCONNECTION - CT1510011 - WATERBURY						
63067	INTERCONNECTION CT0819031 CTWC HILLCREST						

## Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification:		Certification Expiration
Operator Name	Operator Type	Certification(s)
ROBOTHAM, JR., PAUL C.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS II
PEIL, THEODORE W.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II
PHIPPS, RYAN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II WATER TREATMENT PLANT OPERATOR - CLASS II
		6/30/2026 3/31/2026 6/30/2028

Water System Facility: **MARKS BROOK TREATMENT STATION (WSF ID: 171)**

Facility Classification:		Certification Expiration
Operator Name	Operator Type	Certification(s)
SIMS, GREG	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS III
PEIL, THEODORE W.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II
		3/31/2028 9/30/2028 6/30/2026

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0880011	CTWC - NAUGATUCK REGION-CENTRAL SYSTEM	C	22,735	P	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					10,281

Towns Served: BEACON FALLS, NAUGATUCK, PROSPECT, WATERBURY

## Certified Operator Information

Water System Facility: STEWART WATER TREATMENT PLANT (WSF ID: 172)

**Facility Classification:** CLASS 4 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
MEDER, NICHOLAS J.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2027 3/31/2027

Water System Facility: INDIAN FIELDS TREATMENT STATION (WSF ID: 174)

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
SIMS, GREG	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS III	3/31/2028 9/30/2028
PEIL, THEODORE W.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2026

## Contact Information

Name	Organization	Job Title		
Mr. Craig J. Patla	Connecticut Water Company	Vp, Service Delivery		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
93 West Main Street		Clinton	CT	06413
Business Phone	Extension	Fax	Mobile Phone	Email Address
860-664-6140			800-391-1924	craig.patla@ctwater.com

Contact Role(s): Legal Contact, Owner

Name	Organization	Job Title		
Mr. Gerald McDermott	The Connecticut Water Company	Manager, Service Del		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
93 West Main Street		Clinton	CT	06413
Business Phone	Extension	Fax	Mobile Phone	Email Address
860-664-6125				ctwcdphadmin@ctwater.com

Contact Role(s): Administrative Contact

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0880031	IDLEVIEW MOBILE HOME PARK	C	138	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		58			

Towns Served: NAUGATUCK

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30		
<b>Total Coliform (3100)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
<b>Lead And Copper (PBCU)</b>	<b>5 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/25	6/1-9/30	Complete
	1/1/26 - 12/31/26	6/1-9/30	
	1/1/27 - 12/31/27	6/1-9/30	
<b>Physical Parameters (PPS)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: **ENTRY POINT** (WSF ID: 00700)

<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/25		Complete
	1/1/26 - 12/31/34		
<b>Uranium (4006)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/25		Complete
	1/1/26 - 12/31/34		
<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/17 - 12/31/25		Complete
	1/1/26 - 12/31/34		
<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/27		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0880031	IDLEVIEW MOBILE HOME PARK	C	138	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		58			

Towns Served: NAUGATUCK

## Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)		1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
		1/1/27 - 12/31/27		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)			1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete	
	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			
Organic Chemicals (VOCS)			1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete	
	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			

## Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
			Compliance History:	Monitoring
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily	
Start Date: 6/1/2022			Monitoring Period	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION EXEMPTION	3/1/2026	

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total	Lead and	Stage
					Coliform Rule	Copper Rule Tier	
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A			
		IDLEVIEW001	UNIT #25	A	Y	3	Y
		IDLEVIEW002	UNIT #14	A		1	Y
		IDLEVIEW003	UNIT #42	A		N	Y
		IDLEVIEW004	UNIT #27	A		N	Y
		IDLEVIEW005	UNIT #24	A		N	Y
		IDLEVIEW006	UNIT #15	A	Y	N	Y

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT0880031</b>	<b>IDLEVIEW MOBILE HOME PARK</b>	C	138	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
	58				

Towns Served: NAUGATUCK

<b>Water System Facility and Sampling Point Inventory</b>								
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos WQP 2 DBPR	Stage
	IDLEVIEW007	UNIT #35		A	Y	N	Y	
	IDLEVIEW008	UNIT #50		A	Y	N	Y	
	IDLEVIEW009	UNIT #28		A	Y	N	Y	
	IDLEVIEW010	UNIT #11		A	Y	N	Y	
	IDLEVIEW011	UNIT #20		A	Y	N	Y	
	IDLEVIEW012	UNIT #38		A	Y	N	Y	
	IDLEVIEW013	UNIT #34		A	Y	N	Y	
	IDLEVIEW014	UNIT #54		A	Y	N	Y	
	IDLEVIEW015	UNIT #2		A	Y	N	Y	
	IV-0	UNIT 0		A	Y	N		
	IV-1	UNIT 1		A	Y	N		
	IV-10	UNIT 10		A	Y	N		
	IV-12	UNIT 12		A	Y	N		
	IV-13	UNIT 13		A	Y	N		
	IV-14	UNIT 14		A	Y	N		
	IV-16	UNIT 16		A	Y	N		
	IV-17	UNIT 17		A	Y	N		
	IV-18	UNIT 18		A	Y	N		
	IV-19	UNIT 19		A	Y	N		
	IV-1A	UNIT 1-A		A	Y	N		
	IV-21	UNIT 21		A	Y	N		
	IV-22	UNIT 22		A	Y	N		
	IV-23	UNIT 23		A	Y	N		
	IV-25	UNIT 25		A	Y	N		
	IV-26	UNIT 26		A	Y	N		
	IV-29	UNIT 29		A	Y	N		
	IV-3	UNIT 3		A	Y	N		
	IV-30	UNIT 30		A	Y	N		
	IV-31	UNIT 31		A	Y	N		
	IV-32	UNIT 32		A	Y	N		
	IV-33	UNIT 33		A	Y	N		
	IV-36	UNIT 36		A	Y	N		
	IV-37	UNIT 37		A	Y	N		
	IV-39	UNIT 39		A	Y	N		
	IV-4	UNIT 4		A	Y	N		
	IV-40	UNIT 40		A	Y	N		
	IV-41	UNIT 41		A	Y	N		
	IV-43	UNIT 43		A	Y	N		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0880031	IDLEVIEW MOBILE HOME PARK	C	138	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
	58				Agricultural

Towns Served: NAUGATUCK

<b>Water System Facility and Sampling Point Inventory</b>								
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
	IV-44	UNIT 44		A	Y	N		
	IV-45	UNIT 45		A	Y	N		
	IV-46	UNIT 46		A	Y	N		
	IV-47	UNIT 47		A	Y	N		
	IV-48	UNIT 48		A	Y	N		
	IV-49	UNIT 49		A	Y	N		
	IV-5	UNIT 5		A	Y	N		
	IV-51	UNIT 51		A	Y	N		
	IV-52	UNIT 52		A	Y	N		
	IV-53	UNIT 53		A	Y	N		
	IV-55	UNIT 55		A	Y	N		
	IV-56	UNIT 56		A	Y	N		
	IV-57	UNIT 57		A	Y	N		
	IV-58	UNIT 58		A	Y	N		
	IV-6	UNIT 6		A	Y	N		
	IV-7	UNIT 7		A	Y	N		
	IV-8	UNIT 8		A	Y	N		
	IV-9	UNIT 9		A	Y	N		
	UPSTREAM	WITHIN 5 SERVICE CON		A				
00700	ENTRY POINT	3	ENTRY POINT	A				
36426	TREATMENT PLANT							
406	WELL #1	2	WELL #1	A				
407	WELL #2	2	WELL #2	A				
49629	HYDROPNEUMATIC TANK							

## Certified Operator Information

Water System Facility: TREATMENT PLANT (WSF ID: 36426)

Facility Classification: CLASS 2 TREATMENT PLANT			Certification Expiration
Operator Name	Operator Type	Certification(s)	
HELMING, TRAVIS	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2028 9/30/2028

## Contact Information

Name	Organization	Job Title		
Ms. Marcia Stemm	Harmony Acres Mobile Home Park	President		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
68 Cooke Street		Plainville	CT	06062
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone
860-747-6881		860-410-1095		800-822-6690 MHPARKSINC@aol.com

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0880031	IDLEVIEW MOBILE HOME PARK	C	138	P	GW
Local Address (where applicable)	Service Connections	Residential 58	Commercial	Industrial	Combined

Towns Served: NAUGATUCK

Contact Role(s): **Administrative Contact, Legal Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

*<http://www.ct.gov/dph/publicdrinkingwater>*

**End of schedule**