

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0920011	AQUARION-NEW HARTFORD	C	1,872	L	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		124	43	8	

Towns Served: NEW HARTFORD

**Monitoring Requirements**

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

<b>Chlorine Residual (1012)</b>	<b>2 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
<b>Asbestos (1094)</b>	<b>2 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/21 - 12/31/29		
<b>Total Haloacetic Acids (2456)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
TWN HALL 530 MAIN ST (03382)	1/1/25 - 12/31/25	8/1-8/31	Complete
	1/1/26 - 12/31/26	8/1-8/31	
	1/1/27 - 12/31/27	8/1-8/31	
<b>Total Trihalomethanes (2950)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
98 STEELE ROAD (03385)	1/1/25 - 12/31/25	8/1-8/31	Complete
	1/1/26 - 12/31/26	8/1-8/31	
	1/1/27 - 12/31/27	8/1-8/31	
<b>Total Coliform (3100)</b>	<b>2 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
<b>Lead And Copper (PBCU)</b>	<b>10 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/25	6/1-9/30	Complete
<b>Lead And Copper (PBCU)</b>	<b>20 routine (RT) per six months</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/26 - 6/30/26		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0920011	AQUARION-NEW HARTFORD	C	1,872	L	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: NEW HARTFORD

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

Lead And Copper (PBCU)	20 routine (RT) per six months		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	7/1/26 - 12/31/26		
<b>Physical Parameters (PPS)</b>			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: **ENTRY POINT-BLACK BRIDGE WELL** (WSF ID: 00700)

Net Gross Alpha (4000)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - BLACK BRIDGE (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Uranium (4006)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - BLACK BRIDGE (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Combined Radium-226/228 (4010)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - BLACK BRIDGE (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - BLACK BRIDGE (3)	1/1/24 - 12/31/26		Complete
	1/1/27 - 12/31/29		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - BLACK BRIDGE (3)	1/1/25 - 12/31/25		Complete

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0920011	AQUARION-NEW HARTFORD	C	1,872	L	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		124	43	8	

Towns Served: NEW HARTFORD

**Monitoring Requirements**

Water System Facility: ENTRY POINT-BLACK BRIDGE WELL (WSF ID: 00700)

Nitrate And Nitrite (NOX)		1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
	1/1/26 - 12/31/26			
	1/1/27 - 12/31/27			
Pesticides, Herbicides and PCBs-Phase II (SOC2)			1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
EP - BLACK BRIDGE (3)	1/1/23 - 12/31/25			Complete
	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			
Pesticides, Herbicides and PCBs-Phase V (SOC5)			1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
EP - BLACK BRIDGE (3)	1/1/23 - 12/31/25			Complete
	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			
Organic Chemicals (VOCS)			1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
EP - BLACK BRIDGE (3)	1/1/23 - 12/31/25			Complete
	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			

Water System Facility: ENTRY POINT-PINE MEADOW WELL (WSF ID: 00701)

Net Gross Alpha (4000)		1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
EP - PINE MEADOW (3)	1/1/23 - 12/31/25			Complete
	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			
Uranium (4006)		1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
EP - PINE MEADOW (3)	1/1/23 - 12/31/25			Complete
	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			
Combined Radium-226/228 (4010)		1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
EP - PINE MEADOW (3)	1/1/23 - 12/31/25			Complete
	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			
Inorganic Chemicals (IOCS)		1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
EP - PINE MEADOW (3)	1/1/24 - 12/31/26			
	1/1/27 - 12/31/29			

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0920011	AQUARION-NEW HARTFORD	C	1,872	L	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: NEW HARTFORD

### Monitoring Requirements

Water System Facility: ENTRY POINT-PINE MEADOW WELL (WSF ID: 00701)

1 routine (RT) per year			
<b>Nitrate And Nitrite (NOX)</b>	<b>Sampling Point (Sampling Point ID)</b>	<b>Monitoring Period</b>	<b>Collection Period</b>
	EP - PINE MEADOW (3)	1/1/25 - 12/31/25	Complete
		1/1/26 - 12/31/26	
		1/1/27 - 12/31/27	
<b>Pesticides, Herbicides and PCBs-Phase II (SOC2)</b>	<b>Sampling Point (Sampling Point ID)</b>	<b>Monitoring Period</b>	<b>Collection Period</b>
	EP - PINE MEADOW (3)	1/1/23 - 12/31/25	Complete
		1/1/26 - 12/31/28	
		1/1/29 - 12/31/31	
<b>Pesticides, Herbicides and PCBs-Phase V (SOC5)</b>	<b>Sampling Point (Sampling Point ID)</b>	<b>Monitoring Period</b>	<b>Collection Period</b>
	EP - PINE MEADOW (3)	1/1/23 - 12/31/25	Complete
		1/1/26 - 12/31/28	
		1/1/29 - 12/31/31	
<b>Organic Chemicals (VOCS)</b>	<b>Sampling Point (Sampling Point ID)</b>	<b>Monitoring Period</b>	<b>Collection Period</b>
	EP - PINE MEADOW (3)	1/1/23 - 12/31/25	
		1/1/26 - 12/31/28	
		1/1/29 - 12/31/31	

Water System Facility: PINE MEADOW WELL (WSF ID: 1211)

1 routine (RT) per month			
<b>E. Coli (3014)</b>	<b>Sampling Point (Sampling Point ID)</b>	<b>Monitoring Period</b>	<b>Collection Period</b>
	PINE MEADOW WELL 1 (2)	8/1/25 - 8/31/25	Complete
		9/1/25 - 9/30/25	
		10/1/25 - 10/31/25	Complete
		11/1/25 - 11/30/25	Complete
		12/1/25 - 12/31/25	Complete
		1/1/26 - 1/31/26	
		2/1/26 - 2/28/26	
		3/1/26 - 3/31/26	
		4/1/26 - 4/30/26	
		5/1/26 - 5/31/26	
		6/1/26 - 6/30/26	
		7/1/26 - 7/31/26	

Water System Facility: BLACK BRIDGE WELL (WSF ID: 1470)

1 routine (RT) per month			
<b>E. Coli (3014)</b>	<b>Sampling Point (Sampling Point ID)</b>	<b>Monitoring Period</b>	<b>Collection Period</b>
	BLACK BRIDGE WELL (2)	8/1/25 - 8/31/25	Complete

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0920011	AQUARION-NEW HARTFORD	C	1,872	L	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: NEW HARTFORD

## Monitoring Requirements

Water System Facility: BLACK BRIDGE WELL (WSF ID: 1470)

1 routine (RT) per month			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

## Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT-BLACK BRIDGE WELL (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 5/1/2003		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Monitoring Compliance Status:</b>
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.4 PH	Daily
<b>Start Date:</b> 5/1/2003		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Monitoring Compliance Status:</b>
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

Water System Facility: ENTRY POINT-PINE MEADOW WELL (WSFID: 00701)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.05 MG/L	Daily
<b>Start Date:</b> 9/1/2025		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Monitoring Compliance Status:</b>
		9/1/2025 - 9/30/2025	

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0920011	AQUARION-NEW HARTFORD	C	1,872	L	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		124	43	8	

Towns Served: NEW HARTFORD

Water System Facility: ENTRY POINT-PINE MEADOW WELL (WSFID: 00701)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.05 MG/L	Daily
Start Date: 9/1/2025		Compliance History: Monitoring Period	Operating Limit Compliance Status: Monitoring Compliance Status:
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.4 PH	Daily
Start Date: 5/1/2003		Compliance History: Monitoring Period	Operating Limit Compliance Status: Monitoring Compliance Status:
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
MAIL/HAND DELIVER NOTICE TO CONSUMERS	12/31/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2026	
CERTIFY LEAD SL NOTIFICATION	7/1/2026	

### Public Notification Requirements

Violation/Situation	Compliance Period	Notice Tier	Public Notification		PN Certification	
			Required	Performed	Due to DPH	Received
E. Coli M&R Violation	9/1/25 - 9/30/25	3	1/2/2027		1/12/2027	

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total		Lead and Coliform		Stage	
				Status	Rule	Rule Tier	Asbestos	WQP 2	DBPR
00600	DISTRIBUTION SYSTEM	03382	TWN HALL 530 MAIN ST	A	Y	1	Y		Y
		03383	ACR 234 MAIN ST	A	Y	N			
		03384	11 CHURCH STREET	A	Y	3			
		03385	98 STEELE ROAD	A	Y	3			Y
		2350-1	50 HIGH STREET	A	Y	3			
		2350-10	50 WICKET STREET	A	Y	3			
		2350-11	8 COTTAGE STREET	A	Y	3			
		2350-13	11 BROOK ST	A	Y	1			
		2350-14	96 HOLCOMB HILL RD	A	Y	1			
		2350-15	76 COTTAGE STREET	A	Y	1			
		2350-16	21-23 COTTAGE ST	A	Y	2			

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT0920011</b>	<b>AQUARION-NEW HARTFORD</b>	C	1,872	L	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		124	43	8	

Towns Served: NEW HARTFORD

<b>Water System Facility and Sampling Point Inventory</b>									
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	WQP 2	DBPR Stage
	2350-2	16 STEELE ROAD		A	Y	3			
	2350-3	56 HIGH STREET		A	Y	3			
	2350-4	48 PROSPECT STREET		A	Y	3			
	2350-5	15 LOOMIS HEIGHTS		A	Y	3			
	2350-6	59 COTTAGE STREET		A	Y	3			
	2350-7	24 PROSPECT STREET		A	Y	3			
	2350-8	38 PROSPECT STREET		A	Y	3			
	2350-9	15 CHURCH STREET		A	Y	3			
	2352	RVR RUN 238 MAIN ST		A	Y	3			
	2359-16	21-23 COTTAGE STREET		A	Y	2			
	4	DISTRIBUTION SYSTEM		A	Y				
	DOWNSTREAM	WITHIN 5 SERVICE CON		A					
	PB9367	8 BRIDGE ST		A		3			
	PB9368	8 CARTER ST		A		3			
	PB9369	10 COTTAGE ST		A		3			
	PB9370	32 COTTAGE ST		A		3			
	PB9371	16 GREENWOODS RD		A		3			
	PB9372	45 HIGH ST		A		1			
	PB9373	27 HIGHLAND AVE		A		3			
	PB9374	28 HILLSIDE AVE		A		3			
	PB9375	55 HOLCOMB HILL		A		3			
	PB9376	6 JOHNNYCAKE LN		A		3			
	PB9377	34 LOOMIS HTS		A		3			
	PB9378	24 PROSPECT ST		A		1			
	PB9379	51 RESERVOIR RD		A		3			
	PB9380	78 TOWN HILL RD		A		3			
	PB9381	31 CHURCH ST		A		3			
	PB9382	37 CHURCH ST		A		3			
	PB9383	341 MAIN ST		A		3			
	PB9384	16 TEN ST		A		3			
	PB9385	32 WICKETT ST		A		3			
	PB9386	50 WICKETT ST		A		1			
	UPSTREAM	WITHIN 5 SERVICE CON		A					
00700	ENTRY POINT-BLACK BRIDGE WELL	3	EP - BLACK BRIDGE	A					
00701	ENTRY POINT-PINE MEADOW WELL	3	EP - PINE MEADOW	A					
1211	PINE MEADOW WELL	2	PINE MEADOW WELL 1	A					

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0920011	AQUARION-NEW HARTFORD	C	1,872	L	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		124	43	8	

Towns Served: NEW HARTFORD

<b>Water System Facility and Sampling Point Inventory</b>								
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
1470	BLACK BRIDGE WELL	2	BLACK BRIDGE WELL	A				
36435	TREATMENT PLANT - BLACK BRIDGE							
36436	PINE MEADOW TREATMENT PLANT							
45522	GREENWOODS INDUSTRIAL PARK TANK 1							
52373	GREENWOODS INDUSTRIAL PARK TANK 2							
52375	INTERCONNECTION - CT0640011 - RESERVOIR							
52379	BLACK RIDGE TP PUMP STATION							

### Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: CLASS 1 DISTRIBUTION SYSTEM			Certification Expiration
Operator Name	Operator Type	Certification(s)	
MEYERS, JAMES	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	12/31/2027
COLANGELO JR., JOSEPH M	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II	3/31/2028

Water System Facility: **TREATMENT PLANT - BLACK BRIDGE (WSF ID: 36435)**

Facility Classification: CLASS 1 TREATMENT PLANT			Certification Expiration
Operator Name	Operator Type	Certification(s)	
ROMA, MICHAEL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2026
RYLANDER, STEVEN M	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2027

Water System Facility: **PINE MEADOW TREATMENT PLANT (WSF ID: 36436)**

Facility Classification: CLASS 1 TREATMENT PLANT			Certification Expiration
Operator Name	Operator Type	Certification(s)	
ROMA, MICHAEL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2026
RYLANDER, STEVEN M	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2027

### Contact Information

Name	Organization	Job Title		
Mr. Robert J. Ulrich	Aquarion Water Company of Ct	Vp-Supply & Utility		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
505 Huntington St.		Shelton	CT	06484
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone
203-926-4320		203-929-5297		203-395-3205 rulrich@aquarionwater.com
Contact Role(s):	Administrative Contact, Legal Contact, Owner			

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0920011	AQUARION-NEW HARTFORD	C	1,872	L	GW
Local Address (where applicable)	Service Connections	Residential 124	Commercial 43	Industrial 8	Combined Agricultural

Towns Served: NEW HARTFORD

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

*<http://www.ct.gov/dph/publicdrinkingwater>*

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0920041	LITTLE BROOK RD PROPERTY OWNERS ASSN	C	64	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: NEW HARTFORD

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31		
<b>Total Coliform (3100)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
<b>Lead And Copper (PBCU)</b>	<b>5 routine (RT) per six months</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/25 - 12/31/25		
	1/1/26 - 6/30/26		
	7/1/26 - 12/31/26		
<b>Physical Parameters (PPS)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: **ENTRY POINT** (WSF ID: 00700)

<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Uranium (4006)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
ENTRY POINT (3)	1/1/25 - 12/31/27		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0920041	LITTLE BROOK RD PROPERTY OWNERS ASSN	C	64	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		16			

Towns Served: NEW HARTFORD

## Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)				1 routine (RT) per year
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)	1/1/25 - 12/31/25			Complete
	1/1/26 - 12/31/26			
	1/1/27 - 12/31/27			
Lead And Copper (PBCU)	1 routine (RT) per six months			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)	7/1/25 - 12/31/25			
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	1 routine (RT) per three years			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)	1/1/23 - 12/31/25			
	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			
Organic Chemicals (VOCS)	1 routine (RT) per three years			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)	1/1/23 - 12/31/25			
	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			

## Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
			Minimum:	4
pH	Entry Point pH Monitoring (PHRD)	6.4 PH		
Start Date: 1/1/2003		Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SWTS 1: PWS TO RECOMMEND SOWT	12/27/2025	
CCTS 1: PWS TO RECOMMEND OCCT	12/31/2025	
SWTS 2: DWS REVIEW & APPROVAL OF SOWT	6/27/2026	
CCTS 2: DWS REVIEW & APPROVAL OF OCCT	6/30/2026	
CCTS 5: PWS OCCT INSTALLATION	6/30/2028	
CROSS CONNECTION EXEMPTION	3/1/2029	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0920041	LITTLE BROOK RD PROPERTY OWNERS ASSN	C	64	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
	16				

Towns Served: NEW HARTFORD

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
					Rule			
00600	DISTRIBUTION SYSTEM	010	10 LITTLE BROOK ROAD	A	1	Y		
		011	11 LITTLE BROOK ROAD	A	1	Y		
		015	15 LITTLE BROOK ROAD	A	1	Y		
		016	16 LITTLE BROOK ROAD	A	1	Y		
		022	22 LITTLE BROOK ROAD	A	1	Y		
		023	23 LITTLE BROOK ROAD	A	1	Y		
		027	27 LITTLE BROOK ROAD	A	1	Y		
		028	28 LITTLE BROOK ROAD	A	1	Y		
		033	33 LITTLE BROOK ROAD	A	1	Y		
		034	34 LITTLE BROOK ROAD	A	1	Y		
		039	39 LITTLE BROOK ROAD	A	1	Y		
		040	40 LITTLE BROOK ROAD	A	1	Y		
		245	245 TURNBULL ROAD	A	1	Y		
		246	246 TURNBULL ROAD	A	1	Y		
		248	248 TURNBULL ROAD	A	1	Y		
		253	253 TURNBULL ROAD	A	1	Y		
		4	DISTRIBUTION SYSTEM	A	Y			
	DOWNSTREAM	WITHIN 5 SERVICE CON		A				
	UPSTREAM	WITHIN 5 SERVICE CON		A				
00700	ENTRY POINT	3	ENTRY POINT	A				
31	WELL 1	2	WELL 1	A				
36437	TREATMENT PLANT							
36838	HYDROPNEUMATIC TANK							

## Certified Operator Information

Water System Facility: TREATMENT PLANT (WSF ID: 36437)

Facility Classification:	CLASS 1 TREATMENT PLANT			Certification Expiration
Operator Name	Operator Type	Certification(s)		
KILBOURN, ERIC M.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I		12/31/2028
		WATER TREATMENT PLANT OPERATOR - CLASS II		12/31/2028
KILBOURN, JORDAN H	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II		6/30/2026
		DISTRIBUTION SYSTEM OPERATOR - CLASS I		9/30/2027

## Contact Information

Name	Organization	Job Title
Ms. Liz Ward	Little Brook Rd Property Owner	Treasurer
Mailing Address Line One	Mailing Address Line Two	City
28 Little Brook Road		State
Business Phone	Extension	Zip Code
202-221-5670		06057
Mobile Phone	Emergency Phone	Email Address

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name				Classification	Population	Owner Type	Primary Source
CT0920041	LITTLE BROOK RD PROPERTY OWNERS ASSN				C	64	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
			16					
Towns Served: NEW HARTFORD								
203-231-5670		littlebrookassociation@gmail.com						
Contact Role(s): <b>Administrative Contact</b>								
Name		Organization				Job Title		
Mr. Rick Dibella		Little Brook Rd Property Owner				President		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code	
16 Little Brook Rd					New Hartford	CT	06057	
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
				860-748-0281	rdb65@hotmail.com			

Contact Role(s): **Legal Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

**NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0920281	WEST HILL LAKE WATER ASSOC.	C	276	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		69			

Towns Served: NEW HARTFORD

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30	4/1-10/31	
<b>Total Coliform (3100)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
<b>Lead And Copper (PBCU)</b>	<b>5 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/26	6/1-9/30	
	1/1/27 - 12/31/29	6/1-9/30	
<b>Physical Parameters (PPS)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: **ENTRY POINT** (WSF ID: 00700)

<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Uranium (4006)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0920281	WEST HILL LAKE WATER ASSOC.	C	276	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: NEW HARTFORD

## Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Combined Radium-226/228 (4010)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
		1/1/29 - 12/31/31		1 routine (RT) per three years
Inorganic Chemicals (IOCS)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)		1/1/25 - 12/31/27		1 routine (RT) per three years
Nitrate And Nitrite (NOX)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)		1/1/25 - 12/31/25		1 routine (RT) per year
		1/1/26 - 12/31/26		Complete
		1/1/27 - 12/31/27		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)		1/1/23 - 12/31/25		1 routine (RT) per three years
		1/1/26 - 12/31/28		Complete
		1/1/29 - 12/31/31		
Organic Chemicals (VOCS)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)		1/1/25 - 12/31/27		1 routine (RT) per three years

## Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.4 PH	Daily
Start Date: 4/1/2003		Compliance History:	Operating Limit
		Monitoring Period	Monitoring
		Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2026	

Water System Facility and Sampling Point Inventory						
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform Status	Lead and Copper Rule Tier	Asbestos WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION DOWNSTREAM WITHIN 5 SERVICE CON	A	Y	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0920281	WEST HILL LAKE WATER ASSOC.	C	276	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
	69				

Towns Served: NEW HARTFORD

<b>Water System Facility and Sampling Point Inventory</b>							
Water System Facility ID	Water System Facility	Sampling Point		Status	Total Coliform	Lead and Copper Rule Tier	Asbestos WQP 2 DBPR
		ID	Description		Rule	Stage	
	UPSTREAM	WITHIN 5 SERVICE CON	A				
	WESTHILLO01	#60 DAVIS ROAD	A	Y	1	Y	
	WESTHILLO02	#67 DAVIS ROAD	A	Y	1	Y	
	WESTHILLO03	#28 CIRCLE DRIVE	A	Y	1	Y	
	WESTHILLO04	#88 HELEN HIWAY	A	Y	1	Y	
	WESTHILLO05	#9 HILLTOP RD	A	Y	1	Y	
	WESTHILLO06	#24 DILLISTON RD	A	Y	1	Y	
00700	ENTRY POINT	3	ENTRY POINT	A			
1935	WELL #2	2	WELL #2	A			
45671	HYDROPNEUMATIC TANK						
556	WELL # 2 TREATMENT STATION						

## Certified Operator Information

Water System Facility: WELL # 2 TREATMENT STATION (WSF ID: 556)

Facility Classification: CLASS 1 TREATMENT PLANT			Certification Expiration
Operator Name	Operator Type	Certification(s)	
KILBOURN, ERIC M.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2028 12/31/2028
KILBOURN, JORDAN H	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2026 9/30/2027

## Contact Information

Name	Organization	Job Title
West Hill Lake Water Assoc.		
Mailing Address Line One	Mailing Address Line Two	City State Zip Code
Emergency Contact	Emergency Contact	CT 06000
Business Phone	Extension	Fax
877-282-5531		
Mobile Phone		Emergency Phone
Email Address		
Contact Role(s): Owner		
Name	Organization	Job Title
Ms. Jacqueline D'arcy-Lemelin	West Hill Lake Water Assoc.	
Mailing Address Line One	Mailing Address Line Two	City State Zip Code
26 Cemetery Road		CT 06019
Business Phone	Extension	Fax
860-666-0911		
Mobile Phone		Emergency Phone
Email Address		
jdarcy11@gmail.com		
Contact Role(s): Administrative Contact, Legal Contact		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0920281	WEST HILL LAKE WATER ASSOC.	C	276	P	GW
Local Address (where applicable)	Service Connections	Residential 69	Commercial	Industrial	Combined
					Agricultural

Towns Served: NEW HARTFORD

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

*<http://www.ct.gov/dph/publicdrinkingwater>*

**End of schedule**