

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0920014	ALCOVE MOTEL			NC	30	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
87 MAIN STREET					14			
Towns Served: NEW HARTFORD								

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Total Coliform (3100)		3 repeat (RP) per period	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	6/6/25 - 6/11/25		

Total Coliform (3100)		3 temporary routine (TR) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 7/31/25		

Physical Parameters (PPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Water System Facility: **WELL (WSF ID: 21608)**

E. Coli (3014)		1 triggered (TG) per period	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL (2)	6/5/25 - 6/11/25		

### Other Compliance Schedules

<i>Compliance Schedule Activity</i>	<i>Due Date</i>	<i>Achieved Date</i>
RESPOND TO SANITARY SURVEY	2/27/2025	

### Public Notification Requirements

<i>Violation/Situation</i>	<i>Compliance Period</i>	<i>Notice Tier</i>	<i>Public Notification</i>		<i>PN Certification</i>	
			<i>Required</i>	<i>Performed</i>	<i>Due to DPH</i>	<i>Received</i>
E. Coli M&R Violation	6/13/25 -	3	10/9/2026		10/19/2026	
Physical Parameters M&R Violation	1/1/25 - 3/31/25	3	10/9/2026		10/19/2026	
Total Coliform M&R Violation	1/1/25 - 3/31/25	3	10/9/2026		10/19/2026	
Total Coliform M&R Violation	7/1/25 - 7/31/25	3	11/12/2026		11/22/2026	

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0920014	ALCOVE MOTEL			NC	30	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
87 MAIN STREET				14			
Towns Served: NEW HARTFORD							

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
21608	WELL	2	WELL	A				

### Contact Information

Name				Organization			Job Title		
Ms. Aruna B. Desai				Shiva-Tap LLC			Manager		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
87 Main St						New Hartford		CT	06057
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
860-693-8577						860-810-7889	anubhas1030@gmail.com		

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0920024	1165 LITCHFIELD TURNPIKE			NC	25	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				1			

Towns Served: NEW HARTFORD

### Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Physical Parameters (PPS)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
RESPOND TO SANITARY SURVEY	9/8/2010	
RESPOND TO SANITARY SURVEY	2/11/2021	

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
21609	WELL	2	WELL	A				

### Contact Information

Name				Organization			Job Title		
Mr. Jeffrey Radwick				The Bakersville Mall, LLC			Manager		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
The Bakersville Mall, LLC			P.O. Box 223			New Hartford		CT	06057
Business Phone		Extension	Fax	Mobile Phone		Emergency Phone	Email Address		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
<b>CT0920024</b>	<b>1165 LITCHFIELD TURNPIKE</b>	NC	25	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
			1				
Towns Served: NEW HARTFORD							
860-294-6826			jeffradwick@gmail.com				
Contact Role(s): <b>Administrative Contact, Legal Contact, Owner</b>							

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

**<http://www.ct.gov/dph/publicdrinkingwater>**

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0920034	107 MAIN STREET			NC	25	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				1				

Towns Served: NEW HARTFORD

### Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Physical Parameters (PPS)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Water System Facility: WELL 1 (WSF ID: 48669)

E. Coli (3014)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 1 (2)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
48669	WELL 1	2	WELL 1	A				
57168	TREATMENT PLANT							

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0920034	107 MAIN STREET			NC	25	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
				1			

Towns Served: NEW HARTFORD

### Contact Information

Name				Organization				Job Title		
Ms. Barbara J. Krohner										
Mailing Address Line One			Mailing Address Line Two				City		State	Zip Code
P.O. Box 206							New Hartford		CT	06057-0206
Business Phone	Extension	Fax		Mobile Phone	Emergency Phone	Email Address				
860-689-4700										

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

**<http://www.ct.gov/dph/publicdrinkingwater>**

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0920044	CAMP SEQUASSEN (FRIENDSHIP - WELL #3)			NC	25	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
791 WEST HILL ROAD					1			
Towns Served: NEW HARTFORD								

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Total Coliform (3100)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Physical Parameters (PPS)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
21611	WELL	2	WELL	A				

### Contact Information

Name				Organization			Job Title		
Mr. David J. Boyajian				Boy Scouts of America			Ranger		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
791 West Hill Road						New Hartford		CT	06057
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
860-379-2009			860-379-8977				rangerdave.seq@gmail.com		
Contact Role(s): Administrative Contact									

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT0920044</b>	<b>CAMP SEQUASSEN (FRIENDSHIP - WELL #3)</b>	NC	25	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
791 WEST HILL ROAD			1		
Towns Served: NEW HARTFORD					
Name		Organization		Job Title	
<b>Mr. Joseph Andreo</b>		CT Yankee Council Bsa		Ceo	
Mailing Address Line One		Mailing Address Line Two		City	State
60 Wellington Road		P.O. Box 32		Milford	CT
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
203-961-0518					joseph.andreo@scouting.org
Contact Role(s): <b>Legal Contact, Owner</b>					

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

***End of schedule***

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0920054	CAMP SEQUASSEN (LOOMIS - WELL #2)			NC	25	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
791 WEST HILL ROAD					1			
Towns Served: NEW HARTFORD								

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Total Coliform (3100)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Physical Parameters (PPS)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00301	PRESSURE TANKS							
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
21612	WELL	2	WELL	A				

### Contact Information

Name				Organization			Job Title		
Mr. David J. Boyajian				Boy Scouts of America			Ranger		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
791 West Hill Road						New Hartford		CT	06057
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
860-379-2009			860-379-8977				rangerdave.seq@gmail.com		
Contact Role(s):		Administrative Contact							

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT0920054</b>	<b>CAMP SEQUASSEN (LOOMIS - WELL #2)</b>	NC	25	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
791 WEST HILL ROAD			1		
Towns Served: NEW HARTFORD					
Name		Organization		Job Title	
<b>Mr. Joseph Andreo</b>		CT Yankee Council Bsa		Ceo	
Mailing Address Line One		Mailing Address Line Two		City	State
60 Wellington Road		P.O. Box 32		Milford	CT
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
203-961-0518					joseph.andreo@scouting.org
Contact Role(s): <b>Legal Contact, Owner</b>					

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

***End of schedule***

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0920084	CAMP SEQUASSEN (NORTH WELL 5)			NC	25	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
791 WEST HILL ROAD					1			
Towns Served: NEW HARTFORD								

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Total Coliform (3100)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Physical Parameters (PPS)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
63349	NORTH WELL 5A	2	NORTH WELL 5A	A				

### Contact Information

Name				Organization		Job Title			
Mr. David J. Boyajian				Boy Scouts of America		Ranger			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
791 West Hill Road						New Hartford		CT	06057
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
860-379-2009			860-379-8977				rangerdave.seq@gmail.com		
Contact Role(s):		Administrative Contact							

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT0920084</b>	<b>CAMP SEQUASSEN (NORTH WELL 5)</b>	NC	25	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
791 WEST HILL ROAD			1		
Towns Served: NEW HARTFORD					
Name		Organization		Job Title	
<b>Mr. Joseph Andreo</b>		CT Yankee Council Bsa		Ceo	
Mailing Address Line One		Mailing Address Line Two		City	State
60 Wellington Road		P.O. Box 32		Milford	CT
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
203-961-0518					joseph.andreo@scouting.org
Contact Role(s): <b>Legal Contact, Owner</b>					

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

***End of schedule***

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0920094	CAMP WORKCOEMAN - DINING HALL			NC	25	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
WEST HILL ROAD					6			
Towns Served: NEW HARTFORD								

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Total Coliform (3100)		1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete	
	7/1/25 - 9/30/25		Complete	
	10/1/25 - 12/31/25		Complete	
	1/1/26 - 3/31/26			
	4/1/26 - 6/30/26			

Physical Parameters (PPS)		1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete	
	7/1/25 - 9/30/25			
	10/1/25 - 12/31/25		Complete	
	1/1/26 - 3/31/26			
	4/1/26 - 6/30/26			

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate And Nitrite (NOX)		1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete	
	1/1/25 - 12/31/25		Complete	
	1/1/26 - 12/31/26			

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SAMPLING SITE PLAN	3/21/2025	

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		CWDCBSINK	DIRECTORS BATHROOM	A	Y			
		CWDCKSINK	DIRECTORS KITCHEN SI	A	Y			
		CWDRESTRM	DOWNSTAIRS RESTROOM	A	Y			
		CWNHLAT	NATHAN HALE LATRINE	A	Y			
		CWPREP2BK	FOOD PREP SINK	A	Y			
		CWRRSINK	RIFLE RANGE SINK	A	Y			
		CWURESTRM	UPSTAIRS RESTROOM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
21616	WELL #1	2	WELL #1	A				

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0920094	CAMP WORKCOEMAN - DINING HALL			NC	25	P	GW	
Local Address (where applicable)			Service	Residential	Commercial	Industrial	Combined	Agricultural
WEST HILL ROAD			Connections		6			
Towns Served: NEW HARTFORD								

### Contact Information

Name				Organization			Job Title		
Mr. Mark D Switzer				Conn. Rivers Council Bsa			Scout Executive/Ceo		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
State House Square			50 State Street 5Th Floor			Hartford		CT	06103
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
860-913-2710						425-205-5151	MarkDouglas.Switzer@scouting.org		

Contact Role(s): **Administrative Contact, Legal Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

**<http://www.ct.gov/dph/publicdrinkingwater>**

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0920104	TOWN OF NEW HARTFORD - BROWN'S CORNER			NC	200	L	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
812 STEELE ROAD					3			
Towns Served: NEW HARTFORD								

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Total Coliform (3100)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		

Physical Parameters (PPS)		1 routine (RT) per month	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2022	
CROSS CONNECTION SURVEY REPORT	3/1/2023	
CROSS CONNECTION SURVEY REPORT	3/1/2024	
CROSS CONNECTION SURVEY REPORT	3/1/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2026	

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0920104	TOWN OF NEW HARTFORD - BROWN'S CORNER			NC	200	L	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
812 STEELE ROAD					3			
Towns Served: NEW HARTFORD								

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
21617	WELL	2	WELL	A				

### Contact Information

Name		Organization			Job Title		
Mr. Daniel V. Jerram		Town of New Hartford			First Selectman		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
530 Main Street		P.O. Box 316			New Hartford	CT	06057
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-379-3389		860-379-0940		860-480-1377	djerram@town.new-hartford.ct.us		

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source		
CT0920124	SKI SUNDOWN, INC.	NC	600	P	GW		
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
126 RATLUM ROAD				4			
Towns Served: NEW HARTFORD							

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)

1 routine (RT) per quarter

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Physical Parameters (PPS)

1 routine (RT) per quarter

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)

1 routine (RT) per year

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT LEAD SERVICE LINE INVENTORY	10/16/2024	
COMPLETE INITIAL LSL INVENTORY	10/16/2024	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
21619	WELL	2	WELL	A				

Contact Information

Name		Organization		Job Title	
Mr. Robert Switzgable		Ski Sundown		President	
Mailing Address Line One		Mailing Address Line Two		City	State
PO Box 208				New Hartford	CT
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Schedule Generation Date: 12/12/2025

Page 17

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name				Classification	Population	Owner Type	Primary Source	
CT0920124	SKI SUNDOWN, INC.				NC	600	P	GW	
Local Address (where applicable)				Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
126 RATLUM ROAD						4			
Towns Served: NEW HARTFORD									
860-379-7669		220		860-379-1853		860-379-2840		Bob@skisundown.com	
Contact Role(s):	Administrative Contact, Legal Contact, Owner								

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

**<http://www.ct.gov/dph/publicdrinkingwater>**

***End of schedule***

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0920144	TRINITA			NC	30	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
595 TOWN HILL ROAD					6			
Towns Served: NEW HARTFORD								

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Total Coliform (3100)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Physical Parameters (PPS)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2027	

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
21621	WELL	2	WELL	A				

### Contact Information

Name			Organization			Job Title		
Mr. Sr John Christopher Langford			M.S.B.T.			General Treasurer		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
3501 Solly Avenue						Philadelphia	PA	19136
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
215-335-7502		215-335-7580		215-335-7500	JLANGF422@AOL.COM			

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT0920144</b>	<b>TRINITA</b>	<b>NC</b>	<b>30</b>	<b>P</b>	<b>GW</b>
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
595 TOWN HILL ROAD			6		
Towns Served: NEW HARTFORD					
Contact Role(s): <b>Legal Contact, Owner</b>					
Name		Organization		Job Title	
<b>Mr. Deborah Wilson</b>		Msbtt		Team Member	
Mailing Address Line One		Mailing Address Line Two		City	State
595 Town Hill Road				New Hartford	CT
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
860-379-4329		860-379-4329		860-738-0337	trinita@charter.net
Contact Role(s): <b>Administrative Contact</b>					

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

**<http://www.ct.gov/dph/publicdrinkingwater>**

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0920154	WEST HILL BEACH CLUB, INC.			NC	33	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
730 WEST HILL ROAD				2	2			
Towns Served: NEW HARTFORD								

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Total Coliform (3100)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		

Physical Parameters (PPS)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Water System Facility: **WELL (WSF ID: 21622)**

E. Coli (3014)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL (2)	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSSTREAM	WITHIN 5 SERVICE CON	A				
		GH1	GRAY HOUSE MASTER BA	A	Y			
		GH2	GRAY HOUSE HALF BATH	A	Y			
		UPSTREAM	WITHIN 5 SERVICE CON	A				
		WH1	WHITE HOUSE BATH	A	Y			
		WHBC1	CLUB HOUSE KITCHEN	A	Y			
00700	ENTRY POINT	3	ENTRY POINT	A				

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0920154	WEST HILL BEACH CLUB, INC.			NC	33	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
730 WEST HILL ROAD				2	2			
Towns Served: NEW HARTFORD								

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
21622	WELL	2	WELL	A				
63302	TREATMENT PLANT							

### Contact Information

Name				Organization		Job Title		
Mr. Mark K. Stoffer				West Hill Beach Club		Building & Grounds		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
P.O. Box 68			130 Town Hill Road			New Hartford	CT	06057
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
860-593-0645					mkstoffer@gmail.com			

Contact Role(s): **Administrative Contact, Legal Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

***End of schedule***

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0920284	CAMP WORKCOEMAN - CAMPSITE			NC	25	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
WEST HILL ROAD				1				
Towns Served: NEW HARTFORD								

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Total Coliform (3100)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Physical Parameters (PPS)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SAMPLING SITE PLAN	3/21/2025	

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		CWBPLAT	BADEN POWELL LATRINE	A	Y			
		CWCAMPCWS	CAMPCRAFT WASH STAND	A	Y			
		CWKAHLAT	KAHAGON LATRINE	A	Y			
		CWMAINSHR	MAIN SHOWER BLDG	A	Y			
		CWOUTPOST	OUTPOST LATRINE	A	Y			
		CWSETON	SETON LATRINE	A	Y			
		CWSMCABIN	SCOUTMASTERS CABIN	A	Y			
		CWTEEPEE	TEEPEE LATRINE	A	Y			
		CWTRADING	TRADING POST SINK	A	Y			
		CWTUNXLAT	TUNXIS LATRINE	A	Y			

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0920284	CAMP WORKCOEMAN - CAMPSITE			NC	25	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
WEST HILL ROAD				1				
Towns Served: NEW HARTFORD								

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		CWVISITOR	VISITORS LATRINE	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
48806	WELL # 2	2	WELL # 2	A				
61897	ATMOSPHERIC STORAGE TANKS							

### Contact Information

Name				Organization		Job Title		
Mr. Mark D Switzer				Conn. Rivers Council Bsa		Scout Executive/Ceo		
Mailing Address Line One			Mailing Address Line Two			City	State	Zip Code
State House Square			50 State Street 5Th Floor			Hartford	CT	06103
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address	
860-913-2710						425-205-5151	MarkDouglas.Switzer@scouting.org	
Contact Role(s):		Administrative Contact, Legal Contact						

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

**<http://www.ct.gov/dph/publicdrinkingwater>**

**End of schedule**

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0920294	CAMP WORKCOEMAN - BAILEY	NC	25	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
WEST HILL ROAD		1			
Towns Served: NEW HARTFORD					

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Total Coliform (3100)

1 routine (RT) per quarter

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Physical Parameters (PPS)

1 routine (RT) per quarter

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: ENTRY PIONT (WSF ID: 00700)

Nitrate And Nitrite (NOX)

1 routine (RT) per year

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SAMPLING SITE PLAN	3/21/2025	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		CWBAILDBS	DOWNSTAIRS BATH SINK	A	Y			
		CWBAILUBS	UPSTAIRS BATH SINK	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY PIONT	3	ENTRY POINT	A				
48818	WELL # 3	2	WELL # 3	A				

Contact Information

Name	Organization	Job Title
Mr. Mark D Switzer	Conn. Rivers Council Bsa	Scout Executive/Ceo
Mailing Address Line One	Mailing Address Line Two	City
State House Square	50 State Street 5Th Floor	Hartford
		State
		Zip Code
		CT
		06103

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Schedule Generation Date: 12/12/2025

Page 25

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT0920294</b>	<b>CAMP WORKCOEMAN - BAILEY</b>	<b>NC</b>	<b>25</b>	<b>P</b>	<b>GW</b>
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
WEST HILL ROAD		1			
Towns Served: NEW HARTFORD					
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
860-913-2710				425-205-5151	MarkDouglas.Switzer@scouting.org
Contact Role(s): <b>Administrative Contact, Legal Contact</b>					
<p><b>Please note the following:</b></p> <ol style="list-style-type: none"> <li>1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.</li> <li>2. If a Collection Period is specified, all water quality samples must be collected during the specified period.</li> <li>3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.</li> </ol>					

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

**<http://www.ct.gov/dph/publicdrinkingwater>**

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0925014	BERKSHIRE HALL AT BRODIE PARK			NC	28	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
580 WEST HILL ROAD						6	
Towns Served: NEW HARTFORD							

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Physical Parameters (PPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

### Public Notification Requirements

<i>Violation/Situation</i>	<i>Compliance Period</i>	<i>Notice Tier</i>	<i>Public Notification</i>		<i>PN Certification</i>	
			<i>Required</i>	<i>Performed</i>	<i>Due to DPH</i>	<i>Received</i>
Total Coliform M&R Violation	4/1/11 - 6/30/11	2	10/19/2011		10/29/2011	
Physical Parameters M&R Violation	4/1/11 - 6/30/11	3	9/18/2012		9/28/2012	
Total Coliform M&R Violation	1/1/14 - 3/31/14	3	6/26/2014		7/6/2014	
Physical Parameters M&R Violation	1/1/14 - 3/31/14	3	5/27/2015		6/6/2015	

### Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
57701	WELL 1	2	WELL 1	A				

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0925014	BERKSHIRE HALL AT BRODIE PARK			NC	28	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
580 WEST HILL ROAD						6	
Towns Served: NEW HARTFORD							

### Contact Information

Name				Organization		Job Title	
<b>Mr. Daniel V. Jerram</b>				Town of New Hartford		First Selectman	
Mailing Address Line One			Mailing Address Line Two		City	State	Zip Code
530 Main Street			P.O. Box 316		New Hartford	CT	06057
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
860-379-3389		860-379-0940		860-480-1377	djerram@town.new-hartford.ct.us		

Contact Role(s): **Administrative Contact, Legal Contact**

Name				Organization		Job Title	
<b>Town of New Hartford</b>							
Mailing Address Line One			Mailing Address Line Two		City	State	Zip Code
580 Main St					New Hartford	CT	06057
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		

Contact Role(s): **Owner**

#### Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

***End of schedule***

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0920304	CAMP SEQUASSEN (SOUTH SHOWER - WELL #6)			NC	25	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
791 WEST HILL ROAD					1			
Towns Served: NEW HARTFORD								

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

**Total Coliform (3100)** **1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

**Total Coliform (3100)** **1 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete

**Total Coliform (3100)** **3 repeat (RP) per period**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/23/25 - 7/28/25		Complete

**Physical Parameters (PPS)** **1 routine (RT) per quarter**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

**Physical Parameters (PPS)** **1 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

**Nitrate And Nitrite (NOX)** **1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Water System Facility: **WELL #6 (WSF ID: 62519)**

**E. Coli (3014)** **1 triggered (TG) per period**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL #6 (2)	7/22/25 - 7/28/25		Complete

### Water System Facility and Sampling Point Inventory

<i>Water System Facility ID</i>	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A				
		DOWNSTREAM	WITHIN 5 SERVICE CON	A	Y			

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0920304	CAMP SEQUASSEN (SOUTH SHOWER - WELL #6)			NC	25	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
791 WEST HILL ROAD					1			
Towns Served: NEW HARTFORD								

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
		UPSTREAM	WITHIN 5 SERVICE CON	A	Y			
00700	ENTRY POINT	3	ENTRY POINT	A				
62519	WELL #6	2	WELL #6	A				

### Contact Information

Name	Organization			Job Title		
Mr. David J. Boyajian	Boy Scouts of America			Ranger		
Mailing Address Line One	Mailing Address Line Two			City	State	Zip Code
791 West Hill Road				New Hartford	CT	06057
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
860-379-2009		860-379-8977			rangerdave.seq@gmail.com	

Contact Role(s): **Administrative Contact, Legal Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0925024	DOLLAR GENERAL - NEW HARTFORD			NC	25	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
173A MAIN ST					1			
Towns Served: NEW HARTFORD								

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Total Coliform (3100)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Physical Parameters (PPS)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Nitrate And Nitrite (NOX)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A				
		DOWNSTREAM	WITHIN 5 SERVICE CON	A	Y			
		UPSTREAM	WITHIN 5 SERVICE CON	A	Y			
00700	ENTRY POINT	3	ENTRY POINT	A				
62602	WELL1	2	WELL1	A				
62606	TREATMENT PLANT							
62608	PRESSURE TANK							

### Contact Information

Name				Organization			Job Title		
Mr. Gary Eucalitto									
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
PO Box 748						Torrington		CT	06790
Business Phone		Extension	Fax	Mobile Phone		Emergency Phone	Email Address		
860-307-5479							eucalittogary@gmail.com		
Contact Role(s):		Administrative Contact, Owner							

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT0925024	DOLLAR GENERAL - NEW HARTFORD			NC	25	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
173A MAIN ST					1			
Towns Served: NEW HARTFORD								

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

***End of schedule***