

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0920072	FOOTHILLS SHOPPING PLAZA	NTNC	60	P	GW
Local Address (where applicable)	141 MAIN STREET, ROUTE 44	Service Connections	Residential	Commercial	Industrial
			8	Combined	Agricultural

Towns Served: NEW HARTFORD

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
<b>Total Coliform (3100)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
<b>Lead And Copper (PBCU)</b>	<b>5 routine (RT) per six months</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 12/31/25		Complete
	1/1/26 - 6/30/26		
	7/1/26 - 12/31/26		
<b>Physical Parameters (PPS)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: **ENTRY POINT** (WSF ID: 00700)

<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
<b>Pesticides, Herbicides and PCBs-Phase II (SOC2)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Pesticides, Herbicides and PCBs-Phase V (SOC5)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0920072	FOOTHILLS SHOPPING PLAZA	NTNC	60	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
141 MAIN STREET, ROUTE 44	Connections		8		

Towns Served: NEW HARTFORD

### Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Organic Chemicals (VOCS)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	ENTRY POINT (3)	1/1/25 - 12/31/27		1 routine (RT) per three years

### Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit		Samples Req/Month
		Minimum:	7 PH	
pH	Entry Point pH Monitoring (PHRD)			4
Start Date:	12/1/2015	Compliance History:	Operating Limit	Monitoring
		Monitoring Period	Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
RESPOND TO SANITARY SURVEY	9/28/2024	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	3/31/2026	
CROSS CONNECTION EXEMPTION	3/1/2027	

### Public Notification Requirements

Violation/Situation	Compliance Period	Notice Tier	Public Notification		PN Certification	
			Required	Performed	Due to DPH	Received
Physical Parameters M&R Violation	10/1/24 - 12/31/24	3	2/10/2026		2/20/2026	
Total Coliform M&R Violation	10/1/24 - 12/31/24	3	2/10/2026		2/20/2026	

### Water System Facility and Sampling Point Inventory

Water System Facility Facility ID	Sampling Point ID	Sampling Point Description	Total		Lead and		Stage
			Status	Coliform Rule	Copper Rule Tier	Asbestos	
00600 DISTRIBUION SYSTEM	4	DISTRIBUION SYSTEM	A	Y			
	DOWNSTREAM	WITHIN 5 SERVICE CON	A				
	FOOTH001	MEAT ROOM SINK	A	Y	2		
	FOOTH002	BAKERY SINK	A	Y	2		
	FOOTH003	SEAFOOD SINK	A	Y	2		
	FOOTH004	MARKET BATHROOM	A	Y	2		
	FOOTH005	SUBWAY SINK SOUTH EN	A	Y	2		
	FOOTH006	ATHENAS SINK NORTH E	A	Y	2		
	FOOTH007	PACKAGE STORE SINK	A	Y	2		
	FOOTH008	NORTH EAST HYDRANT	A	Y			
	FOOTH009	DELI SINK	A	Y	2		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0920072	FOOTHILLS SHOPPING PLAZA	NTNC	60	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
141 MAIN STREET, ROUTE 44			8		

Towns Served: NEW HARTFORD

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule	Asbestos	Stage WQP 2 DBPR
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
10442	WELL	2	WELL	A				
59901	TREATMENT PLANT							

## Certified Operator Information

Water System Facility: TREATMENT PLANT (WSF ID: 59901)

Facility Classification: CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
COSSETTE, EVAN J	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR IN TRAINING	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	9/30/2027

## Contact Information

Name	Organization	Job Title		
Mr. Michael Fernandez		Owner		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
141 Main St		New Hartford	CT	06057
Business Phone	Extension	Fax	Mobile Phone	Email Address
860-693-8369		860-605-0173	516-426-2242	mikfernandez55@gmail.com

Contact Role(s): Administrative Contact, Legal Contact, Owner

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0920242	BAKERVILLE CONSOLIDATED SCHOOL	NTNC	177	L	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
51 CEDAR LANE		1			

Towns Served: NEW HARTFORD

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
<b>Total Coliform (3100)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
<b>Lead And Copper (PBCU)</b>	<b>5 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/25	6/1-9/30	Complete
	1/1/26 - 12/31/28	6/1-9/30	
	1/1/29 - 12/31/31	6/1-9/30	
<b>Physical Parameters (PPS)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: **ENTRY POINT** (WSF ID: 00700)

<b>Nitrate (1040)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
<b>Nitrite (1041)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0920242	BAKERVILLE CONSOLIDATED SCHOOL	NTNC	177	L	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
51 CEDAR LANE		1			

Towns Served: NEW HARTFORD

### Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Organic Chemicals (VOCS)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2026	

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	WQP 2 DBPR	Stage
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y				
		BAKER001	KITCHEN	A	Y	2		Y	
		BAKER002	NURSES RM HAND SINK	A	Y	2			
		BAKER003	NURSES RM BATHROOM	A	Y	2			
		BAKER004	GIRLS BR OFFICE AREA	A	Y	2			
		BAKER005	BOYS BR OFFICE AREA	A	Y	2			
		BAKER006	KINDER.#5 HAND SINK	A	Y	2			
		BAKER007	KINDER.#5 HAND BR	A	Y	2			
		BAKER008	ART RM	A	Y	2			
		BAKER009	GIRLS BR 1ST GRADE	A	Y	2			
		BAKER010	BOYS BR 1ST GRADE	A	Y	2			
		BAKER011	KINGERGARTEN #4	A	Y	2			
		BAKER012	CLASSROOM #7	A	Y	2			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A					
		UPSTREAM	WITHIN 5 SERVICE CON	A					
00700	ENTRY POINT	3	ENTRY POINT	A					
10443	WELL #1	2	WELL #1	A					
52458	WELL #2	2	WELL #2	A					
52460	ATMOSPHERIC TANK								
54577	BOOSTER PUMP STATION								

### Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
---------------	---------------	------------------	--------------------------

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0920242	BAKERVILLE CONSOLIDATED SCHOOL	NTNC	177	L	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
51 CEDAR LANE		1			

Towns Served: NEW HARTFORD

## Certified Operator Information

BLACK, RON W.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2026 6/30/2026
CROWNSHAW, MICHAEL L	ASSIGNED OPERATOR	SMALL WATER SYSTEM OPERATOR	3/31/2028

## Contact Information

Name	Organization	Job Title		
Mr. Jeffrey Sousa	New Hartford Public Schools	Superintendent		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
PO Box 315	530 Main Street	New Hartford	CT	06057
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone
860-379-8546				
				Email Address sousaj@newhtfd.org

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

***End of schedule***

***NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.***

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0920252	ANTOLINI ELEMENTARY SCHOOL	NTNC	385	L	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
30 ANTOLINI ROAD	Connections	1			

Towns Served: NEW HARTFORD

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
<b>Total Coliform (3100)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
<b>Lead And Copper (PBCU)</b>	<b>5 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Physical Parameters (PPS)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: **ENTRY POINT** (WSF ID: 00700)

<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
ENTRY POINT (3)	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
<b>Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0920252	ANTOLINI ELEMENTARY SCHOOL	NTNC	385	L	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
30 ANTOLINI ROAD	Connections	1			

Towns Served: NEW HARTFORD

**Monitoring Requirements**

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Organic Chemicals (VOCS)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	1/1/29 - 12/31/31		

**Other Compliance Schedules**

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2026	

**Water System Facility and Sampling Point Inventory**

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	WQP 2 DBPR	Stage
					Rule				
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y	2			
		ANT001	NURSES ROOM	A	Y	2			
		ANT002	KIT HAND WASH SINK	A	Y	2			
		ANT003	ART ROOM RM 41	A	Y	2			
		ANT004	BOYS ROOM EAST WING	A	Y	2			
		ANT005	BOYS ROOM WEST WING	A	Y	N		Y	
		ANT006	ROOM 4	A	Y	2			
		ANT007	ROOM 3	A	Y	2			
		ANT008	ROOM 6	A	Y	2			
		ANT009	ROOM 5	A	Y	2			
		ANT010	ROOM 8	A	Y	2			
		ANT011	ROOM 7	A	Y	2			
		ANT012	ROOM 10	A	Y	N			
		ANT013	ROOM 9	A	Y	N			
		ANT014	ROOM 11	A	Y	N			
		ANT015	ROOM 12	A	Y	N			
		ANT016	ROOM 13	A	Y	N			
		ANT017	ROOM 14	A	Y	N			
		ANT018	ROOM 15	A	Y	2			
		ANT019	ROOM 17	A	Y	2			
		ANT020	ROOM 16	A	Y	2			
		ANT021	ROOM 19	A	Y	2			
		ANT022	ROOM 18	A	Y	2			
		ANT023	ROOM 21	A	Y	2			
		ANT024	ROOM 20	A	Y	2			
		ANT025	ROOM 23	A	Y	N			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A					
		UPSTREAM	WITHIN 5 SERVICE CON	A					
00700	ENTRY POINT	3	ENTRY POINT	A					

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0920252	ANTOLINI ELEMENTARY SCHOOL	NTNC	385	L	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
30 ANTOLINI ROAD		1			

Towns Served: NEW HARTFORD

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule	Asbestos	Stage WQP 2 DBPR
					Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR	
10445	WELL 1	2	WELL 1	A				
51839	WELL 2	2	WELL 2	A				
51841	ATMOSPHERIC TANK							
54651	TRANSFER PUMP STATION							

## Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

Facility Classification:	Facility ID	Operator Name	Operator Type	Certification(s)	Certification Expiration
SMALL WATER SYSTEM		BLACK, RON W.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2026 6/30/2026
		CROWNSHAW, MICHAEL L	ASSIGNED OPERATOR	SMALL WATER SYSTEM OPERATOR	3/31/2028

## Contact Information

Name	Organization	Job Title		
Mr. Dan Jerram	Town of New Hartford	First Selectman		
Mailing Address Line One 530 Main St	Mailing Address Line Two P.O. Box 316	City New Hartford	State CT	Zip Code 06057
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone
				Email Address

Contact Role(s): **Owner**

Name	Organization	Job Title		
Mr. Jeffrey Sousa	New Hartford Public Schools	Superintendent		
Mailing Address Line One PO Box 315	Mailing Address Line Two 530 Main Street	City New Hartford	State CT	Zip Code 06057
Business Phone 860-379-8546	Extension	Fax	Mobile Phone	Emergency Phone
				Email Address sousaj@newhtfd.org

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

**If you have any questions, please contact the Drinking Water Section at (860) 509-7333.**

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

**NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.**