

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0950011	NEW LONDON DEPT. OF PUBLIC UTILITIES	C	27,620	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		5,112	1,336	10	569

Towns Served: NEW LONDON, WATERFORD

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

Chlorine Residual (1012)	30 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
Chlorine Residual (1012)	31 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	12/1/25 - 12/31/25		Complete
Asbestos (1094)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
67 LONGVIEW ST (NLDPU022A)	1/1/21 - 12/31/29		
Total Coliform (3100)	30 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
Disinfectant Byproducts - TTHM & HAA5 (DBP)	4 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
PEQUOT HOSE CO (NLDPU002)	7/1/25 - 9/30/25	7/1-7/31	Complete
	10/1/25 - 12/31/25	10/1-10/31	Complete
	1/1/26 - 3/31/26	1/1-1/31	
	4/1/26 - 6/30/26	4/1-4/30	
FIRE HQ BANK STREET (NLDPU003)	7/1/25 - 9/30/25	7/1-7/31	Complete
	10/1/25 - 12/31/25	10/1-10/31	Complete
	1/1/26 - 3/31/26	1/1-1/31	
	4/1/26 - 6/30/26	4/1-4/30	
CONN COLLEGE (NLDPU004)	7/1/25 - 9/30/25	7/1-7/31	Complete
	10/1/25 - 12/31/25	10/1-10/31	Complete
	1/1/26 - 3/31/26	1/1-1/31	
	4/1/26 - 6/30/26	4/1-4/30	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0950011	NEW LONDON DEPT. OF PUBLIC UTILITIES	C	27,620	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		5,112	1,336	10	569

Towns Served: NEW LONDON, WATERFORD

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Disinfectant Byproducts - TTHM & HAA5 (DBP)			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
GAM OCEAN BEACH (NLDP050X)	7/1/25 - 9/30/25	7/1-7/31	Complete
	10/1/25 - 12/31/25	10/1-10/31	Complete
	1/1/26 - 3/31/26	1/1-1/31	
	4/1/26 - 6/30/26	4/1-4/30	
Lead And Copper (PBCU)			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/26	6/1-9/30	
	1/1/27 - 12/31/29	6/1-9/30	
Physical Parameters (PPS)			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: LAKE KONOMOC WTP ENTRY POINT (WSF ID: 00701)

Net Gross Alpha (4000)			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - LAKE KONOMOC TP (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Uranium (4006)			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - LAKE KONOMOC TP (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Combined Radium-226/228 (4010)			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - LAKE KONOMOC TP (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0950011	NEW LONDON DEPT. OF PUBLIC UTILITIES	C	27,620	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		5,112	1,336	10	569

Towns Served: NEW LONDON, WATERFORD

Monitoring Requirements

Water System Facility: LAKE KONOMOC WTP ENTRY POINT (WSF ID: 00701)

Inorganic Chemicals (IOCS)			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - LAKE KONOMOC TP (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
Nitrate And Nitrite (NOX)			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - LAKE KONOMOC TP (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - LAKE KONOMOC TP (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Organic Chemicals (VOCS)			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - LAKE KONOMOC TP (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Water System Facility: LAKE KONOMOC WATER TREATMENT PLANT (WSF ID: 199)

Total Organic Carbon (2920)			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
CFE- LAKE KONOMOC TP (5)	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: LAKE KONOMOC RESERVOIR (WSF ID: 2162)

Total Alkalinity (1927)			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
LAKE KONOMOC RESERVOIR (1)	8/1/25 - 8/31/25		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0950011	NEW LONDON DEPT. OF PUBLIC UTILITIES	C	27,620	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		5,112	1,336	10	569

Towns Served: NEW LONDON, WATERFORD

Monitoring Requirements

Water System Facility: LAKE KONOMOC RESERVOIR (WSF ID: 2162)

Total Alkalinity (1927)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
Total Organic Carbon (2920)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
LAKE KONOMOC RESERVOIR (1)	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
Total Coliform (3100)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
LAKE KONOMOC RESERVOIR (1)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
Surface Water Inorganic Chemicals (RIOC)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
LAKE KONOMOC RESERVOIR (1)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
Surface Water Color and Turbidity (RPPS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0950011	NEW LONDON DEPT. OF PUBLIC UTILITIES	C	27,620	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
	5,112	1,336	10	569	

Towns Served: NEW LONDON, WATERFORD

Monitoring Requirements

Water System Facility: LAKE KONOMOC RESERVOIR (WSF ID: 2162)

Surface Water Color and Turbidity (RPPS)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
LAKE KONOMOC RESERVOIR (1)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
Surface Water Pesticides (RSOC)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
LAKE KONOMOC RESERVOIR (1)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: LAKE KONOMOC WATER TREATMENT PLANT (WSFID: 199)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
Start Date: 10/1/2003			
		Compliance History:	Operating Limit
		Monitoring Period	Monitoring
		Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025	Y
		9/1/2025 - 9/30/2025	Y
		10/1/2025 - 10/31/2025	Y
		11/1/2025 - 11/30/2025	Y
		12/1/2025 - 12/31/2025	Y
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	<spaces> ()	Minimum: 0.55 MG/L	Daily
Start Date: 1/1/2023			
		Compliance History:	Operating Limit
		Monitoring Period	Monitoring
		Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 1/1/2023			
		Compliance History:	Operating Limit
		Monitoring Period	Monitoring
		Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025	Y
		9/1/2025 - 9/30/2025	Y
		10/1/2025 - 10/31/2025	Y
		11/1/2025 - 11/30/2025	Y

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT0950011	NEW LONDON DEPT. OF PUBLIC UTILITIES			C	27,620	L	SW
Local Address (where applicable)		Service	Residential	Commercial	Industrial	Combined	Agricultural
		Connections	5,112	1,336	10	569	

Towns Served: NEW LONDON, WATERFORD

Water System Facility: LAKE KONOMOC WATER TREATMENT PLANT (WSFID: 199)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 1/1/2023		Compliance History:	Operating Limit
		Monitoring Period	Monitoring
		12/1/2025 - 12/31/2025	Compliance Status: Y
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.4 PH	Daily
Start Date: 1/1/2005		Compliance History:	Operating Limit
		Monitoring Period	Monitoring
		8/1/2025 - 8/31/2025	Compliance Status:
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.2 MG/L	2
Start Date: 1/1/2005		Compliance History:	Operating Limit
		Monitoring Period	Monitoring
		8/1/2025 - 8/31/2025	Compliance Status:
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
Start Date: 10/1/2003		Compliance History:	Operating Limit
		Monitoring Period	Monitoring
		8/1/2025 - 8/31/2025	Compliance Status: Y
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
Start Date: 10/1/2003		Compliance History:	Operating Limit
		Monitoring Period	Monitoring
		8/1/2025 - 8/31/2025	Compliance Status: Y
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0950011	NEW LONDON DEPT. OF PUBLIC UTILITIES	C	27,620	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		5,112	1,336	10	569

Towns Served: NEW LONDON, WATERFORD

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2025	
MAIL/HAND DELIVER NOTICE TO CONSUMERS	12/31/2025	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	3/31/2026	
CERTIFY LEAD SL NOTIFICATION	7/1/2026	

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total	Lead and Coliform Rule	Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y				
		DOWNSTREAM	WITHIN 5 SERVICE CON	A					
		NLDPU001	NLWPC	A	Y				Y
		NLDPU002	PEQUOT HOSE CO	A	Y				Y
		NLDPU003	FIRE HQ BANK STREET	A	Y				Y
		NLDPU004	CONN COLLEGE	A	Y				Y
		NLDPU005	109 CRYSTAL AVE.	A	Y				
		NLDPU006	107 COLMAN ST.	A	Y				
		NLDPU007	LOMBARDI AUTO	A	Y				
		NLDPU008	L & M HOSPITAL	A	Y				
		NLDPU009	120 BROAD STREET	A	Y				
		NLDPU010	20 NAMEAUG ST	A	Y	N			Y
		NLDPU013	29 WEST ST.	A	Y	1			
		NLDPU014	41 WOODLAWN ROAD	A	Y	1			
		NLDPU015	298 CRYSTAL AVE.	I	Y	1			
		NLDPU016	552 OCEAN AVE.	A	Y	1			
		NLDPU017	46 SUMMIT AVE.	A	Y	1			
		NLDPU018	311 VAUXHALL ST. ALT	A	Y	1			
		NLDPU021	22 ADDISON ST.	A	Y	1			
		NLDPU022	150 ASHCRAFT RD.	I	Y	1	Y		
		NLDPU022A	67 LONGVIEW ST	A				Y	
		NLDPU023	34 CHAPEL DR.	I	Y	1			
		NLDPU024	278 CRYSTAL AVE.	I	Y	1			
		NLDPU025	12 FINCH AVE.	A	Y	1			
		NLDPU026	83 THAMES ST.	A	Y	1			
		NLDPU028	20 FINCH AVE.	A	Y	1			
		NLDPU029	113 RIVERVIEW AVE.	A	Y	1			
		NLDPU030	366 VAUXHALL ST.	I	Y	1			
		NLDPU033	959 PEQUOT AVE.	A	Y	1			
		NLDPU034	17 THAMES ST.	A	Y	1			
		NLDPU035	88 VAUXHALL ST.	I	Y	1			
		NLDPU040	310 VAUXHALL ST.	I	Y	1			

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0950011	NEW LONDON DEPT. OF PUBLIC UTILITIES	C	27,620	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
		5,112	1,336	10	569

Towns Served: NEW LONDON, WATERFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
					Y	1	N	Y
	NLDPU041	200 LEDYARD ST.		I	Y	1		
	NLDPU042	95 THAMES ST.		A	Y	1		
	NLDPU043	273 OCEAN AVE.		A	Y	1		
	NLDPU044	123 VAUXHALL ST.		A	Y	1		
	NLDPU045	US COAST GUARD		A	Y	N		
	NLDPU046	20 PENNY LN		A	Y	1		
	NLDPU047	22 PENNY LN		A	Y	1		
	NLDPU048	25 PENNY LN		A	Y	1		
	NLDPU049	611 OCEAN AVE B2		A	Y	1		
	NLDPU050	WOW OCEAN BEACH		I				Y
	NLDPU050X	GAM OCEAN BEACH		A				Y
	NLDPU051	226 THAMES ST		A	Y	1		
	NLDPU052	19 STARR ST		A	Y	1		
	NLDPU053	11 WALDEN AVE		A	Y	1		
	NLDPU054	30 GORTON ST		A	Y	1		
	NLDPU055	91 BLINMAN ST		A	Y	1		
	NLDPU056	999 BANK ST		A	Y	1		
	NLDPU057	38 GLENWOOD AVE		A	Y	1		
	NLDPU058	1182 OCEAN AVE		A	Y	1		
	NLDPU059	30 DARROW ST		A	Y	1		
	NLDPU060	32 HARRIS RD		A	Y	1		
	NLDPU061	611 OCEAN AVE A2		A	Y	1		
	NLDPU062	501 BAYONET ST		A	Y	1		
	NLDPU063	40 CENTER ST		A	Y	1		
	NLDPU064	32 CAPE ANN CT		A	Y	1		
	NLDPU065	80 BECKWITH ST		A	Y	1		
	NLDPU066	999 BANK ST		A	Y	1		
	NLDPU067	68 FEDERAL ST		A	Y	1		
	NLDPU068	36 BELDEN ST		A	Y	1		Y
	NLDPU069	171 LOWER BLVD		A	Y	1		
	NLDPU070	320 CONNECTICUT AVE		A	Y	1		
	NLDPU071	557 MONTAUK AVE		A	Y	1		
	NLDPU072	767 MONTAUK AVE		A	Y	1		
	NLDPU073	44 THAMES ST		A	Y	1		
	NLDPU074	298 VAUXHALL ST		A	Y	1		
	NLDPU075	52 SHERMAN ST		A	Y	1		
	NLDPU076	95 COLMAN ST		A	Y	1		
	NLDPU077	18 FARMINGTON AVE		A	Y	1		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0950011	NEW LONDON DEPT. OF PUBLIC UTILITIES	C	27,620	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		5,112	1,336	10	569

Towns Served: NEW LONDON, WATERFORD

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total	Lead and Coliform	Copper Rule	Asbestos Rule Tier	Stage WQP 2	DBPR
	UPSTREAM	WITHIN 5 SERVICE CON		A						
00701	LAKE KONOMOC WTP ENTRY POINT	3	EP - LAKE KONOMOC TP	A						
199	LAKE KONOMOC WATER TREATMENT PLANT	5	CFE- LAKE KONOMOC TP	A						
2162	LAKE KONOMOC RESERVOIR	1	LAKE KONOMOC RESERVO	A						
2163	BARNES RESERVOIR	1	RESERVOIR	A						
2164	BOGUE BROOK RESERVOIR	1	RESERVOIR	A						
2165	FAIRY LAKE RESERVOIR	1	RESERVOIR	A						
2166	BECKWITH POND	1	RESERVOIR	A						
2167	GREAT SWAMP DIVERSION	1	RESERVOIR	A						
2169	HUNTS BROOK DIVERSION	1	RESERVOIR	A						
30065	GREAT SWAMP DIVERSION									
30070	LAKE KONOMOC INTAKE									
49682	WILLIAMS STREET PUMP STATION									
53892	LAKE KONOMOC WTP CLEARWELL									
53894	BECKWITH POND RAW WATER PUMP STATION									
53896	TREMONT STREET STORAGE TANK									
53898	MANATUCK HILL STORAGE TANK									
53902	LAKE KONOMOC WTP PUMP STATION									
53904	LAKE KONOMOC WTP RAW WATER PUMP STATION									
54140	GREAT SWAMP DIVERSION PUMP STATION									
58948	INTERCONNECTION - CT0450011 - EAST LYME									
61782	CT COLLEGE HYDRO TANK									
61805	BECKWITH ROAD PUMP STATION									
61807	INDUSTRIAL DRIVE PUMP STATION									
61809	DAYTON PLACE PUMP STATION									

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT0950011	NEW LONDON DEPT. OF PUBLIC UTILITIES	C	27,620	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		5,112	1,336	10	569

Towns Served: NEW LONDON, WATERFORD

Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: CLASS 2 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
BROWNE, KEITH T	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I WATER TREATMENT PLANT OPERATOR - CLASS III	3/31/2027 3/31/2027

Water System Facility: **LAKE KONOMOC WATER TREATMENT PLANT (WSF ID: 199)**

Facility Classification: CLASS 3 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
BROWNE, KEITH T	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I WATER TREATMENT PLANT OPERATOR - CLASS III	3/31/2027 3/31/2027
MCVICKER, JONATHAN	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2026 3/31/2026

Contact Information

Name	Organization	Job Title
Mr. Thomas Londregan	City of New London	City Attorney
Mailing Address Line One	Mailing Address Line Two	City
38 Huntington Street		State Zip Code
Business Phone	Extension	Fax
860-447-3171		
Mobile Phone		Emergency Phone
		Email Address

Contact Role(s): **Legal Contact**

Name	Organization	Job Title
Mr. Michael Passero	City of New London	Mayor
Mailing Address Line One	Mailing Address Line Two	City
181 State Street		State Zip Code
New London	CT	06230
Business Phone	Extension	Fax
860-447-5201		860-447-7971
Mobile Phone		Emergency Phone
		860-625-7516
Email Address		mpassero@newlondonct.org

Contact Role(s): **Owner**

Name	Organization	Job Title
Mr. Derek N Palmerone	Veolia Water	Water Treatment Mng
Mailing Address Line One	Mailing Address Line Two	City
1153 Hartford Turnpike		State Zip Code
Waterford	CT	05385
Business Phone	Extension	Fax
860-405-6475		
Mobile Phone		Emergency Phone
		860-405-6475
Email Address		derek.palmerone@veolia.com

Contact Role(s): **Administrative Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.