

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180011	AQUARION-RIDGEFIELD	C	7,476	P	SWP
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural

Towns Served: RIDGEFIELD

## Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

<b>Chlorine Residual (1012)</b>	<b>10 routine (RT) per month</b>		
<b>Sampling Point (Sampling Point ID)</b>	<b>Monitoring Period</b> <b>Collection Period</b> <b>Compliance Status</b>		
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
<b>Chlorine Residual (1012)</b>	<b>13 routine (RT) per month</b>		
<b>Sampling Point (Sampling Point ID)</b>	<b>Monitoring Period</b> <b>Collection Period</b> <b>Compliance Status</b>		
Select from Inventory of Active Sampling Points	10/1/25 - 10/31/25		Complete
<b>Asbestos (1094)</b>	<b>3 routine (RT) per nine years</b>		
<b>Sampling Point (Sampling Point ID)</b>	<b>Monitoring Period</b> <b>Collection Period</b> <b>Compliance Status</b>		
PUMPING STATION RD (02616)	1/1/20 - 12/31/28		
NORTH ST SS (02626)	1/1/20 - 12/31/28		
FARMINGVLILE RD SS (02646)	1/1/20 - 12/31/28		
<b>Total Coliform (3100)</b>	<b>10 routine (RT) per month</b>		
<b>Sampling Point (Sampling Point ID)</b>	<b>Monitoring Period</b> <b>Collection Period</b> <b>Compliance Status</b>		
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
<b>Total Coliform (3100)</b>	<b>3 repeat (RP) per period</b>		
<b>Sampling Point (Sampling Point ID)</b>	<b>Monitoring Period</b> <b>Collection Period</b> <b>Compliance Status</b>		
Select from Inventory of Active Sampling Points	10/10/25 - 10/15/25		Complete
<b>Disinfectant Byproducts - TTHM &amp; HAAs (DBP)</b>	<b>2 routine (RT) per quarter</b>		
<b>Sampling Point (Sampling Point ID)</b>	<b>Monitoring Period</b> <b>Collection Period</b> <b>Compliance Status</b>		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180011	AQUARION-RIDGEFIELD	C	7,476	P	SWP
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: RIDGEFIELD

### Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Disinfectant Byproducts - TTHM & HAA5 (DBP)			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
BRANCHVILLE PS RIDGE (02650)	7/1/25 - 9/30/25 10/1/25 - 12/31/25 1/1/26 - 3/31/26 4/1/26 - 6/30/26	9/1-9/30 12/1-12/31 3/1-3/31 6/1-6/30	Complete Complete Complete Complete
WEST LANE DELI (02663)	7/1/25 - 9/30/25 10/1/25 - 12/31/25 1/1/26 - 3/31/26 4/1/26 - 6/30/26	9/1-9/30 12/1-12/31 3/1-3/31 6/1-6/30	Complete Complete Complete Complete
Lead And Copper (PBCU)			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/25 1/1/26 - 12/31/26 1/1/27 - 12/31/27	6/1-9/30 6/1-9/30 6/1-9/30	Complete Complete Complete
Physical Parameters (PPS)			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25 9/1/25 - 9/30/25 10/1/25 - 10/31/25 11/1/25 - 11/30/25 12/1/25 - 12/31/25 1/1/26 - 1/31/26 2/1/26 - 2/28/26 3/1/26 - 3/31/26 4/1/26 - 4/30/26 5/1/26 - 5/31/26 6/1/26 - 6/30/26 7/1/26 - 7/31/26		Complete Complete Complete Complete Complete Complete Complete Complete Complete Complete Complete Complete Complete Complete Complete Complete

Water System Facility: OSCALETA WELLFIELD TP ENTRY POINT (WSF ID: 00700)

Net Gross Alpha (4000)			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - OSCALETA (3)	1/1/17 - 12/31/25		Complete
Uranium (4006)			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - OSCALETA (3)	1/1/17 - 12/31/25		Complete
Combined Radium-226/228 (4010)			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - OSCALETA (3)	1/1/17 - 12/31/25		Complete

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180011	AQUARION-RIDGEFIELD	C	7,476	P	SWP
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: RIDGEFIELD

**Monitoring Requirements**

Water System Facility: OSCALETA WELLFIELD TP ENTRY POINT (WSF ID: 00700)

<b>Inorganic Chemicals (IOCS)</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - OSCALETA (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		
<b>Nitrate And Nitrite (NOX)</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - OSCALETA (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
<b>Radionuclides - Gross Alpha, Combined Radium &amp; Uranium (RADA)</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - OSCALETA (3)	1/1/26 - 12/31/31		
<b>Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - OSCALETA (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Organic Chemicals (VOCS)</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - OSCALETA (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Water System Facility: NORTH STREET WELLFIELD TP ENTRY POINT (WSF ID: 00701)

<b>Inorganic Chemicals (IOCS)</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - NORTH STREET (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		
<b>Nitrate And Nitrite (NOX)</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - NORTH STREET (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
<b>Radionuclides - Gross Alpha, Combined Radium &amp; Uranium (RADA)</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - NORTH STREET (3)	1/1/20 - 12/31/25		Complete
	1/1/26 - 12/31/31		
<b>Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - NORTH STREET (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180011	AQUARIAN-RIDGEFIELD	C	7,476	P	SWP
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: RIDGEFIELD

**Monitoring Requirements**

Water System Facility: NORTH STREET WELLFIELD TP ENTRY POINT (WSF ID: 00701)

<b>Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)</b>	<b>2 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/29 - 12/31/31		
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - NORTH STREET (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Water System Facility: BEECHWOOD WELLFIELD TP ENTRY POINT (WSF ID: 00702)

<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - BEECHWOOD (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - BEECHWOOD (3)	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

<b>Radionuclides - Gross Alpha, Combined Radium &amp; Uranium (RADA)</b>	<b>1 routine (RT) per six years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - BEECHWOOD (3)	1/1/20 - 12/31/25		Complete

<b>Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)</b>	<b>2 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - BEECHWOOD (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT - BEECHWOOD (3)	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Water System Facility: OSCALETA WELL #1 (AKA CHURCH WELL) (WSF ID: 1224)

<b>E. Coli (3014)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
OSCALETA CHURCH (2)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180011	AQUARION-RIDGEFIELD	C	7,476	P	SWP
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural

Towns Served: RIDGEFIELD

### Monitoring Requirements

Water System Facility: OSCALETA CAISSON WELL(#4) (WSF ID: 877)

E. Coli (3014) 1 routine (RT) per quarter			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
OSCALETA CAISSON (2)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: OSCALETA WELL #2 (WSF ID: 878)

E. Coli (3014) 1 routine (RT) per quarter			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
OSCALETA WELL #2 (2)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: OSCALETA WELL #3 (WSF ID: 879)

E. Coli (3014) 1 routine (RT) per quarter			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
OSCALETA WELL #3 (2)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: BEECHWOOD WELL #2 (WSF ID: 902)

E. Coli (3014) 1 routine (RT) per quarter			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
BEECHWOOD WELL #2 (2)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: BEECHWOOD WELL #1 (WSF ID: 903)

E. Coli (3014) 1 routine (RT) per quarter			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
BEECHWOOD WELL #1 (2)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

### Monthly Water System Facility (WSF) Level Monitoring Requirements

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT1180011</b>	<b>AQUARION-RIDGEFIELD</b>	<b>C</b>	<b>7,476</b>	<b>P</b>	<b>SWP</b>
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural

Towns Served: RIDGEFIELD

Water System Facility: **OSCALETA WELLFIELD TP ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily	
<b>Start Date:</b> 7/1/2003		<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.2 PH	4	
<b>Start Date:</b> 7/1/2018		<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
pH	Entry Point pH Monitoring (PHRD)	Maximum: 7.8 PH	4	
<b>Start Date:</b> 7/1/2018		<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		

Water System Facility: **NORTH STREET WELLFIELD TP ENTRY POINT (WSFID: 00701)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily	
<b>Start Date:</b> 7/1/2003		<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180011	AQUARION-RIDGEFIELD	C	7,476	P	SWP
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural

Towns Served: RIDGEFIELD

Water System Facility: NORTH STREET WELLFIELD TP ENTRY POINT (WSFID: 00701)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: .25 UG/L	Continuous
<b>Start Date:</b> 1/1/2014			
	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025	Y	
	10/1/2025 - 10/31/2025	Y	
	11/1/2025 - 11/30/2025	Y	
	12/1/2025 - 12/31/2025	Y	
<b>Analyte</b>	<b>Monitoring Requirement (Summary Type)</b>	<b>Operating Limit</b>	<b>Samples Req/Month</b>
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L	2
<b>Start Date:</b> 7/1/2003			
	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		
	11/1/2025 - 11/30/2025		
	12/1/2025 - 12/31/2025		

Water System Facility: BEECHWOOD WELLFIELD TP ENTRY POINT (WSFID: 00702)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 7/1/2003			
	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		
	11/1/2025 - 11/30/2025		
	12/1/2025 - 12/31/2025		
<b>Analyte</b>	<b>Monitoring Requirement (Summary Type)</b>	<b>Operating Limit</b>	<b>Samples Req/Month</b>
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L	2
<b>Start Date:</b> 7/1/2003			
	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		
	11/1/2025 - 11/30/2025		
	12/1/2025 - 12/31/2025		

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
MAIL/HAND DELIVER NOTICE TO CONSUMERS	12/31/2025	
CROSS CONNECTION SURVEY REPORT		3/1/2026

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180011	AQUARION-RIDGEFIELD	C	7,476	P	SWP
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural

Towns Served: RIDGEFIELD

**Other Compliance Schedules**

Compliance Schedule Activity	Due Date	Achieved Date
CERTIFY LEAD SL NOTIFICATION	7/1/2026	

**Water System Facility and Sampling Point Inventory**

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	WQP 2	Stage DBPR
00600	DISTRIBUTION SYSTEM	02616	PUMPING STATION RD	A	Y			Y	
		02626	NORTH ST SS	A	Y			Y	
		02627	PAMBY MOTORS	I	Y				
		02628	RIDGEFIELD MOBIL 31	A	Y				
		02630	RIDGEFIELD SPORT	I	Y				
		02635	BOYS CLUB	I	Y				
		02636	BARLOW MOUNTAIN SS	A	Y				
		02646	FARMINGVLILE RD SS	A	Y			Y	
		02647	RIDGEFIELD STP	A	Y				
		02650	BRANCHVILLE PS RIDGE	A	Y				Y
		02659	MONTANARI OFFICE	A	Y				
		02661	PEACEABLE RIDGE SS	A	Y				
		02663	WEST LANE DELI	A	Y				Y
		02663D	WEST LANE DELI RFLD	A	Y				
		02663U	WEST LANE DELI RFLD	A	Y				
		02667	OSCALETA RD SS	A	Y				
		02667D	OSCALETA RD SS - DOW	A	Y				
		02667U	OSCALETA RD SS - UPS	A	Y				
		02680	LAURELWOOD MAINTEN	A	Y				
		02686	RIDGEFIELD CROSSINGS	A	Y				
		03409	RUSTIC DRIVE	I	Y				
		03410	CREST ROAD	I	Y				
		03411	18 HIGHVIEW ROAD	I	Y				
		03422	LIMESTONE TERRACE SS	A	Y				
		03442	MOUNTAIN RD SS	A	Y				
		03452	LAKE RD SS	A	Y				
		03464	RITA ROAD	A	Y				
		03484	CRAIGMOOR RD S SS	A	Y				
		03485	CRAIGMOOR RD N SS	A	Y				
		4	GENERIC DISTRIBUTION	A	Y				
		BP7236	236 BENNETT	A	Y		3		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A					
		PB1037	84 BLACKBERRY HL BF	A			3		
		PB5722	13 ROCHAMBEAU RDGFLD	A			1		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT1180011</b>	<b>AQUARION-RIDGEFIELD</b>	C	7,476	P	SWP
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					2,814

Towns Served: RIDGEFIELD

**Water System Facility and Sampling Point Inventory**

Water System Facility ID	Water System Facility	Sampling Point		Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	WQP 2	DBPR Stage
		ID	Description						
	PB5724	388 WILTON W RDGFLD	A			3			
	PB5726	15 SUNSET RDGFLD	A			1			
	PB5729	74 STONECREST RDGFLD	A			1			
	PB5731	80 HOLMES RDGFLD	A			1			
	PB5732	118 HOLMES RD	A			3			
	PB5733	219 HIGH RDG RDGFLD	A			1			
	PB5734	13 GRIFFITH RDGFLD	A			1			
	PB5735	28 FAIRVIEW RDGFLD	A			1			
	PB5737	127 STONECREST RD	A			1			
	PB5738	9 BRANCHVILLE RDGFLD	A			1			
	PB5739	44 BARRY RDGFLD	A			1			
	PB5741	11 CONANT RDGFLD	A			1			
	PB5745	32 JEFFRO RDGFLD	A			1			
	PB5746	89 ROCKWELL RDGFLD	A			1			
	PB5748	16 ROWLAND RDGFLD	A			1			
	PB5749	12 WESTMORELAND	A			3			
	PB5751	82 RAMAPOO RDGFLD	A			1			
	PB5753	102 RAMAPOO RDGFLD	A			1			
	PB5756	93 SOUNDVIEW RDGFLD	A			1			
	PB5758	85 RAMAPOO RD	A			3			
	PB5771	117 WEST LANE	A	Y		1			
	PB5773	128 HIGH RDG RDGFLD	A			1			
	PB5781	151 NORTH ST	A	Y		1			
	PB6263	18 FAIRVIEW AVE	A			3			
	PB6274	47 NORTH SALEM RD	A			3			
	PB6276	11 VICTOR DR	A			3			
	PB6307	199 NORTH ST	A			1			
	PB6310	2 VICTOR DR	A			3			
	PB6311	93 RAMAPOO RD	A			3			
	PB7001	309 LIMESTONE TERR	A	Y		3			
	PB7002	14 LIMESTONE TERR	A	Y		3			
	PB7003	19 LIMESTONE TERR	A	Y		3			
	PB7004	30 LIMESTONE TERR	A	Y		3			
	PB7005	40 LIMESTONE TERR	A	Y		3			
	PB7011	220 MOUNTAIN ROAD	A	Y		3			
	PB7013	226 MOUNTAIN RD	A	Y		3			
	PB7014	229 MOUNTAIN ROAD	A	Y		3			
	PB7015	232 MOUNTAIN ROAD	A	Y		3			

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT1180011</b>	<b>AQUARION-RIDGEFIELD</b>	C	7,476	P	SWP
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					2,814

Towns Served: RIDGEFIELD

<b>Water System Facility and Sampling Point Inventory</b>									
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	WQP 2	DBPR Stage
	PB7016	233 MOUNTAIN RD		A	Y	3			
	PB7017	256 MOUNTAIN RD		A	Y	3			
	PB7042	6 CRAIGMOOR RD N		A		3			
	PB7043	16 CRAIGMOOR RD N		A		3			
	PB7044	6 CRAIGMOOR RD S		A		1			
	PB7045	29 CRAIGMOOR RD S		A		3			
	PB7046	37 CRAIGMOOR RD S		A		3			
	PB7047	41 CRAIGMOOR RD S		A		3			
	PB7232	248 BENNETT		A	Y	3			
	PB7233	32 LAKE ROAD		A	Y	3			
	PB7234	18 LAKE ROAD		A	Y	3			
	PB7235	31 LAKE ROAD		A	Y	3			
	PB7238	PB7238 - 133 PEACEAB		A	Y	3			
	PB7329	PB7329 -48 EAST RIDG		A	Y	3			
	PB7334	48 HIGHVIEW		A	Y	3			
	PB7336	90 LAKESIDE		A	Y	3			
	PB7337	23 SHADY LANE		A	Y	3			
	PB7338	21 SHADY LANE		A	Y	3			
	PB7339	36 HIGHVIEW		A	Y	2			
	PB7340	99 LAKESIDE		A	Y	3			
	PB7342	1 RAINBOW		A	Y	3			
	PB7343	12 RAINBOW		A	Y	3			
	PB7344	34 RUSTIC		A	Y	3			
	PB7345	26 RUSTIC		A	Y	3			
	PB7371	260 BENNETT		A	Y	3			
	PB8230	37-R CATOONAH ST		A	Y	1			
	PB8231	4 ABBOTT AVE		A	Y	1			
	PB8232	7 ROCHAMBEAU AVE		A	Y	1			
	PB8233	8 TRAILS END LANE		A	Y	1			
	PB8234	8 ARMAND PL		A	Y	1			
	PB8235	9 GREEN LANE		A	Y	1			
	PB8236	10 ARMAND RD		A	Y	1			
	PB8237	14 ARMAND RD		A	Y	1			
	PB8238	14 MARYS LANE		A	Y	1			
	PB8239	15 RITA ROAD		A	Y	1			
	PB8240	23 GREEN LANE		A	Y	1			
	PB8241	23 TRAILS END LANE		A	Y	1			
	PB8242	28 BRANCHVILLE RD		A	Y	1			

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT1180011</b>	<b>AQUARION-RIDGEFIELD</b>	C	7,476	P	SWP
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural

Towns Served: RIDGEFIELD

<b>Water System Facility and Sampling Point Inventory</b>									
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	WQP 2	Stage DBPR
	PB8243	41 BLACKSMITH RIDGE	A	Y	1				
	PB8244	44 PUMPING STATION R	A	Y	1				
	PB8245	59 MAIN ST	A	Y	1				
	PB8246	72PUMPING STATION RD	A	Y	1				
	PB8247	75 SOUNDVIEW RD	A	Y	1				
	PB8248	79 SUNSET LN	A	Y	1				
	PB8249	125 WEST MOUNTAIN RD	A	Y	1				
	PB8250	133 ELEVEN LEVELS RD	A	Y	1				
	PB8251	161 OSCALETA RD	A	Y	1				
	PB8252	164 NORTH ST	A	Y	1				
	PB8253	165 HIGH RIDGE AVE	A	Y	1				
	PB8254	264 GREAT HILL RD	A	Y	1				
	PB8255	12 ISLAND HILL AVE	A	Y	1				
	PB8256	6 BRYON AVE	A	Y	1				
	PB8339	127 HOLMES RD	A		3				
	PB8340	40 ARMAND RD	I		1				
	PB8371	1 CRAIGMOOR RD. N	A		1				
	PB8415	174 HOLMES RD	A		1				
	PB8416	199 NORTH ST	A		1				
	PB8417	160 PEACEABLE RIDGE	A		1				
	PB8418	219 PEACABLE HILL RD	A		1				
	PB8419	219 NORTH ST	A		1				
	PB8420	221 NORTH ST	A		1				
	PB8421	223 NORTH ST	A		1				
	PB8422	243 WEST LANE	A		1				
	PB8423	17 ARMAND RD	A		1				
	PB8424	21 ARMAND RD	A		1				
	PB8425	22 ARMAND RD	A		1				
	PB8426	23 ARMAND RD	A		1				
	PB8427	23 ABBOTT AVE	A		1				
	PB8428	26 ARMAND PL	A		1				
	PB8429	50 ARMAND RD	A		1				
	PB8430	52 ARMAND RD	A		1				
	PB8431	22 ARMAND PL	A		1				
	PB8432	70 BRANCHVILLE RD	A		1				
	PB8433	52 BRANCHVILLE RD	A		1				
	PB8434	27 KINGS LANE	A		1				
	PB8435	87 ARMAND RD	A		1				

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180011	AQUARION-RIDGEFIELD	C	7,476	P	SWP
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural

Towns Served: RIDGEFIELD

<b>Water System Facility and Sampling Point Inventory</b>						
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier Asbestos WQP 2 DBPR
					Stage	
		PB8436	93 ARMAND RD	A	1	
		PB8437	95 ARMAND RD	A	1	
		PB8438	97 ARMAND RD	A	1	
		PB8439	99 ARMAND RD	A	1	
		PB8440	102 ARMAND RD	A	1	
		PB8441	143 ELEVEN LEVELS RD	A	1	
		PB8442	174 ELEVEN LEVELS RD	A	1	
		PB8443	153 OSCALETA RD	A	1	
		PB8444	159 NORTH ST	A	1	
		PB8794	26 CRAIGMOOR RD	A	3	
		PB8795	34 CRAIGMOOR RD	A	3	
		PB8796	2 CRAIGMOOR RD N	A	3	
		PB8797	15 CRAIGMOOR RD N	A	3	
		PB8798	22 CRAIGMOOR RD N	A	3	
		PB8799	24 CRAIGMOOR RD N	A	3	
		PB8800	1 CRAIGMOOR RD S	A	3	
		PB8801	3 CRAIGMOOR RD S	A	3	
		PB8802	10 CRAIGMOOR RD S	A	3	
		PB8803	17 CRAIGMOOR RD S	A	3	
		PB8804	18 CRAIGMOOR RD S	A	3	
		PB8805	19 CRAIGMOOR RD S	A	3	
		PB9162	40 ARMAND ROAD	A	1	
		PN8425	22 ARMAND RD	A	1	
		UPSTREAM	WITHIN 5 SERVICE CON	A		
00700	OSCALETA WELLFIELD TP ENTRY POINT	3	EP - OSCALETA	A		
00701	NORTH STREET WELLFIELD TP ENTRY POINT	3	EP - NORTH STREET	A		
00702	BEECHWOOD WELLFIELD TP ENTRY POINT	3	ENTRY POINT - BEECHW	A		
1224	OSCALETA WELL #1 (AKA CHURCH WELL)	2	OSCALETA CHURCH	A		
46179	INTERCONNECTION - CT0150011 -BRANCHVILLE					
50975	NORTH ST STORAGE TANKS (2)					
50977	OSCALETA CLEAR WELLS (2)					
512	NORTH STREET WELLS TREATMENT PLANT					

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180011	AQUARION-RIDGEFIELD	C	7,476	P	SWP
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural

Towns Served: RIDGEFIELD

<b>Water System Facility and Sampling Point Inventory</b>						
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total	Lead and Coliform	Stage
				Status	Copper Rule Tier	Asbestos WQP 2 DBPR
513	OSCALETA WELLS TREATMENT PLANT					
514	BEECHWOOD WELLS TREATMENT PLANT					
58928	BRANCHVILLE PUMP STATION					
58930	ELEVEN LEVELS PUMP STATION					
58932	NORTH ST TRANSFER PUMPS					
58934	OSCALETA TRANSFER PUMP STATION					
59990	PEACEABLE RIDGE STANDPIPES (2)					
60158	LAURELWOOD III PUMP STATION					
874	NORTH STREET WELL #3	2	N. STREET WELL #3	A		
875	NORTH STREET WELL #1	2	N. STREET WELL #1	A		
876	NORTH STREET WELL #2	2	N. STREET WELL #2	A		
877	OSCALETA CAISSON WELL(#4)	2	OSCALETA CAISSON	A		
878	OSCALETA WELL #2	2	OSCALETA WELL #2	A		
879	OSCALETA WELL #3	2	OSCALETA WELL #3	A		
902	BEECHWOOD WELL #2	2	BEECHWOOD WELL #2	A		
903	BEECHWOOD WELL #1	2	BEECHWOOD WELL #1	A		

## Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

<b>Facility Classification:</b>			<b>Certification Expiration</b>
Operator Name	Operator Type	Certification(s)	
HORN, ROBERT	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2028 6/30/2028
ULBRICK, FRED	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2028

Water System Facility: **NORTH STREET WELLS TREATMENT PLANT (WSF ID: 512)**

<b>Facility Classification:</b> CLASS 1 TREATMENT PLANT			<b>Certification Expiration</b>
Operator Name	Operator Type	Certification(s)	
BURKE, JONATHAN	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2028

Water System Facility: **OSCALETA WELLS TREATMENT PLANT (WSF ID: 513)**

<b>Facility Classification:</b> CLASS 1 TREATMENT PLANT			<b>Certification Expiration</b>
Operator Name	Operator Type	Certification(s)	
BURKE, JONATHAN	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2028

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180011	AQUARION-RIDGEFIELD	C	7,476	P	SWP
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
					2,814

Towns Served: RIDGEFIELD

## Certified Operator Information

Water System Facility: BEECHWOOD WELLS TREATMENT PLANT (WSF ID: 514)

**Facility Classification:** CLASS 1 TREATMENT PLANT

**Certification  
Expiration**

Operator Name	Operator Type	Certification(s)	
BURKE, JONATHAN	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2028

## Contact Information

Name		Organization			Job Title		
<b>Mr. John P. Walsh</b>		Aquarion Water Company			Vice President		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
835 Main Street		Mail Stop 700			Bridgeport	CT	06604
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
203-337-5852		203-337-5938		781-413-6175	jwalsh@aquarionwater.com		

Contact Role(s): **Legal Contact**

Name		Organization			Job Title		
<b>Mr. Robert J. Ulrich</b>		Aquarion Water Company of Ct			Vp-Supply & Utility		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
505 Huntington St.					Shelton	CT	06484
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
203-926-4320		203-929-5297		203-395-3205	rulrich@aquarionwater.com		

Contact Role(s): **Administrative Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

**If you have any questions, please contact the Drinking Water Section at (860) 509-7333.**

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180021	AQUARION-RIDGEFIELD KNOLLS	C	958	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural

Towns Served: RIDGEFIELD

### Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30		
<b>Total Haloacetic Acids (2456)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RIDGEFIELD KNOLLS TK (01809)	1/1/25 - 12/31/25	8/3-8/9	Complete
	1/1/26 - 12/31/26	8/3-8/9	
	1/1/27 - 12/31/27	8/3-8/9	
<b>Total Trihalomethanes (2950)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
REDGEFIELD KNOLLS SS (01807)	1/1/25 - 12/31/25	8/3-8/9	Complete
	1/1/26 - 12/31/26	8/3-8/9	
	1/1/27 - 12/31/27	8/3-8/9	
<b>Total Coliform (3100)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
<b>Lead And Copper (PBCU)</b>	<b>10 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/27	6/1-9/30	
<b>Physical Parameters (PPS)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180021	AQUARIAN-RIDGEFIELD KNOLLS	C	958	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: RIDGEFIELD

**Monitoring Requirements**

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Physical Parameters (PPS)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	1 routine (RT) per month
		4/1/26 - 4/30/26			
		5/1/26 - 5/31/26			
		6/1/26 - 6/30/26			
		7/1/26 - 7/31/26			

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Net Gross Alpha (4000)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	1 routine (RT) per three years
	ENTRY POINT (3)	1/1/23 - 12/31/25			Complete
		1/1/26 - 12/31/28			
		1/1/29 - 12/31/31			

Uranium (4006)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	1 routine (RT) per three years
	ENTRY POINT (3)	1/1/23 - 12/31/25			Complete
		1/1/26 - 12/31/28			
		1/1/29 - 12/31/31			

Combined Radium-226/228 (4010)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	1 routine (RT) per three years
	ENTRY POINT (3)	1/1/23 - 12/31/25			Complete
		1/1/26 - 12/31/28			
		1/1/29 - 12/31/31			

Inorganic Chemicals (IOCS)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	1 routine (RT) per three years
	ENTRY POINT (3)	1/1/25 - 12/31/27			

Nitrate And Nitrite (NOX)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	1 routine (RT) per year
	ENTRY POINT (3)	1/1/25 - 12/31/25			Complete
		1/1/26 - 12/31/26			
		1/1/27 - 12/31/27			

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	1 routine (RT) per three years
	ENTRY POINT (3)	1/1/23 - 12/31/25			Complete
		1/1/26 - 12/31/28			
		1/1/29 - 12/31/31			

Organic Chemicals (VOCS)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	1 routine (RT) per year
	ENTRY POINT (3)	1/1/25 - 12/31/25			Complete
		1/1/26 - 12/31/26			
		1/1/27 - 12/31/27			

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180021	AQUARIAN-RIDGEFIELD KNOLLS	C	958	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural

Towns Served: RIDGEFIELD

## Monitoring Requirements

Water System Facility: WELL 1(NEW) (WSF ID: 1698)

E. Coli (3014)			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 1(NEW) (2)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: WELL 7 (WSF ID: 53807)

E. Coli (3014)			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 7 (2)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: WELL 1 (OLD) (WSF ID: 867)

E. Coli (3014)			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 1 (OLD) (2)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: WELL 2 (WSF ID: 868)

E. Coli (3014)			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 2 (2)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: WELL 5 (WSF ID: 871)

E. Coli (3014)			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 5 (2)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

## Monthly Water System Facility (WSF) Level Monitoring Requirements

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180021	AQUARION-RIDGEFIELD KNOLLS	C	958	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural

Towns Served: RIDGEFIELD

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily	
<b>Start Date:</b> 9/1/2007		<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.85 MG/L	2	
<b>Start Date:</b> 8/1/2003		<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Maximum: 1.15 MG/L	2	
<b>Start Date:</b> 8/1/2003		<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2025	
MAIL/HAND DELIVER NOTICE TO CONSUMERS	12/31/2025	
RESPOND TO SANITARY SURVEY	1/21/2026	
CERTIFY LEAD SL NOTIFICATION	7/1/2026	

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total	Lead and			Stage
					Coliform	Copper	Asbestos	WQP 2 DBPR	
00600	DISTRIBUTION SYSTEM	01806	96 ASPEN LEDGES	A	Y	1			Y
		01807	REDGEFIELD KNOLLS SS	A	Y				
		01808	REDGEFIELD KNOLLS FS	A	Y				
		01809	REDGEFIELD KNOLLS TK	A	Y				

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180021	AQUARIAN-RIDGEFIELD KNOLLS	C	958	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural

Towns Served: RIDGEFIELD

<b>Water System Facility and Sampling Point Inventory</b>							
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos WQP 2 DBPR
					Stage	Stage	Stage
		4	DISTRIBUTION SYSTEM	A	Y		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A			
		PB6981	96 ASPEN LE	A		3	
		PB6982	14 VIRGINIA CT	A		3	
		PB6983	40 ASPEN LEDGES	A		3	
		PB6984	83 ASPEN LEDGES	A		3	
		PB6985	128 KNOLLWOOD DR	A		3	
		PB6986	26 VIRGINIA CT	A		3	
		PB6987	41 PARTRIDGE DR	A		3	
		PB6988	5 QUAIL DR	A		3	
		PB6989	17 QUAIL DR	A		3	
		PB6990	25 FOX DR	A		3	
		PB6991	24 BOB HILL RD	A		3	
		PB6992	19 PARTRIDGE DR	A		3	
		PB7531	33 PARTRIDGE DRIVE	A		3	
		PB7532	16 SUGAR LOAF	A		3	
		PB7533	138 KNOLLWOOD DRIVE	A	Y	3	
		PB7534	13 SUGAR LOAF	A	Y	3	
		PB7538	74 ASPEN LEDGES	A		3	
		PB7539	12 FOX DRIVE	A		3	
		RK001	FIRE DEPT KITCHEN	A	Y	1	
		RK002	FIRE DEPT BATHROOM	A	Y	1	
		RK004	33 PARTRIDGE DR	A	Y	1	
		UPSTREAM	WITHIN 5 SERVICE CON	A			
00700	ENTRY POINT	3	ENTRY POINT	A			
1698	WELL 1(NEW)	2	WELL 1(NEW)	A			
53687	ATMOSPHERIC TANK						
53807	WELL 7	2	WELL 7	A			
577	RIDGEFIELD KNOLLS TREATMENT PLANT						
867	WELL 1 (OLD)	2	WELL 1 (OLD)	A			
868	WELL 2	2	WELL 2	A			
871	WELL 5	2	WELL 5	A			
PS01	PUMP STATION						

## Certified Operator Information

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180021	AQUARION-RIDGEFIELD KNOTS	C	958	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
				223	

Towns Served: RIDGEFIELD

## Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

**Facility Classification:** DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
ULBRICK, FRED	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	12/31/2028

Water System Facility: **RIDGEFIELD KNOTS TREATMENT PLANT (WSF ID: 577)**

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
BURKE, JONATHAN	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	9/30/2028

## Contact Information

Name	Organization	Job Title		
Mr. John P. Walsh	Aquarion Water Company	Vice President		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
835 Main Street	Mail Stop 700	Bridgeport	CT	06604
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone
203-337-5852		203-337-5938		781-413-6175
				jwalsh@aquarionwater.com

Contact Role(s): **Legal Contact**

Name	Organization	Job Title		
Mr. Robert J. Ulrich	Aquarion Water Company of Ct	Vp-Supply & Utility		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
505 Huntington St.		Shelton	CT	06484
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone
203-926-4320		203-929-5297		203-395-3205
				rulrich@aquarionwater.com

Contact Role(s): **Administrative Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

**If you have any questions, please contact the Drinking Water Section at (860) 509-7333.**

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180041	AQUARION-SCODON	C	130	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural

Towns Served: RIDGEFIELD

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

<b>Chlorine Residual (1012)</b>	<b>2 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
<b>Asbestos (1094)</b>	<b>2 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31		
<b>Total Coliform (3100)</b>	<b>2 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
<b>Disinfectant Byproducts - TTHM &amp; HAAs (DBP)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
LANGSTROTH DR SS (03502)	1/1/25 - 12/31/25	8/1-8/31	Complete
	1/1/26 - 12/31/26	8/1-8/31	
	1/1/27 - 12/31/27	8/1-8/31	
<b>Lead And Copper (PBCU)</b>	<b>5 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/27	6/1-9/30	Complete
	1/1/26 - 12/31/28	6/1-9/30	
	1/1/29 - 12/31/31	6/1-9/30	
<b>Physical Parameters (PPS)</b>	<b>2 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180041	AQUARION-SCODON	C	130	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: RIDGEFIELD

**Monitoring Requirements**

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Physical Parameters (PPS)	2 routine (RT) per month
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>
	12/1/25 - 12/31/25    Complete
	1/1/26 - 1/31/26
	2/1/26 - 2/28/26
	3/1/26 - 3/31/26
	4/1/26 - 4/30/26
	5/1/26 - 5/31/26
	6/1/26 - 6/30/26
	7/1/26 - 7/31/26

Water System Facility: **ENTRY POINT - WELL #2 & #3 (WSF ID: 00700)**

Net Gross Alpha (4000)	1 routine (RT) per three years
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>
ENTRY POINT - WELLS #2 & #3 (3)	1/1/23 - 12/31/25    Complete
	1/1/26 - 12/31/28
	1/1/29 - 12/31/31

  

Uranium (4006)	1 routine (RT) per three years
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>
ENTRY POINT - WELLS #2 & #3 (3)	1/1/23 - 12/31/25    Complete
	1/1/26 - 12/31/28
	1/1/29 - 12/31/31

Combined Radium-226/228 (4010)	1 routine (RT) per three years
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>
ENTRY POINT - WELLS #2 & #3 (3)	1/1/23 - 12/31/25    Complete
	1/1/26 - 12/31/28
	1/1/29 - 12/31/31

Inorganic Chemicals (IOCS)	1 routine (RT) per three years
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>
ENTRY POINT - WELLS #2 & #3 (3)	1/1/25 - 12/31/27

Nitrate And Nitrite (NOX)	1 routine (RT) per year
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>
ENTRY POINT - WELLS #2 & #3 (3)	1/1/25 - 12/31/25    Complete
	1/1/26 - 12/31/26
	1/1/27 - 12/31/27

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	1 routine (RT) per three years
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>
ENTRY POINT - WELLS #2 & #3 (3)	1/1/23 - 12/31/25    Complete
	1/1/26 - 12/31/28
	1/1/29 - 12/31/31

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180041	AQUARION-SCODON	C	130	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: RIDGEFIELD

**Monitoring Requirements**

Water System Facility: **ENTRY POINT - WELL #2 & #3 (WSF ID: 00700)**

Organic Chemicals (VOCS)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT - WELLS #2 & #3 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

Water System Facility: **ENTRY POINT 2 - WELL #4 & #7 (WSF ID: 00701)**

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)	1 routine (RT) per six years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/25 - 12/31/30		

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

Organic Chemicals (VOCS)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Water System Facility: **WELL 7 (WSF ID: 60572)**

E. Coli (3014)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 7 (2)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: **WELL 2 (WSF ID: 861)**

E. Coli (3014)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180041	AQUARION-SCODON	C	130	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: RIDGEFIELD

### Monitoring Requirements

Water System Facility: WELL 2 (WSF ID: 861)

E. Coli (3014)		1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
WELL 2 (2)	7/1/25 - 9/30/25		Complete	
	10/1/25 - 12/31/25		Complete	
	1/1/26 - 3/31/26			
	4/1/26 - 6/30/26			

Water System Facility: WELL 3 (WSF ID: 862)

E. Coli (3014)		1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
WELL 3 (2)	7/1/25 - 9/30/25		Complete	
	10/1/25 - 12/31/25		Complete	
	1/1/26 - 3/31/26			
	4/1/26 - 6/30/26			

Water System Facility: WELL 4 (WSF ID: 863)

E. Coli (3014)		1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
WELL 4 (2)	7/1/25 - 9/30/25		Complete	
	10/1/25 - 12/31/25		Complete	
	1/1/26 - 3/31/26			
	4/1/26 - 6/30/26			

### Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT - WELL #2 & #3 (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 5/1/2018			
	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		
	11/1/2025 - 11/30/2025		
	12/1/2025 - 12/31/2025		

Water System Facility: ENTRY POINT 2 - WELL #4 & #7 (WSFID: 00701)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 5/1/2018			
	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180041	AQUARION-SCODON	C	130	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural

Towns Served: RIDGEFIELD

Water System Facility: ENTRY POINT 2 - WELL #4 & #7 (WSFID: 00701)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 5/1/2018		Compliance History: Monitoring Period	Operating Limit Monitoring Compliance Status: Compliance Status:
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION EXEMPTION	3/1/2023	
MAIL/HAND DELIVER NOTICE TO CONSUMERS	12/31/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2026	
CERTIFY LEAD SL NOTIFICATION	7/1/2026	

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
					Rule			
00600	DISTRIBUTION SYSTEM	03502	LANGSTROTH DR SS	A	Y			Y
		03514	SCODON DR SS	A	Y			
		03514D	SCODON DR SS - DOWNS	A	Y			
		03514U	SCODON DR SS - UPSTR	A	Y			
		03515	NEDS MTN RD SS SCOD	A	Y			
		03515U	NEDS MTN RD SS SCODO	A	Y			
		4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		PB7048	76 BOGUS RD	A	Y	3		
		PB7049	23 LANGSTROUGH	A	Y	3		
		PB7050	33 LANGSTROUGH	A	Y			
		PB7051	PB7051 -34 LANGSTROT	A	Y			
		PB7052	44 LANGSTROUGH	A	Y	3		
		PB7053	56 SCODON	A	Y	3		
		PB7054	6 EVERGREEN PLACE	A		3		
		PB7055	26 PHEASANT LANE	A	Y	1		
		PB7056	34 PHEASANT LANE	A	Y	1		
		PB7057	45 PHEASANT LANE	A	Y	1		
		PB7058	47 PHEASANT LANE	A	Y	1		
		PB7059	81 SCODON DRIVE	A		3		
		PB8054	37 PHEASANT LANE	A	Y	1		
		PB8055	51 PHEASANT LANE	A	Y	1		
		PB8056	44 PHEASANT LANE	A	Y	1		
		PB8057	31 PHEASANT LANE	A	Y	1		
		PB8058	49 PHEASANT LANE	A	Y	1		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180041	AQUARION-SCODON	C	130	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural

Towns Served: RIDGEFIELD

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
					Y	1	Y	3
		PB8059	48 PHEASANT LANE	A	Y	1		
		PB8060	35 PHEASANT LANE	A	Y	1		
		PB8061	18 EVERGREEN PLACE	A	Y	1		
		PB8062	19 EVERGREEN PLACE	A	Y	1		
		PB8063	11 EVERGREEN PLACE	A	Y	1		
		PB8064	104 BOGUS ROAD	A	Y	1		
		PB8625	PB8625 - 105 SCODON	A	Y			
		PB8628	105 SCODON DR	A		3		
	RWC-S2&3-02	34 LANGSTROUGH		A	Y	3		
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT - WELL #2 & #3	3	ENTRY POINT - WELLS	A				
00701	ENTRY POINT 2 - WELL #4 & #7	3	ENTRY POINT	A				
60201	ATMOSPHERIC TANKS(2)							
60572	WELL 7	2	WELL 7	A				
60804	PUMP STATION							
60941	TREATMENT PLANT - WELL #2 & #3							
60943	TREATMENT PLANT - WELL #4 & #7							
861	WELL 2	2	WELL 2	A				
862	WELL 3	2	WELL 3	A				
863	WELL 4	2	WELL 4	A				
ST01	PARALLEL ATMOSPHERIC TANKS							

## Certified Operator Information

Water System Facility: TREATMENT PLANT - WELL #2 & #3 (WSF ID: 60941)

Facility Classification:	CLASS 1 TREATMENT PLANT	Certification Expiration
Operator Name	Operator Type	Certification(s)
BURKE, JONATHAN	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II

Water System Facility: TREATMENT PLANT - WELL #4 & #7 (WSF ID: 60943)

Facility Classification:	CLASS 1 TREATMENT PLANT	Certification Expiration
Operator Name	Operator Type	Certification(s)
BURKE, JONATHAN	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II

## Contact Information

Name	Organization	Job Title		
Mr. John P. Walsh	Aquarion Water Company	Vice President		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
835 Main Street	Mail Stop 700	Bridgeport	CT	06604

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180041	AQUARION-SCODON	C	130	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
				75	

Towns Served: RIDGEFIELD

Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
203-337-5852		203-337-5938		781-413-6175	jwalsh@aquarionwater.com

Contact Role(s): **Legal Contact**

Name	Organization	Job Title
Mr. Robert J. Ulrich	Aquarion Water Company of Ct	Vp-Supply & Utility
Mailing Address Line One	Mailing Address Line Two	City
505 Huntington St.		State
	Shelton	Zip Code
Business Phone	Emergency Phone	Email Address
203-926-4320	203-929-5297	203-395-3205 rulrich@aquarionwater.com

Contact Role(s): **Administrative Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

*<http://www.ct.gov/dph/publicdrinkingwater>*

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180091	BROOKVIEW WATER COMPANY	C	55	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		23			

Towns Served: RIDGEFIELD

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30		
<b>Total Coliform (3100)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
<b>Lead And Copper (PBCU)</b>	<b>5 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/25	6/1-9/30	Complete
	1/1/26 - 12/31/28	6/1-9/30	
	1/1/29 - 12/31/31	6/1-9/30	
<b>Physical Parameters (PPS)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: **ENTRY POINT** (WSF ID: 00700)

<b>Nitrate (1040)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
<b>Nitrite (1041)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Uranium (4006)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180091	BROOKVIEW WATER COMPANY	C	55	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: RIDGEFIELD

## Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/25 - 12/31/27		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
DISTRIBUTION SYSTEM MATERIALS EVALUATION	8/31/2019	
COMPLETE INITIAL LSL INVENTORY	10/16/2024	
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2025	
CROSS CONNECTION EXEMPTION	3/1/2027	

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total	Lead and Coliform	Copper	Stage
					Rule	Rule Tier	Asbestos	
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM DOWNSTREAM WITHIN 5 SERVICE CON	A	Y			

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180091	BROOKVIEW WATER COMPANY	C	55	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
	23				

Towns Served: RIDGEFIELD

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule	Asbestos Rule Tier	Stage WQP 2	DBPR
	UPSTREAM	WITHIN 5 SERVICE CON		A					
00700	ENTRY POINT	3	ENTRY POINT	A					
52261	ATMOSPHERIC STORAGE								
881	WELL 1	2	WELL 1	A					

## Contact Information

Name	Organization	Job Title
Mr. William T. Peatt III	Brookview Water Company	
Mailing Address Line One	Mailing Address Line Two	
202 Mamanasco Rd	Apt 14	
Business Phone	Extension	
203-788-9834		
Fax		
Mobile Phone		
Emergency Phone		
Email Address		
		tedpeatt@gmail.com

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

**NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.**

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1189161	AQUARION-MCKEON	C	67	P	SWP
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: RIDGEFIELD

**Monitoring Requirements**

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
TURNER HILL MCKEON (02960)	1/1/25 - 12/31/33		
<b>Total Coliform (3100)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
<b>Disinfectant Byproducts - TTHM &amp; HAA5 (DBP)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
21 MCKEON PL SS (02962)	1/1/25 - 12/31/25	8/1-8/31	Complete
	1/1/26 - 12/31/26	8/1-8/31	
	1/1/27 - 12/31/27	8/1-8/31	
<b>Lead And Copper (PBCU)</b>	<b>5 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/27	6/1-9/30	
<b>Physical Parameters (PPS)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1189161	AQUARION-MCKEON	C	67	P	SWP
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
				24	

Towns Served: RIDGEFIELD

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
MAIL/HAND DELIVER NOTICE TO CONSUMERS	12/31/2025	
CERTIFY LEAD SL NOTIFICATION	7/1/2026	
CROSS CONNECTION EXEMPTION	3/1/2030	

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total	Lead and Coliform	Copper	Asbestos	WQP 2	DBPR	Stage
					Rule	Rule Tier					
00600	DISTRIBUTION SYSTEM	02960	TURNER HILL MCKEON	A	Y				Y		
		02961	10 MCKEON PL SS	A	Y				Y		
		02962	21 MCKEON PL SS	A	Y						
		4	GENERIC DISTRIBUTION	A	Y						Y
		DOWNSTREAM	WITHIN 5 SERVICE CON	A							
		PB5856	4 TITUS COURT	A					N		
		PB5857	16 MCKEON PL RDFLD	A					N		
		PB5859	12 MCKEON PL RDFLD	A					N		
		PB5860	19 MCKEON PL RDFLD	A					N		
		PB5865	18 MCKEON PL RDFLD	A					N		
23420	INTERCONNECTION - CT0340011 - DANBURY	PB5868	4 TAYLOR CT RDFLD	A					N		
		PB5870	6 TAYLOR CT RDFLD	A					N		
		PB5883	PB5883 - 12 LYNN PLA	A	Y						
		UPSTREAM	WITHIN 5 SERVICE CON	A							

## Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

Facility Classification:	SMALL WATER SYSTEM	Certification Expiration
Operator Name	Operator Type	Certification(s)
HORN, ROBERT	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III WATER TREATMENT PLANT OPERATOR - CLASS III
BURKE, JONATHAN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II
SMITH, RONDA M.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II WATER TREATMENT PLANT OPERATOR - CLASS II
		6/30/2028 6/30/2028 9/30/2028 6/30/2028 6/30/2028

## Contact Information

Name		Organization			Job Title			
Mr. John P. Walsh		Aquarion Water Company			Vice President			
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code	
835 Main Street		Mail Stop 700			Bridgeport			
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
203-337-5852		203-337-5938		781-413-6175	jwalsh@aquarionwater.com			

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1189161	AQUARION-MCKEON	C	67	P	SWP
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
				24	

Towns Served: RIDGEFIELD

Contact Role(s): **Legal Contact**

Name	Organization	Job Title		
Mr. Robert J. Ulrich	Aquarion Water Company of Ct	Vp-Supply & Utility		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
505 Huntington St.		Shelton	CT	06484

Contact Role(s): **Administrative Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

**NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.**

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1189171	AQUARION-BARNUM	C	120	P	SWP
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: RIDGEFIELD

## Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
TURNER HILL BARNUM (02950)	1/1/25 - 12/31/33		
<b>Total Coliform (3100)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
<b>Disinfectant Byproducts - TTHM &amp; HAA5 (DBP)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
LYNN PL @ HUNT CT SS (02952)	1/1/25 - 12/31/25	8/1-8/31	Complete
	1/1/26 - 12/31/26	8/1-8/31	
	1/1/27 - 12/31/27	8/1-8/31	
<b>Lead And Copper (PBCU)</b>	<b>5 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/27	6/1-9/30	
<b>Physical Parameters (PPS)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1189171	AQUARION-BARNUM	C	120	P	SWP
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		47			

Towns Served: RIDGEFIELD

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT		3/1/2025

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total	Lead and Coliform	Copper	Asbestos	WQP 2	DBPR	Stage
					Coliform Rule	Rule Tier					
00600	DISTRIBUTION SYSTEM	02950	TURNER HILL BARNUM	A	Y				Y		
		02952	LYNN PL @ HUNT CT SS	A	Y				Y		Y
		02953	12 LYNN PL SS	A	Y						
		4	GENERIC DISTRIBUTION	A	Y						
		DOWNSTREAM	WITHIN 5 SERVICE CON	A							
		PB5871	30 BARNUM PL RDFLD	A			N				
		PB5874	7 BARNUM PL RDFLD	A			N				
		PB5879	34 LYNN PL RDFLD	A			N				
		PB5880	32 LYNN PL RDFLD	A			N				
		PB5881	20 LYNN PL RDFLD	A			N				
		PB5883	12 LYNN PLACE	A			N				
		PB6296	25 LYNN PL RDFLD	A			N				
		PB6952	28 LYNN PLACE	A			N				
		UPSTREAM	WITHIN 5 SERVICE CON	A							

23421 INTERCONNECTION -  
CT0340011 - DANBURY

## Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)				Certification Expiration
Facility Classification:	SMALL WATER SYSTEM			Certification Expiration
Operator Name	Operator Type	Certification(s)		Certification Expiration
HORN, ROBERT	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III		6/30/2028
		WATER TREATMENT PLANT OPERATOR - CLASS III		6/30/2028
BURKE, JONATHAN	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II		9/30/2028
SMITH, RONDA M.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS II		6/30/2028
		WATER TREATMENT PLANT OPERATOR - CLASS II		6/30/2028

## Contact Information

Name	Organization	Job Title			
Mr. John P. Walsh	Aquarion Water Company	Vice President			
Mailing Address Line One		Mailing Address Line Two	City	State	Zip Code
835 Main Street		Mail Stop 700	Bridgeport	CT	06604
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
203-337-5852		203-337-5938		781-413-6175	jwalsh@aquarionwater.com

Contact Role(s): Legal Contact

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1189171	AQUARION-BARNUM	C	120	P	SWP
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		47			Agricultural

Towns Served: RIDGEFIELD

Name	Organization	Job Title		
Mr. Robert J. Ulrich	Aquarion Water Company of Ct	Vp-Supply & Utility		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
505 Huntington St.		Shelton	CT	06484
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone
203-926-4320		203-929-5297		203-395-3205
				rulrich@aquarionwater.com

Contact Role(s): **Administrative Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

***End of schedule***