

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180322	KEELER RIDGEFIELD B	NTNC	30	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
746 DANBURY ROAD	Connections	1			

Towns Served: RIDGEFIELD

### Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

<b>Chlorine Residual (1012)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
<b>Chlorine Residual (1012)</b>	<b>3 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
<b>Chlorine Residual (1012)</b>	<b>4 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		Complete
<b>Total Coliform (3100)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 7/31/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
<b>Total Coliform (3100)</b>	<b>3 repeat (RP) per period</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/19/25 - 7/24/25		
<b>Total Coliform (3100)</b>	<b>3 temporary routine (TR) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
<b>Lead And Copper (PBCU)</b>	<b>5 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/26	6/1-9/30	
	1/1/27 - 12/31/29	6/1-9/30	
<b>Physical Parameters (PPS)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/26		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180322	KEELER RIDGEFIELD B	NTNC	30	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
746 DANBURY ROAD	Connections	1			

Towns Served: RIDGEFIELD

## Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Inorganic Chemicals (IOCS)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
		1/1/27 - 12/31/29		1 routine (RT) per three years
Nitrate And Nitrite (NOX)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)		1/1/25 - 12/31/25		Complete
		1/1/26 - 12/31/26		
		1/1/27 - 12/31/27		
Pesticides, Herbicides and PCBs-Phase II (SOC2)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)		1/1/23 - 12/31/25		
		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		
Pesticides, Herbicides and PCBs-Phase V (SOC5)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)		1/1/23 - 12/31/25		
		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		
Organic Chemicals (VOCS)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)		7/1/25 - 9/30/25		Complete
		10/1/25 - 12/31/25		
		1/1/26 - 3/31/26		
		4/1/26 - 6/30/26		

Water System Facility: WELL (WSF ID: 10542)

E. Coli (3014)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL (2)		7/18/25 - 7/24/25		

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2025	

## Public Notification Requirements

Violation/Situation	Compliance Period	Notice Tier	Public Notification Required	Public Notification Performed	PN Certification Due to DPH	PN Certification Received
E. Coli M&R Violation	7/25/25 - 8/9/25	3	11/18/2026		11/28/2026	

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform Status	Lead and Copper Rule Status	Asbestos Rule Tier	Stage WQP 2 DBPR Received

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180322	KEELER RIDGEFIELD B	NTNC	30	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
746 DANBURY ROAD		1			

Towns Served: RIDGEFIELD

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
					Y	Y	N	N
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		COFFSINK01	COFFEE SINK	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		DWNBR01	DWNSTAIRS BREAK ROOM	A	Y			
		DWNSRVMR01	DWNSTAIRS CUST MR	A	Y			
		DWNWS01	DWNSTAIRS WASH SINK	A	Y			
		SHOWLR01	SHOWROOM LR	A	Y			
		SHOWMR01	SHOWROOM MR	A	Y			
		SHOWSNK01	SHOWROOM BAR SINK	A	Y			
		SRVSHOP01	SERVICE SHOP	A	Y			
00700	ENTRY POINT	UPOFBR01	UPSTAIRS BREAK ROOM	A	Y			
		UPOFLR01	UPSTAIRS OFFICE LR	A	Y			
		UPOFMR01	UPSTAIRS OFFICE MR	A	Y			
		UPSTREAM	WITHIN 5 SERVICE CON	A				
		3	ENTRY POINT	A				
10542	WELL	2	WELL	A				
62492	ATMOSPHERIC STORAGE							
974	GAC WATER TREATMENT							

## Certified Operator Information

Water System Facility: **GAC WATER TREATMENT (WSF ID: 974)**

**Facility Classification:** CLASS 1 TREATMENT PLANT

**Certification**

Operator Name	Operator Type	Certification(s)	Certification Expiration
HURLBUT, PAUL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	12/31/2028

## Contact Information

Name		Organization		Job Title		
<b>Ms. Katharine Mulvey</b>		Keeler Ridgefield B		Facilities Manager		
Mailing Address Line One	Mailing Address Line Two			City	State	Zip Code
746 Danbury Rd				Ridgefield	CT	06877
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-438-0471	248	203-438-8770		203-942-8244	mmulvey@bmwofridgefield.com	

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180322	KEELER RIDGEFIELD B	NTNC	30	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
746 DANBURY ROAD	Connections	1			Agricultural

Towns Served: RIDGEFIELD

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

*<http://www.ct.gov/dph/publicdrinkingwater>*

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180342	ULLMAN DEVICES (MAIN BUILDING)	NTNC	30	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
664 DANBURY ROAD	Connections	1			

Towns Served: RIDGEFIELD

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
<b>Total Coliform (3100)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25   Complete		
	9/1/25 - 9/30/25   Complete		
	10/1/25 - 10/31/25   Complete		
	11/1/25 - 11/30/25   Complete		
	12/1/25 - 12/31/25   Complete		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
<b>Total Coliform (3100)</b>	<b>3 repeat (RP) per period</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	8/9/25 - 8/14/25   Complete		
<b>Lead And Copper (PBCU)</b>	<b>5 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/26   6/1-9/30		
	1/1/27 - 12/31/29   6/1-9/30		
<b>Physical Parameters (PPS)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i> <i>Collection Period</i> <i>Compliance Status</i>		
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25   Complete		
	9/1/25 - 9/30/25   Complete		
	10/1/25 - 10/31/25   Complete		
	11/1/25 - 11/30/25   Complete		
	12/1/25 - 12/31/25   Complete		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: **ENTRY POINT** (WSF ID: 00700)

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180342	ULLMAN DEVICES (MAIN BUILDING)	NTNC	30	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
664 DANBURY ROAD	Connections	1			

Towns Served: RIDGEFIELD

## Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
Pesticides, Herbicides and PCBs-Phase II (SOC2)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Pesticides, Herbicides and PCBs-Phase V (SOC5)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Organic Chemicals (VOCS)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: WELL 1 (WSF ID: 10543)

E. Coli (3014)	1 triggered (TG) per period		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL (2)	8/8/25 - 8/14/25		Complete

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION EXEMPTION	3/1/2026	

## Public Notification Requirements

Violation/Situation	Compliance Period	Notice Tier	Public Notification Required	Public Notification Performed	PN Certification Due to DPH	PN Certification Received
E. Coli M&R Violation	7/8/25 - 8/9/25	3	11/18/2026		11/28/2026	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180342	ULLMAN DEVICES (MAIN BUILDING)	NTNC	30	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
664 DANBURY ROAD		1			

### Towns Served: RIDGEFIELD

# Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UD001	KITCHEN	A	Y	1	Y	Y
		UD002	L RM KITCHEN L SINK	A	Y	1	Y	Y
		UD003	L RM KITCHEN R SINK	A	Y	1	Y	Y
		UD004	M RM KITCHEN	A	Y	1	Y	Y
		UD005	UTIL SINK	A	Y		Y	Y
		UD006	L RM REAR L SINK	A	Y	1	Y	Y
		UD007	L RM REAR R SINK	A	Y	1	Y	Y
		UD008	M RM REAR L SINK	A	Y	1	Y	Y
		UD009	M RM REAR R SINK	A	Y	1	Y	Y
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
10543	WELL 1	2	WELL	A				
61629	ATMOSPHERIC STORAGE							
61631	TREATMENT PLANT							

## Certified Operator Information

Water System Facility: **TREATMENT PLANT (WSF ID: 61631)**

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Expiration
HURLBUT, ANDREW	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2026

## Contact Information

Name		Organization			Job Title		
<b>Mr. Rich Sacrieder</b>		Ullman Devices			Building Manager		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
664 Danbury Rd					Ridgefield	CT	06877
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
203-241-7513					rsac@ullman-devices.com		

Contact Role(s): **Administrative Contact, Legal Contact**

Name		Organization			Job Title		
<b>Mr. Doug Spitler</b>		Saunders Midwest			Owner		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
29 East Madison St		Suite 900			Chicago	IL	60602
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
312-372-3690	2008	213-373-7142		630-606-5463	dspitler@saundersmidwest.com		

**NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any**

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
<b>CT1180342</b>	<b>ULLMAN DEVICES (MAIN BUILDING)</b>			NTNC	30	P	GW
Local Address (where applicable)		Service	Residential	Commercial	Industrial	Combined	Agricultural
664 DANBURY ROAD		Connections	1				

Towns Served: RIDGEFIELD

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

*<http://www.ct.gov/dph/publicdrinkingwater>*

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180362	NOD HILL BREWERY	NTNC	60	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
137 ETHAN ALLEN HIGHWAY	Connections	1			

Towns Served: RIDGEFIELD

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/18 - 12/31/26		
	1/1/27 - 12/31/35		
<b>Total Coliform (3100)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
<b>Lead And Copper (PBCU)</b>	<b>5 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/25	6/1-9/30	Complete
	1/1/26 - 12/31/28	6/1-9/30	
	1/1/29 - 12/31/31	6/1-9/30	
<b>Physical Parameters (PPS)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: **ENTRY POINT** (WSF ID: 00700)

<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180362	NOD HILL BREWERY	NTNC	60	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
137 ETHAN ALLEN HIGHWAY	Connections	1			

Towns Served: RIDGEFIELD

## Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Inorganic Chemicals (IOCS)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	ENTRY POINT (3)	1/1/23 - 12/31/25		
		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		
Nitrate And Nitrite (NOX)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
		1/1/26 - 12/31/26		
		1/1/27 - 12/31/27		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	ENTRY POINT (3)	1/1/23 - 12/31/25		
		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		
Organic Chemicals (VOCS)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	ENTRY POINT (3)	7/1/25 - 9/30/25		Complete
		10/1/25 - 12/31/25		
		1/1/26 - 3/31/26		
		4/1/26 - 6/30/26		

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION EXEMPTION	3/1/2024	
CROSS CONNECTION EXEMPTION	3/1/2025	
CROSS CONNECTION EXEMPTION	3/1/2026	

## Public Notification Requirements

Violation/Situation	Compliance Period	Notice Tier	Public Notification		PN Certification	
			Required	Performed	Due to DPH	Received
1,1-Dichloroethylene MCL Violation	7/1/25 - 9/30/25	2	12/4/2025		12/14/2025	

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total	Lead and Coliform	Copper	Stage WQP 2 DBPR
					Rule	Rule Tier	Asbestos	
00500	BETWEEN GAC FILTERS							
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		CC001	COMCLINIC MR	A	Y	N		
		CC002	COMCLINIC WR	A	Y	N		
		CC003	COMCLINIC KITCHEN	A	Y	N		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180362	NOD HILL BREWERY	NTNC	60	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
137 ETHAN ALLEN HIGHWAY	1				

Towns Served: RIDGEFIELD

**Water System Facility and Sampling Point Inventory**

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
					Rule			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		NH001	NOD HILL MENS RM	A	Y		N	
		NH002	NOD HILL WOMENS RM	A	Y		N	
		NH003	NOD HILL SINK	A	Y		N	
		NH004	NOD HILL TRIPLE SINK	A	Y		N	
		NH005	NOD HILL HAND SINK	A	Y		N	
		NH006	NOD HILL UTILITY SNK	A	Y		N	
		NH007	NOD HILL BAR SINK	A	Y		N	
		RBEND001	RIVBERBEND BR1	A	Y		N	
		RBEND002	RIVERBEND BR2	A	Y		N	
		RBEND003	RIVERBEND KITCHEN	A	Y		N	
		RF001	RFENCE MENS RM	A	Y		N	
		RF002	RFENCE WOMENS RM	A	Y		N	
		RF003	RFENCE SINK	A	Y		N	
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
10546	WELL	2	WELL	A				
45156	TREATMENT PLANT							

**Certified Operator Information**

Water System Facility: **TREATMENT PLANT (WSF ID: 45156)**

Facility Classification:	CLASS 1 TREATMENT PLANT	Certification Expiration
Operator Name	Operator Type	Certification(s)

HURLBUT, ANDREW	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2026
-----------------	----------------	---	-----------

**Contact Information**

Name	Organization	Job Title
Mr. Robert Kaye	Riverside Real Estate, LLC.	
Mailing Address Line One	Mailing Address Line Two	City
137 Ethan Allen Highway		State
		Zip Code
Business Phone	Extension	Fax
203-617-1191		
Mobile Phone	Emergency Phone	Email Address
	203-733-5620	rob@nodhillbrewery.com

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

**If you have any questions, please contact the Drinking Water Section at (860) 509-7333.**

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

**NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180382	RIDGEFIELD HIGH AND MIDDLE SCHOOL	NTNC	2,575	L	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
750 & 700 N. SALEM ROAD (RT 116)	Connections	1			

Towns Served: RIDGEFIELD

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

<b>Chlorine Residual (1012)</b>	<b>2 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
<b>Total Haloacetic Acids (2456)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
M/S KITCHEN (RHAMS12)	1/1/25 - 12/31/25	8/1-8/31	Complete
	1/1/26 - 12/31/26	8/1-8/31	
	1/1/27 - 12/31/27	8/1-8/31	
<b>Total Trihalomethanes (2950)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
H/S KITCHEN (RHAMS18)	1/1/25 - 12/31/25	8/1-8/31	Complete
	1/1/26 - 12/31/26	8/1-8/31	
	1/1/27 - 12/31/27	8/1-8/31	
<b>Total Coliform (3100)</b>	<b>2 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
<b>Lead And Copper (PBCU)</b>	<b>10 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/25	6/1-9/30	Complete
	1/1/26 - 12/31/26	6/1-9/30	
	1/1/27 - 12/31/27	6/1-9/30	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180382	RIDGEFIELD HIGH AND MIDDLE SCHOOL	NTNC	2,575	L	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
750 & 700 N. SALEM ROAD (RT 116)	Connections	1			

Towns Served: RIDGEFIELD

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

Physical Parameters (PPS)	2 routine (RT) per month
<i>Sampling Point (Sampling Point ID)</i>	
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25
	9/1/25 - 9/30/25
	10/1/25 - 10/31/25
	11/1/25 - 11/30/25
	12/1/25 - 12/31/25
	1/1/26 - 1/31/26
	2/1/26 - 2/28/26
	3/1/26 - 3/31/26
	4/1/26 - 4/30/26
	5/1/26 - 5/31/26
	6/1/26 - 6/30/26
	7/1/26 - 7/31/26

Water System Facility: **ENTRY POINT** (WSF ID: 00700)

Chloride (1017)	1 routine (RT) per quarter
<i>Sampling Point (Sampling Point ID)</i>	
ENTRY POINT (3)	7/1/25 - 9/30/25
	10/1/25 - 12/31/25
	1/1/26 - 3/31/26
	4/1/26 - 6/30/26

Nitrate (1040)	1 routine (RT) per quarter
<i>Sampling Point (Sampling Point ID)</i>	
ENTRY POINT (3)	7/1/25 - 9/30/25
	10/1/25 - 12/31/25
	1/1/26 - 3/31/26
	4/1/26 - 6/30/26

Nitrite (1041)	1 routine (RT) per year
<i>Sampling Point (Sampling Point ID)</i>	
ENTRY POINT (3)	1/1/25 - 12/31/25
	1/1/26 - 12/31/26
	1/1/27 - 12/31/27

Inorganic Chemicals (IOCS)	1 routine (RT) per three years
<i>Sampling Point (Sampling Point ID)</i>	
ENTRY POINT (3)	1/1/23 - 12/31/25
	1/1/26 - 12/31/28
	1/1/29 - 12/31/31

Pesticides, Herbicides and PCBs-Phase II (SOC2)	1 routine (RT) per three years
<i>Sampling Point (Sampling Point ID)</i>	
ENTRY POINT (3)	1/1/23 - 12/31/25

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180382	RIDGEFIELD HIGH AND MIDDLE SCHOOL	NTNC	2,575	L	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
750 & 700 N. SALEM ROAD (RT 116)	Connections	1			

Towns Served: RIDGEFIELD

**Monitoring Requirements**

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Pesticides, Herbicides and PCBs-Phase II (SOC2)		1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			
Pesticides, Herbicides and PCBs-Phase V (SOC5)			1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)	1/1/23 - 12/31/25			Complete
	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			
Organic Chemicals (VOCS)			1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)	1/1/25 - 12/31/25			Complete
	1/1/26 - 12/31/26			
	1/1/27 - 12/31/27			

Water System Facility: **RED WELL #6 (WSF ID: 47813)**

E. Coli (3014)		1 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
RED WELL #6 (2)	8/1/25 - 8/31/25			Complete
	9/1/25 - 9/30/25			Complete
	10/1/25 - 10/31/25			Complete
	11/1/25 - 11/30/25			Complete
	12/1/25 - 12/31/25			Complete
	1/1/26 - 1/31/26			
	2/1/26 - 2/28/26			
	3/1/26 - 3/31/26			
	4/1/26 - 4/30/26			
	5/1/26 - 5/31/26			
	6/1/26 - 6/30/26			
	7/1/26 - 7/31/26			

Water System Facility: **GREEN WELL #7 (WSF ID: 47815)**

E. Coli (3014)		1 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
GREEN WELL #7 (2)	8/1/25 - 8/31/25			Complete
	9/1/25 - 9/30/25			Complete
	10/1/25 - 10/31/25			Complete
	11/1/25 - 11/30/25			Complete
	12/1/25 - 12/31/25			Complete
	1/1/26 - 1/31/26			
	2/1/26 - 2/28/26			

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180382	RIDGEFIELD HIGH AND MIDDLE SCHOOL	NTNC	2,575	L	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
750 & 700 N. SALEM ROAD (RT 116)	Connections	1			

Towns Served: RIDGEFIELD

### Monitoring Requirements

Water System Facility: GREEN WELL #7 (WSF ID: 47815)

E. Coli (3014)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
		3/1/26 - 3/31/26		
		4/1/26 - 4/30/26		
		5/1/26 - 5/31/26		
		6/1/26 - 6/30/26		
		7/1/26 - 7/31/26		

### Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: .2 MG/L	Daily
Start Date: 1/1/2002		Compliance History: Operating Limit	Monitoring
		Monitoring Period	Compliance Status: Compliance Status:
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Maximum: 10.0 MG/L	2
Start Date: 10/1/2004		Compliance History: Operating Limit	Monitoring
		Monitoring Period	Compliance Status: Compliance Status:
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2026	

Water System Facility and Sampling Point Inventory						
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier
					Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	03191	Ridgefield High Scho	A	Y	
		03194	Ridgefield Middle Sc	A	Y	
		4	DISTRIBUTION SYSTEM	A	Y	
	DOWNSTREAM	WITHIN 5 SERVICE CON		A		
	RHAMS01	MIDDLE SCHOOL 136		A		3

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180382	RIDGEFIELD HIGH AND MIDDLE SCHOOL	NTNC	2,575	L	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
750 & 700 N. SALEM ROAD (RT 116)	Connections	1			

Towns Served: RIDGEFIELD

<b>Water System Facility and Sampling Point Inventory</b>						
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform Status	Lead and Copper Rule Tier	Asbestos WQP 2 DBPR Stage
	RHAMS02	MIDDLE SCHOOL 119	A	3		
	RHAMS03	MIDDLE SCHOOL 107	A	3		
	RHAMS04	MIDDLE SCHOOL 204	A	3		
	RHAMS05	MIDDLE SCHOOL 218	A	3		
	RHAMS06	MIDDLE SCHOOL 319	A	3		
	RHAMS07	MIDDLE SCHOOL 315	A	3		
	RHAMS08	MIDDLE SCHOOL 345	A	3		
	RHAMS09	MIDDLE SCHOOL 327	A	3		
	RHAMS10	MIDDLE SCHOOL 350	A	3		
	RHAMS11	M/S MAIN OFFICE	A	Y	3	
	RHAMS12	M/S KITCHEN	A	Y	3	
	RHAMS13	HIGH SCHOOL A-102	A	3		
	RHAMS14	HIGH SCHOOL A-104	A	3		
	RHAMS15	H/S NURSE OFFICE	A	Y	3	
	RHAMS16	HIGH SCHOOL A-311	A	3		
	RHAMS17	HIGH SCHOOL A-218	A	3		
	RHAMS18	H/S KITCHEN	A	Y	3	
	RHAMS19	H/S MAIN OFFICE	A	Y	3	
	RHAMS20	H/S PE OFFICE	A	3		
	RHAMS21	HIGH SCHOOL G-235	A	3		
	RHAMS22	H/S CUSTODIAN OFFICE	A	3		
	RHAMS23	H/S STAFF DINING	A	Y	3	
	UPSTREAM	WITHIN 5 SERVICE CON	A			
00700	ENTRY POINT	3	ENTRY POINT	A		
47813	RED WELL #6	2	RED WELL #6	A		
47815	GREEN WELL #7	2	GREEN WELL #7	A		
53533	ATMOSPHERIC STORAGE TANK					
53535	BOOSTER PUMPS					
53537	HYDROSTATIC TANK					
975	WATER TREATMENT					

## Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification:		Certification Expiration
Operator Name	Operator Type	Certification(s)
SEGARRA, JULIO A.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I DISTRIBUTION SYSTEM OPERATOR - CLASS I
		3/31/2028 3/31/2028

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180382	RIDGEFIELD HIGH AND MIDDLE SCHOOL	NTNC	2,575	L	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
750 & 700 N. SALEM ROAD (RT 116)	Connections	1			

Towns Served: RIDGEFIELD

## Certified Operator Information

Water System Facility: WATER TREATMENT (WSF ID: 975)

**Facility Classification:** CLASS 1 TREATMENT PLANT

**Certification  
Expiration**

Operator Name	Operator Type	Certification(s)	
SEGARRA, JULIO A.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	3/31/2028
		DISTRIBUTION SYSTEM OPERATOR - CLASS I	3/31/2028

## Contact Information

Name	Organization	Job Title		
Dr. Jeanann C. Paddyfote	Ridgefield School System	Interim S. Intendent		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
70 Prospect St		Ridgefield	CT	06877
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone
203-894-5550	1200	203-431-2810		
				superintendent@ridgefieldps.net

Contact Role(s): Legal Contact, Owner

Name	Organization	Job Title		
Dr. Susie Da Silva	Ridgefield Schools	Superintendent		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
70 Prospect Street		Ridgefield	CT	06877
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone
203-894-5550	1200	203-431-2810		
				sdasilva@ridgefieldps.net

Contact Role(s): Administrative Contact

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180412	FARMINGVILLE ELEMENTARY SCHOOL	NTNC	428	L	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
324 FARMINGVILLE ROAD	Connections	1			

Towns Served: RIDGEFIELD

**Monitoring Requirements**

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

<b>Chlorine Residual (1012)</b>	<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete	
	10/1/25 - 12/31/25		Complete	
<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28			
<b>Total Coliform (3100)</b>	<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete	
	10/1/25 - 12/31/25		Complete	
	1/1/26 - 3/31/26			
	4/1/26 - 6/30/26			
<b>Disinfectant Byproducts - TTHM &amp; HAA5 (DBP)</b>	<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
NURSES ROOM (FARMINGS002)	1/1/25 - 12/31/25	9/1-9/30	Complete	
	1/1/26 - 12/31/26	9/1-9/30		
	1/1/27 - 12/31/27	9/1-9/30		
<b>Lead And Copper (PBCU)</b>	<b>5 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/25	6/1-9/30	Complete	
	1/1/26 - 12/31/26	6/1-9/30		
	1/1/27 - 12/31/27	6/1-9/30		
<b>Physical Parameters (PPS)</b>	<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete	
	10/1/25 - 12/31/25		Complete	
	1/1/26 - 3/31/26			
	4/1/26 - 6/30/26			

Water System Facility: **ENTRY POINT** (WSF ID: 00700)

<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete	
	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete	
	1/1/26 - 12/31/26			
	1/1/27 - 12/31/27			

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180412	FARMINGVILLE ELEMENTARY SCHOOL	NTNC	428	L	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
324 FARMINGVILLE ROAD	Connections	1			

Towns Served: RIDGEFIELD

## Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete	
	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			

  

Organic Chemicals (VOCS)		1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete	
	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			

Water System Facility: WELL (WSF ID: 10549)

E. Coli (3014)		1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
WELL (2)	7/1/25 - 9/30/25		Complete	
	10/1/25 - 12/31/25		Complete	
	1/1/26 - 3/31/26			
	4/1/26 - 6/30/26			

## Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
			Compliance History:	Monitoring
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L		Daily
Start Date: 12/1/2020		Monitoring Period	Operating Limit	Compliance Status:
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2026	

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total	Lead and Coliform	Copper	Stage
					Coliform Rule	Rule Tier	Asbestos	
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		FARMINGS001	KITCHEN	A	Y	2	Y	
		FARMINGS002	NURSES ROOM	A	Y	2		Y

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180412	FARMINGVILLE ELEMENTARY SCHOOL	NTNC	428	L	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
324 FARMINGVILLE ROAD		1			

Towns Served: RIDGEFIELD

Water System Facility and Sampling Point Inventory										
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	WQP 2	DBPR	Stage
	FARMINGS003	ROOM #21 SINK		A	Y	2				
	FARMINGS004	ROOM #19 SINK		A	Y	2				
	FARMINGS005	ROOM #1 SINK		A	Y	2				
	FARMINGS006	ROOM #2 SINK		A	Y	2				
	FARMINGS007	ROOM #3 SINK		A	Y	2				
	FARMINGS008	ROOM #4 SINK		A	Y	2				
	FARMINGS009	ROOM #5 SINK		A	Y	2				
	FARMINGS010	ROOM #6 SINK		A	Y	2				
	FARMINGS011	ROOM #7 SINK		A	Y	2				
	FARMINGS012	ROOM #8 SINK		A	Y	2				
	FARMINGS013	ROOM #9 SINK		A	Y	2				
	FARMINGS014	ROOM #10 SINK		A	Y	2				
	FARMINGS015	ROOM #11 SINK		A	Y	2				
	FARMINGS016	ROOM #14 SINK		A	Y	2				
	FARMINGS017	ROOM #15 SINK		A	Y	2				
	FARMINGS018	ROOM #16 SINK		A	Y	2				
	FARMINGS019	ROOM #17 SINK		A	Y	2				
	FARMINGS020	ROOM #18 SINK		A	Y	2				
	FARMINGS021	ROOM #20 SINK		A	Y	2				
	FARMINGS022	ROOM #22 SINK		A	Y	2				
	FARMINGS023	ROOM #23 SINK		A	Y	2				
	FARMINGS024	ROOM #24 SINK		A	Y	2				
	FARMINGS025	CUSTODIAN RM SINK		A	Y	2				
	FARMINGS026	PHYS ED RM SINK		A	Y	2				
	FARMINGS027	OFFICE SINK		A	Y	2				
	FARMINGS028	STAFF RM SINK		A	Y	2				
	UPSTREAM	WITHIN 5 SERVICE CON		A						
00700	ENTRY POINT	3	ENTRY POINT	A						
10549	WELL	2	WELL	A						
53539	HYDROPNEUMATIC TANK									
62023	TREATMENT PLANT									

## Certified Operator Information

Water System Facility: **TREATMENT PLANT (WSF ID: 62023)**

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
BLACK, RON W.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2026 6/30/2026

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180412	FARMINGVILLE ELEMENTARY SCHOOL	NTNC	428	L	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
324 FARMINGVILLE ROAD	Connections	1			

Towns Served: RIDGEFIELD

## Certified Operator Information

Water System Facility: TREATMENT PLANT (WSF ID: 62023)

Facility Classification: CLASS 1 TREATMENT PLANT

Certification  
Expiration

Operator Name	Operator Type	Certification(s)	
CROWNSHAW, MICHAEL L	ASSIGNED OPERATOR	SMALL WATER SYSTEM OPERATOR	3/31/2028

## Contact Information

Name		Organization			Job Title		
<b>Mr. Rudy Marconi</b>		Town of Ridgefield			First Selectman		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
400 Main Street					Ridgefield	CT	06877
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
203-431-2774		203-431-2722			torfirstselectperson@ridgefieldct.gov		

Contact Role(s): **Legal Contact**

Name		Organization			Job Title		
<b>Dr. Susie Da Silva</b>		Ridgefield Schools			Superintendent		
Mailing Address Line One		Mailing Address Line Two			City	State	Zip Code
70 Prospect Street					Ridgefield	CT	06877
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address		
203-894-5550	1200	203-431-2810			sdasilva@ridgefieldps.net		

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

**If you have any questions, please contact the Drinking Water Section at (860) 509-7333.**

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

**NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180422	BRANCHVILLE SCHOOL	NTNC	488	L	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
40 FLORIDA ROAD	Connections	1			

Towns Served: RIDGEFIELD

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

<b>Chlorine Residual (1012)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
<b>Total Coliform (3100)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
<b>Disinfectant Byproducts - TTHM &amp; HAA5 (DBP)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
NURSES SINK (BRANCH029)	1/1/25 - 12/31/25	9/1-9/30	Complete
	1/1/26 - 12/31/26	9/1-9/30	
	1/1/27 - 12/31/27	9/1-9/30	
<b>Lead And Copper (PBCU)</b>	<b>5 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/25	6/1-9/30	Complete
	1/1/26 - 12/31/26	6/1-9/30	
	1/1/27 - 12/31/27	6/1-9/30	
<b>Physical Parameters (PPS)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: **ENTRY POINT** (WSF ID: 00700)

<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180422	BRANCHVILLE SCHOOL	NTNC	488	L	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
40 FLORIDA ROAD	Connections	1			

Towns Served: RIDGEFIELD

## Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete	
	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			

Organic Chemicals (VOCS)		1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)	1/1/26 - 12/31/26			
	1/1/27 - 12/31/27			

Water System Facility: WELL (WSF ID: 10550)

E. Coli (3014)		1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
WELL (2)	7/1/25 - 9/30/25		Complete	
	10/1/25 - 12/31/25		Complete	
	1/1/26 - 3/31/26			
	4/1/26 - 6/30/26			

## Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSFID: 00600)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
			Compliance History:	Monitoring
Start Date:	Monitoring Period	Operating Limit	Monitoring	Compliance Status:
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily	
	8/1/2025 - 8/31/2025			
	9/1/2025 - 9/30/2025			
	10/1/2025 - 10/31/2025			
	11/1/2025 - 11/30/2025			
	12/1/2025 - 12/31/2025			

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2026	

Water System Facility and Sampling Point Inventory							
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y		
		BRANCH001	KITCHEN	A	Y	2	Y
		BRANCH002	BOYS BATH 5TH GRADE	A	Y	2	
		BRANCH003	GIRLS BATH 5TH GRADE	A	Y	2	
		BRANCH004	MAIN OFFICE BATHRM	A	Y	2	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180422	BRANCHVILLE SCHOOL	NTNC	488	L	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
40 FLORIDA ROAD		1			

Towns Served: RIDGEFIELD

Water System Facility and Sampling Point Inventory									
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	WQP 2	DBPR Stage
	BRANCH005	GIRLS BATH 1ST GRADE	A	Y	2				
	BRANCH006	BOYS BATH 1ST GRADE	A	Y	2				
	BRANCH007	ROOM 16	A	Y	2				
	BRANCH008	ROOM 1	A	Y	2				
	BRANCH009	ROOM 2	A	Y	2				
	BRANCH010	ROOM 3	A	Y	2				
	BRANCH011	ROOM 4	A	Y	2				
	BRANCH012	ROOM 6	A	Y	2				
	BRANCH013	ROOM 7	A	Y	2				
	BRANCH014	ROOM 8	A	Y	2				
	BRANCH015	ROOM 9	A	Y	2				
	BRANCH016	ROOM 10	A	Y	2				
	BRANCH017	ROOM 11	A	Y	2				
	BRANCH018	ROOM 12	A	Y	2				
	BRANCH019	ROOM 13	A	Y	2				
	BRANCH020	ROOM 14	A	Y	2				
	BRANCH021	ROOM 15	A	Y	2				
	BRANCH022	ROOM 18	A	Y	2				
	BRANCH023	ROOM 19	A	Y	2				
	BRANCH024	ROOM 20	A	Y	2				
	BRANCH025	ROOM 21	A	Y	2				
	BRANCH026	ROOM 22	A	Y	2				
	BRANCH027	ROOM 23	A	Y	2				
	BRANCH028	ROOM 24	A	Y	2				
	BRANCH029	NURSES SINK	A	Y	2				
	DOWNSTREAM	WITHIN 5 SERVICE CON	A						
	UPSTREAM	WITHIN 5 SERVICE CON	A						
00700	ENTRY POINT	3	ENTRY POINT	A					
10550	WELL	2	WELL	A					
53530	BOOSTER PUMPS WITH VFDS								
62017	ATMOSPHERIC STORAGE TANK								
62025	TREATMENT PLANT								

## Certified Operator Information

Water System Facility: **TREATMENT PLANT (WSF ID: 62025)**

Facility Classification:		Certification Expiration
CLASS 1 TREATMENT PLANT		
Operator Name	Operator Type	Certification(s)
BLACK, RON W.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II
		6/30/2026

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180422	BRANCHVILLE SCHOOL	NTNC	488	L	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
40 FLORIDA ROAD		1			

Towns Served: RIDGEFIELD

## Certified Operator Information

Water System Facility: **TREATMENT PLANT (WSF ID: 62025)**

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	6/30/2026
CROWNSHAW, MICHAEL L	ASSIGNED OPERATOR	SMALL WATER SYSTEM OPERATOR	3/31/2028

## Contact Information

Name	Organization	Job Title		
Mr. Rudy Marconi	Town of Ridgefield	First Selectman		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
400 Main Street		Ridgefield	CT	06877

Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
203-431-2774		203-431-2722			torfirstselectperson@ridgefieldct.gov

Contact Role(s): **Legal Contact**

Name	Organization	Job Title		
Dr. Susie Da Silva	Ridgefield Schools	Superintendent		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
70 Prospect Street		Ridgefield	CT	06877

Contact Role(s): **Administrative Contact, Owner**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1189063	890 ETHAN ALLEN HIGHWAY - RIDGEFIELD	NTNC	138	P	GW
Local Address (where applicable)	Service Connections	Residential 2	Commercial	Industrial	Combined

Towns Served: RIDGEFIELD

### Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
<b>Total Coliform (3100)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
<b>Lead And Copper (PBCU)</b>	<b>5 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/25	6/1-9/30	Complete
	1/1/26 - 12/31/28	6/1-9/30	
	1/1/29 - 12/31/31	6/1-9/30	
<b>Physical Parameters (PPS)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/27		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
<b>Pesticides, Herbicides and PCBs-Phase II (SOC2)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Pesticides, Herbicides and PCBs-Phase V (SOC5)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1189063	890 ETHAN ALLEN HIGHWAY - RIDGEFIELD	NTNC	138	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: RIDGEFIELD

## Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Organic Chemicals (VOCS)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	ENTRY POINT (3)	1/1/25 - 12/31/27		1 routine (RT) per three years

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION EXEMPTION	3/1/2030	

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	WQP 2 DBPR	Stage
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y				
		DOWNSTREAM	WITHIN 5 SERVICE CON	A					
		MW003	KITCHEN HAND SINK	A	Y	2	Y	Y	
		MW004-FP	FOOD PREP SINK	A	Y	2	Y	Y	
		MW004-KS	KINDERGARDEN SINK	A	Y		Y	Y	
		MW007-3HS	THREES RM HAND SINK	A	Y	2	Y	Y	
		MW007-4SNK	FOURS ROOM SINK	A	Y	2	Y	Y	
		MW007-A	INFANT ROOM A	A	Y		Y	Y	
		MW007-B	INFANT ROOM B	A	Y		Y	Y	
		MW007-C	INFANT ROOM C	A	Y		Y	Y	
		MW009	TWO'S ROOM	A	Y	2	Y	Y	
		MW013-I	INFANT BATHROOM	A	Y		Y	Y	
		MW017-E	STAFF BATHROOM	A	Y		Y	Y	
		MW017-U	UPSTAIRS BATHROOM	A	Y		Y	Y	
		MW026-D	LAB DENTIST	A	Y		Y	Y	
		UPSTREAM	WITHIN 5 SERVICE CON	A					
00700	ENTRY POINT	3	ENTRY POINT	A					
10555	WELL	2	WELL	A					
52242	TREATMENT PLANT								

## Certified Operator Information

Water System Facility: TREATMENT PLANT (WSF ID: 52242)

Facility Classification:	CLASS 1 TREATMENT PLANT	Certification Expiration
Operator Name	Operator Type	Certification(s)
HURLBUT, ANDREW	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II
HURLBUT, PAUL	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1189063	890 ETHAN ALLEN HIGHWAY - RIDGEFIELD	NTNC	138	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		2			Agricultural

Towns Served: RIDGEFIELD

## Contact Information

Name	Organization	Job Title		
Mr. Richard Bradley		Property Owner		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
20 Culver Hill Road		Lyme	NH	03768
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone
203-770-4001				603-795-2780
				890Ethan@gmail.com

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

*<http://www.ct.gov/dph/publicdrinkingwater>*

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180034	720 BRANCHVILLE LLC	NTNC	100	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
720 BRANCHVILLE ROAD (ROUTE 102)	Connections		1		

Towns Served: RIDGEFIELD

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<b>Sampling Point (Sampling Point ID)</b>	<b>Monitoring Period</b>	<b>Collection Period</b>	<b>Compliance Status</b>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
<b>Total Coliform (3100)</b>	<b>1 routine (RT) per quarter</b>		
<b>Sampling Point (Sampling Point ID)</b>	<b>Monitoring Period</b>	<b>Collection Period</b>	<b>Compliance Status</b>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
<b>Lead And Copper (PBCU)</b>	<b>5 routine (RT) per six months</b>		
<b>Sampling Point (Sampling Point ID)</b>	<b>Monitoring Period</b>	<b>Collection Period</b>	<b>Compliance Status</b>
Select from Inventory of Active Sampling Points	7/1/25 - 12/31/25		
	1/1/26 - 6/30/26		
	7/1/26 - 12/31/26		
<b>Physical Parameters (PPS)</b>	<b>1 routine (RT) per quarter</b>		
<b>Sampling Point (Sampling Point ID)</b>	<b>Monitoring Period</b>	<b>Collection Period</b>	<b>Compliance Status</b>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: **ENTRY POINT** (WSF ID: 00700)

<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<b>Sampling Point (Sampling Point ID)</b>	<b>Monitoring Period</b>	<b>Collection Period</b>	<b>Compliance Status</b>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<b>Sampling Point (Sampling Point ID)</b>	<b>Monitoring Period</b>	<b>Collection Period</b>	<b>Compliance Status</b>
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
<b>Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)</b>	<b>1 routine (RT) per three years</b>		
<b>Sampling Point (Sampling Point ID)</b>	<b>Monitoring Period</b>	<b>Collection Period</b>	<b>Compliance Status</b>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per year</b>		
<b>Sampling Point (Sampling Point ID)</b>	<b>Monitoring Period</b>	<b>Collection Period</b>	<b>Compliance Status</b>
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT1180034	720 BRANCHVILLE LLC			NTNC	100	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
720 BRANCHVILLE ROAD (ROUTE 102)				1			

Towns Served: RIDGEFIELD

## Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Organic Chemicals (VOCS)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	1/1/27 - 12/31/27		

Water System Facility: WELL (WSF ID: 22046)

E. Coli (3014)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL (2)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

## Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit		Samples Req/Month	
		Minimum:	7 PH	4	Monitoring
pH	Entry Point pH Monitoring (PHRD)				Compliance Status:
Start Date:	11/1/2015	Compliance History:		Operating Limit	Monitoring
		Monitoring Period		Compliance Status:	Compliance Status:
		8/1/2025 - 8/31/2025			
		9/1/2025 - 9/30/2025			
		10/1/2025 - 10/31/2025			
		11/1/2025 - 11/30/2025			
		12/1/2025 - 12/31/2025			

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SWTS 1: PWS TO RECOMMEND SOWT	12/31/2015	
SWTS 2: DWS REVIEW & APPROVAL OF SOWT	6/30/2016	
CROSS CONNECTION EXEMPTION	3/1/2026	

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total		Lead and Coliform		Copper Rule Tier		Asbestos WQP 2 DBPR		Stage
				Status	Rule							
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y							
		AM001	RR DOVER LADY	A	Y	2		Y				
		AM002	RR DOVER MENS	A	Y	2		Y				
		AM003	RR CVS LADY	A	Y	2		Y				
		AM004	RR CVS MENS	A	Y	2		Y				
		AM005	BREAKROOM CVS	A	Y	2		Y				
		AM006	RR LIQUOR STORE	A	Y	2		Y				
		CVS001	CVS WOMENS ROOM	A	Y	N		Y		Y		
		CVS002	CVS MENS ROOM	A	Y	N		Y		Y		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180034	720 BRANCHVILLE LLC	NTNC	100	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
720 BRANCHVILLE ROAD (ROUTE 102)	Connections		1		

Towns Served: RIDGEFIELD

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
					Y	N	Y	Y
		DOV001	DOVER WOMENS ROOM	A	Y	N	Y	Y
		DOV002	DOVER MENS ROOM	A	Y	N	Y	Y
	DOWNSTREAM	WITHIN 5 SERVICE CON		A				
	UPSTREAM	WITHIN 5 SERVICE CON		A				
		WS001	WINE SHOP	A	Y	2	Y	
00700	ENTRY POINT	3	ENTRY POINT	A				
22046	WELL	2	WELL	A				
53131	ANCONAS TREATMENT PLANT							

## Certified Operator Information

Water System Facility: ANCONAS TREATMENT PLANT (WSF ID: 53131)

Facility Classification:	CLASS 1 TREATMENT PLANT			Certification Expiration
Operator Name	Operator Type	Certification(s)		
HURLBUT, ANDREW	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2026	

## Contact Information

Name	Organization	Job Title		
Mr. Joseph Ancona	Anconas Market	Co-Owner		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
720 Branchville Road		Ridgefield	CT	06877
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone
203-544-8436		203-544-8021		203-417-2254
				jrancona@gmail.com

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

Name	Organization	Job Title		
Mr. John C. Ancona	Anconas Market	Co-Owner		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
720 Branchville Road		Ridgefield	CT	06877
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone
203-544-8436		203-544-8021		203-431-8127

Contact Role(s): **Owner**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

**If you have any questions, please contact the Drinking Water Section at (860) 509-7333.**

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

**NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1189514	GOLF PERFORMANCE CENTER	NTNC	25	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
45 STONEHENGE ROAD	Connections		3		

Towns Served: RIDGEFIELD

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/21 - 12/31/29		
<b>Total Coliform (3100)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
<b>Lead And Copper (PBCU)</b>	<b>5 routine (RT) per six months</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 12/31/25		
	1/1/26 - 6/30/26		
	7/1/26 - 12/31/26		
<b>Physical Parameters (PPS)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: **ENTRY POINT** (WSF ID: 00700)

<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/26		
	1/1/27 - 12/31/29		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
<b>Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT1189514	GOLF PERFORMANCE CENTER			NTNC	25	P	GW
Local Address (where applicable)		Service	Residential	Commercial	Industrial	Combined	Agricultural
45 STONEHENGE ROAD		Connections		3			

Towns Served: RIDGEFIELD

**Monitoring Requirements**

Water System Facility: **ENTRY POINT (WSF ID: 00700)**

Organic Chemicals (VOCS)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: **WELL 1 (WSF ID: 53098)**

E. Coli (3014)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 1 (2)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

**Other Compliance Schedules**

Compliance Schedule Activity	Due Date	Achieved Date
SAMPLING SITE PLAN	7/20/2020	
CROSS CONNECTION SURVEY REPORT	3/1/2021	
CROSS CONNECTION SURVEY REPORT	3/1/2022	
CROSS CONNECTION SURVEY REPORT	3/1/2023	
CROSS CONNECTION SURVEY REPORT	3/1/2024	
CROSS CONNECTION SURVEY REPORT	3/1/2025	
CROSS CONNECTION SURVEY REPORT	3/1/2026	

**Water System Facility and Sampling Point Inventory**

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total	Lead and	Stage
					Coliform Rule	Copper Rule Tier	
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A			
		4-01	KITCHEN SINK	A	Y		Y
		4-02	BAR SINK	A	Y		Y
		4-03	MENS ROOM AT BAR	A	Y		Y
		4-04	LADIES ROOM AT BAR	A	Y		Y
		4-05	LOBBY RESTROOM	A	Y		Y
		4-06	KITCHEN LEFT	A	Y		Y
		4-07	KITCHEN SMALL HAND	A	Y		Y
		4-08	CHEFS WORK AREA	A	Y		Y
		4-09	COLD PANTRY AREA	A	Y		Y
		4-10	BUS BOY AREA	A	Y		Y
		4-11	WINDSOR ROOM	A	Y		Y
		4-12	YORK ROOM	A	Y		Y
		4-13	STRATFORD ROOM	A	Y		Y
		4-14	CAMBRIDGE ROOM	A	Y		Y

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1189514	GOLF PERFORMANCE CENTER	NTNC	25	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
45 STONEHENGE ROAD			3		

Towns Served: RIDGEFIELD

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
					Y	Y	Y	Y
		4-15	WESTMINSTER ROOM	A	Y			
		4-16	OXFORD ROOM	A	Y			
		4-3	GENERATED BY BATCH	A	Y			
		4-4	GENERATED BY BATCH	A	Y			
		4-5	GENERATED BY BATCH	A	Y			
		4-7	GENERATED BY BATCH	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
53098	WELL 1	2	WELL 1	A				
61889	TREATMENT PLANT							
63006	ATMOSPHERIC STORAGE							
63008	PUMP FACILITY							

## Certified Operator Information

Water System Facility: **TREATMENT PLANT (WSF ID: 61889)**

Facility Classification:	CLASS 1 TREATMENT PLANT	Certification Expiration
<b>Operator Name</b>	<b>Operator Type</b>	<b>Certification(s)</b>

HURLBUT, PAUL CHIEF OPERATOR WATER TREATMENT PLANT OPERATOR - CLASS II 12/31/2028

## Contact Information

Name	Organization	Job Title		
Mr. John Foster	Eap Property, LLC	Owner		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
45 Stonehenge Rd		Ridgefield	CT	06877
Business Phone	Extension	Fax	Mobile Phone	Email Address
203-790-4653				203-790-4653 roger@thegolfperformancecenter.com

Contact Role(s): **Legal Contact, Owner**

Name	Organization	Job Title		
Mr. Edward Murphy	The Golf Performance Center	Facilities Manager		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
824 Ethan Allen Highway		Ridgefield	CT	06877
Business Phone	Extension	Fax	Mobile Phone	Email Address
203-790-4653				edward.murphy@thegolfperformancecenter.c

Contact Role(s): **Administrative Contact**

**NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.**

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
<b>CT1189514</b>	<b>GOLF PERFORMANCE CENTER</b>			NTNC	25	P	GW
Local Address (where applicable)		Service	Residential	Commercial	Industrial	Combined	Agricultural
45 STONEHENGE ROAD		Connections		3			

Towns Served: RIDGEFIELD

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

*<http://www.ct.gov/dph/publicdrinkingwater>*

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180653	ENCHANTED GARDEN - ETHAN ALLEN HWY	NTNC	61	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
529 ETHAN ALLEN HWY					1

Towns Served: RIDGEFIELD

## Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	1/1/17 - 12/31/25			
	1/1/26 - 12/31/34			
<b>Total Coliform (3100)</b>	<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete	
	10/1/25 - 12/31/25			
	1/1/26 - 3/31/26			
	4/1/26 - 6/30/26			
<b>Lead And Copper (PBCU)</b>	<b>5 routine (RT) per six months</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	7/1/25 - 12/31/25			
	1/1/26 - 6/30/26			
	7/1/26 - 12/31/26			
<b>Physical Parameters (PPS)</b>	<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete	
	10/1/25 - 12/31/25			
	1/1/26 - 3/31/26			
	4/1/26 - 6/30/26			

Water System Facility: ENTRY POINT (WSF ID: 00700)

<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/23 - 12/31/25			
	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete	
	1/1/26 - 12/31/26			
	1/1/27 - 12/31/27			
<b>Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)</b>	<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	
ENTRY POINT (3)	7/1/25 - 9/30/25		Complete	
	10/1/25 - 12/31/25			
	1/1/26 - 3/31/26			
	4/1/26 - 6/30/26			
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per quarter</b>			
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180653	ENCHANTED GARDEN - ETHAN ALLEN HWY	NTNC	61	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
529 ETHAN ALLEN HWY	Connections				1

Towns Served: RIDGEFIELD

### Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Organic Chemicals (VOCS)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	ENTRY POINT (3)	7/1/25 - 9/30/25		Complete
		10/1/25 - 12/31/25		
		1/1/26 - 3/31/26		
		4/1/26 - 6/30/26		

Water System Facility: WELL 1 (WSF ID: 63313)

E. Coli (3014)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	WELL 1 (2)	10/1/25 - 12/31/25		
		1/1/26 - 3/31/26		
		4/1/26 - 6/30/26		

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Coliform Status	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A	Y		
		EG01	3-5 YEAR CLASSROOM	A			
		EG02	2 YEAR CLASSROOM	A	Y		
		EG03	STAFF BATHROOM	A			
		EG04	FOOD PREP SINK	A			
		EG05	RESIDENT KITCHEN	A			
		EG06	RESIDENT DWNSTRS BAT	A			
		EG07	RESIDENT UPSTRS BATH	A			
		UPSTREAM	WITHIN 5 SERVICE CON	A	Y		
00700	ENTRY POINT	3	ENTRY POINT	A			
63313	WELL 1	2	WELL 1	A			
63315	TREATMENT PLANT						

### Certified Operator Information

Water System Facility: TREATMENT PLANT (WSF ID: 63315)

Facility Classification:	CLASS 1 TREATMENT PLANT	Certification Expiration
Operator Name	Operator Type	Certification(s)
LEMKE, BRIAN	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II
		3/31/2027

### Contact Information

Name	Organization	Job Title		
Mr. Aron Hirt-Manheimer	The Enchanted Garden LLC	Property Owner		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
99 New Street		Ridgefield	CT	06877

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1180653	ENCHANTED GARDEN - ETHAN ALLEN HWY	NTNC	61	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
529 ETHAN ALLEN HWY				1	

Towns Served: RIDGEFIELD

Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
203-431-8080					ahirtman@sbcglobal.net

Contact Role(s): **Legal Contact**

Name	Organization	Job Title
Mr. Isaac Hirt-Manheimer	The Enchanted Garden LLC	Director

Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
529 Ethan Allen Hwy		Ridgefield	CT	06877
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone
203-894-1987				203-885-2510
				enchantegrdrn@gmail.com

Contact Role(s): **Administrative Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**