

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1230092	SCOTLAND ELEMENTARY SCHOOL	NTNC	200	L	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
68 BROOK ROAD	Connections	1			

Towns Served: SCOTLAND

Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Asbestos (1094)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
Total Coliform (3100)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
Lead And Copper (PBCU)	5 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/26	6/1-9/30	
	1/1/27 - 12/31/29	6/1-9/30	
Physical Parameters (PPS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: ENTRY POINT- WELLS 1 & 2 (WSF ID: 00701)

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP- WELL 2 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP- WELL 2 (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	1 (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP- WELL 2 (3)	1/1/23 - 12/31/25	1/1-12/31	Waiver
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP- WELL 2 (3)	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Organic Chemicals (VOCS)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP- WELL 2 (3)	1/1/25 - 12/31/25		Complete

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1230092	SCOTLAND ELEMENTARY SCHOOL	NTNC	200	L	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
68 BROOK ROAD		1			

Towns Served: SCOTLAND

Monitoring Requirements

Water System Facility: ENTRY POINT- WELLS 1 & 2 (WSF ID: 00701)

Organic Chemicals (VOCS)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2026	

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule	Asbestos	Stage WQP 2 DBPR
					Rule	Rule Tier		
00600	DISTRIBUTION SYSTEM	001	GYM KITCHEN SINK	P	Y	2		
		002	TEACHER LOUNGE	P	Y	2		
		003	KINDERGARTEN	P	Y	2		
		004	BOILER ROOM (WELL)	P	Y	2		
		005	BOILER RM (TANK)	P	Y	2		
		4	DISTRIBUTION SYSTEM	A	Y			
		4-3	Room #7	A	Y			
		4-5	Room #2	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00701	ENTRY POINT- WELLS 1 & 2	3	EP- WELL 2	A				
10573	WELL #1	2	WELL #1	A				
55353	WELL #2	2	WELL #2	A				
55355	GAC FILTERS	3	ENTRY POINT	A				
55357	6K GAL ATM STORAGE							
55359	BOOSTER PUMPS (3)							

Certified Operator Information

Water System Facility: GAC FILTERS (WSF ID: 55355)

Facility Classification:		Certification Expiration
Operator Name	Operator Type	Certification(s)
LAFRAMBOISE, PAUL F.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I
		WATER TREATMENT PLANT OPERATOR - CLASS II

Contact Information

Name	Organization	Job Title
Ms. Valerie Bruneau	Scotland Elementary School	Superintendent
Mailing Address Line One	Mailing Address Line Two	City
68 Brook Road	P.O. Box 97	State
		Zip Code
Business Phone	Extension	Fax
Mobile Phone	Emergency Phone	Email Address

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1230092	SCOTLAND ELEMENTARY SCHOOL	NTNC	200	L	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
68 BROOK ROAD		1			

Towns Served: SCOTLAND

BUSINESS PHONE	EXTENSION	FAX	MOBILE PHONE	EMERGENCY PHONE	EMAIL ADDRESS
860-423-0064					VBruneau@scotlandes.org

Contact Role(s): **Administrative Contact**

Name	Organization	Job Title		
Mr. Gary Greenberg	Town of Scotland	First Selectman		
Mailing Address Line One 9 Devotion Road	Mailing Address Line Two P.O. Box 122	City Scotland	State CT	Zip Code 06264
Business Phone 860-456-7797	Extension 1	Fax	Mobile Phone	Emergency Phone Email Address firstselectman@scotlandct.org

Contact Role(s): **Legal Contact**

Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

If you have any questions, please contact the Drinking Water Section at (860) 509-7333.

<http://www.ct.gov/dph/publicdrinkingwater>

End of schedule