

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT1291152	NORTHFIELD COMMONS ASSOCIATION			NTNC	80	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
64 FIELD ROAD UNIT 2 A				1				

Towns Served: SOMERS

### Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
Lead And Copper (PBCU)		5 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/24	6/1-9/30	Complete
	1/1/25 - 12/31/25	6/1-9/30	Complete
	1/1/26 - 12/31/26	6/1-9/30	
Physical Parameters (PPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
Water System Facility: ENTRY POINT (WSF ID: 00700)			
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/27		
Nitrate And Nitrite (NOX)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Pesticides, Herbicides and PCBs-Phase II (SOC2)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
Pesticides, Herbicides and PCBs-Phase V (SOC5)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT1291152	NORTHFIELD COMMONS ASSOCIATION			NTNC	80	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
64 FIELD ROAD UNIT 2 A				1				
Towns Served: SOMERS								

### Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Organic Chemicals (VOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT (3)	1/1/25 - 12/31/27		

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2025	
CROSS CONNECTION EXEMPTION	3/1/2030	

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		NC1A	BLDG 1 UNIT A	P	Y	3	Y	
		NC1B	BLDG 1 UNIT B	P	Y	3	Y	
		NC1C	BLDG 1 UNIT C	P	Y	3	Y	
		NC1D	BLDG 1 UNIT D	P	Y	3	Y	
		NC2A	BLDG 2 UNIT A	P	Y	3	Y	
		NC2B	BLDG 2 UNIT B	P	Y	3	Y	
		NC2C	BLDG 2 UNIT C	P	Y	3	Y	
		NC2D	BLDG 2 UNIT D	P	Y	3	Y	
		NC2E	BLDG 2 UNIT E	P	Y	3	Y	
		NC2F	BLDG 2 UNIT F	P	Y	3	Y	
		NC3A	BLDG 3 UNIT A	P	Y	3	Y	
		NC3B	BLDG 3 UNIT B	P	Y	3	Y	
		NC3C	BLDG 3 UNIT C	P	Y	3	Y	
		NC3D	BLDG 3 UNIT D	P	Y	3	Y	
		NC4A	BLDG 4 UNIT A	P	Y	3	Y	
		NC4B	BLDG 4 UNIT B	P	Y	3	Y	
		NC4C	BLDG 4 UNIT C	P	Y	3	Y	
		NC4D	BLDG 4 UNIT D	P	Y	3	Y	
		NC4E	BLDG 4 UNIT E	P	Y	3	Y	
		NC4F	BLDG 4 UNIT F	P	Y	3	Y	
		NC5A	BLDG 5 UNIT A	P	Y	3	Y	
		NC5B	BLDG 5 UNIT B	P	Y	3	Y	
		NC5C	BLDG 5 UNIT C	P	Y	3	Y	
		NC5D	BLDG 5 UNIT D	P	Y	3	Y	
		UPSTREAM	WITHIN 5 SERVICE CON	A				
00700	ENTRY POINT	3	ENTRY POINT	A				
10584	WELL	2	WELL	A				

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type		Primary Source	
CT1291152	NORTHFIELD COMMONS ASSOCIATION			NTNC	80	P		GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
64 FIELD ROAD UNIT 2 A				1					
Towns Served: SOMERS									

### Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
NIGRO, JR., VICTOR N.	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2026
NIGRO, SCOTT A.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I	6/30/2028
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2026

### Contact Information

Name				Organization		Job Title			
Mr. Scott H. Sutter				Northfield Commons Association		Asso. President			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
64 Field Rd			Unit 1A			Somers		CT	06071
Business Phone		Extension	Fax	Mobile Phone	Emergency Phone	Email Address			
413-519-6566					413-519-6566	scott@srtins.com			

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

***End of schedule***

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT1299033	GROWER DIRECT FARMS INC			NTNC	160	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
164 HAMPDEN ROAD								1

Towns Served: SOMERS

### Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		Complete
Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
Lead And Copper (PBCU)		5 routine (RT) per six months	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 6/30/25		Complete
	7/1/25 - 12/31/25		Complete
	1/1/26 - 6/30/26		
Physical Parameters (PPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
Water System Facility: ENTRY POINT (WSF ID: 00700)			
Nitrate (1040)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Nitrite (1041)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/26 - 12/31/28		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section										
Water Quality Monitoring and Compliance Schedule										
PWS ID	PWS Name				Classification	Population	Owner Type	Primary Source		
CT1299033	GROWER DIRECT FARMS INC				NTNC	160	P	GW		
Local Address (where applicable)				Service Connections	Residential	Commercial	Industrial	Combined	Agricultural	
164 HAMPDEN ROAD									1	
Towns Served: SOMERS										
Monitoring Requirements										
Water System Facility: ENTRY POINT (WSF ID: 00700)										
Organic Chemicals (VOCS)					1 routine (RT) per year					
Sampling Point (Sampling Point ID)					Monitoring Period		Collection Period		Compliance Status	
ENTRY POINT (3)					1/1/24 - 12/31/24				Complete	
					1/1/25 - 12/31/25				Complete	
					1/1/26 - 12/31/26					
Other Compliance Schedules										
Compliance Schedule Activity					Due Date		Achieved Date			
CROSS CONNECTION SURVEY REPORT					3/1/2026					
Water System Facility and Sampling Point Inventory										
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2	DBPR	
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION	A						
		DOWNSTREAM	WITHIN 5 SERVICE CON	A						
		GDF005	OFFICE MEN'S ROOM	A	Y	2	Y			
		GDF010	OFFICE LADIES ROOM	A	Y	2	Y			
		GDF015	KITCHEN SINK	A	Y	2	Y			
		GDF020	MENS BATH	A	Y	2	Y			
		GDF025	LADIES BATH	A	Y	2	Y			
		UPSTREAM	WITHIN 5 SERVICE CON	A						
00700	ENTRY POINT	3	ENTRY POINT	A						
54858	WELL	2	WELL	A						
Certified Operator Information										
Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)										
Facility Classification: SMALL WATER SYSTEM										
Operator Name		Operator Type		Certification(s)				Certification Expiration		
NIGRO, JR., VICTOR N.		CHIEF OPERATOR		WATER TREATMENT PLANT OPERATOR - CLASS II				6/30/2027		
				DISTRIBUTION SYSTEM OPERATOR - CLASS III				6/30/2026		
NIGRO, SCOTT A.		ASSIGNED OPERATOR		DISTRIBUTION SYSTEM OPERATOR - CLASS I				6/30/2028		
				WATER TREATMENT PLANT OPERATOR - CLASS II				6/30/2026		
NIGRO, DAVID		ASSIGNED OPERATOR		WATER TREATMENT PLANT OPERATOR - CLASS I				3/31/2028		
Contact Information										
Name				Organization			Job Title			
Mr. Sam C. Smith				Grower Direct Farms, Inc			Co-Owner			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code	
164 Hampden Rd						Somers		CT	06071	
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address					
860-265-7100	7117	860-763-3096			sam@growerdirectfarms.com					

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT1299033</b>	<b>GROWER DIRECT FARMS INC</b>	<b>NTNC</b>	<b>160</b>	<b>P</b>	<b>GW</b>
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
164 HAMPDEN ROAD					
Towns Served: SOMERS					
Contact Role(s): <b>Legal Contact</b>					
Name		Organization		Job Title	
<b>Mr. Adam A. Van Wingerden</b>		Grower Direct Farms, Inc		Co-Owner	
Mailing Address Line One		Mailing Address Line Two		City	State
164 Hampden Rd				Somers	CT
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
860-265-7100	7118	860-763-3096			adam@growerdirectfarms.com
Contact Role(s): <b>Owner</b>					
Name		Organization		Job Title	
<b>Mr. Mark A. Netherton II</b>		Grower Direct Farms		Maintenance Manager	
Mailing Address Line One		Mailing Address Line Two		City	State
164 Hampden Rd				Somers	CT
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
413-206-8910					markn@gdf.farm
Contact Role(s): <b>Administrative Contact</b>					
<p><b>Please note the following:</b></p> <ol style="list-style-type: none"> <li>1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.</li> <li>2. If a Collection Period is specified, all water quality samples must be collected during the specified period.</li> <li>3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.</li> </ol>					

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

***End of schedule***