

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1310011	SOUTHBURY WATER DEPARTMENT	C	43,069	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
					13,665

Towns Served: CHESHIRE, SOUTHBURY, WOLCOTT

### Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

<b>Chlorine Residual (1012)</b>	<b>50 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/21 - 12/31/29		
<b>Total Coliform (3100)</b>	<b>50 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
<b>Disinfectant Byproducts - TTHM &amp; HAAs (DBP)</b>	<b>4 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
2279 MT VERNON RD (SMP0004)	7/1/25 - 9/30/25	8/1-8/31	Complete
	10/1/25 - 12/31/25	11/1-11/30	Complete
	1/1/26 - 3/31/26	2/1-2/28	
	4/1/26 - 6/30/26	5/1-5/31	
252 MARION AVENUE (SWD0003)	7/1/25 - 9/30/25	8/1-8/31	Complete
	10/1/25 - 12/31/25	11/1-11/30	Complete
	1/1/26 - 3/31/26	2/1-2/28	
	4/1/26 - 6/30/26	5/1-5/31	
6 CARTER LANE (SWD0021)	7/1/25 - 9/30/25	8/1-8/31	Complete
	10/1/25 - 12/31/25	11/1-11/30	Complete
	1/1/26 - 3/31/26	2/1-2/28	
	4/1/26 - 6/30/26	5/1-5/31	
2321 MERIDEN WTBY RD (SWD0022)	7/1/25 - 9/30/25	8/1-8/31	Complete
	10/1/25 - 12/31/25	11/1-11/30	Complete

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1310011	SOUTHBURY WATER DEPARTMENT	C	43,069	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
					13,665

Towns Served: CHESHIRE, SOUTHBURY, WOLCOTT

### Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

**Disinfectant Byproducts - TTHM & HAA5 (DBP)**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	1/1/26 - 3/31/26	2/1-2/28	
	4/1/26 - 6/30/26	5/1-5/31	

**Lead And Copper (PBCU)**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/26	6/1-9/30	
	1/1/27 - 12/31/29	6/1-9/30	

**Physical Parameters (PPS)**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: SOUTHBURY FP - ENTRY POINT (WSF ID: 00700)

**Net Gross Alpha (4000)**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - SOUTHBURY FP (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

**Uranium (4006)**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - SOUTHBURY FP (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

**Combined Radium-226/228 (4010)**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - SOUTHBURY FP (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

**Inorganic Chemicals (IOCS)**

Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
------------------------------------	-------------------	-------------------	-------------------

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1310011	SOUTHBURY WATER DEPARTMENT	C	43,069	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural

Towns Served: CHESHIRE, SOUTHBURY, WOLCOTT

## Monitoring Requirements

Water System Facility: SOUTHBURY FP - ENTRY POINT (WSF ID: 00700)

Inorganic Chemicals (IOCS)				1 routine (RT) per year
Sampling Point (Sampling Point ID)		Monitoring Period	Collection Period	Compliance Status
EP - SOUTHBURY FP (3)		1/1/25 - 12/31/25		Complete
		1/1/26 - 12/31/26		
		1/1/27 - 12/31/27		
Nitrate And Nitrite (NOX)				1 routine (RT) per year
Sampling Point (Sampling Point ID)		Monitoring Period	Collection Period	Compliance Status
EP - SOUTHBURY FP (3)		1/1/25 - 12/31/25		Complete
		1/1/26 - 12/31/26		
		1/1/27 - 12/31/27		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)				2 routine (RT) per three years
Sampling Point (Sampling Point ID)		Monitoring Period	Collection Period	Compliance Status
EP - SOUTHBURY FP (3)		1/1/23 - 12/31/25		Complete
		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		
Organic Chemicals (VOCS)				1 routine (RT) per year
Sampling Point (Sampling Point ID)		Monitoring Period	Collection Period	Compliance Status
EP - SOUTHBURY FP (3)		1/1/25 - 12/31/25		Complete
		1/1/26 - 12/31/26		
		1/1/27 - 12/31/27		

Water System Facility: ENTRY POINT - WELL 1A (WSF ID: 00701)

Net Gross Alpha (4000)				1 routine (RT) per three years
Sampling Point (Sampling Point ID)		Monitoring Period	Collection Period	Compliance Status
EP - WELL 1A (3)		1/1/23 - 12/31/25		Complete
		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		
Uranium (4006)				1 routine (RT) per three years
Sampling Point (Sampling Point ID)		Monitoring Period	Collection Period	Compliance Status
EP - WELL 1A (3)		1/1/23 - 12/31/25		Complete
		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		
Combined Radium-226/228 (4010)				1 routine (RT) per three years
Sampling Point (Sampling Point ID)		Monitoring Period	Collection Period	Compliance Status
EP - WELL 1A (3)		1/1/23 - 12/31/25		Complete
		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		
Gross Beta Particle Activity (4100)				1 routine (RT) per three years
Sampling Point (Sampling Point ID)		Monitoring Period	Collection Period	Compliance Status
EP - WELL 1A (3)		1/1/23 - 12/31/25		Complete
		1/1/26 - 12/31/28		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1310011	SOUTHBURY WATER DEPARTMENT	C	43,069	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural

Towns Served: CHESHIRE, SOUTHBURY, WOLCOTT

### Monitoring Requirements

Water System Facility: ENTRY POINT - WELL 1A (WSF ID: 00701)

<b>Gross Beta Particle Activity (4100)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/29 - 12/31/31		
<b>Man-Made Beta Particle &amp; Photon Emitters (4101)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 1A (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Tritium (4102)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 1A (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Strontium-90 (4174)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 1A (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 1A (3)	1/1/24 - 12/31/26		Complete
	1/1/27 - 12/31/29		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 1A (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
<b>Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)</b>	<b>2 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 1A (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 1A (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Water System Facility: ENTRY POINT - WELLS 2 & 2A (WSF ID: 00702)

<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1310011	SOUTHBURY WATER DEPARTMENT	C	43,069	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
					13,665

Towns Served: CHESHIRE, SOUTHBURY, WOLCOTT

### Monitoring Requirements

Water System Facility: ENTRY POINT - WELLS 2 & 2A (WSF ID: 00702)

1 routine (RT) per three years				
Inorganic Chemicals (IOCS)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - WELLS 2 & 2A (3)		1/1/23 - 12/31/25		Complete
		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		
Nitrate And Nitrite (NOX)	1 routine (RT) per year			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
EP - WELLS 2 & 2A (3)	1/1/25 - 12/31/25		Complete	
	1/1/26 - 12/31/26			
	1/1/27 - 12/31/27			
Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)	1 routine (RT) per three years			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
EP - WELLS 2 & 2A (3)	1/1/24 - 12/31/26		Complete	
	1/1/27 - 12/31/29			
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	1 routine (RT) per three years			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
EP - WELLS 2 & 2A (3)	1/1/24 - 12/31/26		Complete	
	1/1/27 - 12/31/29			
Organic Chemicals (VOCS)	1 routine (RT) per year			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
EP - WELLS 2 & 2A (3)	1/1/25 - 12/31/25		Complete	
	1/1/26 - 12/31/26			
	1/1/27 - 12/31/27			

Water System Facility: ENTRY POINT - WELL 3 (WSF ID: 00703)

1 routine (RT) per quarter				
Nitrate (1040)	Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - WELL 3 (3)		7/1/25 - 9/30/25		Complete
		10/1/25 - 12/31/25		Complete
		1/1/26 - 3/31/26		
		4/1/26 - 6/30/26		
Nitrite (1041)	1 routine (RT) per year			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
EP - WELL 3 (3)	1/1/25 - 12/31/25		Complete	
	1/1/26 - 12/31/26			
	1/1/27 - 12/31/27			
Net Gross Alpha (4000)	1 routine (RT) per three years			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
EP - WELL 3 (3)	1/1/23 - 12/31/25		Complete	
	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1310011	SOUTHBURY WATER DEPARTMENT	C	43,069	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: CHESHIRE, SOUTHBURY, WOLCOTT

## Monitoring Requirements

Water System Facility: ENTRY POINT - WELL 3 (WSF ID: 00703)

<b>Uranium (4006)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 3 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 3 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Gross Beta Particle Activity (4100)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 3 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Man-Made Beta Particle &amp; Photon Emitters (4101)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 3 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Tritium (4102)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 3 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Strontium-90 (4174)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 3 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 3 (3)	1/1/24 - 12/31/26		Complete
	1/1/27 - 12/31/29		
<b>Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)</b>	<b>2 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 3 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1310011	SOUTHBURY WATER DEPARTMENT	C	43,069	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
					13,665

Towns Served: CHESHIRE, SOUTHBURY, WOLCOTT

**Monitoring Requirements**

Water System Facility: ENTRY POINT - WELL 3 (WSF ID: 00703)

Organic Chemicals (VOCS)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - WELL 3 (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Water System Facility: ENTRY POINT - WELLS 7 & 7A (WSF ID: 00704)

Metolachlor (2045)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT - WELLS 7 & 7A (3)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT - WELLS 7 & 7A (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

Nitrate And Nitrite (NOX)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT - WELLS 7 & 7A (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Radionuclides - Gross Alpha, Combined Radium & Uranium (RADA)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT - WELLS 7 & 7A (3)	1/1/25 - 12/31/27		

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)	2 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT - WELLS 7 & 7A (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

Organic Chemicals (VOCS)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT - WELLS 7 & 7A (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Water System Facility: ENTRY POINT - WELL 8 (WSF ID: 00705)

Net Gross Alpha (4000)	1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - WELL 8 (3)	1/1/23 - 12/31/25		Complete

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1310011	SOUTHBURY WATER DEPARTMENT	C	43,069	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
					13,665

Towns Served: CHESHIRE, SOUTHBURY, WOLCOTT

## Monitoring Requirements

Water System Facility: ENTRY POINT - WELL 8 (WSF ID: 00705)

<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Uranium (4006)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 8 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 8 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 8 (3)	1/1/24 - 12/31/26		Complete
	1/1/27 - 12/31/29		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 8 (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
<b>Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)</b>	<b>2 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 8 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 8 (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
Water System Facility: ENTRY POINT - WELL 9 (WSF ID: 00706)			
<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 9 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1310011	SOUTHBURY WATER DEPARTMENT	C	43,069	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural

Towns Served: CHESHIRE, SOUTHBURY, WOLCOTT

### Monitoring Requirements

Water System Facility: ENTRY POINT - WELL 9 (WSF ID: 00706)

<b>Uranium (4006)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 9 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 9 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 9 (3)	1/1/24 - 12/31/26		Complete
	1/1/27 - 12/31/29		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 9 (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
<b>Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)</b>	<b>2 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 9 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELL 9 (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
Water System Facility: WELL 8 (WSF ID: 1170)			
<b>E. Coli (3014)</b>	<b>1 routine (RT) per month</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 8 (2)	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1310011	SOUTHBURY WATER DEPARTMENT	C	43,069	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural

Towns Served: CHESHIRE, SOUTHBURY, WOLCOTT

## Monitoring Requirements

Water System Facility: WELL 8 (WSF ID: 1170)

E. Coli (3014) <span style="float: right;">1 routine (RT) per month</span>			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: WELL 1A (WSF ID: 1172)

E. Coli (3014) <span style="float: right;">1 routine (RT) per month</span>			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 1A (2)	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: WELL 3 (WSF ID: 1173)

E. Coli (3014) <span style="float: right;">1 routine (RT) per month</span>			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 3 (2)	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: WELL 9 (WSF ID: 1451)

E. Coli (3014) <span style="float: right;">1 routine (RT) per month</span>			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1310011	SOUTHBURY WATER DEPARTMENT	C	43,069	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural

Towns Served: CHESHIRE, SOUTHBURY, WOLCOTT

## Monitoring Requirements

Water System Facility: WELL 9 (WSF ID: 1451)

1 routine (RT) per month			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 9 (2)	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: SOUTHBURY RESERVOIR #1 (WSF ID: 2235)

1 routine (RT) per month			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
SOUTHBURY RESERVOIR #1 (1)	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

1 routine (RT) per month			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
SOUTHBURY RESERVOIR #1 (1)	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

1 routine (RT) per year			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
SOUTHBURY RESERVOIR #1 (1)	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

1 routine (RT) per quarter			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
SOUTHBURY RESERVOIR #1 (1)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

1 routine (RT) per year			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1310011	SOUTHBURY WATER DEPARTMENT	C	43,069	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: CHESHIRE, SOUTHBURY, WOLCOTT

## Monitoring Requirements

Water System Facility: SOUTHBURY RESERVOIR #1 (WSF ID: 2235)

Surface Water Pesticides (RSOC)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
SOUTHBURY RESERVOIR #1 (1)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Water System Facility: SOUTHBURY RESERVOIR #3 (WSF ID: 2237)

Total Coliform (3100)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
SOUTHBURY RESERVOIR #3 (1)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Surface Water Inorganic Chemicals (RIOC)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
SOUTHBURY RESERVOIR #3 (1)	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Surface Water Color and Turbidity (RPPS)	1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
SOUTHBURY RESERVOIR #3 (1)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Surface Water Pesticides (RSOC)	1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
SOUTHBURY RESERVOIR #3 (1)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Water System Facility: SOUTHBURY FILTER PLANT (WSF ID: 310)

Total Organic Carbon (2920)	1 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
EP - SOUTHBURY FP (5)	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: WELL 7A (WSF ID: 60726)

E. Coli (3014)	1 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 7A (2)	8/1/25 - 8/31/25		Complete

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1310011	SOUTHBURY WATER DEPARTMENT	C	43,069	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: CHESHIRE, SOUTHBURY, WOLCOTT

## Monitoring Requirements

Water System Facility: WELL 7A (WSF ID: 60726)

E. Coli (3014)			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: WELL 2A (WSF ID: 61740)

E. Coli (3014)			
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
WELL 2A (2)	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

## Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: SOUTHBURY FP - ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit		Samples Req/Month	
		Compliance History:	Operating Limit	Monitoring Period	Compliance Status:
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L		Daily	
Start Date: 5/1/2023					
		8/1/2025 - 8/31/2025			
		9/1/2025 - 9/30/2025			
		10/1/2025 - 10/31/2025			
		11/1/2025 - 11/30/2025			
		12/1/2025 - 12/31/2025			

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1310011	SOUTHBURY WATER DEPARTMENT	C	43,069	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
					13,665

Towns Served: CHESHIRE, SOUTHBURY, WOLCOTT

Water System Facility: SOUTHBURY FP - ENTRY POINT (WSID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily	
<b>Start Date:</b> 5/1/2023		<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
		8/1/2025 - 8/31/2025	Y	
		9/1/2025 - 9/30/2025	Y	
		10/1/2025 - 10/31/2025	Y	
	Offline	11/1/2025 - 11/30/2025	n/a	Y
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
pH	Entry Point pH Monitoring (PHRD)	Minimum: 6.8 PH	Daily	
<b>Start Date:</b> 7/1/2003		<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Maximum: 3 MG/L	2	
<b>Start Date:</b> 7/1/2003		<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		

Water System Facility: ENTRY POINT - WELL 1A (WSID: 00701)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month	
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.53 MG/L	Daily	
<b>Start Date:</b> 6/1/2010		<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
		<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
		8/1/2025 - 8/31/2025		
		9/1/2025 - 9/30/2025		
		10/1/2025 - 10/31/2025		
		11/1/2025 - 11/30/2025		
		12/1/2025 - 12/31/2025		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1310011	SOUTHBURY WATER DEPARTMENT	C	43,069	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural

Towns Served: CHESHIRE, SOUTHBURY, WOLCOTT

### Water System Facility: ENTRY POINT - WELL 1A (WSFID: 00701)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
<b>Start Date:</b> 5/1/2023		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Monitoring Compliance Status:</b>
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	
<b>Analyte</b>	<b>Monitoring Requirement (Summary Type)</b>	<b>Operating Limit</b>	<b>Samples Req/Month</b>
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
<b>Start Date:</b> 5/1/2023		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Monitoring Compliance Status:</b>
		8/1/2025 - 8/31/2025	Y
		9/1/2025 - 9/30/2025	Y
		10/1/2025 - 10/31/2025	Y
		11/1/2025 - 11/30/2025	Y
		12/1/2025 - 12/31/2025	

### Water System Facility: ENTRY POINT - WELLS 2 & 2A (WSFID: 00702)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 1/1/2020		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Monitoring Compliance Status:</b>
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	
<b>Analyte</b>	<b>Monitoring Requirement (Summary Type)</b>	<b>Operating Limit</b>	<b>Samples Req/Month</b>
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
<b>Start Date:</b> 5/1/2023		<b>Compliance History:</b>	<b>Operating Limit</b>
		<b>Monitoring Period</b>	<b>Monitoring Compliance Status:</b>
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT1310011</b>	<b>SOUTHBURY WATER DEPARTMENT</b>	C	43,069	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					13,665

Towns Served: CHESHIRE, SOUTHBURY, WOLCOTT

Water System Facility: **ENTRY POINT - WELLS 2 & 2A (WSID: 00702)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
<b>Start Date:</b> 5/1/2023			
	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025	Y	
	10/1/2025 - 10/31/2025	Y	
	11/1/2025 - 11/30/2025	Y	
	12/1/2025 - 12/31/2025		
<b>Analyte</b>	<b>Monitoring Requirement (Summary Type)</b>	<b>Operating Limit</b>	<b>Samples Req/Month</b>
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Maximum: 3.0 MG/L	2
<b>Start Date:</b> 1/1/2020			
	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		
	11/1/2025 - 11/30/2025		
	12/1/2025 - 12/31/2025		

Water System Facility: **ENTRY POINT - WELL 3 (WSID: 00703)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 5/1/2005			
	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		
	11/1/2025 - 11/30/2025		
	12/1/2025 - 12/31/2025		
<b>Analyte</b>	<b>Monitoring Requirement (Summary Type)</b>	<b>Operating Limit</b>	<b>Samples Req/Month</b>
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
<b>Start Date:</b> 5/1/2023			
	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		
	11/1/2025 - 11/30/2025		
	12/1/2025 - 12/31/2025		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT1310011</b>	<b>SOUTHBURY WATER DEPARTMENT</b>	C	43,069	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					13,665

Towns Served: CHESHIRE, SOUTHBURY, WOLCOTT

Water System Facility: **ENTRY POINT - WELL 3 (WSID: 00703)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
<b>Start Date:</b> 5/1/2023			
	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025	Y	
	10/1/2025 - 10/31/2025	Y	
	11/1/2025 - 11/30/2025	Y	
	12/1/2025 - 12/31/2025		

Water System Facility: **ENTRY POINT - WELLS 7 & 7A (WSID: 00704)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 10/1/2017			
	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		
	11/1/2025 - 11/30/2025		
	12/1/2025 - 12/31/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
<b>Start Date:</b> 5/1/2023			
	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		
	11/1/2025 - 11/30/2025		
	12/1/2025 - 12/31/2025		

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
<b>Start Date:</b> 5/1/2023			
	<b>Compliance History:</b>	<b>Operating Limit</b>	<b>Monitoring</b>
	<b>Monitoring Period</b>	<b>Compliance Status:</b>	<b>Compliance Status:</b>
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025	Y	
	10/1/2025 - 10/31/2025	Y	
	11/1/2025 - 11/30/2025	Y	
	12/1/2025 - 12/31/2025		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1310011	SOUTHBURY WATER DEPARTMENT	C	43,069	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural

Towns Served: CHESHIRE, SOUTHBURY, WOLCOTT

Water System Facility: ENTRY POINT - WELLS 7 & 7A (WSFID: 00704)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.1 MG/L	2
Start Date: 10/1/2017		Compliance History: Monitoring Period	Operating Limit Monitoring Compliance Status: Compliance Status:
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

Water System Facility: ENTRY POINT - WELL 8 (WSFID: 00705)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 5/1/2005		Compliance History: Monitoring Period	Operating Limit Monitoring Compliance Status: Compliance Status:
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 5/1/2023		Compliance History: Monitoring Period	Operating Limit Monitoring Compliance Status: Compliance Status:
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 5/1/2023		Compliance History: Monitoring Period	Operating Limit Monitoring Compliance Status: Compliance Status:
		8/1/2025 - 8/31/2025	Y
		9/1/2025 - 9/30/2025	Y
		10/1/2025 - 10/31/2025	Y
		11/1/2025 - 11/30/2025	Y
		12/1/2025 - 12/31/2025	

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT1310011</b>	<b>SOUTHBURY WATER DEPARTMENT</b>	C	43,069	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
					13,665

Towns Served: CHESHIRE, SOUTHBURY, WOLCOTT

**Water System Facility: ENTRY POINT - WELL 8 (WSID: 00705)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Maximum: 3 MG/L	2
<b>Start Date:</b> 1/1/2002		<b>Compliance History:</b>	
		<b>Monitoring Period</b>	<b>Operating Limit</b>
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

**Water System Facility: ENTRY POINT - WELL 9 (WSID: 00706)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 5/1/2005		<b>Compliance History:</b>	
		<b>Monitoring Period</b>	<b>Operating Limit</b>
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
<b>Start Date:</b> 5/1/2023		<b>Compliance History:</b>	
		<b>Monitoring Period</b>	<b>Operating Limit</b>
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
<b>Start Date:</b> 5/1/2023		<b>Compliance History:</b>	
		<b>Monitoring Period</b>	<b>Operating Limit</b>
		8/1/2025 - 8/31/2025	Y
		9/1/2025 - 9/30/2025	Y
		10/1/2025 - 10/31/2025	Y
		11/1/2025 - 11/30/2025	Y
		12/1/2025 - 12/31/2025	

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1310011	SOUTHBURY WATER DEPARTMENT	C	43,069	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural

Towns Served: CHESHIRE, SOUTHBURY, WOLCOTT

### Water System Facility: ENTRY POINT - WELL 9 (WSID: 00706)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Phosphate (as PO4)	Entry Point Phosphate Monitoring (PHOS)	Maximum: 3 MG/L	2
<b>Start Date:</b> 10/1/2003		<b>Compliance History:</b>	
		<b>Monitoring Period</b>	<b>Operating Limit</b>
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

### Water System Facility: SOUTHBURY FILTER PLANT (WSID: 310)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
<b>Start Date:</b> 1/1/2002		<b>Compliance History:</b>	
		<b>Monitoring Period</b>	<b>Operating Limit</b>
		8/1/2025 - 8/31/2025	Y
		9/1/2025 - 9/30/2025	Y
		10/1/2025 - 10/31/2025	Y
	Offline	11/1/2025 - 11/30/2025	n/a
		12/1/2025 - 12/31/2025	Y

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
<b>Start Date:</b> 1/1/2002		<b>Compliance History:</b>	
		<b>Monitoring Period</b>	<b>Operating Limit</b>
		8/1/2025 - 8/31/2025	Y
		9/1/2025 - 9/30/2025	Y
		10/1/2025 - 10/31/2025	Y
	Offline	11/1/2025 - 11/30/2025	n/a
		12/1/2025 - 12/31/2025	Y

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
<b>Start Date:</b> 1/1/2002		<b>Compliance History:</b>	
		<b>Monitoring Period</b>	<b>Operating Limit</b>
		8/1/2025 - 8/31/2025	Y
		9/1/2025 - 9/30/2025	Y
		10/1/2025 - 10/31/2025	Y
	Offline	11/1/2025 - 11/30/2025	n/a
		12/1/2025 - 12/31/2025	Y

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
MAIL/HAND DELIVER NOTICE TO CONSUMERS	12/31/2025	
CROSS CONNECTION SURVEY REPORT		3/1/2026

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1310011	SOUTHBURY WATER DEPARTMENT	C	43,069	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
					13,665

Towns Served: CHESHIRE, SOUTHBURY, WOLCOTT

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CERTIFY LEAD SL NOTIFICATION	7/1/2026	

## Public Notification Requirements

Violation/Situation	Compliance Period	Notice Tier	Public Notification Required	Public Notification Performed	PN Certification Due to DPH	PN Certification Received
Total Organic Carbon M&R Violation	3/1/25 - 3/31/25	3	10/1/2026		10/11/2026	
Total Organic Carbon M&R Violation	3/1/25 - 3/31/25	3	10/1/2026		10/11/2026	
Total Alkalinity M&R Violation	3/1/25 - 3/31/25	3	10/1/2026		10/11/2026	

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper	Stage WQP 2 DBPR
					Rule	Rule Tier	
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y		
		4-1	FLANDERS SCHOOL	A	Y		
		4-2	HATTON SCHOOL	A	Y		
		4-3	KELLEY SCHOOL	A	Y		
		4-4	JW MUNICIPAL CENTER	A	Y		
		4-5	SOUTH END SCHOOL	A	Y		
		4-6	STRONG SCHOOL	A	Y		
		DOWNSTREAM	WITHIN 5 SERVICE CON	A			
		S-15	WELL 3 RAW/HOBART ST	A	Y		
		SMP0004	2279 MT VERNON RD	A	Y		Y
		SMP004	2279 MT. VERNON RD	A	Y		
		SWD0001	200 EXECUTIVE BLVD	I	Y		
		SWD0002	570 MAIN STREET	I	Y		
		SWD0003	252 MARION AVENUE	A	Y		Y
		SWD0004	1237 MARION AVENUE	A	Y		Y
		SWD0005	1156 M.W.T.	A	Y		
		SWD0006	65 AMATO CIRCLE	I	Y		
		SWD0007	88 BERLIN STREET	A	Y		
		SWD0008	460 PLEASANT STREET	I	Y		
		SWD0009	408 QUEEN STREET	A	Y		
		SWD0010	50 RIVER STREET	A	Y		
		SWD0011	246 REDSTONE STREET	A	Y		
		SWD0012	FILTER PLANT	A			
		SWD0013	ST DOMINIC'S CHURCH	A			
		SWD0014	FLANDERS SCHOOL	A			Y
		SWD0015	DEPAULO SCHOOL	A			
		SWD0016	TRUCK STOP	A			
		SWD0017	LAKE COMPOUNCE PARK	A			
		SWD0018	388 PLEASANT STREET	A	Y		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT1310011</b>	<b>SOUTHBURY WATER DEPARTMENT</b>	C	43,069	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
					13,665

Towns Served: CHESHIRE, SOUTHBURY, WOLCOTT

**Water System Facility and Sampling Point Inventory**

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total	Lead and Coliform	Copper	Asbestos	WQP 2	Stage DBPR
					Rule	Rule Tier				
	SWD0019	620 MAIN STREET		I	Y					
	SWD0020	1131 WEST STREET		A	Y					
	SWD0021	6 CARTER LANE		A	Y					Y
	SWD0022	2321 MERIDEN WTBY RD		A	Y					
	SWD0A01	KELLEY SCHOOL		A						Y
	SWD0A02	HATTON SCHOOL		A						Y
	SWD0A03	SOUTH END SCHOOL		A						Y
	SWD0A04	JW MUNICIPAL CENTER		A						Y
	SWD0A05	STRONG SCHOOL		A						Y
	SWDLC01	29 AMANDA LANE		I	Y	1				
	SWDLC02	37 AMANDA LANE		A	Y	1				
	SWDLC03	48 AMANDA LANE		I	Y	1				
	SWDLC04	54 AMATO CIRCLE		I	Y	1				
	SWDLC05	64 AMATO CIRCLE		I	Y	1				
	SWDLC06	65 AMATO CIRCLE		I	Y	1				
	SWDLC07	289 ANNELISE AVENUE		A	Y	1				
	SWDLC08	93 BISHOP AVENUE		A	Y	1				
	SWDLC09	27 BRIGHTWOOD LANE		A	Y	1				
	SWDLC10	73 BRIGHTWOOD LANE		I	Y	1				
	SWDLC100	56 CARTER LN		A	Y	1				
	SWDLC101	53 ELM ST		A		1				
	SWDLC102	81 GROVE ST		A		1				
	SWDLC103	47 HIGHWOOD AVE		A		1				
	SWDLC104	55 HOMESDALE AVE		A		1				
	SWDLC105	30 KNOX DR		A		1				
	SWDLC106	5 LACEY RD		A		1				
	SWDLC107	38 MACARTHUR DR		A		1				
	SWDLC108	128 MERIDEN AVE		A		1				
	SWDLC109	291 MERIDEN AVE		A		1				
	SWDLC111	93 BUCKLAND STREET		A	Y	1				
	SWDLC110	1585 MWT		A		1				
	SWDLC111	57 MERRELL AVE		A		1				
	SWDLC112	82 NORTON ST		A		1				
	SWDLC113	67 OAKLAND RD		A		1				
	SWDLC114	327 SOUTH END RD		A		1				
	SWDLC115	972 SOUTH MAIN ST		A		1				
	SWDLC116	106 SUMMER ST		A		1				
	SWDLC117	73 SUNNYRIDGE DR		A		1				

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT1310011</b>	<b>SOUTHBURY WATER DEPARTMENT</b>	C	43,069	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					13,665

Towns Served: CHESHIRE, SOUTHBURY, WOLCOTT

**Water System Facility and Sampling Point Inventory**

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
					Rule			
	SWDLC118	18 TAUNTON ST		A		1		
	SWDLC119	31 VERMONT TERRACE		A		1		
	SWDLC12	163 BUTTERNUT LANE		A	Y	1		
	SWDLC120	164 WEST MAIN ST		A		1		
	SWDLC121	167 WONX SPRING RD		A		1		
	SWDLC13	29 CANTERBURY LANE		A	Y	1		
	SWDLC14	130 CICCOLELLA COURT		A	Y	1		
	SWDLC15	140 CREST ROAD		A	Y	1		
	SWDLC16	54 DAYTON DRIVE		A	Y	1		
	SWDLC17	197 DECKERT DRIVE		I	Y	1		
	SWDLC18	73 DEERBROOKE CRICLE		I	Y	1		
	SWDLC19	93 DOE MEADOW COURT		I	Y	1		
	SWDLC20	105 DOE MEADOW COURT		A	Y	1		
	SWDLC21	54GALLANT DRIVE		A	Y	1		
	SWDLC22	87 GREAT PINE PATH		A	Y	1		
	SWDLC23	28 GREENWOOD DRIVE		I	Y	1		
	SWDLC24	50 GREENWOOD DRIVE		I	Y	1		
	SWDLC25	6 GREYSTONE DRIVE		I	Y	1		
	SWDLC26	20 GREYSTONE DRIVE		I	Y	1		
	SWDLC27	32 GREYSTOKE DRIVE		I	Y	1		
	SWDLC28	50 GREYSTONE DRIVE		A	Y	1		
	SWDLC29	51 GREYSTONE DRIVE		A	Y	1		
	SWDLC30	78 GREYSTONE DRIVE		A	Y	1		
	SWDLC31	105 GREYSTONE DRIVE		I	Y	1		
	SWDLC32	461 HART STREET		A	Y	1		
	SWDLC33	82 HOLLY HILL DRIVE		A	Y	1		
	SWDLC34	96 HOLLY HILL DRIVE		A	Y	1		
	SWDLC35	139 HUCKLEBERRY LANE		A	Y	1		
	SWDLC36	192 LEPAGE DRIVE		A	Y	1		
	SWDLC37	24 MARK DRIVE		A	Y	1		
	SWDLC38	50 MARK DRIVE		I	Y	1		
	SWDLC39	580 MOUNT VERNON RD		A	Y	1		
	SWDLC40	10 NUNZIO DRIVE		I	Y	1		
	SWDLC41	50 NUNZIO DRIVE		A	Y	1		
	SWDLC42	64 NUNZIO DRIVE		I	Y	1		
	SWDLC43	65 NUNZIO DRIVE		I	Y	1		
	SWDLC44	74 NUNZIO DRIVE		A	Y	1		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT1310011</b>	<b>SOUTHBURY WATER DEPARTMENT</b>	C	43,069	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined Agricultural
					13,665

Towns Served: CHESHIRE, SOUTHBURY, WOLCOTT

**Water System Facility and Sampling Point Inventory**

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
					Y	1	Y	1
	SWDLC45	75 NUNZIO DRIVE		I	Y	1		
	SWDLC46	85 NUNZIO DRIVE		A	Y	1		
	SWDLC47	95 NUNZIO DRIVE		I	Y	1		
	SWDLC48	105 NUNZIO DRIVE		I	Y	1		
	SWDLC49	110 NUNZIO DRIVE		I	Y	1		
	SWDLC50	120 NUNZIO DRIVE		A	Y	1		
	SWDLC51	57 ROXBURY ROAD		I	Y	1		
	SWDLC52	57 ROXBURY ROAD		A	Y	1		
	SWDLC53	21 ROYAL OAK DRIVE		I	Y	1		
	SWDLC54	20 SUNSET RIDGE		I	Y	1		
	SWDLC55	96 WOODBERRY HILL DR		A	Y	1		
	SWDLC56	50 NUNZIO DRIVE		I		1		
	SWDLC57	74 NUNZIO DRIVE		A		1		
	SWDLC58	85 NUNZIO DRIVE		I		1		
	SWDLC59	95 NUNZIO DRIVE		I		1		
	SWDLC60	110 NUNZIO DRIVE		I		1		
	SWDLC61	120 NUNZIO DRIVE		I		1		
	SWDLC62	21 BELLEVUE AVE		A		1		
	SWDLC63	33 BERKLEY AVE		A		1		
	SWDLC64	49 BERKLEY AVE		A		1		
	SWDLC65	87 BERLIN ST		A		1		
	SWDLC66	148 BERLIN ST		A		1		
	SWDLC67	265 BRISTOL ST		A		1		
	SWDLC68	25 BURWELL AVE		A		1		
	SWDLC69	79 GROVE ST		A		1		
	SWDLC70	118 HIGHWOOD AVE		A		1		
	SWDLC71	49 HOMESDALE AVE		A		1		
	SWDLC72	31 KNOX DR		A		1		
	SWDLC73	37 LACEY RD		A		1		
	SWDLC74	224 MARION AVE		A		1		
	SWDLC75	27 MACARTHUR DR		A		1		
	SWDLC76	243 MERIDEN AVE		A		1		
	SWDLC77	622 MWT		A		1		
	SWDLC78	38 MERRELL AVE		A		1		
	SWDLC79	312 MILL ST		A		1		
	SWDLC80	51 OAK ST		A		1		
	SWDLC81	80 OAKLAND RD		A		1		
	SWDLC82	101 OAKLAND RD		A		1		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1310011	SOUTHBURY WATER DEPARTMENT	C	43,069	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
					13,665

Towns Served: CHESHIRE, SOUTHBURY, WOLCOTT

**Water System Facility and Sampling Point Inventory**

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
	SWDLC83	1981 PECK LN		A		1		
	SWDLC84	387 SOUTH END RD		A		1		
	SWDLC85	974 SOUTH MAIN ST		A		1		
	SWDLC86	287 SUMMER ST		A		1		
	SWDLC87	165 SUMMIT ST		A		1		
	SWDLC88	42 TODD RD		A		1		
	SWDLC89	20 VERMONT AVE		A		1		
	SWDLC90	76 WILBUR ST		A		1		
	SWDLC91	161 WONX SPRING RD		A		1		
	SWDLC92	80 ACADEMY ST		A		1		
	SWDLC93	56 BELLEVUE AVE		A		1		
	SWDLC94	25 BERKLEY AVE		A		1		
	SWDLC95	71 BERKLEY AVE		A		1		
	SWDLC96	10 BERKLEY CT		A		1		
	SWDLC97	37 BERLIN ST		A		1		
	SWDLC98	131 BERLIN ST		A		1		
	SWDLC99	39 BURWELL AVE		A		1		
	UPSTREAM	WITHIN 5 SERVICE CON		A				
00700	SOUTHBURY FP - ENTRY POINT	3	EP - SOUTHBURY FP	A				
00701	ENTRY POINT - WELL 1A	3	EP - WELL 1A	A				
00702	ENTRY POINT - WELLS 2 & 2A	3	EP - WELLS 2 & 2A	A				
00703	ENTRY POINT - WELL 3	3	EP - WELL 3	A				
00704	ENTRY POINT - WELLS 7 & 7A	3	ENTRY POINT - WELLS	A				
00705	ENTRY POINT - WELL 8	3	EP - WELL 8	A				
00706	ENTRY POINT - WELL 9	3	EP - WELL 9	A				
1170	WELL 8	2	WELL 8	A				
1172	WELL 1A	2	WELL 1A	A				
1173	WELL 3	2	WELL 3	A				
1451	WELL 9	2	WELL 9	A				
2235	SOUTHBURY RESERVOIR #1	1	SOUTHBURY RESERVOI	A				
2236	SOUTHBURY RESERVOIR #2	1	SOUTHBURY RESERVOI	A				
2237	SOUTHBURY RESERVOIR #3	1	SOUTHBURY RESERVOI	A				
262	WELL #1A TREATMENT STATION	5	IESWTR - ENTRY POINT	A				
30082	RESERVOIR #3 INTAKE							
30084	RESERVOIR #1 INTAKE							
310	SOUTHBURY FILTER PLANT	5	EP - SOUTHBURY FP	A				

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1310011	SOUTHBURY WATER DEPARTMENT	C	43,069	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
					13,665

Towns Served: CHESHIRE, SOUTHBURY, WOLCOTT

## Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule	Asbestos	Stage WQP 2 DBPR
					Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR	
492	WELLS 2 & 2A TREATMENT STATION	5	IESWTR - ENTRY POINT	A				
493	WELL #3 TREATMENT STATION	5	IESWTR - ENTRY POINT	A				
494	WELL 7 & 7A TREATMENT STATION	5	IESWTR - ENTRY POINT	A				
495	WELL #8 TREATMENT STATION	5	IESWTR - ENTRY POINT	A				
496	WELL #9 TREATMENT STATION	5	IESWTR - ENTRY POINT	A				
50880	SOUTHBURY FILTER PLANT STORAGE TANK							
50882	WEST QUEEN STREET TANK #1							
50884	WEST QUEEN STREET TANK #2							
50886	VILLAGE GATE STORAGE TANK							
54003	WEST QUEEN STREET BOOSTER STATION							
54005	SOUTHEAST PUMPING STATION							
58145	MARIONDALE DR TANK (NEW)							
60726	WELL 7A	2	WELL 7A	A				
61043	INTERCONNECTION - CT0930011 - RWA							
61740	WELL 2A	2	WELL 2A	A				
62091	MILL STREET TANK							
62289	EAST SIDE WATER STORAGE BOOSTER STATION							
62291	EASTSIDE WATER STORAGE TANK							
XX704	ENTRY POINT - WELL 7	3X	EP - WELL 7	A				

## Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification:	CLASS 2 DISTRIBUTION SYSTEM			Certification Expiration
Operator Name	Operator Type	Certification(s)		Certification Expiration
DAMIANO, TROY W,	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III		3/31/2028
KARELUS, ROBERT, R	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III		3/31/2028

Water System Facility: **WELL #1A TREATMENT STATION (WSF ID: 262)**

Facility Classification:	CLASS 1 TREATMENT PLANT			Certification Expiration
Operator Name	Operator Type	Certification(s)		Certification Expiration
HEDMAN, MICHAEL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV		3/31/2026
MONGILLO, JEREMY M	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III		6/30/2028

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1310011	SOUTHBURY WATER DEPARTMENT	C	43,069	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
					13,665

Towns Served: CHESHIRE, SOUTHBURY, WOLCOTT

**Certified Operator Information**

Water System Facility: WELL #1A TREATMENT STATION (WSF ID: 262)

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
LOGLISCI, DAVID	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2027
DELSANTO, LORENZO J	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2027
THAYER, RAYMOND J	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	6/30/2026

Water System Facility: SOUTHBURY FILTER PLANT (WSF ID: 310)

**Facility Classification:** CLASS 4 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
HEDMAN, MICHAEL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2026
MONGILLO, JEREMY M	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2028
LOGLISCI, DAVID	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2027
DELSANTO, LORENZO J	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2027
THAYER, RAYMOND J	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	6/30/2026

Water System Facility: WELLS 2 & 2A TREATMENT STATION (WSF ID: 492)

**Facility Classification:** CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
HEDMAN, MICHAEL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2026
MONGILLO, JEREMY M	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2028
LOGLISCI, DAVID	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2027
DELSANTO, LORENZO J	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2027
THAYER, RAYMOND J	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	6/30/2026

Water System Facility: WELL #3 TREATMENT STATION (WSF ID: 493)

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
HEDMAN, MICHAEL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2026
MONGILLO, JEREMY M	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2028
LOGLISCI, DAVID	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2027
DELSANTO, LORENZO J	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2027
THAYER, RAYMOND J	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	6/30/2026

Water System Facility: WELL 7 & 7A TREATMENT STATION (WSF ID: 494)

**Facility Classification:** CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
HEDMAN, MICHAEL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2026
MONGILLO, JEREMY M	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2028
LOGLISCI, DAVID	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2027
DELSANTO, LORENZO J	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2027
THAYER, RAYMOND J	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	6/30/2026

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1310011	SOUTHBURY WATER DEPARTMENT	C	43,069	L	SW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
					13,665

Towns Served: CHESHIRE, SOUTHBURY, WOLCOTT

## Certified Operator Information

Water System Facility: WELL #8 TREATMENT STATION (WSF ID: 495)

**Facility Classification:** CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
HEDMAN, MICHAEL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2026
MONGILLO, JEREMY M	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2028
LOGLISCI, DAVID	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2027
DELSANTO, LORENZO J	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2027
THAYER, RAYMOND J	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	6/30/2026

Water System Facility: WELL #9 TREATMENT STATION (WSF ID: 496)

**Facility Classification:** CLASS 2 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
HEDMAN, MICHAEL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2026
MONGILLO, JEREMY M	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	6/30/2028
LOGLISCI, DAVID	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	3/31/2027
DELSANTO, LORENZO J	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III	12/31/2027
THAYER, RAYMOND J	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS I	6/30/2026

## Contact Information

Name	Organization	Job Title		
Mr. Albert T Fiorillo	Southington Water Department	Asst Superintendent		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
P.O. Box 111	605 West Queen Street	Southington	CT	06489
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone
860-628-5593				Email Address afiorillo@southingtonwater.org

Contact Role(s): Legal Contact

Name	Organization	Job Title		
Mr. Douglas R. Arndt	Southington Water Department	Superintendent		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
605 West Queen Street		Southington	CT	06489
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone
860-628-5593				Email Address darndt@southingtonwater.org

Contact Role(s): Administrative Contact

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

**If you have any questions, please contact the Drinking Water Section at (860) 509-7333.**

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1310031	APPLE VALLEY VILLAGE	C	70	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: SOUTHBURG

### Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/31		
<b>Total Coliform (3100)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
<b>Lead And Copper (PBCU)</b>	<b>5 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/25 - 12/31/27	6/1-9/30	
<b>Physical Parameters (PPS)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

<b>Net Gross Alpha (4000)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Uranium (4006)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Combined Radium-226/228 (4010)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/27		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1310031	APPLE VALLEY VILLAGE	C	70	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined

Towns Served: SOUTHBURG

## Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Nitrate And Nitrite (NOX)		1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
	1/1/26 - 12/31/26			
	1/1/27 - 12/31/27			
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)			1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)	1/1/23 - 12/31/25			Complete
	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			
Organic Chemicals (VOCS)			1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)	1/1/23 - 12/31/25			Complete
	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION EXEMPTION	3/1/2026	

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		4-1	KITCHEN	A	Y			
		AVV WH	WELL HOUSE	A	Y			
		AVV1	UNIT 1	A	Y	N		
		AVV10	UNIT 10	A	Y	3		
		AVV11	UNIT 11	A	Y	N		
		AVV12	UNIT 12	A	Y	N		
		AVV13	UNIT 13	A	Y	N		
		AVV14	UNIT 14	A	Y	N		
		AVV15	UNIT 15	A	Y	N		
		AVV16	UNIT 16	A	Y	3		
		AVV17	UNIT 17	A	Y	N		
		AVV18	UNIT 18	A	Y	3		
		AVV19	UNIT 19	A	Y	N		
		AVV2	UNIT 2	A	Y	N		
		AVV20	UNIT 20	A	Y	3		
		AVV21	UNIT 21	A	Y	N		
		AVV22	UNIT 22	A	Y	N		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1310031	APPLE VALLEY VILLAGE	C	70	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		41			Agricultural

Towns Served: SOUTHBURG

<b>Water System Facility and Sampling Point Inventory</b>									
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	WQP 2	DBPR Stage
					Rule	Asbestos			
	AVV23	UNIT 23		A	Y	N			
	AVV24	UNIT 24		A	Y	N			
	AVV25	UNIT 25		A	Y	N			
	AVV26	UNIT 26		A	Y	1			
	AVV27	UNIT 27		A	Y	N			
	AVV28	UNIT 28		A	Y	N			
	AVV29	UNIT 29		A	Y	1			
	AVV3	UNIT 3		A	Y	N			
	AVV30	UNIT 30		A	Y	N			
	AVV31	UNIT 31		A	Y	N			
	AVV32	UNIT 32		A	Y	3			
	AVV33	UNIT 33		A	Y	N			
	AVV34	UNIT 34		A	Y	3			
	AVV35	UNIT 35		A	Y	N			
	AVV36	UNIT 36		A	Y	3			
	AVV37	UNIT 37		A	Y	N			
	AVV38	UNIT 38		A	Y	1			
	AVV39	UNIT 39		A	Y	3			
	AVV4	UNIT 4		A	Y	N			
	AVV40	UNIT 40		A	Y	3			
	AVV5	UNIT 5		A	Y	N			
	AVV6	UNIT 6		A	Y	3			
	AVV7	UNIT 7		A	Y	N			
	AVV8	UNIT 8		A	Y	N			
	AVV9	UNIT 9		A	Y	3			
	DOWNSTREAM	WITHIN 5 SERVICE CON		A					
	UPSTREAM	WITHIN 5 SERVICE CON		A					
00700	ENTRY POINT	3	ENTRY POINT	A					
1037	WELL 1	2	WELL 1	A					

## Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

**Facility Classification:** SMALL WATER SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
HELMING, TRAVIS	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS III DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2028 9/30/2028

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1310031	APPLE VALLEY VILLAGE	C	70	P	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
		41			

Towns Served: SOUTHBURG

## Contact Information

Name	Organization	Job Title		
Mr. Corey Davis	Pyramid Real Estate Group			
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
20 Summer Street		Stamford	CT	06901
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone
203-348-8566				Email Address corey@pyramidregroup.com

Contact Role(s): **Legal Contact**

Name	Organization	Job Title		
Mr. Kevin Rohrbacher	Pyramid Ronlestato	Site Manager		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
20 Summer Street		Stamford	CT	06901
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone
860-912-5159				Email Address kdrohrbacher@gmail.com

Contact Role(s): **Administrative Contact, Legal Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

**NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.**