

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT1390021	AQUARION-SUFFIELD			C	595	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
3999 MOUNTAIN ROAD						231	
Towns Served: SUFFIELD							

### Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/22 - 12/31/30		
Total Haloacetic Acids (2456)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
COPPER HILL RD SS S (04877)	1/1/24 - 12/31/24	9/1-9/30	Complete
	1/1/25 - 12/31/25	9/1-9/30	Complete
	1/1/26 - 12/31/26	9/1-9/30	
Total Trihalomethanes (2950)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
COPPER HILL RD SS S (04877)	1/1/24 - 12/31/24	9/1-9/30	Complete
	1/1/25 - 12/31/25	9/1-9/30	Complete
	1/1/26 - 12/31/26	9/1-9/30	
Total Coliform (3100)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
Lead And Copper (PBCU)		10 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/24	6/1-9/30	Complete
	1/1/25 - 12/31/25	6/1-9/30	Complete
	1/1/26 - 12/31/26	6/1-9/30	
Physical Parameters (PPS)		1 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT1390021	AQUARION-SUFFIELD			C	595	P	GW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
3999 MOUNTAIN ROAD						231	
Towns Served: SUFFIELD							

### Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Physical Parameters (PPS)		1 routine (RT) per month		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
	1/1/26 - 1/31/26			
	2/1/26 - 2/28/26			
	3/1/26 - 3/31/26			
	4/1/26 - 4/30/26			
	5/1/26 - 5/31/26			
	6/1/26 - 6/30/26			

Water System Facility: ENTRY POINT-WELL 2 (WSF ID: 00700)

Nitrate (1040)		1 routine (RT) per quarter	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT-WELL 2 (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
Nitrite (1041)		1 routine (RT) per year	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT-WELL 2 (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
Net Gross Alpha (4000)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT-WELL 2 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Uranium (4006)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT-WELL 2 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Combined Radium-226/228 (4010)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT-WELL 2 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT-WELL 2 (3)	1/1/25 - 12/31/27		
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status
ENTRY POINT-WELL 2 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT1390021	AQUARION-SUFFIELD			C	595	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
3999 MOUNTAIN ROAD							231	
Towns Served: SUFFIELD								

### Monitoring Requirements

Water System Facility: ENTRY POINT-WELL 2 (WSF ID: 00700)

Organic Chemicals (VOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL 2 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Water System Facility: ENTRY POINT-WELL 3 (WSF ID: 00701)

Nitrate (1040)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL 3 (3)	4/1/25 - 6/30/25		Complete
	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Nitrite (1041)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL 3 (3)	1/1/24 - 12/31/24		Complete
	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		

Net Gross Alpha (4000)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL 3 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Uranium (4006)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL 3 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Combined Radium-226/228 (4010)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL 3 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Inorganic Chemicals (IOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL 3 (3)	1/1/25 - 12/31/27		

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL 3 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

Organic Chemicals (VOCS)		1 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT-WELL 3 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT1390021	AQUARION-SUFFIELD			C	595	P	GW	
Local Address (where applicable)			Service	Residential	Commercial	Industrial	Combined	Agricultural
3999 MOUNTAIN ROAD			Connections				231	
Towns Served: SUFFIELD								

### Monitoring Requirements

Water System Facility: **WELL 3 (WSF ID: 1771)**

**E. Coli (3014)**

**1 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 3 (2)	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		

Water System Facility: **WELL 2 (WSF ID: 26472)**

**E. Coli (3014)**

**1 routine (RT) per month**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
WELL 2 (2)	7/1/25 - 7/31/25		Complete
	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		

### Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: **ENTRY POINT-WELL 2 (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 7/1/2020	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	7/1/2025 - 7/31/2025		
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT1390021	AQUARION-SUFFIELD			C	595	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
3999 MOUNTAIN ROAD							231	
Towns Served: SUFFIELD								

### Water System Facility: ENTRY POINT-WELL 2 (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 7/1/2020	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
11/1/2025 - 11/30/2025			

### Water System Facility: ENTRY POINT-WELL 3 (WSFID: 00701)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 7/1/2020	Compliance History: Monitoring Period	Operating Limit Compliance Status:	Monitoring Compliance Status:
7/1/2025 - 7/31/2025			
8/1/2025 - 8/31/2025			
9/1/2025 - 9/30/2025			
10/1/2025 - 10/31/2025			
11/1/2025 - 11/30/2025			

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2025	
CERTIFY LEAD SL NOTIFICATION	7/1/2025	4/21/2025
SUBMIT LEAD CONSUMER NOTICE CERTIFICATE	12/29/2025	
MAIL/HAND DELIVER NOTICE TO CONSUMERS	12/31/2025	
CERTIFY LEAD SL NOTIFICATION	7/1/2026	

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	04876	OLD MOUNTAIN RD SS S	A	Y			
		04877	COPPER HILL RD SS S	A	Y			Y
		4	DISTRIBUTION SYSTEM	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		PB7441	3800 OLD MOUNTAIN RO	A		3		
		PB7442	15 RIDGEWOOD DRIVE	A		3		
		PB7443	15 SUNSET DRIVE	A		1		
		PB7444	164 CHESTNUT CIRCLE	A		3		
		PB7445	45 STRATTON FARMS RO	A		3		
		PB7446	12 CHESTNUT DRIVE	A		3		
		PB7447	101 BROADLEAF CIRCLE	A		3		
		PB7448	85 WOODS HOLLOW ROAD	A		3		
		PB7449	221 BABBS ROAD	A		1		
		PB7450	16 PONDVIEW LANE	A		3		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule									
PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source		
CT1390021	AQUARION-SUFFIELD			C	595	P	GW		
Local Address (where applicable)			Service	Residential	Commercial	Industrial	Combined	Agricultural	
3999 MOUNTAIN ROAD			Connections				231		
Towns Served: SUFFIELD									
Water System Facility and Sampling Point Inventory									
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2	DBPR
		PB7451	10 SUNSET DRIVE	A		1			
		PB7452	30 SUNSET DRIVE	A		1			
		PB8388	20 SUNSET DRIVE	A		1			
		PB8389	25 SUNSET DRIVE	A		1			
		PB8390	25 RIDGEWOOD DR	A		1			
		PB8391	35 SUNSET DRIVE	A		1			
		PB8392	35 CHESTNUT CIR	A		1			
		PB8393	40 SUNSET DRIVE	A		1			
		PB8394	45 SUNSET DRIVE	A		1			
		PB8395	55 SUNSET DRIVE	A		1			
		PB8882	60 SUNSET DR	A		1			
		PB8883	80 SUNSET DR	A		1			
		PB8884	90 SUNSET DR	A		1			
		PB8885	100 SUNSET DR	A		1			
		PB8886	209 BABBS RD	A		1			
		PB8887	235 BABBS RD	A		1			
		PB8888	22 WOODS HOLLOW RD	A		1			
		PB8889	28 WOODS HOLLOW RD	A		1			
		PB8890	49 WOODS HOLLOW RD	A		1			
		PB8891	58 WOODS HOLLOW RD	A		1			
		UPSTREAM	WITHIN 5 SERVICE CON	A					
00700	ENTRY POINT-WELL 2	3	ENTRY POINT-WELL 2	I					
00701	ENTRY POINT-WELL 3	3	ENTRY POINT-WELL 3	I					
1771	WELL 3	2	WELL 3	A					
26472	WELL 2	2	WELL 2	I					
62367	TREATMENT PLANT WELL 2								
62369	TREATMENT PLANT WELL 3								
Certified Operator Information									
Water System Facility: TREATMENT PLANT WELL 2 (WSF ID: 62367)									
Facility Classification: CLASS 1 TREATMENT PLANT									
Operator Name	Operator Type	Certification(s)						Certification Expiration	
FARRELLY, MARC	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III						6/30/2027	
		WATER TREATMENT PLANT OPERATOR - CLASS II						6/30/2027	
		DISTRIBUTION SYSTEM OPERATOR - CLASS II						8/26/2024	

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT1390021	AQUARION-SUFFIELD			C	595	P	GW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
3999 MOUNTAIN ROAD							231	
Towns Served: SUFFIELD								

### Certified Operator Information

**Water System Facility:** TREATMENT PLANT WELL 3 (WSF ID: 62369)

**Facility Classification:** CLASS 1 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
FARRELLY, MARC	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	6/30/2027
		WATER TREATMENT PLANT OPERATOR - CLASS II	6/30/2027
		DISTRIBUTION SYSTEM OPERATOR - CLASS II	8/26/2024

### Contact Information

Name		Organization		Job Title		
<b>Mr. John P. Walsh</b>		Aquarion Water Company		Vice President		
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
835 Main Street		Mail Stop 700		Bridgeport	CT	06604
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-337-5852		203-337-5938		781-413-6175	jwalsh@aquarionwater.com	

**Contact Role(s):** Legal Contact, Owner

Name		Organization		Job Title		
<b>Mr. Robert J. Ulrich</b>		Aquarion Water Company of Ct		Vp-Supply & Utility		
Mailing Address Line One		Mailing Address Line Two		City	State	Zip Code
505 Huntington St.				Shelton	CT	06484
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address	
203-926-4320		203-929-5297		203-395-3205	rulrich@aquarionwater.com	

**Contact Role(s):** Administrative Contact

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule.

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

***<http://www.ct.gov/dph/publicdrinkingwater>***

**End of schedule**