

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1450112	UNION ELEMENTARY SCHOOL	NTNC	80	L	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
18 KINNEY HOLLOW ROAD	Connections	1			

Towns Served: UNION

**Monitoring Requirements**

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

<b>Chlorine Residual (1012)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
<b>Total Coliform (3100)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
<b>Disinfectant Byproducts - TTHM &amp; HAA5 (DBP)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
KITCHEN AREA (4-4)	1/1/25 - 12/31/25	7/1-7/31	Complete
	1/1/26 - 12/31/26	7/1-7/31	
	1/1/27 - 12/31/27	7/1-7/31	
<b>Lead And Copper (PBCU)</b>	<b>5 routine (RT) per six months</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 12/31/25		Complete
	1/1/26 - 6/30/26		
	7/1/26 - 12/31/26		
<b>Physical Parameters (PPS)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: **ENTRY POINT - WELLS 1 & 3** (WSF ID: 00702)

<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 1 & 3 (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
EP - WELLS 1 & 3 (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1450112	UNION ELEMENTARY SCHOOL	NTNC	80	L	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
18 KINNEY HOLLOW ROAD	Connections	1			

Towns Served: UNION

## Monitoring Requirements

Water System Facility: ENTRY POINT - WELLS 1 & 3 (WSF ID: 00702)

Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)		1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
EP - WELLS 1 & 3 (3)	1/1/23 - 12/31/25		Complete	
	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			

Organic Chemicals (VOCS)		1 routine (RT) per year		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
EP - WELLS 1 & 3 (3)	1/1/25 - 12/31/25		Complete	
	1/1/26 - 12/31/26			
	1/1/27 - 12/31/27			

Water System Facility: WELL# 1 (WSF ID: 57263)

E. Coli (3014)		1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
WELL# 1 (2)	7/1/25 - 9/30/25		Complete	
	10/1/25 - 12/31/25		Complete	
	1/1/26 - 3/31/26			
	4/1/26 - 6/30/26			

Water System Facility: WELL #3 (WSF ID: 57932)

E. Coli (3014)		1 routine (RT) per quarter		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
WELL #3 (2)	7/1/25 - 9/30/25		Complete	
	10/1/25 - 12/31/25		Complete	
	1/1/26 - 3/31/26			
	4/1/26 - 6/30/26			

## Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: ENTRY POINT - WELLS 1 & 3 (WSFID: 00702)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point Chlorine Residual Monitoring (CHLR)	Minimum: 0.2 MG/L	Daily
Start Date: 1/1/2012	Compliance History: Monitoring Period	Operating Limit	Monitoring
	8/1/2025 - 8/31/2025	Compliance Status:	Compliance Status:
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		
	11/1/2025 - 11/30/2025		
	12/1/2025 - 12/31/2025		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1450112	UNION ELEMENTARY SCHOOL	NTNC	80	L	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
18 KINNEY HOLLOW ROAD	Connections	1			

Towns Served: UNION

Water System Facility: ENTRY POINT - WELLS 1 & 3 (WSFID: 00702)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit		Samples Req/Month	
		Minimum:	7.0 PH	Daily	Monitoring
pH	Entry Point pH Monitoring (PHRD)				Compliance Status:
Start Date:	1/1/2012	Compliance History:	Operating Limit	Monitoring	Compliance Status:
		Monitoring Period	Compliance Status:	Compliance Status:	
		8/1/2025 - 8/31/2025			
		9/1/2025 - 9/30/2025			
		10/1/2025 - 10/31/2025			
		11/1/2025 - 11/30/2025			
		12/1/2025 - 12/31/2025			

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2025	

Water System	Water System Facility	Sampling Point ID	Sampling Point Description	Total Status	Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
Facility ID								
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y			
		4-1	JAN #109	A	Y	1	Y	
		4-2	JAN #407	A	Y	1	Y	
		4-3	ROOM 403	A	Y	1	Y	
		4-4	KITCHEN AREA	A	Y	1		Y
		4-5	BOY S RESTROOM	I	Y			
		4-6	ROOM 201	A	Y	1		
	DOWNSTREAM		WITHIN 5 SERVICE CON	A				
	UPSTREAM		WITHIN 5 SERVICE CON	A				
00702	ENTRY POINT - WELLS 1 & 3	3	EP - WELLS 1 & 3	A				
57261	TREATMENT PLANT							
57263	WELL# 1	2	WELL# 1	A				
57267	STORAGE TANKS							
57932	WELL #3	2	WELL #3	A				

## Certified Operator Information

Water System Facility: TREATMENT PLANT (WSF ID: 57261)

Facility Classification:	CLASS 2 TREATMENT PLANT	Certification Expiration
Operator Name	Operator Type	Certification(s)
WITTENZELLNER, ROBERT	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III
		WATER TREATMENT PLANT OPERATOR - CLASS III
HARKINS, STUART A.	ASSIGNED OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III
		WATER TREATMENT PLANT OPERATOR - CLASS II
		6/30/2028
		9/30/2027
		6/30/2028
		6/30/2028

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1450112	UNION ELEMENTARY SCHOOL	NTNC	80	L	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
18 KINNEY HOLLOW ROAD	1				

Towns Served: UNION

## Contact Information

Name	Organization	Job Title		
Mr. Steven Jackopsic	Union School District	Superintendent		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
18 Kinney Hollow Rd		Union	CT	06076
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone
860-684-3146	405	860-684-9385		sjackopsic@union.k12.ct.us

Contact Role(s): **Administrative Contact, Legal Contact**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

*<http://www.ct.gov/dph/publicdrinkingwater>*

**End of schedule**