

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1510011	WATERBURY WATER DEPARTMENT	C	107,271	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					Combined
					26,915

Towns Served: MIDDLEBURY, PROSPECT, WATERBURY, WATERTOWN, WOLCOTT

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Chlorine Residual (1012)		100 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
Asbestos (1094)		1 routine (RT) per nine years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/21 - 12/31/29		
Total Coliform (3100)		100 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		
Disinfectant Byproducts - TTHM & HAA5 (DBP)		8 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
519 EAST MAIN STREET (WBW002)	7/1/25 - 9/30/25	9/1-9/30	Complete
	10/1/25 - 12/31/25	12/1-12/31	Complete
	1/1/26 - 3/31/26	3/1-3/31	
	4/1/26 - 6/30/26	6/1-6/30	
197 BUNKER HILL AV (WBW008)	7/1/25 - 9/30/25	9/1-9/30	Complete
	10/1/25 - 12/31/25	12/1-12/31	Complete
	1/1/26 - 3/31/26	3/1-3/31	
	4/1/26 - 6/30/26	6/1-6/30	
380 PIERPONT RD (WBW012)	7/1/25 - 9/30/25	9/1-9/30	Complete
	10/1/25 - 12/31/25	12/1-12/31	Complete
	1/1/26 - 3/31/26	3/1-3/31	
	4/1/26 - 6/30/26	6/1-6/30	
235 BIRCH STREET (WBW014)	7/1/25 - 9/30/25	9/1-9/30	Complete
	10/1/25 - 12/31/25	12/1-12/31	Complete

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1510011	WATERBURY WATER DEPARTMENT	C	107,271	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					Combined
					26,915

Towns Served: MIDDLEBURY, PROSPECT, WATERBURY, WATERTOWN, WOLCOTT

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Disinfectant Byproducts - TTHM & HAA5 (DBP)		8 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
3196 E MAIN ST (WBW022)	1/1/26 - 3/31/26	3/1-3/31	
	4/1/26 - 6/30/26	6/1-6/30	
	7/1/25 - 9/30/25	9/1-9/30	Complete
	10/1/25 - 12/31/25	12/1-12/31	Complete
N MAIN ST PUMP STA (WBW025)	1/1/26 - 3/31/26	3/1-3/31	
	4/1/26 - 6/30/26	6/1-6/30	
	7/1/25 - 9/30/25	9/1-9/30	Complete
	10/1/25 - 12/31/25	12/1-12/31	Complete
150 MATTATUCK HEIGHTS RD (WBW095)	1/1/26 - 3/31/26	3/1-3/31	
	4/1/26 - 6/30/26	6/1-6/30	
	7/1/25 - 9/30/25	9/1-9/30	Complete
	10/1/25 - 12/31/25	12/1-12/31	Complete
2176 THOMASTON AVE (WBW097)	1/1/26 - 3/31/26	3/1-3/31	
	4/1/26 - 6/30/26	6/1-6/30	
	7/1/25 - 9/30/25	9/1-9/30	Complete
	10/1/25 - 12/31/25	12/1-12/31	Complete
	1/1/26 - 3/31/26	3/1-3/31	
	4/1/26 - 6/30/26	6/1-6/30	
Lead And Copper (PBCU)		50 routine (RT) per three years	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/25	6/1-9/30	Complete
	1/1/26 - 12/31/28	6/1-9/30	
	1/1/29 - 12/31/31	6/1-9/30	
Physical Parameters (PPS)		100 routine (RT) per month	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1510011	WATERBURY WATER DEPARTMENT	C	107,271	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					Combined
					26,915
					Agricultural

Towns Served: MIDDLEBURY, PROSPECT, WATERBURY, WATERTOWN, WOLCOTT

### Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

**Water Quality Parameters Orthophosphate, Alkalinity, Calcium (WQ11)** **50 routine (RT) per six months**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/26 - 6/30/26		
	7/1/26 - 12/31/26		

Water System Facility: **WATERBURY WTP ENTRY POINT (WSF ID: 00700)**

**Net Gross Alpha (4000)** **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

**Uranium (4006)** **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

**Combined Radium-226/228 (4010)** **1 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

**Inorganic Chemicals (IOCS)** **1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/25		
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

**Nitrate And Nitrite (NOX)** **1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

**Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)** **2 routine (RT) per three years**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

**Organic Chemicals (VOCS)** **1 routine (RT) per year**

<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1510011	WATERBURY WATER DEPARTMENT	C	107,271	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					Combined
					26,915
					Agricultural

Towns Served: MIDDLEBURY, PROSPECT, WATERBURY, WATERTOWN, WOLCOTT

### Monitoring Requirements

Water System Facility: **PITCH RESERVOIR (WSF ID: 2275)**

Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RESERVOIR (1)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
Surface Water Inorganic Chemicals (RIOCI)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RESERVOIR (1)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
Surface Water Color and Turbidity (RPPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RESERVOIR (1)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
Surface Water Pesticides (RSOC)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RESERVOIR (1)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Water System Facility: **MORRIS RESERVOIR (WSF ID: 2277)**

Total Coliform (3100)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RESERVOIR (1)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
Surface Water Inorganic Chemicals (RIOCI)		1 routine (RT) per year	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RESERVOIR (1)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
Surface Water Color and Turbidity (RPPS)		1 routine (RT) per quarter	
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RESERVOIR (1)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1510011	WATERBURY WATER DEPARTMENT	C	107,271	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					Combined
					26,915
					Agricultural

Towns Served: MIDDLEBURY, PROSPECT, WATERBURY, WATERTOWN, WOLCOTT

### Monitoring Requirements

Water System Facility: MORRIS RESERVOIR (WSF ID: 2277)

Surface Water Pesticides (RSOC)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RESERVOIR (1)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Water System Facility: WIGWAM RESERVOIR (WSF ID: 2278)

Total Coliform (3100)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RESERVOIR (1)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Surface Water Inorganic Chemicals (RIOCI)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RESERVOIR (1)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Surface Water Color and Turbidity (RPPS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RESERVOIR (1)	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Surface Water Pesticides (RSOC)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RESERVOIR (1)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

Water System Facility: WATERBURY WATER TREATMENT PLANT (WSF ID: 294)

Total Organic Carbon (2920)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
CFE - WATERBURY TP (5)	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1510011	WATERBURY WATER DEPARTMENT	C	107,271	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					Combined
					26,915
					Agricultural

Towns Served: MIDDLEBURY, PROSPECT, WATERBURY, WATERTOWN, WOLCOTT

### Monitoring Requirements

Water System Facility: WATERBURY WATER TREATMENT PLANT (WSF ID: 294)

Total Organic Carbon (2920)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Water System Facility: WATERBURY WTP INTAKE (WSF ID: 30096)

Total Alkalinity (1927)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RESERVOIRS COMBINED (SS)	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

Total Organic Carbon (2920)	1 routine (RT) per month		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
RESERVOIRS COMBINED (SS)	8/1/25 - 8/31/25		Complete
	9/1/25 - 9/30/25		Complete
	10/1/25 - 10/31/25		Complete
	11/1/25 - 11/30/25		Complete
	12/1/25 - 12/31/25		Complete
	1/1/26 - 1/31/26		
	2/1/26 - 2/28/26		
	3/1/26 - 3/31/26		
	4/1/26 - 4/30/26		
	5/1/26 - 5/31/26		
	6/1/26 - 6/30/26		
	7/1/26 - 7/31/26		

### Monthly Water System Facility (WSF) Level Monitoring Requirements

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT1510011	WATERBURY WATER DEPARTMENT			C	107,271	L	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							26,915	

Towns Served: MIDDLEBURY, PROSPECT, WATERBURY, WATERTOWN, WOLCOTT

Water System Facility: **WATERBURY WTP ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Minimum: 0.55 MG/L	Daily
Start Date: 5/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2025 - 8/31/2025		
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		
	11/1/2025 - 11/30/2025		
	12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Fluoride	Entry Point Fluoride Monitoring (FLRD)	Maximum: 0.85 MG/L	Daily
Start Date: 5/1/2023	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	8/1/2025 - 8/31/2025	Y	
	9/1/2025 - 9/30/2025	Y	
	10/1/2025 - 10/31/2025	Y	
	11/1/2025 - 11/30/2025	Y	
	12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Maximum: 0.6 MG/L	2
Start Date: 9/1/2025	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		
	11/1/2025 - 11/30/2025		
	12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Orthophosphate	Entry Point Phosphate Monitoring (PHOS)	Minimum: 0.5 MG/L	2
Start Date: 9/1/2025	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		
	11/1/2025 - 11/30/2025		
	12/1/2025 - 12/31/2025		
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Maximum: 8.0 PH	Daily
Start Date: 9/1/2025	Compliance History:	Operating Limit	Monitoring
	Monitoring Period	Compliance Status:	Compliance Status:
	9/1/2025 - 9/30/2025		
	10/1/2025 - 10/31/2025		
	11/1/2025 - 11/30/2025		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT1510011	WATERBURY WATER DEPARTMENT			C	107,271	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						26,915	

Towns Served: MIDDLEBURY, PROSPECT, WATERBURY, WATERTOWN, WOLCOTT

Water System Facility: **WATERBURY WTP ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Maximum: 8.0 PH	Daily
Start Date: 9/1/2025			
		Compliance History: Monitoring Period	Operating Limit Compliance Status: Monitoring Compliance Status:
		12/1/2025 - 12/31/2025	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	Entry Point pH Monitoring (PHRD)	Minimum: 7.0 MG/L	Daily
Start Date: 9/1/2025			
		Compliance History: Monitoring Period	Operating Limit Compliance Status: Monitoring Compliance Status:
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

Water System Facility: **WATERBURY WATER TREATMENT PLANT (WSFID: 294)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Chlorine	Entry Point RDC (EPRD)	Minimum: 0.2 MG/L	Daily
Start Date: 9/1/2003			
		Compliance History: Monitoring Period	Operating Limit Compliance Status: Monitoring Compliance Status:
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE Maximum Turbidity (MAXT)	Maximum: 1 NTU	186
Start Date: 1/1/2002			
		Compliance History: Monitoring Period	Operating Limit Compliance Status: Monitoring Compliance Status:
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	
Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
Turbidity	CFE 95% Turbidity (95PT)	95% Turbidity Limit: 0.3 NTU	186
Start Date: 1/1/2002			
		Compliance History: Monitoring Period	Operating Limit Compliance Status: Monitoring Compliance Status:
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.



# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT1510011	WATERBURY WATER DEPARTMENT			C	107,271	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						26,915	

Towns Served: MIDDLEBURY, PROSPECT, WATERBURY, WATERTOWN, WOLCOTT

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
RESPOND TO SANITARY SURVEY	10/29/2025	
MAIL/HAND DELIVER NOTICE TO CONSUMERS	12/31/2025	
CORRECTIVE ACTION/CORRECTIVE ACTION PLAN	1/27/2026	
CROSS CONNECTION SURVEY REPORT	3/1/2026	
CERTIFY LEAD SL NOTIFICATION	7/1/2026	

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	GENERIC DISTRIBUTION	A	Y			
		DOWNSTREAM	WITHIN 5 SERVICE CON	A				
		UPSTREAM	WITHIN 5 SERVICE CON	A				
		WBW001	26 FIELD STREET	A	Y			
		WBW002	519 EAST MAIN STREET	A	Y			Y
		WBW003	21 E. AURORA STREET	A	Y			
		WBW004	268 N MAIN STREET	A	Y			
		WBW005	823 BALDWIN STREET	A	Y			
		WBW006	317 S LEONARD STREET	I	Y			
		WBW007	1676 WATERTOWN AV	A	Y			
		WBW008	197 BUNKER HILL AV	A	Y			Y
		WBW009	742 PARK ROAD	A	Y			
		WBW010	459 PINE STREET	A	Y			
		WBW011	84 MATTATUCK HEIGHTS	I	Y			Y
		WBW012	380 PIERPONT RD	A	Y			Y
		WBW013	2817 N MAIN STREET	A	Y			
		WBW014	235 BIRCH STREET	A	Y			Y
		WBW015	1255 HAMILTON AV	A	Y			
		WBW016	740 HIGHLAND AV	A	Y			
		WBW017	431 WILLOW STREET	A	Y			
		WBW018	283 SYLVAN AV	A	Y			
		WBW019	170 GRANDVIEW AV	A	Y			
		WBW020	1956 E MAIN STREET	A	Y			
		WBW021	315 WALNUT STREET	A	Y			
		WBW022	3196 E MAIN ST	A	Y			Y
		WBW023	1979 N MAIN ST	A	Y			
		WBW024	1161 WOLCOTT ST	A	Y			
		WBW025	N MAIN ST PUMP STA	A				Y
		WBW026	108 DRACUT AVE	A		1		
		WBW027	118 ATWOOD AVE	A		1		
		WBW028	302 COURTLAND AV	A		1		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT1510011	WATERBURY WATER DEPARTMENT			C	107,271	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						26,915	

Towns Served: MIDDLEBURY, PROSPECT, WATERBURY, WATERTOWN, WOLCOTT

### Water System Facility and Sampling Point Inventory

<i>Water System</i> Facility ID	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		WBW029	586 HILL ST	A		1		
		WBW030	140 JOSEPH DR	A		1		
		WBW031	104 SPRUCEDALE DR	A		1		
		WBW032	77 BUCKLAND DR	A		1		
		WBW033	53 CITIZENS AV	A		1		
		WBW034	36 KENNETH CIR	A		1		
		WBW035	24 TWINING AV	A		1		
		WBW036	40 ERMA DR	A		1		
		WBW037	44 PEACH ORCHARD RD	A		1		
		WBW038	41 CHIPPER RD	A		1		
		WBW039	5 CRAIGIE AV	A		1		
		WBW040	52 MACAULEY AV	A		1		
		WBW041	38 STARLET LN	A		1		
		WBW042	939 COOKE ST	A		1		
		WBW043	194 DEVONWOOD AV	A		1		
		WBW044	65 FOX RUN RD	A		1		
		WBW045	6 HARTLEY DR	A		1		
		WBW046	118 ALEXANDER AV	A		1		
		WBW047	95 SPRUCEDALE ST	A		1		
		WBW048	137 WHITEBIRCH DR	A		1		
		WBW049	370 WINDY DR	A		1		
		WBW050	12 BATESMOOR RD	A		1		
		WBW051	35 CESTARO ST	A		1		
		WBW052	62 CHESTER AV	A		1		
		WBW053	50 FOX RUN RD	A		1		
		WBW054	253 GRASSY HILL RD	A		1		
		WBW055	953 BUNKER HILL AV	A		1		
		WBW056	102 HORSESHOE DR	A		1		
		WBW057	174 MANSFIELD AV	A		1		
		WBW058	73 OLDHAM DR	A		1		
		WBW059	78 CHIPPER RD	A		1		
		WBW060	123 GILMAN ST	A		1		
		WBW061	79 GRILLEYTOWN RD	A		1		
		WBW062	17 HEATON ST	A		1		
		WBW063	118 LAMONT ST	A		1		
		WBW064	106 OAK HOLLOW DR	A		1		
		WBW065	136 LARCHMONT AV	A		1		
		WBW066	152 BAMFORD AV	A		1		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT1510011	WATERBURY WATER DEPARTMENT			C	107,271	L	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							26,915	

Towns Served: MIDDLEBURY, PROSPECT, WATERBURY, WATERTOWN, WOLCOTT

### Water System Facility and Sampling Point Inventory

<i>Water System</i> Facility ID	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		WBW067	417 PEARL LAKE RD	A		1		
		WBW068	208 HOPE ST	A		1		
		WBW069	359 MAYBROOK RD	A		1		
		WBW070	101 RUMFORD ST	A		1		
		WBW071	371 WINDY DR	A		1		
		WBW072	16 KODAK ST	A		1		
		WBW073	933 BUNKER HILL AV	A		1		
		WBW074	7 OLD COLONY DR	A		1		
		WBW075	159 ROSETTE ST	A		1		
		WBW076	138 MONMOUTH AV	A		1		
		WBW077	126 HORSESHOE DR	A		1		
		WBW078	227 CHESNUT HILL	A		1		
		WBW079	67 BUCKLAND DR	A		1		
		WBW080	8 HIDDEN POND DRIVE	A	Y	1		
		WBW081	119 ANNA AVENUE	I	Y	1		
		WBW082	88 WOODSIDE AVENUE	I	Y	1		
		WBW083	100 ATWOOD AVENUE	I	Y	1		
		WBW084	149 PINERIDGE ROAD	I	Y	1		
		WBW085	31 BRACKENRIDGE DR	I	Y	1		
		WBW086	57 STILLSON ROAD	I	Y	1		
		WBW087	94 MADERA DRIVE	I	Y	1		
		WBW088	227 FOREST RIDGE RD	I	Y	1		
		WBW089	1929 BALDWIN STREET	I	Y	1		
		WBW090	76 HOUSTON STREET	I	Y	1		
		WBW091	49 NATALIE TERRACE	I	Y	1		
		WBW092	112 CELIA DRIVE	I	Y	1		
		WBW093	2200 THOMASTON AVE	I				Y
		WBW094	290 HIGHLAND AVENUE	A	Y			
		WBW095	150 MATTATUCK HEIGHT	A	Y			Y
		WBW096	210 MUNICIPAL ROAD	A	Y	N		
		WBW097	2176 THOMASTON AVE	A				Y
		WBW098	97 JOSEPH ST	I		3		
		WBW099	85 SOUTHRIDGE DR	I		3		
		WBW100	333 BUNKER HILL AVE	I		3		
		WBW101	162 WEST RIDGE DR	I		3		
		WBW102	2 GEM DR	I		3		
		WBW103	21 JODIE CIR	I		3		
		WBW104	177 ATWOOD AVE	I		3		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source	
CT1510011	WATERBURY WATER DEPARTMENT			C	107,271	L	SW	
Local Address (where applicable)			Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
							26,915	

Towns Served: MIDDLEBURY, PROSPECT, WATERBURY, WATERTOWN, WOLCOTT

### Water System Facility and Sampling Point Inventory

<i>Water System</i> Facility ID	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		WBW105	865 WOODTICK RD	I		3		
		WBW106	62 HORSESHOE DR	I		3		
		WBW107	100 EASTRIDGE DR	I		3		
		WBW108	214 SCOTT ROAD	I		3		
		WBW109	20 FIRST AVE	I		3		
		WBW110	515 WILLOW ST	I		3		
		WBW111	114 BIRCHFIELD DR	I		3		
		WBW112	5 BLACKMAN ROAD	A		1		
		WBW113	18 CROWNBROOK DR	A		1		
		WBW114	23 FANNING ST	A		1		
		WBW115	27 BUCKWOOD AVE	A		1		
		WBW116	30 CHIPPER RD	A		1		
		WBW117	35 DANA DR	A		1		
		WBW118	124 BENEFIT ST	A		1		
		WBW119	211 GRASSY HILL RD	A		1		
		WBW120	435 BOYDEN ST	A		1		
		WBW121	15 BELLEWOOD AVE	A		1		
		WBW122	84 BRENTWOOD AVE	A		1		
		WBW123	84 FAIRLAWN AVE	A		1		
		WBW124	292 COURTLAND AVE	A		1		
		WBW125	389 WOODTICK RD	A		1		
		WBW126	606 WOODTICK RD	A		1		
		WBW127	652 FROST RD	A		1		
		WBW128	18 DEERLING LANE	A		1		
		WBW129	145 EASTSIDE BLVD	A		1		
		WBW130	150 EAST SIDE BLVD	A		1		
		WBW131	204 HARWOOD RD	A		1		
		WBW132	228 FANNING ST	A		1		
		WBW133	3 FRANCIS ST	A		1		
		WBW134	11 OAK HOLLOW DR	A		1		
		WBW135	61 CREST ST	A		1		
		WBW136	76 MIDDELWAY EAST	A		1		
		WBW137	86 KENDALL CIR	A		1		
		WBW138	102 PARKWOOD AVE	A		1		
		WBW139	139 HUBBELL AVE	A		1		
		WBW140	146 WHITE BIRCH DR	A		1		
		WBW141	152 BAMFORD AVE	A		1		
		WBW142	197 PINECREST DR	A		1		

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT1510011	WATERBURY WATER DEPARTMENT			C	107,271	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						26,915	

Towns Served: MIDDLEBURY, PROSPECT, WATERBURY, WATERTOWN, WOLCOTT

### Water System Facility and Sampling Point Inventory

<i>Water System</i> Facility ID	<i>Water System Facility</i>	<i>Sampling Point ID</i>	<i>Sampling Point Description</i>	<i>Status</i>	<i>Total Coliform Rule</i>	<i>Lead and Copper Rule Tier</i>	<i>Asbestos</i>	<i>Stage WQP 2 DBPR</i>
		WBW143	271 JUNIPER RIDGE DR	A		1		
		WBW144	282 BAMFORD AVE	A		1		
		WBW145	296 JUNIPER RIDGE DR	A		1		
		WBW146	357 CLOUGH RD	A		1		
		WBW147	943 BUNKER HILL AVE	A		1		
00700	WATERBURY WTP ENTRY POINT	3	ENTRY POINT	A				
2274	CAIRNS RESERVOIR	1	RESERVOIR	A				
2275	PITCH RESERVOIR	1	RESERVOIR	A				
2276	SHEPAUG RESERVOIR	1	RESERVOIR	A				
2277	MORRIS RESERVOIR	1	RESERVOIR	A				
2278	WIGWAM RESERVOIR	1	RESERVOIR	A				
294	WATERBURY WATER TREATMENT PLANT	5	CFE - WATERBURY TP	A				
30093	PITCH RESERVOIR							
30094	MORRIS RESERVOIR							
30095	WIGWAM RESERVOIR							
30096	WATERBURY WTP INTAKE	SS	RESERVOIRS COMBINED	A				
50091	INTERSTATE LANE TANK							
50093	PROGRESS LANE TANK							
50095	VIVIAN DRIVE TANK							
50097	AUSTIN ROAD TANK							
50099	HITCHCOCK ROAD TANK							
50101	CLOUGH ROAD TANK 100,000 GALLONS							
50103	LONG HILL RD TANK							
50105	BENEFIT ST TANK							
50218	BLACKMAN RD TANK							
50220	DEVONWOOD 4 TANK							
50222	DEVONWOOD 6 TANK							
50224	PEACH ORCHARD TANK							
50226	PIERPONT RD PUMP STATION							
50228	CLOUGH ROAD PUMP STATION							
50230	EAST MOUNTAIN PUMP STATION							
50232	NORTH MAIN ST PUMP STATION							
50234	PROGRESS LANE PUMP STATION							
50236	SCOTT RD PUMP STATION							
50238	RUMFORD ST PUMP STATION							

**NOTE:** This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT1510011	WATERBURY WATER DEPARTMENT			C	107,271	L	SW
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial	Combined	Agricultural
						26,915	

Towns Served: MIDDLEBURY, PROSPECT, WATERBURY, WATERTOWN, WOLCOTT

### Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
50240	INTERSTATE LN PUMP STATION							
55466	CLOUGH ROAD TANK 400,000 GALLONS							

### Certified Operator Information

Water System Facility: **DISTRIBUTION SYSTEM (WSF ID: 00600)**

Facility Classification: CLASS 3 DISTRIBUTION SYSTEM

Operator Name	Operator Type	Certification(s)	Certification Expiration
SCHULTZ, JOHN W.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS III	9/30/2027
		WATER TREATMENT PLANT OPERATOR - CLASS IV	9/30/2027
SAVAGE, CHRISTOPHER A.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2026

Water System Facility: **WATERBURY WATER TREATMENT PLANT (WSF ID: 294)**

Facility Classification: CLASS 4 TREATMENT PLANT

Operator Name	Operator Type	Certification(s)	Certification Expiration
GIORDANO, STEVEN M	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2026
SAVAGE, CHRISTOPHER A.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	12/31/2026
RANDALL, DANIEL J.	ASSIGNED OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	9/30/2026

### Contact Information

Name				Organization		Job Title			
Mr. Bradley Malay				Waterbury Water Department		Actingsuperintendent			
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
21 East Aurora St.						Waterbury		CT	06708
Business Phone		Extension	Fax		Mobile Phone	Emergency Phone	Email Address		
203-574-8251		7657				203-545-0820	bmalay@waterburyct.org		

Contact Role(s): **Administrative Contact**

Name				Organization			Job Title		
Ms. Angela R. Juliani				City of Waterbury			Corporation Counsel		
Mailing Address Line One			Mailing Address Line Two			City		State	Zip Code
City Hall			235 Grand Street, 3Rd Floor			Waterbury		CT	06702
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address				
203-574-6731	7040	203-574-8340			ajuliani@waterburyct.org				

Contact Role(s): **Legal Contact**

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
<b>CT1510011</b>	<b>WATERBURY WATER DEPARTMENT</b>	<b>C</b>	<b>107,271</b>	<b>L</b>	<b>SW</b>
Local Address (where applicable)		Service Connections	Residential	Commercial	Industrial
					26,915
Towns Served: MIDDLEBURY, PROSPECT, WATERBURY, WATERTOWN, WOLCOTT					
Name		Organization		Job Title	
<b>Mr. Paul K. Pernerewski</b>		City of Waterbury		Mayor	
Mailing Address Line One		Mailing Address Line Two		City	State
City Hall		235 Grand Street		Waterbury	CT
Zip Code	06702				
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone	Email Address
203-574-6712				203-592-3810	ppernerewski@waterburyct.org
Contact Role(s): <b>Owner</b>					

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

***If you have any questions, please contact the Drinking Water Section at (860) 509-7333.***

**<http://www.ct.gov/dph/publicdrinkingwater>**

***End of schedule***

**NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.**