

**Connecticut Department of Public Health Drinking Water Section  
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1549003	PUMPKIN PATCH DAYCARE	NTNC	105	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
310 GROVE BEACH ROAD	Connections	1			

Towns Served: WESTBROOK

**Monitoring Requirements**

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
<b>Total Coliform (3100)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
<b>Lead And Copper (PBCU)</b>	<b>5 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/23 - 12/31/25	6/1-9/30	Complete
	1/1/26 - 12/31/28	6/1-9/30	
	1/1/29 - 12/31/31	6/1-9/30	
<b>Physical Parameters (PPS)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: **ENTRY POINT** (WSF ID: 00700)

<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
<b>Pesticides, Herbicides and PCBs-Phase II (SOC2)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Pesticides, Herbicides and PCBs-Phase V (SOC5)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1549003	PUMPKIN PATCH DAYCARE	NTNC	105	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
310 GROVE BEACH ROAD	Connections	1			

Towns Served: WESTBROOK

### Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Pesticides, Herbicides and PCBs-Phase V (SOC5)		1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
		1/1/29 - 12/31/31		
Organic Chemicals (VOCS)			1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete	
	1/1/26 - 12/31/28			
	1/1/29 - 12/31/31			

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION EXEMPTION	3/1/2030	

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total Status	Coliform Rule	Lead and Copper Rule Tier	Asbestos	WQP 2 DBPR	Stage
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y				
		DOWNSTREAM	WITHIN 5 SERVICE CON	A					
		SINK 1	SINK 1	A	Y	3	Y		
		SINK 10	SINK 10	A	Y	3			
		SINK 11	SINK 11	A	Y	3			
		SINK 12	SINK 12	A	Y	3			
		SINK 2	SINK 2	A	Y	3			
		SINK 3	SINK 3	A	Y	3			
		SINK 4	SINK 4	A	Y	3			
		SINK 5	SINK 5	A	Y	3			
		SINK 6	SINK 6	A	Y	3			
		SINK 7	SINK 7	A	Y	3			
		SINK 8	SINK 8	A	Y	3			
		SINK 9	SINK 9	A	Y	3			
		UPSTREAM	WITHIN 5 SERVICE CON	A					
00700	ENTRY POINT	3	ENTRY POINT	A					
10658	WELL	2	WELL	A					

### Certified Operator Information

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

Facility Classification:	SMALL WATER SYSTEM	Certification(s)	Certification Expiration
Operator Name	Operator Type		
FILANDA, MICHAEL	CHIEF OPERATOR	WATER TREATMENT PLANT OPERATOR - CLASS IV	6/30/2028

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1549003	PUMPKIN PATCH DAYCARE	NTNC	105	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
310 GROVE BEACH ROAD	Connections	1			

Towns Served: WESTBROOK

## Contact Information

Name	Organization	Job Title		
Ms. Teresa Anderson	Pumpkin Patch Child Care	Owner		
Mailing Address Line One	Mailing Address Line Two	City	State	Zip Code
310 Grove Beach Road N		Westbrook	CT	06498
Business Phone	Extension	Fax	Mobile Phone	Emergency Phone
860-669-0579		860-669-7161		860-575-2071
				ppatchwestbrook@gmail.com

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

**Please note the following:**

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

*If you have any questions, please contact the Drinking Water Section at (860) 509-7333.*

*<http://www.ct.gov/dph/publicdrinkingwater>*

**End of schedule**

# Connecticut Department of Public Health Drinking Water Section

## Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name			Classification	Population	Owner Type	Primary Source
CT1549023	CLINTON NURSERIES - SECONDARY SYSTEM			NTNC	143	P	GW
Local Address (where applicable)		Service	Residential	Commercial	Industrial	Combined	Agricultural
517 POND MEADOW ROAD		Connections	2	2			

Towns Served: WESTBROOK

### Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSF ID: 00600)

<b>Asbestos (1094)</b>	<b>1 routine (RT) per nine years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
<b>Total Coliform (3100)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
<b>Lead And Copper (PBCU)</b>	<b>5 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/24 - 12/31/26	6/1-9/30	
	1/1/27 - 12/31/29	6/1-9/30	
<b>Physical Parameters (PPS)</b>	<b>1 routine (RT) per quarter</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: ENTRY POINT (WSF ID: 00700)

<b>Inorganic Chemicals (IOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/27		
<b>Nitrate And Nitrite (NOX)</b>	<b>1 routine (RT) per year</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		
<b>Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
<b>Organic Chemicals (VOCS)</b>	<b>1 routine (RT) per three years</b>		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		

### Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date

*NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.*

# Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1549023	CLINTON NURSERIES - SECONDARY SYSTEM	NTNC	143	P	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
517 POND MEADOW ROAD	Connections	2	2		

Towns Served: WESTBROOK

## Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT		3/1/2029

Water System Facility and Sampling Point Inventory							
Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform Rule	Lead and Copper Rule Tier	Asbestos WQP 2 DBPR
00600	DISTRIBUTION SYSTEM	4	DISTRIBUTION SYSTEM	A	Y		
		517PMR-GAR	GARAGE RESIDENCE	A	Y	2	
		DOWNSTREAM	WITHIN 5 SERVICE CON	A			
		PBLR	PROD. BLD. LADY ROOM	A	Y	2	
		PBMR	PROD. BLD. MENS ROOM	A	Y	2	Y
		UPSTREAM	WITHIN 5 SERVICE CON	A			
00700	ENTRY POINT	3	ENTRY POINT	A			
50111	WELL 2	2	WELL 2	A			

## Certified Operator Information

Water System Facility: <b>DISTRIBUTION SYSTEM (WSF ID: 00600)</b>	Facility Classification: SMALL WATER SYSTEM				Certification Expiration
Operator Name	Operator Type		Certification(s)		
RADICCHI, PAUL J.	CHIEF OPERATOR		DISTRIBUTION SYSTEM OPERATOR - CLASS III		6/30/2027
			WATER TREATMENT PLANT OPERATOR - CLASS II		12/31/2027

## Contact Information

Name	Organization	Job Title
Mr. Matthew Richards	Clinton Nurseries	
Mailing Address Line One	Mailing Address Line Two	City
517 Pond Meadow Rd		Westbrook
Business Phone	Extension	Fax
860-399-3000	221	
Mobile Phone		Emergency Phone
		860-388-7211
Email Address		
		mrichards@cngrp.com

Contact Role(s): **Administrative Contact, Legal Contact, Owner**

### Please note the following:

1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample.
2. If a Collection Period is specified, all water quality samples must be collected during the specified period.
3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this

**If you have any questions, please contact the Drinking Water Section at (860) 509-7333.**

<http://www.ct.gov/dph/publicdrinkingwater>

**End of schedule**

**NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.**