

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1680112	NONNEWAUG HIGH SCHOOL	NTNC	887	L	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
5 MINORTOWN ROAD	Connections		1		

Towns Served: WOODBURY

Monitoring Requirements

Water System Facility: **DISTRIBUTION SYSTEM** (WSF ID: 00600)

Asbestos (1094)	1 routine (RT) per nine years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	1/1/20 - 12/31/28		
Total Coliform (3100)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
Lead And Copper (PBCU)	20 routine (RT) per six months		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 12/31/25		Complete
	1/1/26 - 6/30/26		
	7/1/26 - 12/31/26		
Physical Parameters (PPS)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
Select from Inventory of Active Sampling Points	7/1/25 - 9/30/25		Complete
	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		

Water System Facility: **ENTRY POINT** (WSF ID: 00700)

Di(2-Ethylhexyl) - Phthalate (2039)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
Aldicarb Sulfoxide (2043)	1 routine (RT) per quarter		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	10/1/25 - 12/31/25		Complete
	1/1/26 - 3/31/26		
	4/1/26 - 6/30/26		
Inorganic Chemicals (IOCS)	1 routine (RT) per three years		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/23 - 12/31/25		Complete
	1/1/26 - 12/31/28		
	1/1/29 - 12/31/31		
Nitrate And Nitrite (NOX)	1 routine (RT) per year		
<i>Sampling Point (Sampling Point ID)</i>	<i>Monitoring Period</i>	<i>Collection Period</i>	<i>Compliance Status</i>
ENTRY POINT (3)	1/1/25 - 12/31/25		Complete
	1/1/26 - 12/31/26		
	1/1/27 - 12/31/27		

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section

Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1680112	NONNEWAUG HIGH SCHOOL	NTNC	887	L	GW
Local Address (where applicable)	Service	Residential	Commercial	Industrial	Combined
5 MINORTOWN ROAD	Connections		1		

Towns Served: WOODBURY

Monitoring Requirements

Water System Facility: ENTRY POINT (WSF ID: 00700)

Pesticides, Herbicides and PCBs-Phase II (SOC2)		1 routine (RT) per three years		
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)		1/1/23 - 9/30/25	1/1-9/30	Complete
Pesticides, Herbicides and PCBs-Phase V (SOC5)			1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)		1/1/23 - 12/31/25	Complete	
Pesticides, Herbicides and Polychlorinated Biphenyls (PCBs) (SOCS)			1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		
Organic Chemicals (VOCS)			1 routine (RT) per three years	
Sampling Point (Sampling Point ID)	Monitoring Period	Collection Period	Compliance Status	
ENTRY POINT (3)		1/1/23 - 12/31/25	Complete	
		1/1/26 - 12/31/28		
		1/1/29 - 12/31/31		

Monthly Water System Facility (WSF) Level Monitoring Requirements

Water System Facility: DISTRIBUTION SYSTEM (WSFID: 00600)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	<spaces> ()	Minimum: 7.0 PH	Daily
Start Date: 5/1/2020		Compliance History: Monitoring Period	Operating Limit Monitoring Compliance Status: Compliance Status:
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

Water System Facility: ENTRY POINT (WSFID: 00700)

Analyte	Monitoring Requirement (Summary Type)	Operating Limit	Samples Req/Month
pH	<spaces> ()	Maximum: 7.8 PH	Daily
Start Date: 5/1/2020		Compliance History: Monitoring Period	Operating Limit Monitoring Compliance Status: Compliance Status:
		8/1/2025 - 8/31/2025	
		9/1/2025 - 9/30/2025	
		10/1/2025 - 10/31/2025	
		11/1/2025 - 11/30/2025	
		12/1/2025 - 12/31/2025	

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

**Connecticut Department of Public Health Drinking Water Section
Water Quality Monitoring and Compliance Schedule**

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1680112	NONNEWAUG HIGH SCHOOL	NTNC	887	L	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
5 MINORTOWN ROAD			1		

Towns Served: WOODBURY

Water System Facility: **ENTRY POINT (WSFID: 00700)**

Analyte	Monitoring Requirement (Summary Type)	Operating Limit		Samples Req/Month	
		Minimum:	7.2 PH	Daily	Monitoring
pH	Entry Point pH Monitoring (PHRD)				Compliance Status:
Start Date: 5/1/2020		Compliance History:	Operating Limit	Monitoring	Compliance Status:
		Monitoring Period	Compliance Status:	Compliance Status:	
		8/1/2025 - 8/31/2025	Y		
		9/1/2025 - 9/30/2025	Y		
		10/1/2025 - 10/31/2025	Y		
		11/1/2025 - 11/30/2025	Y		
		12/1/2025 - 12/31/2025	Y		

Other Compliance Schedules

Compliance Schedule Activity	Due Date	Achieved Date
CROSS CONNECTION SURVEY REPORT	3/1/2026	

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Total		Lead and Coliform Rule		Copper Rule Tier	Asbestos	WQP 2 DBPR	Stage
				Status	Coliform Rule	Copper Rule Tier					
00600	DISTRIBUTION SYSTEM	2	GENERATED BY BATCH	A	Y						
		4	DISTRIBUTION SYSTEM	A	Y						
		DOWNSTREAM	WITHIN 5 SERVICE CON	A							
		NONWG001	CAFE VEGETABLE SINK	A	Y	N	Y				
		NONWG002	CAFE HAND SINK	A	Y	2	Y	Y			Y
		NONWG003	ART ROOM #128	I	Y	2		Y			
		NONWG004	CUSTODIAL OFFICE	A	Y	2		Y			
		NONWG005	CNTRL OFC KITCHEN	I	Y	2		Y			
		NONWG006	MAIN OFFICE KITCHEN	A		2		Y			
		NONWG007	ART ROOM #224	I		2		Y			
		NONWG008	A G MECHANICS	A		2		Y			Y
		NONWG009	CNTRL OFC MENS ROOM	A		2		Y			
		NONWG010	1ST FLR BOYS ROOM	A		2		Y			
		NONWG011	1ST FLR SPECIAL ED	I		2		Y			
		NONWG012	ROOM 404	A		2		Y			
		NONWG013	HANDICAP MENS ROOM	I		2		Y			
		NONWG014	1ST FLOOR GIRLS ROOM	I		2		Y			
		NONWG015	ROOM 410	A		2		Y			
		NONWG016	GREENHOUSE #1	A		2		Y			
		NONWG017	1ST FLR S BOYS ROOM	A		2		Y			
		NONWG018	2ND FLR S BOYS ROOM	A		2		Y			
		NONWG019	2ND FLR N BOYS ROOM	I		2		Y			
		NONWG020	2ND FLR N MENS ROOM	A		2		Y			
		NONWG021	W107 FACULTY DINING	A	Y	N					
		NONWG022	L101 FACULTY BATH	A	Y	N					

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1680112	NONNEWAUG HIGH SCHOOL	NTNC	887	L	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
5 MINORTOWN ROAD			1		

Towns Served: WOODBURY

Water System Facility and Sampling Point Inventory

Water System Facility ID	Water System Facility	Sampling Point ID	Sampling Point Description	Status	Total Coliform	Lead and Copper Rule Tier	Asbestos	Stage WQP 2 DBPR
					Y	N	N	N
	NONWG023	S107 CUSTODIAL SINK	A	Y				
	NONWG024	W130 NURSE EXAM ROOM	A	Y				
	NONWG025	D01D LIBRARY MEDIA	A	Y				
	NONWG026	S114 CUSTODIAL SINK	A	Y				
	NONWG027	CAFE CUSTODIAL SINK	A	Y				
	NONWG028	CULINARY HAND WASH	A	Y				
	NONWG029	CULINARY 2 BAY SINK	A	Y				
	NONWG030	S111 CUSTODIAL SINK	A	Y				
	NONWG031	S2109 2ND FL CUSTOD	A	Y				
	NONWG032	B17 2ND FL S LAB	A	Y				
	NONWG033	W203 FACULTY DINING	A	Y				
	NONWG034	1A MUSIC	A	Y				
	NONWG035	W109 RECEIVING	A	Y				
	NONWG036	A14A ART ROOM	A	Y				
	NONWG037	S007 CUSTODIAL SINK	A	Y				
	NONWG038	C29A TRAINERS ROOM	A	Y				
	NONWG039	430 FOOD TECHNOLOGY	A	Y				
	UPSTREAM	WITHIN 5 SERVICE CON	A					
00700	ENTRY POINT	3	ENTRY POINT	A				
10705	WELL 2	2	WELL	A				
51349	WELL 3	2	WELL 3	A				
61595	ATMOSPHERIC STORAGE TANK 2019							
62502	TREATMENT PLANT							

Certified Operator Information

Water System Facility: TREATMENT PLANT (WSF ID: 62502)

Facility Classification:		Certification Expiration
Operator Name	Operator Type	Certification(s)
KILBOURN, ERIC M.	CHIEF OPERATOR	DISTRIBUTION SYSTEM OPERATOR - CLASS I WATER TREATMENT PLANT OPERATOR - CLASS II
		12/31/2028 12/31/2028

Contact Information

Name	Organization	Job Title
Mr. Michael P. Molzon	Regional School District #14	Dir Buildings & Grnd
Mailing Address Line One	Mailing Address Line Two	City
5 Minor Town Road	P.O. Box 469	State
Business Phone	Mobile Phone	Zip Code
203-263-4330	203-263-0372	203-263-4330
		mimolzon@ctreg14.org

NOTE: This information has been provided to help owners and operators of public water systems maintain compliance with drinking water quality monitoring requirements. Any inaccuracies contained herein will not relieve the owner or operator of the requirement to maintain compliance with the applicable regulations.

Connecticut Department of Public Health Drinking Water Section Water Quality Monitoring and Compliance Schedule

PWS ID	PWS Name	Classification	Population	Owner Type	Primary Source
CT1680112	NONNEWAUG HIGH SCHOOL	NTNC	887	L	GW
Local Address (where applicable)	Service Connections	Residential	Commercial	Industrial	Combined
5 MINORTOWN ROAD			1		
Towns Served: WOODBURY					
Contact Role(s): Administrative Contact, Legal Contact					
Please note the following: <ol style="list-style-type: none"> 1. The residual disinfectant concentration must be measured at the same location and time as each total coliform sample. 2. If a Collection Period is specified, all water quality samples must be collected during the specified period. 3. Depending on results, additional monitoring may be required (i.e. repeat or confirmation samples). This schedule is subject to change, and any related correspondence sent by the DWS on or after the generation date of this schedule will have precedence over what is contained in this schedule. <p><i>If you have any questions, please contact the Drinking Water Section at (860) 509-7333.</i></p>					
http://www.ct.gov/dph/publicdrinkingwater					

End of schedule