

STATE OF CONNECTICUT
DEPARTMENT OF PUBLIC HEALTH

Jewel Mullen, M.D., M.P.H., M.P.A.
Commissioner



Dannel P. Malloy
Governor
Nancy Wyman
Lt. Governor

May 1, 2014

Carl W. Thompson, P.E., Vice President of Sales and Marketing
Infiltrator Systems, Inc.
4 Business Park Road
P.O. Box 768
Old Saybrook, CT 06475

**Re: Infiltrator Systems Inc. Quick 4 Plus Standard Low Profile Chamber Proprietary
Leaching System Approval for Installation in Gallery Configuration Only**

Dear Mr. Thompson:

This program has received your request to allow for the installation of the Infiltrator Systems, Inc. Quick 4 Plus Standard Low Profile chamber proprietary leaching system in a gallery configuration only. Approval for this product will be limited to its usage in this manner only and usage or crediting in any other arrangement is prohibited at this time.

Installation of this 8 inch high product will require that a minimum of 4 inches of approved aggregate be placed ovetop (and on the sides) of two units placed side-by-side in a 6 foot wide excavation. Crediting of this product in a gallery configuration will be equivalent to a 12 inch high gallery at 5.9 S.F./L.F. In addition, this installation will require that the top of approved aggregate of the first leaching row be lower than the septic tank outlet invert and when installed in a high level-overflow arrangement, full utilization of the 12 inch depth of each row is also required.

No documentation was submitted indicating the Infiltrator Systems, Inc. Quick 4 Plus Standard Low Profile chamber is designed for H-20 loading applications (vehicular wheel loading applications). Therefore, this product cannot be installed in vehicular traffic areas.

This letter may be reproduced in its entirety as a means of notifying local health departments, engineers and installers of approval to use the Infiltrator Systems, Inc. Quick 4 Plus Standard Low Profile chamber in a gallery configuration only. This approval should not be construed to be an endorsement of this product, nor does it convey intellectual property rights.




Phone: (860) 509-7296 • Fax: (860) 509-7295 • VP: (860) 899-1611
410 Capitol Avenue, P.O. Box 340308 – MS #51SEW
Hartford, Connecticut 06134-0308
www.ct.gov/dph

Affirmative Action/Equal Opportunity Employer and Provider
If you require aid or accommodation to full and fairly enjoy this publication,
please phone (860) 509-7293

If you have any questions, please contact me at (860) 509-7296.

Sincerely,

A handwritten signature in blue ink that reads "Matthew A. Pawlik". The signature is fluid and cursive, with the first name being the most prominent.

Matthew A. Pawlik, P.E., R.S.
Sanitary Engineer III
Environmental Engineering Program

C: Robert W. Scully, P.E., Supervising Sanitary Engineer, EEP, DPH