

DATE(S) OF VISIT: January 3, 2012

THE FOLLOWING VIOLATION(S) OF THE REGULATIONS OF CONNECTICUT  
STATE AGENCIES AND/OR CONNECTICUT GENERAL STATUTES  
WERE IDENTIFIED

The following is a violation of the Regulations of Connecticut State Agencies Section 19-13D8t(f)(3):

1. During a tour of the facility and subsequent documentation review and staff interviews on *January 3, 2012*, the following was observed:
  - a. The facility did not ensure that a source of air changes, exhaust and a means to heat the space was provided for the 2 (two), new, offices that have been installed within the Physical Therapy/Occupational Therapy gym as required by the CT Public Health Code; i.e. this room shall be provided with the proper amount of air changes and exhaust for the rooms' usage in accordance with AIA Guidelines or CT Building Code, no HVAC installed in new offices.





310 Terraco Avenue • West Haven, CT 06516  
203-932-2247  
203-937-5583  
www.paradigmhdc.com

Barbara Cass RN  
Facility Licensing & Investigations Section  
Department of Public Health  
410 Capitol Avenue MS #12HFC  
PO Box 340308  
Hartford, CT 06134

January 13, 2013

*Approved  
1-26-12  
JAS*

Dear Ms. Cass,

Paradigm of West Haven is filing this plan of correction for an alleged violation of the Ct State Agencies and/or General Statutes of Connecticut which was noted during a survey by the Building and Fire Safety Unit on January 3, 2012.

1. Section 19-13D8t(f)(3)

The two offices in the Therapy Room will be provided with the proper amount of air exchanges and exhaust for the rooms usage.

The corrective measure will be implemented by February 20, 2012

The Director of Environmental Services will be responsible for monitoring this plan.

Please fell free to call me if you have any questions or concerns.

Sincerely,

A handwritten signature in black ink, appearing to read 'Donna C. Stango'.

Donna C. Stango  
Administrator

