

8BRUCE L. McDERMOTT
203.772.7787 DIRECT TELEPHONE
860.240.5723 DIRECT FACSIMILE
BMCDERMOTT@MURTHALAW.COM

September 25, 2023

Melanie A. Bachman, Esq.
Executive Director/Staff Attorney
Connecticut Siting Council
10 Franklin Square
New Britain, CT 06051

Re: Docket No. 508 - The United Illuminating Company Application for a Certificate of Environmental Compatibility and Public Need for the Milvon to West River Railroad Transmission Line 115-kV Rebuild Project

Dear Ms. Bachman:

The following information supplements The United Illuminating Company's ("UI" or the "Company") September 9, 2023 letter that was filed pursuant to the Siting Council's June 8, 2023 and August 18, 2023 letters concerning the Development and Management Plan for the Milvon to West River Railroad Transmission Line Rebuild Project. The September 9, 2023 letter identified the construction laydown areas for the project at 3191 Broadbridge Avenue in Stratford and at 51 Carlson Road in Orange.

The Company's Erosion and Sediment Control ("E&SC") plan will utilize Best Management Practices and proper erosion controls as required at both locations throughout the duration of the Company's use of the two properties. The Company does not believe that either location will require significant E&SCs since both properties will be mostly paved/gravel lots during the project. The properties will not be used as soil stockpile areas and no subsurface disturbance is expected. The Company's E&SC controls will include:

- The installation and maintenance of silt fence/sock around perimeter of property as required.
- The installation and maintenance of inlet protection for all drainage on site.

Murtha Cullina LLP
265 Church Street
New Haven, CT 06510
T 203.772.7700
F 203.772.7723

- The use of dust control measures as needed (i.e., water trucks). Equipment brought to and stored at the laydown area will be cleaned free of invasive species prior to mobilization from the project sites.
- To avoid the potential for dumping and vandalism, laydown yards will be fenced and locked.

An original will be mailed via first-class mail to the Siting Council today.

Please feel free to contact me with any questions concerning this submittal at (203) 772-7787.

Very truly yours,



Bruce L. McDermott

Enclosures